

SUMMER - UNIT 1

3/4 3-28

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>Functional Unit</u>	<u>Total Allowance (TA)</u>	<u>Z</u>	<u>S</u>	<u>Trip Setpoint</u>	<u>Allowable Value</u>
5. TURBINE TRIP AND FEEDWATER ISOLATION					
a. Steam Generator Water Level - High-High	5.0	2.18	1.5	<82.4% of narrow range instrument span	<84.2% of narrow range instrument span
6. EMERGENCY FEEDWATER					
a. Manual	NA	NA	NA	NA	NA
b. Automatic Actuation Logic	NA	NA	NA	NA	NA
c. Steam Generator Water Level - Low-Low	12.0	9.18	1.5	>12% of span from 0% to 30% RTP increasing linearly to >30.0% of span from 30% to 100% RTP	>10.2% of span from 0% and 30% RTP increasing linearly to >28.2% of span from 30% to 100% RTP
d & f. Undervoltage - ESF Bus				>5760 volts with a <0.25 second time delay	>5652 volts with a <0.275 second time delay
				>6576 volts with a <3.0 second time delay	>6511 volts with a <3.3 second time delay

8408280114 840824
PDR ADDOCK 05000395
P PDR

TABLE 2.2-1 (continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

Functional Unit	Total Allowance (TA)	Z	S	Trip Setpoint	Allowable Value
13. Steam Generator Water Level Low-Low	12.0	9.18	1.5	>12% of span from 0 to 30% RTP increasing linearly to >5.2% of span from 30% to 100% RTP 30.0%	>10.2% of span from 0 to 30% RTP increasing linearly to >5.2% of span from (30% to 100% RTP 28.2%
14. Steam/Feedwater Flow Mismatch Coincident With Steam Generator Water Level Low-Low	16.0 12.0	13.24 9.18	1.5/ 1.5 1.5	<40% of full steam flow at RTP >12% of span from 0 to 30% RTP increasing linearly to >5.2% of span from 30% to 100% RTP 30.0%	<42.5% of full steam flow at RTP >10.2% of span from 0 to 30% RTP increasing linearly to >5.2% of span from 30% to 100% RTP 28.2%
15. Undervoltage - Reactor Coolant Pump	2.1	1.28	0.23	>4830 volts	>4760
16. Underfrequency - Reactor Coolant Pumps	7.5	0	0.1	>57.5 Hz	>57.1 Hz
17. Turbine Trip A. Low Trip System Pressure B. Turbine Stop Valve Closure	NA NA	NA NA	NA NA	>800 psig >1% open	>750 psig >1% open

RTP = RATED THERMAL POWER

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTSNOTATIONNOTE 1: OVERTEMPERATURE ΔT

$$\Delta T \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \left(\frac{1}{1 + \tau_3 S} \right) \leq \Delta T_o \{ K_1 - K_2 \frac{(1 + \tau_4 S)}{(1 + \tau_5 S)} [T \left(\frac{1}{1 + \tau_6 S} \right) - T'] + K_3(P - P') - f_1(\Delta I) \}$$

Where: ΔT = Measured ΔT by RTD Manifold Instrumentation
 $\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = Lead-lag compensator on measured ΔT
 τ_1, τ_2 = Time constants utilized in lead-lag controller for ΔT , $\tau_1 = 8$ sec.,
 $\tau_2 = 3$ sec.

 $\frac{1}{1 + \tau_3}$ = Lag compensator on measured ΔT
 τ_3 = Time constants utilized in the lag compensator for ΔT , $\tau_3 = 0$ secs.

 ΔT_o = Indicated ΔT at RATED THERMAL POWER

 K_1 = 1.090

 K_2 = 0.01450

 $\frac{1 + \tau_4 S}{1 + \tau_5 S}$ = The function generated by the lead-lag controller for T_{avg}
dynamic compensation

 $\tau_4, \& \tau_5$ = Time constants utilized in the lead-lag controller for T_{avg} , $\tau_4 = \cancel{X}$ secs.,
 $\tau_5 = 4$ secs. 28
 T = Average temperature °F

 $\frac{1}{1 + \tau_6 S}$ = Lag compensator on measured T_{avg}
 τ_6 = Time constant utilized in the measured T_{avg} lag compensator, $\tau_6 = 0$ secs.