

April 23, 1992

Docket No. 50-285

Mr. W. Gary Gates
Division Manager - Nuclear Operations
Omaha Public Power District
444 South 16th Street Mall
Mail Stop 8E/EP4
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 145 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC No. 82608)

The Commission has issued the enclosed Amendment No. 145 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated January 9, 1992, as supplemented by letter dated March 23, 1992.

The amendment revises Technical Specification (TS) 3.14 by implementing Generic Letter (GL) 90-09, "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions." The amendment also deletes TS 3.14(2), which is no longer needed, and corrects a typographical error in the Bases for 3.14. You had also requested an amendment regarding vessel material withdrawal schedules pursuant to GL 91-01. That amendment was granted on March 19, 1992 (57 FR 11121, Amendment No. 142).

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original signed by:

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 145 to DPR-40
- 2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File NRC/Local PDR PD4-1 Reading
D. Wigginton(2) M. Virgilio J. Larkins
P. Noonan ACRS(10) (MSP315) OGC(MS15B18)
D. Hagan(MS3206) G. Hill(4) Wanda Jones(MS7103)
C. Grimes(MS11E22) PD4-1 Plant File S. Bloom
OPA(MS2G5) OC/LFMB(MS4503) L. Constable,RIV

* See previous concurrence

OFC	LA:PD4-1	PE:PD4-1	PM:PD4-1	OGC	D:PD4-1
NAME	PNoohan	SBloom	DWigginton	MZobler*	JLarkins
DATE	4/17/92	4/20/92	4/20/92	4/10/92	4/22/92

OFFICIAL RECORD COPY Document Name: FC82608.amd

9204290097 920423
PDR ADOCK 05000285
P PDR

NRC FILE CENTER COPY

DFO!



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20565

April 23, 1992

Docket No. 50-285

Mr. W. Gary Gates
Division Manager - Nuclear Operations
Omaha Public Power District
444 South 16th Street Mall
Mail Stop 8E/EP4
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 145 TO FACILITY
OPERATING LICENSE NO. DPR-40 (TAC NO. M82608)

The Commission has issued the enclosed Amendment No. 145 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated January 9, 1992, as supplemented by letter dated March 23, 1992.

The amendment revises Technical Specification (TS) 3.14 by implementing Generic Letter (GL) 90-09, "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions." The amendment also deletes TS 3.14(2), which is no longer needed, and corrects a typographical error in the Bases for 3.14. You had also requested an amendment regarding vessel material withdrawal schedules pursuant to GL 91-01. That amendment was granted on March 19, 1992 (57 FR 11121, Amendment No. 142).

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "D. Wigginton".

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 145 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. W. Gary Gates
Omaha Public Power District

Fort Calhoun Station, Unit No. 1

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1875 Connecticut Avenue, NW
Washington, D.C. 20009-5728

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68008

Mr. Raymond P. S. W. S. W. S. W.
U.S. Nuclear Regulatory Commission
Post Office Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Harold Borchert, Director
Division of Radiological Health
Nebraska Department of Health
301 Centennial Mall, South
Post Office Box 95007
Lincoln, Nebraska 68509

Mr. T. L. Patterson, Manager
Fort Calhoun Station
Post Office Box 399
Fort Calhoun, Nebraska 68023