

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4280
File # 10010
903.11

August 23, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
BIW QUALIFICATION REPORTS AND
RADIATION LEVELS

REF: (1) TXX-4254 of August 10, 1984 entitled
"Environmental Qualification of BIW Cable"

Dear Sir:

In reference (1) and in a follow-up phone conversation on August 14, 1984, Texas Utilities explained that the BIW silicone insulated cable is being qualified by the two cable assembly qualification reports (BIW Report #82E080-TU, Rev. 1 and the Litton report of November 1978). This was acceptable but raised a concern about radiation. The FSAR provides a postulated total integrated dose (TID) of 1×10^8 Rads gamma. The BIW report tested to only 5×10^7 Rads gamma and the Litton reporter tested to 1.1×10^8 Rads gamma.

To resolve this concern, the calculations used to determine the postulated total integrated dose were examined to see if a lower postulated dose was acceptable. The existing dose calculation yielded 1.16×10^8 Rad (beta plus gamma). This calculation was found to contain conservatisms that could be justifiably reduced to yield a new postulated TID. The new TID is 6.67×10^7 Rads (beta plus gamma). Since the 1.1×10^8 Rads of testing performed for the Litton test report clearly envelopes this new postulated TID value, radiation is no longer a concern in the qualification of the BIW cable. The FSAR will be updated to reflect these new values in an upcoming amendment.

Respectfully,

H. C. Schmidt for

H. C. Schmidt

8408280142 840823
PDR ADOCK 05000445
A PDR

DRW:tlb

Original + 40 copies