

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JOHN S. KEMPER  
VICE-PRESIDENT  
ENGINEERING AND RESEARCH

August 22, 1984

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Docket Nos.: 50-352  
50-353

SUBJECT: Limerick Generating Station, Unit 1 and 2  
Fire Protection Audit

Reference: 1) Telecon between NRC Staff and PECO  
on August 17, 1984  
2) Site Audit - April 9-12, 1984


File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

Pursuant to the Reference 1) telecon, this letter provides resolution of the concern addressing fusible links on fire doors identified during the Reference 2) site audit of fire protection systems and documentation.

Fusible links were provided on the hold open mechanisms for hollow-metal doors for construction purposes. All fusible links on fire doors in safety-related structures have been removed.

Sincerely,



GJR/bls/08178406

Copy to: See Attached Service List

8408280177 840822  
PDR ADOCK 05000352  
F PDR

A006  
110

cc: Judge Lawrence Brenner  
Judge Peter A. Morris  
Judge Richard F. Cole  
Troy B. Conner, Jr., Esq.  
Ann P. Hodgdon, Esq.  
Mr. Frank R. Romano  
Mr. Robert L. Anthony  
Maureen Mulligan  
Charles W. Elliott, Esq.  
Zori G. Ferkin, Esq.  
Mr. Thomas Gerusky  
Director, Penna. Emergency  
Management Agency  
Angus Love, Esq.  
David Wersan, Esq.  
Robert J. Sugarman, Esq.  
Martha W. Bush, Esq.  
Spence W. Perry, Esq.  
Jay M. Gutierrez, Esq.  
Atomic Safety & Licensing Appeal Board  
Atomic Safety & Licensing Board Panel  
Docket & Service Section  
James Wiggins  
Timothy R. S. Campbell