

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. #1 • DALLAS, TEXAS 75201

Log # TXX-4283
File # 10010
919

August 24, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
RESPONSE TO QUESTIONS ON THE SAFETY
PARAMETER DISPLAY SYSTEM

REF: (1) B. J. Youngblood to M. D. Spence letter of
August 7, 1984, entitled "Request for Additional
Information Concerning the Safety Parameter Display
System (SPDS) for Comanche Peak Steam Electric
Station (Units 1 and 2)"

Dear Sir:

Attached is the response to reference (1). Attachment A responds to the specific questions. Attachment B is a list of the parameters available in each Mode of Operation (NORMAL, HEAT UP/COOL DOWN, and/or COLD SHUTDOWN). Also indicated in the list is if the parameter is trended or available (numerically) in the 1/2 page Accident Indication Displays (AIDs). Also available on the top level display is the Critical Safety Function Monitor (CSFM) summary for each tree. In the message area of the top level display are indications of Power, AUCT HI T_{avg} , Start-up rate, etc.

The final parameter safety analysis is scheduled for completion mid-September 1984. This analysis will be submitted when available.

Respectfully,

H. C. Schmidt

H. C. Schmidt

DRW:tls
Attachments

Original + 40 copies

8408280190 840824
PDR ADOCK 05000445
A PDR

Boo!
1/1

Q033.1

SAFETY PARAMETER DISPLAY SYSTEM

Each operating reactor shall be provided with a Safety Parameter Display System (SPDS). The Commission approved requirements for an SPDS are defined in NUREG-0737, Supplement 1. In the Regional Workshops on Generic Letter 82-33 held during March 1983, the NRC discussed these requirements and the staff's review of the SPDS.

The staff reviewed the SPDS description provided by Texas Utilities Generating Company (Reference 1). The staff was unable to complete the review because of insufficient information. The following additional information is required to continue the review:

Instrumentation and Control Systems Information

1. Isolation Devices:

Provide the following:

- a. For each type of device used to accomplish electrical isolation, describe the specific testing performed to demonstrate that the device is acceptable for its application(s). This description should include elementary diagrams when necessary to indicate the test configuration and how the maximum credible faults were applied to the devices.
- b. Data to verify that the maximum credible faults applied during the test were the maximum voltage/current to which the device

CPSES/FSAR

could be exposed, and define how the maximum voltage/current was determined.

- c. Data to verify that the maximum credible fault was applied to the output of the device in the transverse mode (between signal and return) and other faults were considered (i.e., open and short circuits).
 - d. Define the pass/fail acceptance criteria for each type of device.
 - e. A commitment that the isolation devices comply with the environmental qualifications (10 CFR 50.49) and with the seismic qualifications which were the basis for plant licensing.
 - f. A description of the measures taken to protect the safety systems from electrical interference (i.e., Electrostatic Coupling, EMI, Common Mode and Crosstalk) that may be generated by the SPDS.
2. Provide conclusions regarding unreviewed safety questions or changes to technical specifications.

The applicant has committed to providing a safety analysis concerning the SPDS prior to fuel load (Reference 2). When that analysis is submitted and the applicant has responded to this request for information, the staff will continue its review process.

REFERENCES

1. Amendment 36 to the Comanche Peak FSAR, Section III, A-21 through A-28.
2. Letter to B. J. Youngblood (NRC) from R. J. Gary (TUGCO), dated April 15, 1983.

R033.1

1. Isolation Devices

The isolation of the SPDS from safety related devices is described as follows for each type of safety related device that has an input to the SPDS computer system.

- 1.1 Multiplexed Analog and Digital Inputs

These inputs are obtained from various systems throughout the plant. Examples of analog signals are: tank levels, system pressures, flow rates, etc. Examples of digital signals are: valve position, breaker position, etc. All multiplexed inputs from safety related devices are routed to their respective (Train A or B) qualified multiplexer cabinets (MUX) located in the environmentally protected cable spread room. Since the output of the qualified multiplexers is used as input to the non-qualified SPDS computer system, an appropriate qualified isolation device was chosen that would electrically isolate the MUXs from the SPDS and also allow the rapid transmission of data. Fiber Optic Cable (FOC) was chosen as the isolation device. FOC provides optical coupling and is totally immune to all

types of electrical interference (i.e., electrostatic coupling, electro-magnetic interference, RF interference, cross talk, etc.) that might otherwise affect the safety device. All credible adverse conditions were considered and tested per specifications given in the qualification test report. The isolation devices are in compliance with applicable NRC guidelines and IEEE standards for environmental and seismic qualification and the entire MUX system is designed and qualified for "fail-safe" operation.

1.2 Core Cooling Monitor Inputs

The inputs to the SPDS from the core exit thermocouples and the Margin to Saturation indicator is by way of the two (Train A and Train B) qualified safety related Core Cooling Monitors (CCM). The input signal from each CCM is an optically isolated ASCII character string transmitted on a standard RS232 data link. The optical isolation between the safety related circuits and the non-qualified data link is accomplished within the CCM itself using a qualified optical isolator which provides electrical isolation and rapid data transmission. All credible adverse conditions were considered and tested per specifications given in the qualification test report. The isolation devices are in compliance with applicable NRC guidelines and IEEE standards for environmental and seismic qualification and the entire CCM system is designed for "fail-safe" operation.

CPSES/FSAR

1.3 Radiation Monitoring System Inputs

All inputs to the SPDS from the Radiation Monitoring System (RMS) are transmitted as ASCII data from the RMS computer system. (Except for containment radiation inputs which are routed to the multiplexers described in section 1.1 above.) The RMS computers are non-safety related devices therefore no provision for electrical isolation between them and the SPDS is required.

1.4 Reactor Vessel Level Indication System Inputs

All inputs to the SPDS from the qualified Reactor Vessel Level Indication System (RVLIS) are transmitted as ASCII data through a fiber optic cable (FOC) data link from the qualified, safety related RVLIS cabinet to the SPDS computer system. FOC was chosen as the electrical isolation device for the reasons given in 1.1 above. All credible adverse conditions were considered and tested per specifications given in the qualification test reports. The isolation devices are in compliance with applicable NRC guidelines and IEEE standards for environmental and seismic qualification and the entire RVLIS system is designed for "fail-safe" operation.

2.0 Safety Question/Technical Specification

All portions of the SPDS have been designed and specified such that all design basis safety questions have been considered. The SPDS, as implemented at CPSES Units 1 and 2,

CPSES/FSAR

1. does not increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the FSAR,
2. does not create the possibility for an accident or malfunction of a different type than any evaluated previously in the FSAR, or
3. does not reduce the margin of safety as defined in the technical specifications.

No changes to the CPSES Unit 1 or Unit 2 Technical Specifications have been effected by the addition of the SPDS.

Reference 2 did not include a commitment to submit the parameter safety analysis; however, in response to this question, the analysis will be submitted by separate letter when completed.

ATTACHMENT B

INPUT PARAMETER	NORMAL	MODES		AIDS	TRENDS (½ HR)
		HU/CLDN	(2 Hr. Trend) CLD SHTDN		
RCS PRESS	X	X	X	LOCA SGTR	X
PRZR LVL	X	X		LOCA SGTR LOSC	X
RCS LOOP TEMP CL1	X	X			X
RCS LOOP TEMP CL2	X	X			X
RCS LOOP TEMP CL3	X	X			X
RCS LOOP TEMP CL4	X	X			X
SG NR LVL 1	X	X		LOSC SGTR ICC	X
SG NR LVL 2	X	X		LOSC SGTR ICC	X
SG NR LVL 3	X	X		LOSC SGTR ICC	X
SG NR LVL 4	X	X		LOSC SGTR ICC	X
SG PRESS 1	X	X		LOSC	X
SG PRESS 2	X	X		LOSC	X
SG PRESS 3	X	X		LOSC	X
SG PRESS 4	X	X		LOSC	X
SEC RAD TARGET	X	X			
(a) COND OFF GAS				SGTR	X
(b) SG BLDN RAD				SGTR	X
CNTMT ATMOS TARGET	X	X			
(a) PRESSURE				LOCA SGTR LOSC	X
(b) TEMP				LOCA SGTR LOSC	X

INPUT PARAMETER	NORMAL	MODES		AIDS	TRENDS (1/2 HR)
		HU/CLDN	(2 Hr. Trend) CLD SHTDN		
(c) WTR LVL				LOCA	X
(d) HUMIDITY				LOCA SGTR LOSC	X
CNTMT RAD	X	X		LOCA	X
RV LVL	X	X	X	ICC	X
MARGIN TO SATURATION	X	X		ICC	X
CORE EXIT TEMP	X	X	X	ICC	X
SR A			X		
SR B			X		
RHR FLOW A			X		
RHR FLOW B			X		
RHR HX INLET TEMP A			X		
RHR HX INLET TEMP B			X		
RHR HX OUTLET TEMP A			X		
RHR HX OUTLET TEMP B			X		
PRZR PORV				LOCA	
PRZR SFTY VLV				LOCA	
PRT PRESS				LOCA	
HIGHEST CNTMT SUMP LVL				LOSC SGTR	
HIGHEST SG NR LVL				SGTR	
SG AFW FLOW 1				SGTR	
SG AFW FLOW 2				SGTR	
SG AFW FLOW 3				SGTR	
SG AFW FLOW 4				SGTR	
LOWEST SG NR LVL				LOSC	
LOWEST SG PRESS				LOSC	


INPUT PARAMETER	NORMAL	MODES		AIDS	TRENDS (½ HR)
		HU/CLDN	(2 Hr. Trend) CLD SHTDN		
MS-FW MISMATCH 1				LOSC	
MS-FW MISMATCH 2				LOSC	
MS-FW MISMATCH 3				LOSC	
MS-FW MISMATCH 4				LOSC	
RCP (ON/OFF)				ICC	
SR				ICC	X
IR					X
PR					X
CNTMT SUMP LVL 1					X
CNTMT SUMP LVL 2					X
RWST					X
CST					X
SG WR LVL 1					X
SG WR LVL 2					X
SG WR LVL 3					X
SG WR LVL 4					X
STM FLOW 1					X
STM FLOW 2					X
STM FLOW 3					X
STM FLOW 4					X
AFW FLOW 1					X
AFW FLOW 2					X
AFW FLOW 3					X
AFW FLOW 4					X

INPUT PARAMETER	NORMAL	MODES		AIDS	TRENDS (½ HR)
		HU/CLDN	(2 Hr. Trend) CLD SHTDN		
RCS LOOP TEMP HL 1					X
RCS LOOP TEMP HL 2					X
RCS LOOP TEMP HL 3					X
RCS LOOP TEMP HL 4					X
CNTMT H ₂ CONC					X
HIGHEST MSL RAD					X

CSFM


- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

RCS PRESS




PSIG

PRZR LVL




**** %


CL 1




CL 2



CL 3



CL 4



**** **** **** ****
F

MODE: NORMAL OPERATION


POWER SESS POPS
PLUCT HE Tave SESS F

3 FM ISOL

COMPUTER TROUBLE


CHANNEL MALFUNCTION

SG NR LVL



47 77 *** 22 %

SG PRESS




10 4 8 20
PSIG

SEC RAD



ATMOS RAD



CNTMT RAD



RV LVL

**** %

SUBCOOL

**** F

CORE EXIT TEMP

**** F

21 JUN 84 12:00:35
CONACHE PEAK UNIT 1


TOP LVL | AIDS | TRENDS | NORM | HTOP/CLDN/CLO SHTDNI

CSFM

SUBCRITICALITY
CORE COOLING
INTEGRITY
HEAT SINK
CONTAINMENT
INVENTORY




RCS PRESS



PSIG

PRZR LVL




%

CL 1

CL 2

CL 3

CL 4



**** **** **** ****

F

MODE: HEATUP / COOLDOWN


POWER **** AMPS
RUCT HI Tave **** F
STARTUP RATE **** DPH

3 FM ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION


SG NR LVL



47 77 *** 22

%

SG PRESS




10 4 8 20

PSIG

SEC
RAD



CNTMT
ATMOS RAD



R/HR

RV
LVL

%

SUBCOOL

F

CORE EXIT
TEMP

f

21 JUN 84 12:01:19
COMANCHE PEAK UNIT 1










TOP LVL

AIDS

TRENDS

NORM

HTUP/CLDN/CLD SHDN



MODE: COLD SHUTDOWN

21 JUN 84 12:01:35

COMANCHE PEAK UNIT 1

HTOP/CLONICLO SHTDNI

TRENDS | NORTH

AIDS

TOP LVL

CSFM

- SUBCRITICALITY
- CORE COOLING
- INTEGRITY
- HEAT SINK
- CONTAINMENT
- INVENTORY

MODE: NORMAL OPERATION

POWER **** AMP
AUCT HI Tave **** F

3 FW ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

LOCA

- RCS PRESS PSIG ^
- ✓ PRZR LVL **** %
- ✓ CNTMT TEMP 83 F
- ✓ CNTMT NR PRESS -1 PSIG
- ✓ CNTMT HUMIDITY 24 %
- ✓ CNTMT WTR LVL EL
- CNTMT RAD R/HR
- PRZR PORV CLOSED
- ✓ PRZR SFTY VLV CLOSED
- ✓ PRT PRESS 1 PSIG

SGTR

- RCS PRESS PSIG ^
- ✓ PRZR LVL **** %
- ✓ CNTMT TEMP 83 F
- ✓ CNTMT NR PRESS -1 PSIG
- ✓ CNTMT HUMIDITY 24 %
- ✓ HIGHEST CNTMT SUMP LVL **** FT
- ✓ CNDSR OFF GAS RAD **** µC/ml
- ✓ SG BLDN RAD **** µC/ml
- ✓ HIGHEST SG NR LVL %

	1	2	3	4	
✓ SG NR LVL	<input type="text" value="47"/>	<input type="text" value="77"/>	****	<input type="text" value="22"/>	%
✓ SG AFW FLOW	****	<input type="text" value="216"/>	<input type="text" value="175"/>	****	GPM

21 JUN 84 12:01:57
COMANCHE PEAK UNIT 1

TOP LVL | MODES |

| TRENDS | LOCA | SGTR | LOSC | ICC

CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION

POWER ***** AMPS
RUCT HI Tavs ***** F

3 FW ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:02:13
COMANCHE PEAK UNIT 1

TOP LVL | MODES |

LOSC

✓ PRZR LVL *****
 ✓ LOWEST SG NR LVL [22] %
 ✓ LOWEST SG PRESS 8 PSIG
 ✓ CNTMT TEMP 83 F
 ✓ CNTMT NR PRESS -1 PSIG
 ✓ CNTMT HUMIDITY 24 %
 ✓ HIGHEST CNTMT SUMP LVL ***** FT

1	2	3	4
✓ SG NR LVL [47]	[77]	*****	[22] %
✓ SG PRESS [18]	[4]	8	PSIG
MS-FW MISMATCH [3511690]	*****	403778	LB/HR

ICC

✓ CORE EXIT TEMP ***** F
 ✓ RV LVL ***** %
 ✓ RCP OFF F
 ✓ SUBCOOL *****
 ✓ SR *****

✓ SG NR LVL [47] [77] [*****] [22] %
 | 1 | 2 | 3 | 4 |

✓ TRENDS | LOCA | SGTR | LOSC | ICC

CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION

POWER ***** AMPS
 RUCT HI Tave ***** F

3 FW ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:04:29
 COMANCHE PEAK UNIT 1

TOP LVL | NIS | TANK LVL | RAD MON | RCS TR | SG TR | CNTAT TRI

SR




IR




PR




NIS



CNTAT SUP 1 LVL




CNTAT SUP 2 LVL




RUST



CST



TK LVL



CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION





POWER ***** RMPSS
FRUCT HI Tave ***** F

3 FM ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:03:54
COMANCHE PEAK UNIT 1



TOP LVL | FLOW TR | NR LVL | MR LVL | RCS TR | PRESS | CNTMT TRI | OTHER TR

CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION

POWER *** ANPS
DUCT HI Tave **** F


3 FW ISOL

COMPUTER TROUBLE


CHANNEL MALFUNCTION

21 JUN 84 12:03:31
COMANCHE PEAK UNIT 1


STM FLOW




4




3



2




1



LBS/HR (10')

0.01 0.15 0.03 0.00


AFW FLOW



4



3



2



1



*** 178 216 ***

GPM

TOP LVL | STM FLOW | AFW FLOW | RCS TR | SG TR | CNTMT TRI | OTHER TR

CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION



POWER **** AMPS
 RUCT HI Tave ***** F

3 F/W ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:03:13
 COMANCHE PEAK UNIT 1



TOP LVL | FLOW TR | NR LVL | WR LVL | RCS TR | PRESS | CNTMT TRI | OTHER TR

CSFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION



POWER ***** RAMP
RUCT H7 Tave ***** F

3 FM ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:02:58
COMANCHE PEAK UNIT 1



TOP LVL | LOOP TR | RCS | CORE CLG | PRES TEMP | SG TR | CNTMT TRI | OTHER TR

CSFM

- SUBCRITICALITY
- CORE COOLING
- INTEGRITY
- HEAT SINK
- CONTAINMENT
- INVENTORY

MODE: NORMAL OPERATION





POWER ***** RMP5
ALUCT HI Tave ***** F

3 FW ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:02:40
COMANCHE PEAK UNIT 1



TOP LVL | 1&2 TEMPI 3&4 TEMPI RCS TR | SG TR | CNTMT TRI OTHER TR

C-SFM

- SUBCRITICALITY ○
- CORE COOLING ○
- INTEGRITY ○
- HEAT SINK ○
- CONTAINMENT ○
- INVENTORY ○

MODE: NORMAL OPERATION

POWER **** ANPS
DUCT HI T > 2 ***** F

3 FM ISOL


COMPUTER TROUBLE

CHANNEL MALFUNCTION


21 JUN 84 12:04:11
COMANCHE PEAK UNIT 1

TOP LVL | LVL PRESS | H2 HUMID |

MTR LVL




MR PRESS




PRD




CNTMT




H₂ COC




HUMIDITY



TEMP



CNTMT



RCS TR | SG TR | OTHER TR

CSFM

- SUBCRITICALITY
- CORE COOLING
- INTEGRITY
- HEAT SINK
- CONTAINMENT
- INVENTORY

MODE: HEATUP / COOLDOWN

POWER **** ANPS
 FRICT HI TAVE **** F
 STARTUP RATE **** DPH

3 FW ISOL

COMPUTER TROUBLE

CHANNEL MALFUNCTION

21 JUN 84 12:04:57
 COMANCHE PEAK UNIT 1

TOP LVL | NIS | TANK LVL | RAD MON | RCS TR | SG TR | CNTMT TRI

