

23A1739  
CLASS I  
JUNE 1984

**SUPPLEMENTAL RELOAD  
LICENSING SUBMITTAL FOR  
DUANE ARNOLD ATOMIC ENERGY CENTER  
UNIT 1, RELOAD 7**

8408280211 840817  
PDR ADOCK 05000331  
P PDR

**GENERAL  ELECTRIC**

23A1739  
Revision 0  
Class I  
June 1984

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL  
FOR  
DUANE ARNOLD ATOMIC ENERGY CENTER  
UNIT 1, RELOAD 7

Prepared: P. A. Lambert  
P. A. Lambert

Verified: W. A. Larpis  
W. A. Larpis

Approved: R. G. Charnley 7/5/84  
J. S. Charnley, Manager  
Fuel Licensing

---

NUCLEAR ENERGY BUSINESS OPERATIONS • GENERAL ELECTRIC COMPANY  
SAN JOSE, CALIFORNIA 95125

---

GENERAL  ELECTRIC

IMPORTANT NOTICE REGARDING  
CONTENTS OF THIS REPORT  
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Iowa Electric Light and Power Company (IELP) for IELP's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending IELP's operating license of the Duane Arnold Energy Center Unit 1. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the contract between Iowa Electric Light and Power Company and General Electric Company for nuclear fuel and related services for the nuclear system for Duane Arnold Energy Center Unit 1, dated February 8, 1968, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

1. PLANT UNIQUE ITEM (1.0)\*

Appendix A: Transient Analysis Input Parameters

Appendix B: Feedwater Controller Failure

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1 AND 4.0)

<u>Fuel Type</u>	<u>Cycle Loaded</u>	<u>Number</u>	<u>Number Drilled</u>
Irradiated			
P8DPB289	5	36	36
P8DPB289	6	84	84
P8DRB299	7	40	40
P8DRB284H	7	88	88
New			
BP8DRB299	8	64	64
BP8DRB301L	8	56	56
Total		368	368

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle core average exposure at end of cycle:	17954 MWD/ST
Minimum previous cycle core average exposure at end of cycle from cold shutdown considerations:	17754 MWD/ST
Assumed reload cycle core average exposure at end of cycle:	17499 MWD/ST
Core loading pattern:	Figure 1

\* ( ) Refers to area of discussion in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-6, April 1983. A letter "S" preceding the number refers to the appropriate section in the United States Supplement, NEDE-24011-P-A-6-US, April 1983.

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C (3.3.2.1.1 AND 3.3.2.1.2)

Beginning of Cycle, $k_{eff}$	
Uncontrolled	1.112
Fully Controlled	0.960
Strongest Control Rod Out	0.987
R, Maximum Increase in Cold Core Reactivity with Exposure into Cycle, $\Delta k$	0.003

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (<math>\Delta</math>)</u> (20°C, Xenon Free)
600	0.030

6. RELOAD UNIQUE TRANSIENT ANALYSIS INPUT (3.3.2.1.5 AND S.2.2)

(COLD WATER INJECTION EVENTS ONLY)

Void Fraction (%)	41.8
Average Fuel Temperature (°F)	1280
Void Coefficient N/A* (c/% Rg)	-9.11/-11.39
Doppler Coefficient N/A (c/°F)	-0.225/-0.214
Scram Worth N/A (\$)	**

7. RELOAD UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (S.2.2)

Fuel Design	Peaking Factors			R-Factor	Bundle Power (MWt)	Bundle Flow (1000 lb/hr)	Initial MCPR
	Local	Radial	Axial				
Exposure: BOC to EOC							
BP/P8x8R	1.20	1.47	1.40	1.051	6.493	112.9	1.23

\*N = Nuclear Input Data, A = Used in Transient Analysis

\*\*Generic exposure dependent values are used as given in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-6, April 1983.

8. SELECTED MARGIN IMPROVEMENT OPTIONS (S.2.2.2)

Transient Recategorization: No  
 Recirculation Pump Trip: Yes  
 Rod Withdrawal Limiter: No  
 Thermal Power Monitor: No  
 Improved Scram Time: Yes (ODYN Option B)  
 Exposure Dependent Limits: No  
 Exposure Points Analyzed: EOC

9. OPERATING FLEXIBILITY OPTIONS (S.2.2.3)

Single Loop Operation: Yes  
 Load Line Limit: Yes  
 Extended Load Line Limit: Yes  
 Increased Core Flow: No  
 Flow Point Analyzed: N/A  
 Feedwater Temperature Reduction: No

10. CORE-WIDE TRANSIENT ANALYSIS RESULTS (S.2.2.1)

Exposure: BOC to EOC

<u>Transient</u>	<u>Flux (% NBR)</u>	<u>Q/A (% NBR)</u>	<u><math>\Delta</math>CPR BP/P8x8R</u>	<u>Figure</u>
Load Rejection Without Bypass	448	113	0.16	2
Loss of Feedwater Heater	121	117	0.14	3
Feedwater Controller Failure*	289	111	0.12	4

\*See Appendix B

11. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (S.2.2.1)

(Generic Bounding Analysis Results)

<u>Rod Block Reading</u>	<u>ΔCPR (All Fuel Types)</u>
104	0.13
105	0.16
106	0.19
107	0.22
108	0.28
109	0.32
110	0.36

Setpoint Selected: 105

12. CYCLE MCPR VALUES (S.2.2.)

Non-Pressurization Events

Exposure Range: BOC to EOC

	<u>BP/P8x8R</u>
Loss of Feedwater Heater	1.21
Fuel Loading Error	1.26 *
Rod Withdrawal Error	1.23

Pressurization Events

Exposure Range: BOC to EOC

	<u>Option A</u>	<u>Option B</u>
	<u>BP/P8x8R</u>	<u>BP/P8x8R</u>
Load Rejection Without Bypass	1.28	1.20
Feedwater Controller Failure	1.24	1.21

\*Includes a 0.02 penalty due to variable water gap R-factor uncertainty.

13. OVERPRESSURIZATION ANALYSIS SUMMARY (S.2.3)

<u>Transient</u>	$P_{sl}$ (psig)	$P_v$ (psig)	<u>Plant Response</u>
MSIV Closure (Flux Scram)	1244	1275	Figure 5

14. STABILITY ANALYSIS RESULTS (S.2.4)

Rod Line Analyzed: Extrapolated Rod Block Line	
Decay Ratio:	Figure 6
Reactor Core Stability Decay Ratio, $x_2/x_0$ :	0.84
Channel Hydrodynamic Performance Decay Ratio, $x_2/x_0$	
Channel Type	
BP/P8x8R	0.31

15. LOADING ERROR RESULTS (S.2.5.4)

Variable Water Gap Misoriented Bundle Analysis: Yes

<u>Event</u>	<u>Initial MCPR</u>	<u>Resulting MCPR</u>
Misoriented	1.23	1.06

16. CONTROL ROD DROP ANALYSIS RESULTS (S.2.5.1)

## Bounding Analysis Results:

Doppler Reactivity Coefficient	Figure 7
Accident Reactivity Shape Functions:	Figures 8 and 9
Scram Reactivity Functions:	Figures 10 and 11


## Plant Specific Analysis Results:

Parameter(s) not Bounded, Cold:	None
Resultant Peak Enthalpy, Cold:	N/A
Parameter(s) not Bounded, HSB:	Accident Reactivity
Resultant Peak Enthalpy, HSB:	274.8



17. LOSS-OF-COOLANT ACCIDENT RESULT (S.2.5.2)

See "Loss-of-Coolant Accident Analysis Report for Duane Arnold Energy Center (Lead Plant)," June 1984 (NEDO-21080-03-1A).



FUEL TYPE	
A = P8DRB299	D = BP8DRB301L
B = P8DRB284H	E = P8DPB289
C = BP8DRB299	F = P8DPB289

Figure 1. Reference Core Loading Pattern







Figure 2. Plant Response to Generator Load Rejection Without Bypass







Figure 3. Plant Response to Loss of 100°F Feedwater Heating







Figure 4. Plant Response to Feedwater Controller Failure







Figure 5. Plant Response to MSIV Closure (Flux Scram)





Figure 6. Reactor Core Decay Ratio

Figure 7. Fuel Doppler Coefficient in  $1/\Delta^{\circ}\text{C}$






Figure 8. Accident Reactivity Shape Function (Cold Startup)




Figure 9. Accident Reactivity Shape Function (Hot Startup)




Figure 10. Scram Reactivity Function (Cold Startup)




Figure 11. Scram Reactivity Function (Hot Startup)

APPENDIX A  
TRANSIENT ANALYSIS INPUT PARAMETERS

The values listed below were used as inputs to the licensing analyses rather than the values provided in Reference A-1, in order to reflect actual plant operating parameters.

	<u>Analysis Value</u>
Dome Pressure (psig)	1026
Turbine Pressure (psig)	975
Reactor Pressure (psia)	1055
Inlet Enthalpy (BTU/lb)	528.6
S/RV Lowest Setpoint (psig)	1110+1%

Reference

- A-1. NEDE-24011-P-A-6-US, "General Electric Standard Application for Reactor Fuel (U.S. Supplement)", April 1983.

APPENDIX B  
FEEDWATER CONTROLLER FAILURE

The Feedwater Controller Failure (FWCF) event was analyzed at the 100% power/87% flow point for the Extended Load Line Limit Analysis, since this point was found to be more conservative than the 100% power/100% flow point.

**GENERAL**  **ELECTRIC**