



Southern California Edison Company

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92674-0128

RICHARD M. ROSENBLUM
VICE PRESIDENT

December 18, 1995

TELEPHONE
714-368-1480

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **Docket Nos. 50-361 and 50-362**
Control Room Emergency Air Cleanup System Proposed Technical
Specification Change No. NPF-10/15-407, Supplement 1
San Onofre Nuclear Generating Station
Units 2 and 3

Reference: October 14, 1992 letter from R. M. Rosenblum (Southern California Edison (Edison) to Document Control Desk (NRC); Subject: Control Room Emergency Air Cleanup System (CREACUS) Proposed Technical Specification Change NPF-10/15-407

Enclosed is Supplement 1 to Amendment Application Number 116 and Amendment Application Number 100 to Facility Operating Licenses NPF-10 and NPF-15 for the San Onofre Nuclear Generating Station (SONGS) Units 2 and 3; respectively. These Amendment Applications, submitted to the NRC by the above reference, consist of Proposed Technical Specification Change Number NPF-10/15-407 (PCN-407). PCN-407 is an amendment request to change Technical Specification (TS) 3/4.7.5, "Control Room Emergency Air Cleanup System."

Supplement 1 to Amendment Applications 116 and 100 changes the requirement of Surveillance Requirement (SR) 4.7.5.b to run CREACUS every 31 days from 10 hours to two hours. This change is based on the engineering analysis which is provided for information in the Enclosure. Also, the air flow rate for the CREACUS air conditioning unit was changed from 35,485 cfm to 35,705 cfm to reflect equipment replacement. Changes made to the original amendment request are highlighted and marked with bars in the right margin of the enclosure. Other than these changes, all aspects of Amendment Applications Numbers 116 and 100 remain unchanged. Also enclosed are markups to proposed post-Technical Specifications Improvement Program LCO 3.7.11, "Control Room Emergency Air Cleanup System," and its associated Bases.

It is requested that this licensing action be considered a Cost Beneficial Licensing Action based on the criteria outlined in NRC Administrative Letter 95-02: Cost Beneficial Licensing Actions, dated February 23, 1995. The expected cost savings from this change over the life of the plant is expected to exceed \$100,000.

220004

9512210343 951218
PDR ADDOCK 05000361
P PDR

ADD3


Document Control Desk

-2-

Edison requests Amendment Application Numbers 116 and 100 be issued effective as of its date of issuance, to be implemented within 30 days from the date of issuance. This will provide adequate time for the necessary procedure changes and training on the new Technical Specifications.

If you have any questions regarding this Supplement, please contact me.

Sincerely,



Enclosures

cc: L. J. Callan, Regional Administrator, NRC Region IV
J. E. Dyer, Director, Division of Reactor Projects, NRC Region IV
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV
J. A. Sloan, NRC Senior Resident Inspector, San Onofre Units 2 and 3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3
H. Kocol, California Department Of Health Services