RECEIVED

Southern California Edison Company 22

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

REGIONVIAS

TELEPHONE (714) 492-7700

August 17, 1984

U.S. Nuclear Regulatory Commission Office of Inspection and Inforcement Region V 1450 Maria Lane, Suite 210 Walnut Creek, California 94596-5368

J. G. HAYNES

STATION MANAGER

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject:

Docket No. 50-361 Special Report

San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to Section 6.9.2 of Appendix A, Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this submittal provides the required Special Report for inoperable accident monitoring instrumentation.

On August 4, 1984, at 0855, with Unit 2 in Mode 1 at 97% power and Unit 3 in Mode 5, Purge/Vent Stack Wide Range Monitor 2RE-7865 was removed from service for performance of the 92-day surveillance. Flow rate estimates, grab samples and auxiliary sampling were initiated in accordance with Limiting Condition for Operation (LCO) 3.3.3.9, Action Statements 36, 37 and 40, respectively. 2RE-7865 was not restored to operable status within 72 hours to permit corrective maintenance to be performed on a system valve, although the valve deficiency had not rendered the monitor inoperable. The preplanned alternate method of monitoring was initiated per LCO 3.3.3.6, Action Statement 22. Monitor 2RE-7865 was tested in accordance with Station Procedure SO23-3.21.1 and returned to service at 2130 on August 9, 1984.

Neither the health and safety of plant personnel nor the public were affected by this event. If you require any additional information, please so advise.

V6 Haynes