

CALCULATION TITLE PAGE

ICCN NO./ PRELIM. CCN NO. PAGE 1 OF 15

Calc No M-0073-125 DCP/FIDCN/ FCN No. & Rev. _____

Subject: Relative humidity at Charcoal Beds (E-418 &419), No Heating Sheet _____ of _____

System Number/Primary Station System Designators 1510 /GKA SONGS Unit 2/3 Q-Class II

Tech. Spec. Affecting? NO YES Section No. _____ Equipment Tag No. _____

CCN CONVERSION:
CCN NO. CCN-

CONTROLLED COMPUTER PROGRAM/ DATABASE	<input type="checkbox"/> PROGRAM <input type="checkbox"/> DATABASE According to SO123-XXIV-5.1	PROGRAM/ DATABASE NAME(S) <input type="checkbox"/> ALSO, LISTED BELOW	VERSION/ RELEASE NO. (S)
--	--	--	--------------------------

RECORD OF ISSUES

REV. DISC	DESCRIPTION	TOTAL SHTS. LAST SHT	PREPARED (Print name/sign/date)	APPROVED (Signature/date)
10	ISSUE FOR USE	15	ORIG. <u>F. UDRETTU</u>	FLS <u>[Signature]</u> OTHER <u>[Signature]</u>
		15	IRE <u>NO. M. GREGOVICH</u>	OTHER
			ORIG.	FLS OTHER
			IRE	OTHER OTHER
			ORIG.	FLS OTHER
			IRE	OTHER OTHER
			ORIG.	FLS OTHER
			IRE	OTHER OTHER

Space for RPE Stamp, identify use of an alternate calc., and notes as applicable.



This calc. was prepared for the identified DCP/FCN. DCP/FCN completion and turnover acceptance to be verified by receipt of a memorandum directing DCN Conversion. Upon receipt, this calc. represents the as-built condition. Memo date. _____ by _____

9512210348 951218
PDR ADOCK 05000361
P PDR

CALCULATION CROSS-INDEX

ICCN NO./ PRELIM. CCN NO.	PAGE _____ OF _____
Sheet No. <u>2</u> of <u>15</u>	
CCN CONVERSION: CCN NO. CCN-	

Calculation No. Relative Humidity at Charcoal Beds (418&419), no heating

Calc. rev. number and responsible FLS initials and date	INPUTS These interfacing calculations and/or documents provide input to the subject calculation and if revised may require revision of the subject calculation.		OUTPUTS Results and conclusions of the subject calculation are used in these interfacing calculations and/or documents.		Does the output interface calc/document require revision?	Identify output interface calc/document CCN, DCN, TCN/Rev., FIDCN, or tracking number.
	Calc / Document No.	Rev. No.	Calc / Document No.	Rev. No.	YES / NO	
	M-73-041 M-73-041 ICCN C-6 M-73-041 ICCN C-7 DWG. 40030 DWG. 40096 DWG. 41358 DWG. 41368	7 0 0 13 13 12 9	M-73-125	0	NO	
	SO23 410-1-8 SO23-410-798	11 0				

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 3

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

TABLE OF CONTENTS

SECTION	SHEET NO.
I. PURPOSE/BACKGROUND	4
II. RESULTS/CONCLUSIONS	5
III. ASSUMPTIONS	6
IV. DESIGN INPUT	7
V. METHODOLOGY	8
VI. REFERENCES	9
VII. NOMENCLATURE	10
VIII. CALCULATION	11
IX. APPENDICES	14

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO. / PRELIM. CCN NO.	PAGE OF
-------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHAECOAL BEDS (E-418&419), NO HEATING Sheet No. 4

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

I. PURPOSEBACKGROUND:

Determine the condition of the air upstream of the charcoal filter (E-418 and E-419). Per "USNRC Regulatory Guide RG 152" (Reference 10), the maximum allowable air humidity upstream of the charcoal beds is 70%.

PCN 407 requested that no credit be taken for Emergency Ventilation Unit Heaters E-296 or E-297, during the monthly 10-hour surveillance of the CREACUS test, because SCE is not currently taking credit for Emergency Ventilation Units (A-206 or E-207). In their review, the NRC expressed concern that the charcoal in the Emergency Air Conditioning Units may degrade to an unacceptable level without the monthly drying presently accomplished by the E-296 and E-297 heaters.

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 5

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

II. RESULTS/CONCLUSIONS:

For the evaluated scenario the relative humidity of the air upstream of the charcoal filter in the Emergency Air Conditioning Unit will not exceed the required maximum of 70%.

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHAECOAL BEDS (E-418&419), NO HEATING Sheet No. 6

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

III. ASSUMPTIONS:

1. During non operating periods, the moisture in air is trapped in volume (V), Train B, defined by the A-206 fan assembly, the ductwork between A-206 and E-419, E-419 plenum upstream of the charcoal filter and the HV-9778 damper on the return air duct (see sketch in the appendix).
 There are no dampers on the return ducts on Train A, therefore the moisture in the air is dissipated to the rooms. Thus no calculation is performed Train A.
2. The temperature of moist air entrapped in the volume (V), during the 30 day idle period, will reach equilibrium with the fan room temperature.
3. Fire dampers located at the common wall between the fan room and computer room are open and air is being transferred from the computer room to the fan room.
4. Fan Room lights are on, normal operating condition due to operation action and inspection requirements.
5. Heat of compression for the outside supply air is significant enough to be considered in the evaluation.
6. Evaluation is performed during winter operation when outside air relative humidity is 100%.
7. From Reference 7, the fan efficiency is assumed to be 70%.

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 7

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

IV. DESIGN INPUT:

1. OSA (outside supply air): 2,050 CFM at 36° FDB and 100% RH (Reference 1 & 6), point 1 on the psychrometric chart, sheet 13
2. Return Air: 33,655 CFM at 70° FDB and 50% RH (Reference 1), point 3 on the psychrometric chart, sheet 13
3. Transfer Air to the Fan Room: 860 CFM at 70° FDB and 50% RH (Reference 1)
4. Exhaust Air from the Fan Room: 820 CFM (Reference 1)
5. Fan Room (233) Lighting Load: 4,670 Btuh (Reference 6)
6. Emergency Ventilating Units A-206 & A-207 and Emergency Air Conditioning Units E-419 & E-418 (CREACUS) test is performed every 30 days (Reference 10).
7. Unit 206, fan outlet area: 0.37ft² (based on as built measurements, see sketch in the appendix)

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO. / PRELIM. CCN NO.	PAGE OF
-------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 8

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

V. METHODOLOGY:

The calculation indicates that the worst impact to the Emergency Recirculation charcoal filter is during winter operation. The Normal Control Room Complex Air Conditioning (E-295) System is normally operating when a CRIS is actuated or the CREACUS surveillance is due. One Train of the Control Room Complex Emergency Air Conditioning System operates automatically/manually. During this condition, outside air is supplied by the Emergency Ventilation Unit (A-206) and enters the inlet end of the Emergency Air Conditioning Unit (E-419) and is mixed with the return air coming from the different areas of the control room complex. Air from Computer Room, 232, is transferred to Fan Room 233 to maintain an acceptable temperature.

To determine the condition of the entrapped air, the temperature of the mixed return air and outside air will be calculated. Fan Room 233 temperature is calculated by using the room heat balance. Subsequent to the 10 hour CREACUS test, the temperature of the entrapped air in volume (V) will reach equilibrium with Room 233 temperature. The final condition of the entrapped air will be determined using the psychometric chart by cooling the entrapped air to the calculated room temperature.

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO. / PRELIM. CCN NO.	PAGE OF
-------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHAECOAL BEDS (E-418&419), NO HEATING Sheet No. 9

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

VI. REFERENCES

1. Air Flow Diagram Train B - Control Bldgs.-EI 30'-0", 40096 Rev.13
2. Equipment Schedule HV&AC, 40030 Rev.13
3. Area CA9, HV&AC EI 50'-0" to 30'-0", 41358 Rev.12
4. Fan Engineering by Buffalo Forge Co., Fifth Edition
5. ASHRAE Fundamentals 1985 Edition
6. Calculation M-73-041 Rev. 7. ICCN C-6, ICCN C-7
7. Barry Blower Fan, S023 410-1-798 Rev. 0
8. Filter House, Aux. Bldg., Control Room Complex Emergency Air Conditioning Unit # E419, S023 410-1-8 Rev. 11
9. Area CA9 & CA10 HV&AC Partial Plan, 41368 Rev. 9
10. USNRC Regulatory Guide RG 152 Rev. 2

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 10

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

VII. NOMENCLATURE

Nomenclature is defined in the body of the calculation.

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. //

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

VIII. CALCULATION

1. Temperature rise due to the compression of OSA, unit A-206

Increase in temperature is: $0.367[(\text{total pressure}/\text{total efficiency}) - \text{velocity pressure}]$ (Reference 4 page 165)

$$\text{Temperature increase} = 0.367 [(10.6/0.7) - 1.85] = 4.88^{\circ}\text{F}$$

where: Fan static pressure = 10.6 inch WC (Reference 2)

Fan outlet velocity = $2,050 \text{ CFM}/0.37 \text{ sq. Ft.} = 5,540 \text{ FT}/\text{min}$
 (Design input 7)

Velocity pressure = 1.85 inches WC (Reference 5, page 33.25)

Efficiency = 70% (Assumption 7)

Air temperature at the fan outlet opening (t_f) is:


$t_f = 36 + 4.88 = 40.88^{\circ}\text{F}$ (36 °F is from Design Input 1), point 2 on the psychrometric chart, sheet 13

2. Mixed air temperature in E-419 plenum (point 4 on the psychrometric chart sheet 13)

$$t_m = \frac{33,655 \times 70 + 2,050 \times 40.88}{33,655 + 2,050} = 68.32^{\circ}\text{F at 51\% RH}$$

This is the temperature and relative humidity (RH) of the volume (V) at the end of 10 hours surveillance.

3. Fan Room 233 temperature t_{room} (psychrometric chart, Page 13):



EC&FS DEPARTMENT CALCULATION SHEET

ICCN NO. / PRELIM. CCN NO.	PAGE OF
-------------------------------	------------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 12

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						

Fan room heat balance:

$$Q_{\text{light}} - Q_{\text{bldg}} + Q_{\text{air supply}} - Q_{\text{air return}} = 0$$

Building Load Q (Btu/h) = A x U x Δt

Where: A = area in ft² (Reference 3 & 9)
 U = heat transfer coefficient in BTU/ ft², Δt, °F (Reference 6)
 Δt = temperature difference in °F (Reference 6)

$$Q_{\text{ceiling}} = 1370 \times 0.2 \times (t_{\text{room}} - 50) = 274 t_{\text{room}} - 13,700$$

$$Q_{\text{floor}} = 1370 \times 0.36 \times (t_{\text{room}} - 50) = 493 t_{\text{room}} - 24,660$$

$$Q_{\text{wall N}} = 520 \times 0.3 \times (t_{\text{room}} - 50) = 156 t_{\text{room}} - 7,800$$

$$Q_{\text{wall W}} = 800 \times 0.3 \times (t_{\text{room}} - 36) = 240 t_{\text{room}} - 8,640$$

$$Q_{\text{wall S}} = 721 \times 0.29 \times (t_{\text{room}} - 70) = 209 t_{\text{room}} - 14,636$$

$$Q_{\text{wall E}} = 800 \times 0.29 \times (t_{\text{room}} - 70) = 232 t_{\text{room}} - 16,240$$

$$Q_{\text{bldg}} = 1,604 t_{\text{room}} - 85,676$$

Heat Balance:

$$4,670 - (1,604 t_{\text{room}} - 85,676) + (860 \times 1.08 \times 70) - (820 \times 1.08 \times t_{\text{room}}) = 0$$

$$4,670 - 1,604 t_{\text{room}} + 85,676 + 65,016 - 885.6 t_{\text{room}} = 0$$

$$2,489.6 t_{\text{room}} = 155,362 \qquad t_{\text{room}} = 62.4^{\circ}\text{F}$$

After sensible cooling, the final temperature of air of the volume (V) becomes equal with the Fan Room temperature, $t_{\text{room}} = T = 62.4^{\circ}\text{F}$, point 5 on the psychrometric chart sheet 13, with the relative humidity 64% RH. Therefore the relative humidity upstream of the charcoal filter in the Emergency Air Conditioning unit will not exceed 70% RH.



SONGS UNIT 2 & 3, TRAIN B

ASHRAE PSYCHROMETRIC CHART NO. 1



NORMAL TEMPERATURE
BAROMETRIC PRESSURE 29.921 INCHES OF MERCURY
COPYRIGHT 1963

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.



" WITHOUT HEATING "

EC&FS DEPARTMENT
CALCULATION SHEET

ICCN NO./ PRELIM. CCN NO.	PAGE OF
------------------------------	---------

Project or DCP/FCN _____ Calc No. M-0073-125

CCN CONVERSION CCN NO. CCN -

Subject RELATIVE HUMIDITY AT CHARCOAL BEDS (E-418&419), NO OSA HEATING Sheet No. 14

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
	F. Udrea		Gregovich						


IX. APPENDICES

COMPUTER ROOM

232

SHADED AREA REPRESENTS VOLUME (V)

FOR POINTS 1, 2, 3, 4 & 5 SEE ALSO PSYCHOMETRIC CHART



CALCULATION M-73-125

APPENDIX SHEET 15

FAN ROOM 233 - TRAIN 'B'

REF. 8.