



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203-1475

R. E. DENTON
GENERAL MANAGER
CALVERT CLIFFS

April 23, 1992

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
10 CFR 50.72 Reportability Retraction

REFERENCE: (a) 10 CFR 50.72 Notification from BG&E to NRC Operations Center,
on March 18, 1992

Gentlemen:

We are retracting Reference (a) which was made in accordance with 10 CFR 50.72. This notification was made after it was discovered that one of the core flush paths at Calvert Cliffs Units 1 and 2 might not provide enough flow to prevent Boron precipitation in the event of a cold leg Loss of Coolant Accident.

After further analysis of the issue and review of the reportability guidelines in 10 CFR 50.72 and 10 CFR 50.73, we have determined that this event is not reportable. A more detailed analysis showed that sufficient flow was available to fulfill the safety function.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

RED/JV/jv/bjd

- cc: D. A. Brune, Esquire
- J. E. Silberg, Esquire
- R. A. Capra, NRC
- D. G. McDonald, Jr., NRC
- T. T. Martin, NRC
- P. R. Wilson, NRC
- R. I. McLean, DNR
- J. H. Walter, PSC

Case No 807 576 345

April 11

9204290216 920423
PDR ADOCK 05000317
PDR