

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Washington Nuclear Plant - Unit 2 DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 1 OF 0 2 PAGE (3)

TITLE (4) Containment Temperature Monitoring

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)												
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)										
*											0 5 0 0 0 0										
0	8	0	4	8	4	0	3	4	0	2	0	8	2	4	8	4	0	5	0	0	0

OPERATING MODE (9) 1

POWER LEVEL (10) 0 3 5

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)

20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
20.406(a)(1)(i)	50.36(e)(1)	50.73(a)(2)(v)	73.71(e)
20.406(a)(1)(ii)	50.36(e)(2)	50.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)
20.406(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(vii)(A)	Special Report
20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(vii)(B)	Tech. Spec. 3.7.8.a
20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12) NAME R. L. Koenigs, Compliance Engineer TELEPHONE NUMBER 5 0 9 3 7 7 - 2 5 0 1 AREA CODE Ext. 2279

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS
B	VB	- - - -	- - - -	N					

SUPPLEMENTAL REPORT EXPECTED (14) YES (If yes, complete EXPECTED SUBMISSION DATE) NO EXPECTED SUBMISSION DATE (15) 1 2 0 1 8 4

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Revision 0 of LER 034 was submitted on May 11, 1984 describing drywell temperature indications above 150°F. Revision 1 of LER 034 was issued to report that on July 3, 1984 drywell temperature monitor CMS-TI-55 indicated above 150°F. This revision is being issued to report that on August 4, 1984 drywell temperature monitor CMS-TI-55 indicated above 150°F for a period of greater than 8 hours, and thus, also falls into the reporting category of Technical Specification requirement 3.7.8.a. This condition is a continuation of the original problem addressed in Revision 0 and Revision 1.

The average drywell temperature did not exceed 135°F as per Technical Specification 3.6.1.7 during the event of August 4, 1984.

- *Event 1 5/11/84 (LER 84-034-0)
- Event 2 7/03/84 (LER 84-034-1)
- Event 3 8/04/84 (LER 84-034-2)

8408290017 840824
PDR ADOCK 05000397
S PDR

IEER
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 8 4	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		84	034	01	02	OF	02

TEXT (If more space is required, use additional NRC Form 388A's) (17)

Plant Condition

- Event 1 (5/11/84) Plant Mode - 1 Power Level - 1%
- Event 2 (7/03/84) Plant Mode - 1 Power Level - 35%
- Event 3 (8/04/84) Plant Mode - 1 Power Level - 50%

Event

On August 4, 1984 drywell temperature monitor CMS-TI-55 indicated temperatures above 150°F in the upper drywell area return duct. The temperature exceeded 150°F for over 8 hours and, thus is reportable per Technical Specification 3.7.8.a, although the drywell average air temperature did not exceed 135°F.

Immediate Corrective Action

This condition is considered a part of the ongoing problem identified in Rev. 0 and Rev. 1 of LER 84-034. Consequently, no additional corrective action was initiated as a result of this event.

Further Corrective Action

Modifications to the design of the Drywell H&V are being completed and field changes implemented to correct the high temperature conditions. A final report on the modifications and results achieved will be provided by December 1, 1984.

Safety Significance

The results of local high temperatures have not jeopardized Plant safety or that of the public.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

August 24, 1984


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-034-02

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-034-02 for WNP-2 Plant. This report is a special report and is submitted in accordance with the requirements of the WNP-2 Technical Specification Section 6.9.2.

Very truly yours,



J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-034-01

cc: Mr. John B. Martin, Administrator
Region V, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
1450 Maria Lane
Walnut Creek, California 94596
Mr. A. D. Toth, NRC Resident Inspector (901A)
Ms. Dottie Sherman
American Nuclear Insurers
The Exchange Suite 245
270 Farmington Ave.
Farmington, CT 06032

IE22
11