

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

December 15, 1995

WO 95-0182

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Reference: Letter WO 95-0143, dated October 5, 1995,
from O. L. Maynard, WCNOG, to USNRC
Subject: Docket No. 50-482: WCNOG Licensee Event
Report 95-005-00 Corrective Action
Completion Status

Gentlemen:

Wolf Creek Nuclear Operating Corporation (WCNOG) Licensee Event Report (LER) 95-005-00 reported WCNOG's failure to develop an adequate program for identifying and maintaining emergency lights associated with the Fire Protection Program. This failure resulted in WCNOG having inadequate emergency lighting in two areas, and having inadequately identified and maintained emergency lights in several additional areas of the plant. The emergency lights are needed to meet the requirements of 10 CFR 50, Appendix R.

This letter is being issued to advise the Nuclear Regulatory Commission (NRC) of the status of corrective actions associated with LER 95-005-00. WCNOG will have all corrective actions completed by December 15, 1995, with the exception of the following items:

- Two new emergency lights will be installed to correct lighting deficiencies. All activities associated with the installation of two new emergency lights will be completed by March 2, 1996.
- The WCNOG's System Engineering Group conducted a corrective work history review to determine if repetitive or premature failures of emergency lights associated with the WCNOG Fire Protection Program were occurring. This evaluation determined WCNOG had experienced repetitive emergency light failures. Therefore, WCNOG is conducting a subsequent evaluation to determine if enhancements to the maintenance program for fire protection emergency lights are required. All activities associated with this evaluation will be completed by January 15, 1996.

9512260193 951215
PDR ADOCK 05000482
S PDR

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831


An Equal Opportunity Employer M/F/HC/VET

ADOCK 1/0

WCNOC's intent to extend the completion date for these items was discussed with Mr. J. F. Ringwald, NRC Senior Resident Inspector WCNOC on December 7, 1995. A followup discussion was held with Mr. T. F. Stetka and Mr. P. M. Qualls, NRC Region IV, during a tele-conference on December 8, 1995.

If you should have any questions regarding this response, please contact me at (316) 364-8831, extension 4000, or Mr. William M. Lindsay at extension 8760.

Very truly yours,



Otto L. Maynard

OLM/jad

cc: L. J. Callan (NRC)
W. D. Johnson (NRC)
J. F. Ringwald (NRC)
J. C. Stone (NRC)
P. M. Qualls (NRC)
C. A. Vandeburgh (NRC)