

April 17, 1992

Docket Nos. 50-313  
50-368

Mr. Neil S. Carns  
Vice President, Operations ANO  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

Dear Mr. Carns:

SUBJECT: OPERATIONAL AND SURVEILLANCE REQUIREMENTS FOR THE MAIN  
STEAM LINE RADIATION MONITORS FOR ARKANSAS NUCLEAR ONE,  
UNIT NOS. 1 AND 2 (ANO-1&2) (TAC NOS. M75252 AND M75253)

On October 19, 1989, you submitted proposed changes to the ANO-1&2 Technical Specifications (TS) to incorporate limiting conditions for operation and surveillance requirements for each unit's main steam line radiation monitors in accordance with Generic Letter 83-27. On December 5, 1991, you withdrew the proposed TS changes based on a proposal, which was being developed pursuant to Generic Letter 89-01, to relocate these TS changes into the Offsite Dose Calculation Manual (ODCM). As discussed with members of our staff, we do not agree with your reasons for withdrawing the proposed TS changes for the main steam line radiation monitors. In addition, because the TS changes that you proposed by letter dated October 19, 1989, could not be approved by the staff, we request that you resubmit a proposed TS change in compliance with Generic Letter 83-27 to incorporate the main steam line radiation monitors into ANO-1&2 TS. Please provide a schedule for submitting the requested TS change within 30 days of receiving this letter.

If you have any questions regarding this matter, please contact us.

Sincerely,

Original signed by:  
Sheri R. Peterson, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File      NRC & Local PDRs      BBoger      MVirgilio  
JLarkins          SPeterson          PNoonan      OGC  
ACRS (10)        PD4-1 p/f        ABBeach      LCunningham

OFC	LA:PD4-1	PM:PD4-1	PRPB	D:PD4-1
NAME	PNoonan	SPeterson	LCunningham	JLarkins
DATE	3/30/92	3/13/92	4/1/92	4/12/92

OFFICIAL RECORD COPY Document Name: AR75252.tr

9204300354 920417  
PDR ADDCK 03000313  
P PDR

**NRC FILE CENTER COPY**

*JFO*  
*1/0*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

April 17, 1992

Docket Nos. 50-313  
50-368

Mr. Neil S. Carns  
Vice President, Operations ANO  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

Dear Mr. Carns:

SUBJECT: OPERATIONAL AND SURVEILLANCE REQUIREMENTS FOR THE MAIN  
STEAM LINE RADIATION MONITORS FOR ARKANSAS NUCLEAR ONE,  
UNIT NOS. 1 AND 2 (ANO-1&2) (TAC NOS. M75252 AND M75253)

On October 19, 1989, you submitted proposed changes to the ANO-1&2 Technical Specifications (TS) to incorporate limiting conditions for operation and surveillance requirements for each unit's main steam line radiation monitors in accordance with Generic Letter 83-37. On December 5, 1991, you withdrew the proposed TS changes based on a proposal, which was being developed pursuant to Generic Letter 89-01, to relocate these TS changes into the Offsite Dose Calculation Manual (ODCM). As discussed with members of your staff, we do not agree with your reasons for withdrawing the proposed TS changes for the main steam line radiation monitors. In addition, because the TS changes that you proposed by letter dated October 19, 1989, could not be approved by the staff, we request that you resubmit a proposed TS change in compliance with Generic Letter 83-27 to incorporate the main steam line radiation monitors into ANO-1&2 TS. Please provide a schedule for submitting the requested TS change within 30 days of receiving this letter.

If you have any questions regarding this matter, please contact us.

Sincerely,

A handwritten signature in cursive script that reads "Sheri R. Peterson".

Sheri R. Peterson, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Neil S. Carns  
Entergy Operations, Inc.

Arkansas Nuclear One, Units 1 & 2

cc:

Mr. Donald C. Hintz  
Executive Vice President  
and Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. John R. McGaha  
Vice President, Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. Jerry Yelverton  
General Manager, Plant Operations  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

Mr. Robert B. McGehee  
Wise, Carter, Child & Caraway  
P. O. Box 671  
Jackson, Mississippi 39205

Mr. Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, N.W.  
Washington, D.C. 20005-3502

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering Nuclear Power  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Mr. Robert B. Borsum  
Licensing Representative  
B&W Nuclear Technologies  
1700 Rockville Pike, Suite 525  
Rockville, Maryland 20852

Mr. James J. Fiscaro  
Director, Licensing  
Entergy Operations, Inc.  
Route 3, Box 137G  
Russellville, Arkansas 72801

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
1 Nuclear Plant Road  
Russellville, Arkansas 72801

Admiral Kinnaird R. McKee, USN (Ret)  
214 South Morris Street  
Oxford, Maryland 21654

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Honorable Joe W. Phillips  
County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801

Ms. Greta Dicus, Director  
Division of Radiation Control and  
Emergency Management  
Arkansas Department of Health  
4815 West Markham Street  
Little Rock, Arkansas 72205-3867