

DUKE POWER

April 22, 1992

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

Subject: Catawba Nuclear Station, Unit 2

Docket No. 50-414 Special Report

Vibration and Loose Parts Monitoring System

Pursuant to Technical Specification 3.3.3.9, find attached a Special Report concerning the inoperability of the Unit 2 Vibration and Loose Parts Monitoring System Channel 7 (Steam Generator C). Because of an administrative oversight, this report is being submitted after its due date. This Special Report should have been submitted by April 12, 1992.

Very truly yours,

M. S. Tuckman

CRL/SR42292.SGC

Attachment

xc: S. D. Ebneter
Regional Administrator, Region II

R. E. Martin, ONRR

W. T. Orders Senior Resident Inspector

9205010008 920422 PDR ADOCK 05000414 S PDR 4538 1

SPECIAL REPORT

CATAWBA NUCLEAR STATION, UNIT 2

Vibration and Loose Parts Monitoring System Channel 7

On March 3, 1992, Channel 7 (Steam Generator C) of the Vibration and Loose Parts Monitoring System was declared inoperable because a signal was not present on the channel. A work request was written to repair the channel during a future outage of sufficient length. This is being scheduled for an outage because a containment entry is necessary to make the repair.

Since the channel has been inoperable for more than 30 days, it is reportable to the NRC pursuant to Technical Specification 3.3.3.9.