

Georgia Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7122



Georgia Power  
the southern electric system

C. K. McCoy  
Vice President, Nuclear  
Vogtle Project

December 22, 1995

Docket Nos. 50-424  
50-425


LCV-0679-A

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

VOGTLE ELECTRIC GENERATING PLANT  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS  
TO ALLOW TYPE B AND C TESTS FOR REFUELING OUTAGE 1R6  
TO BE CONDUCTED IN ACCORDANCE WITH 10 CFR 50 APPENDIX J OPTION B

Gentlemen:

By letter dated October 16, 1995, Georgia Power Company (GPC) proposed to revise the Vogtle Electric Generating Plant Unit 1 Technical Specifications (TS) to allow use of Option B of 10 CFR 50 Appendix J for Type B and C testing. The proposed change added a footnote to TS 4.6.1.2.d stating that the Type B and C tests scheduled for refueling outage 1R6 will be conducted in accordance with Option B of 10 CFR 50, Appendix J, and using the guidance of Regulatory Guide 1.163, *Revision 0*. However, the current version of Regulatory Guide 1.163 is not identified as Revision 0. The current version of Regulatory Guide 1.163 is identified by date, i. e., September 1995. Therefore, at the request of the NRC staff, GPC will revise our proposed footnote to TS 4.6.1.2.d to reference Regulatory Guide 1.163, September 1995. A revised marked-up page is attached for your use.

  
C. K. McCoy

CKM/NJS

270058

9512270019 951222  
PDR ADOCK 05000424  
P PDR

A017

U. S. Nuclear Regulatory Commission  
LCV-0679-A  
Page 2

Attachment

xc: Georgia Power Company  
Mr. J. B. Beasley, Jr.  
Mr. M. Sheibani  
NORMS

U. S. Nuclear Regulatory Commission  
Mr. S. D. Ebnetter, Regional Administrator  
Mr. L. L. Wheeler, Licensing Project Manager, NRR  
Mr. C. R. Ogle, Senior Resident Inspector, Vogtle

State of Georgia  
Mr. J. D. Tanner, Commissioner, Department of Natural Resources