Southern Nuclear Operating Company Post Office Box 1295 Birmingham, Alabama 35201 Telephone 205 868-5086

J. D. Woodard Vice President Farley Project



April 28, 1992

Docket No. 50-364

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555

> Joseph M. Farley Nuclear Plant - Unit 2 Special Report No. 92-001, Fire Barrier Penetration Open For More Than seven Days

Gentlemen:

In accordance with the requirements of Technical Specification 3.7.12, the enclosed Special Report No. 92-001, Unit 2, is submitted.

Respectfully submitted,

JJD. Woodard

JDW/BHW:map 0101

Enclosure

cc: Mr. S. D. Ebneter

Mr. S. T. Hoffman

Mr. G. F. Maxwell

1827

9205010253 920428 PDR ADOCK 05000364 Joseph M. Farley Nuclear Plant Special Report No. 92-001, Unit 2 Fire Barrier Penetration Open For More Than Seven Days

The containment equipment hatch was open for more than seven days during the Unit 2 refueling outage. The hatch was opened to support outage activities. The seven-day time limit for the equipment hatch was exceeded on March 29, 1992. Since the containment wall is considered to be a fire barrier, opening this hatch constitutes breaching a fire barrier.

Technical Specification 3.7.12 requires that within one hour, either establish a continuous fire watch or verify the operability of fire detectors and establish an hourly fire watch pairol. Technical Specification action statement requirements were met for the open equipment hatch. Technical Specification 3.7.12 also requires that breached fire barriers be restored to functional status within seven days or a Special Report must be submitted within the following 30 days. Therefore, this Special Report is being submitted.

Due to the scope of the work in progress, it was not practical to close this hatch within seven days. The containment equipment hatch was closed on April 6, 1992 at 0919.