

10CFR50.90

**PECO ENERGY**PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

December 19, 1995

Docket Nos. 50-277
50-278License Nos. DPR-44
DPR-56U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555**SUBJECT:** Peach Bottom Atomic Power Station, Units 2 and 3
Technical Specifications Change Request No. 95-13

Dear Sir:

PECO Energy Company (PECO Energy) hereby submits Technical Specifications (TS) Change Request No. 95-13, in accordance with 10CFR50.90, requesting changes to Appendix A of the Peach Bottom Facility Operating Licenses. The proposed changes correct an administrative error in the Improved Technical Specifications concerning the Ventilation Filter Testing Program (VFTP).

Attachment 1 to this letter describes the proposed changes and provides justification for the changes including the basis for PECO Energy's determination that the proposed changes do not involve a significant hazards consideration. Attachment 2 provides marked-up TS Pages indicating the proposed changes.

PECO Energy requests exigent handling of TS Change Request No. 95-13. On December 11, 1995, it was determined that a change to the Improved Technical Specifications issued by Amendments 210 and 214 to Unit 2 and Unit 3, respectively, was required. An administrative error in the VFTP would result in the Engineered Safety Feature (ESF) filter ventilation systems being declared inoperable upon implementation of Improved Technical Specifications which is scheduled for January 11, 1996. Because these ESF filter ventilation systems are common to both Units and because the ESF filter ventilation systems cannot be maintained operable in accordance with the administrative error in the VFTP, a shutdown of both Units would be required. Therefore, approval of

9512270270 951219
PDR ADOCK 05000277
P PDR


ADD 11

December 19, 1995

Page 2

TS Change Request No. 95-13 in advance of the implementation of Improved Technical Specifications would result in eliminating unnecessary hardship. If you have any questions concerning this matter, please do not hesitate to contact us.

Very truly yours,



G. A. Hunger, Jr.,
Director-Licensing

Enclosures: Affidavit, Attachment 1, Attachment 2

cc: T. T. Martin, Administrator, Region I, USNRC
W. L. Schmidt, USNRC Senior Resident Inspector, PBAPS
R. R. Janati, Commonwealth of Pennsylvania


COMMONWEALTH OF PENNSYLVANIA :

: ss.

COUNTY OF CHESTER :

D. B. Fetters, being first duly sworn, deposes and says:

That he is Vice President of PECO Energy; the Applicant herein; that he has read the enclosed Technical Specifications Change Request No. 95-13, "Administrative Change to Ventilation Filter Testing Program," for Peach Bottom Atomic Power Station, Unit 2 and Unit 3, Facility Operating License Nos. DPR-44 and DPR-56, and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.




Vice President


Subscribed and sworn to

before me this 19 day

of DECEMBER 1995.



Notary Public



Member, Pennsylvania Association of Notaries