

December 18, 1995

Distribution

Mr. William R. McCollum  
Site Vice President  
Catawba Nuclear Station  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745-9635

Docket File  
PUBLIC G.Hill(4) T-5 C3  
PDII-2 Reading C.Grimes 0-11 F23  
S.Varga ACRS T-2 E26  
R.Crlenjak, RII E.Merschhoff, RII

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2,  
STEAM GENERATOR PORV STROKE TIMES, (TAC NOS. M91467, M91468)

Dear Mr. McCollum:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 139 to Facility Operating License NPF-35 and Amendment No. 133 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated October 31, 1994.

The amendments remove the stroke times for the steam generator power operated relief valves from TS Tables 3.6-2a and 3.6-2b.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

Robert E. Martin, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 139 to NPF-35
2. Amendment No. 133 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\CATAWBA\CAT91467.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD22:DRPE	E	PM:PD22:DRPE	OGC	D:PD22:DRPE	SCSB	X
NAME	LBerry			S. Horn 4 changes	HBerkow	CBerlinger	
DATE	12/18/95		12/6/95	12/8/95	12/11/95	12/11/95	

*\* See previous concurrence*

OFFICIAL RECORD COPY

9512280185 951218  
PDR ADOCK 05000413  
P PDR

NRC FILE CENTER COPY

*DF01*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 18, 1995

Mr. William R. McCollum  
Site Vice President  
Catawba Nuclear Station  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745-9635

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2,  
STEAM GENERATOR PORV STROKE TIMES, (TAC NOS. M91467, M91468)

Dear Mr. McCollum:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 139 to Facility Operating License NPF-35 and Amendment No. 133 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated October 31, 1994.

The amendments remove the stroke times for the steam generator power operated relief valves from TS Tables 3.6-2a and 3.6-2b.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "Robert E. Martin".

Robert E. Martin, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 139 to NPF-35
2. Amendment No. 133 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

Mr. W. R. McCollum  
Duke Power Company

cc:

Mr. Z. L. Taylor  
Regulatory Compliance Manager  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745

Mr. Paul R. Newton  
Duke Power Company, PB05E  
422 South Church Street  
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

North Carolina Municipal Power  
Agency Number 1  
1427 Meadowwood Boulevard  
P. O. Box 29513  
Raleigh, North Carolina 27626-0513

Mr. Peter R. Harden, IV  
Account Sales Manager  
Westinghouse Electric Corporation  
Power Systems Field Sales  
P. O. Box 7288  
Charlotte, North Carolina 28241

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Richard P. Wilson, Esquire  
Assistant Attorney General  
South Carolina Attorney General's  
Office  
P. O. Box 11549  
Columbia, South Carolina 29211

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Dayne H. Brown, Director  
Division of Radiation Protection  
N.C. Department of Environment,  
Health and Natural Resources  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Catawba Nuclear Station

North Carolina Electric Membership  
Corporation  
P. O. Box 27306  
Raleigh, North Carolina 27611

Senior Resident Inspector  
4830 Concord Road  
York, South Carolina 29745

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323

Max Batavia, Chief  
Bureau of Radiological Health  
South Carolina Department of  
Health and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242-0001

Saluda River Electric  
P. O. Box 929  
Laurens, South Carolina 29360

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335