

50-416



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 26, 1995

Mr. C. Randy Hutchinson
Vice President, Operations GGNS
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - ALTERNATIVE REQUIREMENTS TO
REPAIR AND REPLACEMENT DOCUMENTATION REQUIREMENTS: CODE CASE N-532
(TAC NO. M93853)

Dear Mr. Hutchinson:

By letter dated October 6, 1995, Entergy Operations, Inc. submitted a request on behalf of Arkansas Nuclear One, Units 1 and 2, Waterford Steam Electric Station, Unit 3, Grand Gulf Nuclear Station, Unit 1, and River Bend Station, Unit 1. This submittal requests approval to use Code Case N-532, "Alternative Requirements to Repair and Replacement Documentation Requirements and Inservice Summary Report Preparation and Submission as Required by IWA-4000 and IWA-6000," as an alternative to the American Society of Mechanical Engineers (ASME) Section XI requirements for documentation of inservice report preparation and submission as required by IWA-4901(d), IWA-6210(c), (d), and (e), IWA-6220, IWA-6230(b), (c), and (d), and IWA-6420(b). Code Case N-532 was approved by the ASME Board of Nuclear Codes and Standards on December 12, 1994, and is included in the Nuclear Code Case Book for the 1995 edition of the Code. Code Case N-532 has not received NRC endorsement and has not been added to the list of code cases in NRC Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability-ASME Section XI Division I."

Entergy Operations, Inc. contends that the use of this code case would result in a significant reduction in the administrative burden associated with the preparation and submittal of more than 100 NIS-2 forms after each outage following repairs and replacements of components and for the preparation and submittal of the inservice inspection summary report and Form NIS-1 within 90 days after each refueling outage.

Use of the Code Case N-532 will still involve the preparation of a REPAIR/REPLACEMENT CERTIFICATION RECORD, FORM NIS-2A. The NIS-2A form will be certified by the inspector and will be maintained by the Owner. An OWNER'S ACTIVITY REPORT FORM, OAR-1 shall be prepared and certified at the completion of each refueling outage. Each OAR-1 form shall contain an abstract of applicable examinations and tests, a list of item(s) with flaws or relevant conditions that require evaluation to determine acceptability for continued service, an abstract for repairs, replacements and corrective measures performed, which were required due to an item containing a flaw or relevant condition that exceeded the applicable acceptance criteria. The use of Code Case N-532 will result in the submittal of information to assess the safety of

9512290060 951226
PDR ADOCK 05000416
P PDR

280085

NRC FILE CENTER COPY

DF01/0

using the information as prescribed by the code case will provide the same or an improved level of safety as reviews that may have been conducted using the older reporting requirements. In addition, more detailed information will be available and may be requested by the staff if it is deemed necessary.

We find that pursuant to 10 CFR 50.55a(a)(3)(i), the proposed alternative would result in an acceptable level of quality and safety. Therefore, the use of Code Case N-532 is authorized.

Sincerely,

ORIGINAL SIGNED BY:

William D. Beckner, Director
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

Distribution:

<u>Docket File</u>	G. Hill (2)
PUBLIC	J. Mitchell (17-G-21)
PDIV-4 r/f	
J. Roe	
E. Adensman (Email)	
W. Beckner	
D. Wigginton	
P. Noonan	
OGC	
ACRS	
J. Dyer, RIV	

Document Name: GG93853.LTR


OFC	LA:PD4-1	PM:PD4-1 <i>PWOC</i>	OGC <i>W/NLO</i>	D:PD4-1
NAME	<i>PNoonan</i>	PO'Connor:sw	MYoung	WBeckner <i>WOB</i>
DATE	12/12/95	12/12/95	12/14/95	12/26/95
COPY	YES/NO	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

the code activities that have occurred at the refueling outage. The review using the information as prescribed by the code case will provide the same or an improved level of safety as reviews that may have been conducted using the older reporting requirements. In addition, more detailed information will be available and may be requested by the staff if it is deemed necessary.

We find that pursuant to 10 CFR 50.55a(a)(3)(i), the proposed alternative would result in an acceptable level of quality and safety. Therefore, the use of Code Case N-532 is authorized.

Sincerely,



William D. Beckner, Director
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-416

cc: See next page

Mr. C. Randy Hutchinson
Entergy Operations, Inc.

Grand Gulf Nuclear Station

cc:

Mr. H. W. Keiser, Exec. Vice President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Mr. D. L. Pace
GGNS General Manager
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Robert B. McGehee, Esquire
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, LA 70804-9005

Nicholas S. Reynolds, Esquire
Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, DC 20005-3502

Dr. F. E. Thompson, Jr.
State Health Officer
State Board of Health
P. O. Box 1700
Jackson, MS 39205

Mr. Sam Mabry, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, MS 39209

Office of the Governor
State of Mississippi
Jackson, MS 39201

President,
Claiborne County Board of Supervisors
Port Gibson, MS 39150

Mike Moore, Attorney General
Frank Spencer, Asst. Attorney General
State of Mississippi
Post Office Box 22947
Jackson, MS 39225

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 2900
Atlanta, GA 30323

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Mr. K. G. Hess
Bechtel Power Corporation
P. O. Box 2166
Houston, TX 77252-2166

Mr. Michael J. Meisner
Director, Nuclear Safety
and Regulatory Affairs
Entergy Operations, Inc.
P.O. Box 756
Port Gibson, MS 39150

Mr. J. Tedrow
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, MS 39150

N. G. Chapman, Manager
Bechtel Power Corporation
9801 Washington Boulevard
Gaithersburg, MD 20878