

Docket No. 50-341

April 22, 1992

Mr. William S. Orser
Senior Vice President -
Nuclear Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Orser:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11 "RESOLUTION OF GENERIC ISSUE 48, 'LCO'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS AND LCO'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)" FOR FERMI 2 (TAC NO. M82411)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated January 27, 1992, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place or a justification as to why these controls are not needed is available at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's review related to TAC No. 82411.

Sincerely,

Original signed by
Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects III, IV, V
Office of Nuclear Reactor Regulation

cc:
See next page

OFFICE	LA:PDIII-1 <i>Rec for</i>	PM:PDIII-1	D:PDIII-1		
NAME	MShuttleworth	TColburn <i>Rec</i>	LMarsh <i>Rec for</i>		
DATE	4/22/92	4/22/92	4/22/92	/ /	/ /

9205050345 920422
PDR ADDCK 05000341
P PDR

NRC FILE CENTER COPY

DF01-10

Mr. William Orser
Detroit Edison Company

Fermi-2 Facility

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

Mr. Stan Stasek
U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. A. Cecil Settles
Director - Nuclear Licensing
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION:

Docket file 50-341
NRC & Local PDRs
PD31 r/f
BBoger
JZwolinski
LMarsh
MShuttleworth
TColburn
OGC
OChopra 7E4
SHoffman 14B20
EAdensam 14B20
FRosa 7E4
ACRS (??)
Fermi Plant File
W. Shafer R111