

April 27, 1992

Docket Nos. 50-413
and 50-414

Mr. M. S. Tuckman, Vice President
Catawba Site
Duke Power Company
4800 Concord Road
York, South Carolina 29745

DISTRIBUTION: ACRS (10), P-315
Docket File OGC, 15B18
NRC & Local PDR LReyes, RII
PDII-3 R/F
Catawba R/F
LBerry
SVarga
GLainas
DMatthews
RMartin

Dear Mr. Tuckman:

SUBJECT: REVISION TO APRIL 8, 1992, NRC LETTER ON ACCUMULATOR TANK
INSTRUMENTATION ISSUE - CATAWBA NUCLEAR STATION, UNITS 1 AND 2

Your staff has called to our attention a potential typographical error in the Safety Evaluation (SE) attached to our letter to you of April 8, 1992, on the above subject. The first paragraph of the EVALUATION portion of the SE discusses the basis for the NRC staff's prior position that accumulator level and pressure monitoring instrumentation should be classified as Category 2 and also discusses what Category 2 classification requires for the instrumentation. The next paragraph intends to identify the differences in requirements that would apply for an assignment of Category 3 classification to this instrumentation. However, the number "3" was mistyped as a "2." Therefore, please change "Category 2" in the first paragraph of page two of the SE to "Category 3." I apologize for any inconvenience that this has caused you.

Sincerely,

/s/

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

OFC	PDII-3:LA	PDII-3:PM	D:PDIII-3	D:PDII-3		
NAME	L. Berry	RMartin:cw	J. Hannon	D. Matthews		
DATE	4/21/92	4/22/92	4/27/92	4/27/92		

OFFICIAL RECORD COPY
Document Name: C:\CATAUM.LTR

9205070109 920427
PDR ADOCK 05000413
P PDR

WFOI
1/10

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

April 27, 1992

Docket Nos. 50-413
and 50-414

Mr. M. S. Tuckman, Vice President
Catawba Site
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Dear Mr. Tuckman:

SUBJECT: REVISION TO APRIL 8, 1992, NRC LETTER ON ACCUMULATOR TANK
INSTRUMENTATION ISSUE - CATAWBA NUCLEAR STATION, UNITS 1 AND 2

Your staff has called to our attention a potential typographical error in the Safety Evaluation (SE) attached to our letter to you of April 8, 1992, on the above subject. The first paragraph of the EVALUATION portion of the SE discusses the basis for the NRC staff's prior position that accumulator level and pressure monitoring instrumentation should be classified as Category 2 and also discusses what Category 2 classification requires for the instrumentation. The next paragraph intends to identify the differences in requirements that would apply for an assignment of Category 3 classification to this instrumentation. However, the number "3" was mistyped as a "2." Therefore, please change "Category 2" in the first paragraph of page two of the SE to "Category 3." I apologize for any inconvenience that this has caused you.

Sincerely,

A handwritten signature in dark ink, appearing to read "R. E. Martin".

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Mr. M. S. Tuckman
Duke Power Company

Catawba Nuclear Station

cc:

Mr. R. C. Futrell
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Mr. Alan R. Herdt, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Senior Resident Inspector
Route 2, Box 179 N
York, South Carolina 29745

North Carolina MPA-1
Suite 600
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 27602

County Manager of York County
York County Courthouse
York, South Carolina 29745

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P. O. Box 1007
Charlotte, North Carolina 28201-1007

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 1549
Columbia, South Carolina 29211

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602