

NOTICE OF VIOLATION

Illinois Power Company
Clinton Nuclear Power Station

Docket No. 50-461
License No. NPF-62

During an NRC inspection conducted on March 2-12 and April 7-10, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," (10 CFR Part 2, Appendix C, 1991), the violation is listed below:

Technical Specification (TS) 6.8.1 requires that written procedures be established, implemented and maintained.

TS 4.4.5, Table 4.4.5-1, Primary Coolant Specific Activity Sample and Analysis Program requires that an E-Bar determination be performed.


Procedure CPS No. 9945.02, E-Bar Determination, Section 8.2.6, requires that a gross beta analysis be performed.

Contrary to the above, on September 24, 1991, a chemistry technician obtained the required sample for the determination of E-Bar, however the gross beta analysis was not performed.

This is a Severity Level IV violation (Supplement I).

With respect to the above item, the inspection showed that actions had been taken to correct the identified violation and to prevent recurrence. Consequently, no reply to the violation is required and we have no further questions regarding this matter.

Dated at Glen Ellyn, Illinois
this 29 day of April 1992


L. Robert Greger, Chief
Reactor Programs Branch