

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Vermont Yankee Nuclear Power Station	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1	PAGE (3) 1 OF 0 2
---	--------------------------------------	----------------------

TITLE (4)
Environmental Air Sampling Station Inoperable

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 7	2 3	8 4	8 4	0 1 4	0 0	0 8	2 0	8 4			0 5 0 0 0
											0 5 0 0 0

OPERATING MODE (9) N	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)										
POWER LEVEL (10) 0 0 0	20.402(b)			20.408(a)			80.73(a)(2)(iv)			73.71(b)	
	20.408(a)(1)(i)			80.38(a)(1)			80.73(a)(2)(v)			73.71(a)	
	20.408(a)(1)(ii)			80.38(a)(2)			80.73(a)(2)(vi)			OTHER (Specify in Abstract below and in Text, NRC Form 366A)	
	20.408(a)(1)(iii)			X 80.73(a)(2)(i)			80.73(a)(2)(vii)(A)				
	20.408(a)(1)(iv)			80.73(a)(2)(ii)			80.73(a)(2)(vii)(B)				
	20.408(a)(1)(v)			80.73(a)(2)(iii)			80.73(a)(2)(viii)				
20.408(a)(1)(vi)			80.73(a)(2)(iii)			80.73(a)(2)(ix)					

LICENSEE CONTACT FOR THIS LER (12)

NAME James P. Pelletier, Plant Manager	TELEPHONE NUMBER 8 0 2 2 5 7 - 7 7 1 1
---	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
C	I	S	FU	0 0 0 0 N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-spaced typewritten lines) (16)

During weekly Environmental Air Sample Collections on 7/22/84, it was discovered that a continuous sample was not being drawn at Sample Station AT 1.2. Technical Specifications Table 3.9.i requires that continuous air sampling be performed. Low plant release levels were monitored during this period and past experience has indicated that these levels are undetectable by environmental air sampling. The equipment was repaired and placed back on line.

8408300478 840820
PDR ADOCK 05000271
S PDR

IE 23
11


LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Vermont Yankee	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1 8 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		0 1 4	0 0 0	2	OF	0 2

TEXT (If more space is required, use additional NRC Form 365A's) (17)

During weekly Environmental Air Sample Collections on 7/22/84, it was discovered that a continuous sample was not being drawn at Sample Station AT 1.2. Technical Specifications Table 3.9.1 requires that continuous air sampling be performed. Low plant release levels were monitored during this period and past experience has indicated that these levels are undetectable by environmental air sampling.

The main fuse for the sampling station had blown out approximately 8 hours into the sampling cycle. A severe electrical storm was reported in the area at this time. A new fuse was installed in the sample station and a subsequent functional check of the station was performed. No further damage was noted. A previous similar occurrence was reported as LER 80-28/3L.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157
GOVERNOR HUNT ROAD
VERNON, VERMONT 05354

August 20, 1984

VYV84-429

U. S. Nuclear Regulatory Commission
Document No. 50-271
Washington D. C. 20555

REFERENCE: Operating License DPR-28
Docket No. 50-271
Reportable Occurrence No. LER 84-14

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 84-14.

Very truly yours,

James P. Pelletier
Plant Manager

RDP/cjm

cc: Regional Administrator
USNRC Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

IE22
1/1