



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION V  
1450 MARIA LANE, SUITE 210  
WALNUT CREEK, CALIFORNIA 94596

RSB

AUG 2 1984

Docket No. 50-312

Sacramento Municipal Utility District  
P. O. Box 15830  
Sacramento, California 95813

Attention: R. J. Rodriguez  
Executive Director for Nuclear Operations

Gentlemen:

Subject: Emergency Preparedness Inspection

This refers to the inspection conducted by Mr. Ray Fish, Team Leader, and others of this office on June 18-22, 1984, of activities authorized by NRC License No. DPR-54, and to the discussion of our findings held by Mr. Fish with Messrs. R. P. Oubre' and R. A. Dieterich and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Based on the results of this inspection, it appears that two of your activities were not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation enclosed herewith as Appendix A. We are especially concerned by the fact that one of these items, failure to train shift supervisors as required by our Regulations and your Emergency Plan, is similar to a significant deficiency identified in our enforcement correspondence dated June 15, 1983. Your response to this Notice, to be submitted in accordance with the provisions of 10 CFR 2.201 as stated in Appendix A, Notice of Violation, should also address the management actions taken to assure compliance on a continuing basis with the training requirements of our regulations and your Emergency Plan.

One item, the 1983 annual review of the Emergency Plan, is still considered to be open. Paragraph 6 of the enclosed inspection report discusses this matter. We are considering this item open to provide you with additional time to locate records that have become misplaced. This item will be reexamined during our observation of your next emergency preparedness exercise.

8408300483 840802  
PDR ADOCK 05000312  
G PDR

120 / 11

AUG 2 1984

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,

*M. D. Schuster*  
M. D. Schuster, Acting Chief  
Safeguards and Emergency  
Preparedness Branch

Enclosures:

- A. Notice of Violation
- B. Inspection Report  
No. 50-312/84-11 (IE-V-634)

cc w/o enc:

L. G. Schwieger, SMUD  
P. Oubre', SMUD

cc w/encl:

State of CA (Johnson)

bcc:

RSB/Document Control Desk (RIDS)  
Mr. J. Martin  
Resident Inspector

RV *R.F.*  
R.Fish:dh  
8/1/84

*K.P.*  
K. Prendergast  
8/1/84

*rv* *mcS*  
A. Johnson  
8/2/84

*mcS*  
M. Schuster  
8/2/84