



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20565

March 12, 1992

Docket Nos. 50-369  
and 50-370

MEMORANDUM FOR: David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II

FROM: Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II

SUBJECT: MCGUIRE NUCLEAR STATION STEAM GENERATOR INSPECTION -  
ACTIONS/STATUS MEETING

DATE & TIME: May 7, 1992  
1:00 p.m. - 4:00 p.m.

LOCATION: One White Flint North  
11555 Rockville Pike  
Rockville, MD  
Room 1F5

PURPOSE: This meeting is to discuss the results of the steam generator inspections, pulled tube examinations, crack growth rate prediction, and future inspection plans for the McGuire Nuclear Station steam generators.

PARTICIPANTS*:	NRC		Duke Power	
D. Matthews	T. Reed	T. McMeekin	T. McConnell	
E. Murphy	K. Karwoski	P. Harran	D. Mayes	
H. Conrad	A. Herdt	R. Sharpe	et al.	

Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II

Enclosure:  
Agenda

cc w/enclosure:  
See next page

**NRC FILE CENTER COPY**

\*A portion of the meeting will involve discussions pertaining to proprietary information and, therefore, will be closed to the public. (The nonproprietary portion of the meeting will be opened for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy", 43 Federal Register 28058, 6/28/78.)

*Handwritten initials: EOL 111*

Duke Power Company

cc:  
Mr. A.V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. R. O. Sharpe  
Compliance  
Duke Power Company  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078-8985

J. Michael McGarry, III, Esq.  
Winston and Strawn  
1400 L Street, N.W.  
Washington, DC 20005

Senior Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. Frank Modrak  
Project Manager, Mid-South Area  
ESSD Projects  
Westinghouse Electric Corporation  
MNC West Tower - Bay 241  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

McGuire Nuclear Station

Dr. John M. Barry  
Mecklenburg County  
Dept. of Environmental Protection  
700 N. Tryon Street  
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director  
Department of Environmental,  
Health and Natural Resources  
Division of Radiation Protection  
P.O. Box 27687  
Raleigh, North Carolina 27611-7687

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Ms. Karen E. Long  
Assistant Attorney General  
N. C. Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Mr. P. L. Gill, Jr.  
Licensing  
Duke Power Company  
P.O. Box 1007  
Charlotte, North Carolina 28201-1007

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
P. O. Box 1439  
Seneca, South Carolina 29679

MCGUIRE NUCLEAR STATION STEAM GENERATOR INSPECTION

MEETING AGENDA

May 7, 1992

1. General Description of Unit 1 Tube Leak Event
2. Inspection Plan Implemented Following Tube Leak
3. Discussion of Results of Tube Inspections
4. Results from Pulled Tube Examinations
5. Crack Growth Rate, Detection Limit, R.G. 1.121 Implications for Remaining Unit 1 Operating Cycle
6. Future Inspections and Tube Removal Plans at McGuire

March 12, 1992

DISTRIBUTION

Docket File

NRC & Local PDRs

PD II-3 R/F

McGuire R/F

T. Murley/F. Miraglia, 12G18

J. Partlow, 12G18

S. Varga, 14E4

G. Lainas

T. Reed

A. Chaffee, FAB 11A1

OGC, 15B18

E. Jordan, MNBB 3701

B. Grimes, 9A2

ACRS (10), P-315

OPA, 2G5

E. Tana, PMAS, 12G18

P. O'Dell, PMAS, 12G18

L. Plisco, 12G18

J. Wechselberger, EDO, 17G21

K. Clark, RII

L. Berry

Receptionist, White Flint

E. Murphy, 7D4

K. Karwoski, 7D4

H. Conrad, 7D4

A. Herdt, RII