

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) DONALD C. COOK NUCLEAR PLANT UNIT 1	DOCKET NUMBER (2) 0 5 0 0 0 3 1 5	PAGE (3) 1 OF 0 1
--	--------------------------------------	----------------------

TITLE (4)
FAILURE TO COMPLETE DAILY SURVEY OF SPENT FUEL STORAGE AREA

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MON.	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
0	7	2 8 8 4	8 4	0 1 5	0	0 0 8	2 4	8 4	D. C. COOK UNIT 2	0 5 0 0 0 3 1 6
										0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)

OPERATING MODE (9) 5	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 0 10 10	20.406(a)(1)(i)	50.36(e)(1)	50.73(a)(2)(v)	73.71(c)
	20.406(a)(1)(ii)	50.36(e)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
20.406(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(viii)(A)		
20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)		
20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)		

LICENSEE CONTACT FOR THIS LER (12)

NAME T. A. KRIESEL - TECHNICAL/PHYSICAL SCIENCES DEPARTMENT	TELEPHONE NUMBER
	AREA CODE: 6 1 1 6 4 6 5 1 - 5 9 1 0 1 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

ON JULY 28 AND JULY 29, 1984, WITH UNIT ONE IN MODE FIVE AND UNIT TWO IN MODE ONE AT 100% REACTOR POWER, TECHNICAL SPECIFICATION 3.3.3.1 TABLE 3.3-6 ITEM 3A ACTION STATEMENT NUMBER 19 WAS VIOLATED. THE ACTION STATEMENT, TO PERFORM AREA SURVEYS OF THE MONITORED AREA WITH PORTABLE MONITORING INSTRUMENTATION AT LEAST ONCE PER DAY, WAS IN EFFECT DUE TO RADIATION MONITOR 12 R-5 BEING DECLARED INOPERABLE. THE TECHNICAL SPECIFICATION VIOLATION OCCURRED WHEN A RADIATION PROTECTION TECHNICIAN FAILED TO MAKE THE DAILY SURVEYS OF THE SPENT FUEL STORAGE AREA AS REQUIRED BY THE ACTION STATEMENT. THE CAUSE OF THIS PERSONNEL ERROR WAS DUE TO A DEFICIENCY IN COMMUNICATIONS WITHIN THE RADIATION PROTECTION SECTION. TO PREVENT RECURRENCE, CHANGES IN TECHNICAL SPECIFICATION REQUIREMENTS DUE TO ENTRY INTO ACTION STATEMENTS ARE BEING APPROPRIATELY LOGGED IN THE DAILY LOG AND SUPERVISORS LOG. THIS INFORMATION IS ALSO DISPLAYED IN THE TECHNICIANS OFFICE. THE HEALTH AND SAFETY OF THE PUBLIC WERE NOT AFFECTED.

8408300505 840824
PDR ADOCK 05000315
S PDR

IE 22
11



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

August 24, 1984

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Operating License DPR-58
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10CFR50.73
entitled Licensee Event Reporting System, the following
report/s are being submitted:

RO 84-015-0

Sincerely,


W.G. Smith, Jr.
Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H. Brugger
E.R. Swanson, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee, EPRI
INPO
PNSRC
J.F. Stietzel
E.L. Townley
Dottie Sherman, ANI Library

IE22
1/1