

January 2, 1996

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 62A-1  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, PA 19087-0195

SUBJECT: DEFERRAL OF TURBINE ROTOR INSPECTIONS, LIMERICK GENERATING STATION, UNIT 1 (TAC NO. M93756)

Dear Mr. Hunger:

In your letter dated September 11, 1995, you informed the Commission of PECO Energy Company's plans to defer turbine rotor inspections on the Limerick Generating Station (LGS), Unit 1, main turbine which were planned to be performed during the next Unit 1 sixth refueling outage (1R06), scheduled to begin in January 1996. Further, you stated that these inspections are being deferred to the seventh refueling outage (1R07), which is planned for 1998.

The staff has evaluated the information, and agrees with your conclusion that the deferral of the required main turbine rotor inspection from 1R06 to 1R07 will not adversely impact the operation of the turbine at LGS, Unit 1, and finds it acceptable. A copy of our safety evaluation is also enclosed.

The staff considers this matter resolved and is closing out TAC No. M93756. If you have any questions, please contact me at (301)415-1447.

Sincerely,

/s/  
Frank Rinaldi, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-352

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket File	JStolz	ACRS
PUBLIC	MO'Brien	WPasciak, RGN-I
PDI-2 Reading	TLiu	
SVarga	FRinaldi	
JZwolinski	OGC	

OFFICE	PDI-2/LA	PDI-2/PM	PDI-2/PM	PDI-2/D	
NAME	MO'Brien	TLiu:mw	FRinaldi	JStolz	
DATE	1/2/95	1/2/96	1/2/96	1/2/96	

OFFICIAL RECORD COPY  
DOCUMENT NAME: LI93756.FXE

040048

9601050091 960102  
PDR ADOCK 05000352  
Q PDR

NRC FILE CENTER COPY

DF011



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 2, 1996

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 62A-1  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, PA 19087-0195

SUBJECT: DEFERRAL OF TURBINE ROTOR INSPECTIONS, LIMERICK GENERATING  
STATION, UNIT 1 (TAC NO. M93756)

Dear Mr. Hunger:

In your letter dated September 11, 1995, you informed the Commission of PECO Energy Company's plans to defer turbine rotor inspections on the Limerick Generating Station (LGS), Unit 1, main turbine which were planned to be performed during the next Unit 1 sixth refueling outage (1R06), scheduled to begin in January 1996. Further, you stated that these inspections are being deferred to the seventh refueling outage (1R07), which is planned for 1998.

The staff has evaluated the information, and agrees with your conclusion that the deferral of the required main turbine rotor inspection from 1R06 to 1R07 will not adversely impact the operation of the turbine at LGS, Unit 1, and finds it acceptable. A copy of our safety evaluation is also enclosed.

The staff considers this matter resolved and is closing out TAC No. M93756. If you have any questions, please contact me at (301)415-1447.

Sincerely,

A handwritten signature in cursive script that reads "Frank Rinaldi".

Frank Rinaldi, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-352

Enclosure: Safety Evaluation

cc w/encl: See next page

Mr. George A. Hunger, Jr.  
PECO Energy Company

Limerick Generating Station,  
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
PECO Energy Company  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief  
Division of Nuclear Safety  
PA Dept. of Environmental Resources  
P. O. Box 8469  
Harrisburg, Pennsylvania 17105-8469

Mr. David P. Helker, MC 62A-1  
Manager-Limerick Licensing  
PECO Energy Company  
965 Chesterbrook Boulevard  
Wayne, Pennsylvania 19087-5691

Mr. Michael P. Gallagher  
Director - Site Engineering  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Walter G. McFarland, Vice President  
Limerick Generating Station  
Post Office Box A  
Sanatoga, Pennsylvania 19464

Mr. James L. Kantner  
Manager-Experience Assessment  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Robert Boyce  
Plant Manager  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464

Library  
US Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Ludwig E. Thibault  
Senior Manager - Operations  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Neil S. Perry  
Senior Resident Inspector  
US Nuclear Regulatory Commission  
P. O. Box 596  
Pottstown, Pennsylvania 19464

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Mr. Craig L. Adams  
Director - Site Support Services  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464

Chairman  
Board of Supervisors  
of Limerick Township  
646 West Ridge Pike  
Linfield, PA 19468