

JUL 09 1984

Handwritten initials

Tennessee Valley Authority
ATTN: Mr. H. G. Parris
Manager of Power and Engineering
500A Chestnut Street Tower II
Chattanooga, TN 37401

Gentlemen:

SUBJECT: MEETING SUMMARY - REPORT NOS. 50-259/84-21, 50-260/84-21 AND
50-296/84-21

A

This letter refers to the Enforcement Conference held at our request in the NRC Region II Office on June 21, 1984. This meeting concerned activities authorized by NRC Operating License Nos. DPR-33, DPR-52, and DPR-68 of the Browns Ferry facilities. The meeting related to design errors associated with separation of electrical cables, paralleling diesel generators, and shutdown board room cooling.

The subjects discussed are detailed in the enclosed inspection report.

It is our opinion that this meeting was beneficial and has provided for a better understanding of inspection findings and enforcement issues. In accordance with Section 2.790 of NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosure will be placed in NRC's Public Document Room. If you wish to withhold information contained in the inspection report, please notify this office by telephone and submit a written application to withhold information consistent with the requirements of 2.790(b)(1).

Should you have any questions concerning this matter, we will be pleased to discuss them.

Sincerely,

ORIGINAL SIGNED BY
ROBERT D. MARTIN */for*
James P. O'Reilly
Regional Administrator

Enclosures:

1. Inspection Report Nos. 50-259/84-21,
50-260/84-21 and 50-296/84-21
2. Agenda for June 21, 1984 Browns
Ferry Enforcement Conference

cc w/encls: (See page 2)

8408310109 840709
PDR ADOCK 05000259
G PDR

LE01 70

Tennessee Valley Authority

2

cc w/encls:

- J. A. Coffey, Browns Ferry Nuclear
Plant Site Director
- G. T. Jones, Plant Manager
- J. W. Anderson, Manager
Office of Quality Assurance
- H. N. Culver, Chief, Nuclear Safety Staff
- D. L. Williams, Jr., Supervisor
Licensing Section
- R. E. Rogers, Project Engineer

bcc w/encls:

- NRC Resident Inspector
- R. J. Clark, Licensing
Project Manager, NRR
- Document Control Desk
- State of Tennessee

RII *gln*
 FSCantrell:cdg
 6/27/84

RII
DM
 DMVerrelli
 6/27/84

RII
fr DM
 RCLewis
 6/28/84

R II
DM
 RCLewis
 6/28/84