

NOTICE OF VIOLATION

Wisconsin Electric Power Company  
Point Beach Nuclear Plant

Docket Nos. 50-266; 50-301;  
License Nos. DPR-24; DPR-27

During an NRC inspection conducted from October 4, 1995 through November 16, 1995, a violation of NRC requirements was identified. In accordance with the NUREG-1600, "General Statement of Policy and Procedure for NRC Enforcement Actions," the violation is listed below:

Technical Specification (TS) 15.6.8.1 required that safety related equipment be tested in accordance with approved procedures.

Test ORT 3A, "Safety Injection Actuation With Loss Of Engineered Safeguards AC Unit 2," revision 30, step 3.8 required that all other safeguards systems-related testing on both units be suspended during performance.

Contrary to the above, on November 7, 1995, all other safeguards systems-related testing on Unit 1 was not suspended during Test ORT 3A.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Wisconsin Electric is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region III, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or if contested, the basis for disputing the violation; (2) corrective action taken and the results achieved; (3) corrective action to be taken to avoid further violations; and (4) the date when full compliance will be achieved. Where good cause is shown, consideration may be given to extending your response time.

Dated at Lisle, Illinois  
this 26 day of December, 1995