




UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 22, 1995



Peter B. Bloch, Chairman
Administrative Judge
Atomic Safety
and Licensing Board
Mail Stop: T-3 F23
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Thomas D. Murphy
Administrative Judge
Atomic Safety
and Licensing Board
Mail Stop: T-3 F23
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

James H. Carpenter
Administrative Judge
Atomic Safety
and Licensing Board
Mail Stop: T-3 F23
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

In the Matter of
Georgia Power Company, et al.
(Vogtle Electric Generating Station, Units 1 and 2)
Docket Nos: 50-424-OLA-3 and 50-425-OLA-3

Dear Administrative Judges:

Pursuant to the Board's request (Tr. 2609-2611) and for the clarity of the record, the Staff is providing the following evidentiary materials for the Board to provide to the Office of the Secretary: (1) three color copies of GPC Exhibit II-71 (Webb List) and (2) three audiocassettes of the excerpt of Tape 259 (transcribed in GPC Exhibits 29 and 30, ff. Tr. 2354) that was played on January 12, 1995 (see Tr. 2532-2545).

Sincerely,

Mitzi A. Young
Mitzi A. Young
Counsel for NRC Staff

Enclosure: As stated

cc w/o encls: Service List

9601050206 951222
PDR ADDCK 05000424
G PDR

7507

DGIA STARTS since JAE

~~Missing April 1, 5, 7, 8, 9~~ - ^{Al 2} Contallog

3-20-90	2119	4-1-90	0423	
	2223	4-6-90	1345	
	2293		1419	
3-23-90	0254		1404	
	1724 +	4-9-90	2141	
3-29-90	1109	4-6-90	<u>2347</u>	UV test
3-30-90	1920		32	
	2295			
	2254			
	2313			
	<u>2328</u>			
	2343			
	2348			
3-31-90	0012			
	<u>0016</u>			
	1827			
	1846			
	1758			
	1904			
	<u>1921</u>			
	1955			
	2254			
4-11-90	1258			
4-13-90	1316			
4-17-90	<u>0304</u>			
4-18-90	1306			

DGIB STARTS since JAE

3-21-90 2156 - failed to start

2259

2314

3-22-90 3017

0428

0714

1106 - Tripped on Hi Lube Oil Temp

3-23-90 3509

1730 - Tripped on Lo Jacket Water Press / Turbo Lube Oil Pres L

1744

3-24-90 0048 - Hi Jacket H₂O Alarm.

3-27-90 1649

1909

1951

1957

Final check test 2004

2220 UV start

3-28-90 0403 14980

1350

1356 < - 15 20 170 175
20 sec.

4-4-90 1632

55 sec.

4-5-90 0030

0307

4-10-90 0137

4-12-90 1020

4-16-90 0000

4-18-90 0759

27

4-3-90 0515

Moist. Lock out
Alarm due to
low control air
pressure, at
41 psi.