

AUG 24 1984

016

MEMORANDUM FOR: C. E. Norelius, Director
 Division of Project and Resident Programs
 Region III

FROM: Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation (NRR)

SUBJECT: POINT BEACH AUXILIARY FEEDWATER (AFW) AUTOMATIC
 INITIATION/OPERABILITY

By memorandum dated March 22, 1983, you requested technical assistance of the NRR staff in reviewing the subject item for Point Beach Units 1 and 2. We agreed to provide the requested assistance under Task Interface Agreement 83-35 dated April 8, 1983.

By letter dated June 20, 1983 Wisconsin Electric Power Company, licensee for Point Beach Units 1 and 2, proposed modifications to the motor operated discharge valves for the electric driven AFW pumps to satisfy the staff's concerns. We approved those modifications by letter dated September 15, 1983. As verified by the resident inspector at Point Beach, these modifications have been completed for both Point Beach Units 1 and 2 and tested satisfactorily.

This completes NRR action requested in the Region III memorandum (C. E. Norelius to D. G. Eisenhut March 22, 1983) for Point Beach Units 1 and 2 as specified in Task Interface Agreement 83-35.

Original signed by:

Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation

DISTRIBUTION:

Docket File

- NRC PDR
- LOCAL PDR
- ORB#3 RDG
- TCOLBURN
- PMKREUTZER
- RWESSMAN
- JCARTER
- GHOLAHAN

50-266
 50-302

ORB#3:DL
 PKreutzer
 8/21/84

ORB#3:DL
 TColburn:dd
 8/27/83

ORB#3:DL
 JRMiller
 8/27/84

AD:OR:DL
 GCLainas
 8/28/84

DCG Eisenhut
 8/24/84

8408310284 840824
 PDR ADUCK 05000266
 PDR