

# UNITED STATES NUCLEAR REGULATORY COMMISSION

---

IN THE MATTER OF:

DOCKET NO:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

COMBINED MILLSTONE NUCLEAR POWER STATION  
UNIT 3/RELIABILITY AND PROBABILISTIC  
ASSESSMENT SUBCOMMITTEE MEETING

LOCATION: WINDSOR LOCKS, CONNECTICUT PAGES: 231 to 466

DATE: Wednesday, August 29, 1984

---

TR-04 (Add LPDR)

Original<sup>o/i</sup> return to B. White, H-1016

50-423

ACE-FEDERAL REPORTERS, INC.

Official Reporters  
444 North Capitol Street  
Washington, D.C. 20001  
(202) 347-3700

8409040078 840829

PDR ACRS

T

PDR

NATIONWIDE COVERAGE

BEFORE THE  
UNITED STATES  
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

COMBINED MILLSTONE NUCLEAR POWER STATION  
UNIT 3/RELIABILITY AND PROBABILISTIC  
ASSESSMENT SUBCOMMITTEE MEETING

Howard Johnson's Conference  
Center  
Yankee Trader West Room  
Windsor Locks, Connecticut

Wednesday, August 29, 1984

The committees and subcommittees convened at 8:00 a.m.,

Dr. William Kerr presiding.

ACRS MEMBERS PRESENT:

DR. CHESTER SIESS  
DR. CARSON MARK  
MR. CARLYLE MICHELSON  
DR. FORREST REMICK  
DR. WILLIAM KERR  
DR. DAVID OKRENT  
MR. JESSE EBERSOLE

N U MEMBERS PRESENT:

MR. ROBERT BUSCH  
MR. RICHARD WERNER  
MR. JAMES CROCKETT  
MR. WILLIAM COUNCIL  
MR. RICHARD LAUDENAT  
DR. FREDERICK SEARS  
MR. JOHN OPEKA

CONSULTANTS:

MR. ALLEN CAMP  
DR. CHARLES MUELLER  
DR. PAUL POMEROY  
MR. MYER BENDER  
MR. MICHAEL BOHM

MR. SAM DURAIWAMY, Designated Federal Employee  
MR. RICHARD SAVIO, Staff  
MR. WANG, Staff

1 WRBeb

## P R O C E E D I N G S

2 DR. KERR: We will continue with the Subcommittee  
3 meeting on Millstone 3. I will assume that all those  
4 preambles for yesterday's meeting are applicable to today's  
5 meeting. You will remember that there were a few items on  
6 yesterday's agenda that we did not cover completely, and I  
7 would propose to treat those with questions this morning.

8 I would first ask the members of the Subcommittee  
9 if there are any further questions on the ATWS issue that  
10 should be raised.

11 (No response.)

12 DR. KERR: I hear none at this point, so let me  
13 go to control room design and habitability or remote  
14 shutdown capability.

15 Are there questions that you want to raise?

16 Mr. Remick.

17 MR. REMICK: I have a question on the control  
18 room design review. Specifically has it been completed and  
19 were there any specific findings that might lead to any  
20 modifications of the control room as we saw it yesterday?

21 MR. ROBY: My name is Arnold Roby, and I am the  
22 system manager for generation electrical engineering.

23 I will respond to your question, and I am also  
24 prepared to address the two open questions that remained  
25 following yesterday's meeting, one on degraded voltage

1 WRBeb

1 considerations and the second one of course was on the  
2 probability or the possibility of cross-ties between units.

3 DR. KERR: Please do.

4 MR. ROBY: The response to the question on CRDR  
5 is that by and large we have completed our reviews and work  
6 is completed for Millstone Unit 3. The schedule calls for a  
7 finalization of that completion, certainly within the next  
8 several months.

9 The CRDR reviews by and large have shown or  
10 demonstrated the adequacy of our design considerations for  
11 the control board. In one or two instances, there were  
12 minor changes. There were changes to labeling, there were  
13 changes to coloring, or there were changes to the scaling on  
14 instrumentation indications, but overall, the control board  
15 has proved to be very adequate, even given the review of the  
16 CRDR.

17 MR. REMICK: Thank you.

18 MR. EBERSOLE: May I ask a question?

19 In the control room design review, I guess I  
20 could say that the most important function that it will  
21 perform is to enable the operator to monitor and review to  
22 accomplish safe shutdown in more or less normal condition  
23 of operation, not post-accident. It is the fact that  
24 you can shut down when you can shut down when you have to  
25 for whatever reason, and in doing that, I think you list

1 WRBeb

1 approximately nine or ten or a dozen-odd systems that are  
2 critical to the safe accomplishment of that shutdown.

3 It is interesting to me that over all these years  
4 that these systems have never been looked upon, as are ECCS  
5 systems, in an integrated pattern. They are scattered, both  
6 physically out in the plant, they are scattered on your  
7 control board, there is no sense of unity or integration of  
8 these critical shutdown functions.

9 Do you follow me?

10 MR. ROBY: Yes, I understand your question.

11 DR. KERR: And your question is --?

12 MR. EBERSOLE: My question is do you have any  
13 intent to attempt to better illustrate to the operator which  
14 of the systems must be functional to execute and carry on a  
15 safe shutdown, not with a LOCA, just an everyday matter?

16 DR. ROBY: Yes, those concerns are addressed of  
17 course in the Task Analysis Reviews which are done for the  
18 control boards. In those Task Analysis, the evaluations  
19 actually identify all the operations that an operator has to  
20 perform, and the way in which he has to do it to deal with  
21 all of those situations.

22 From that Task Analysis then arises the  
23 evaluations which demonstrate the adequacy of equipment  
24 placement, equipment availability, instrumentation  
25 availability, to address that particular function. It is

2 WRBeb

1 from those evaluations that of course the placement of  
2 control switches, the coloring schemes that we use, are all  
3 decided to be adequate or in need of some modification.

4 MR. EBERSOLE: Well, that speech contained  
5 absolutely nothing with respect to what you are going to do  
6 to attempt to unify these functions by color code or  
7 whatever.

8 DR. KERR: That's not a question, that's a  
9 statement.

10 MR. EBERSOLE: Well, let me ask, do you disagree?

11 MR. ROBY: Do I disagree it's a statement?

12 MR. EBERSOLE: No, do you disagree that you have  
13 no unified presentation of these functions by the control  
14 board?

15 DR. KERR: You can feel free to disagree if you  
16 like.

17 MR. ROBY: I disagree.

18 MR. EBERSOLE: Well, I guess that will remain a  
19 continuing issue.

20 DR. KERR: Mr. Okrent.

21 DR. OKRENT: In some power plants and in the  
22 research and development world there have been efforts  
23 underway to assist the control room crew in diagnosing  
24 relatively more complex events. The Seabrook plant, for  
25 example, has a kind of a prioritization scheme, alarms.

1 WRBeb

1 Others have been looking at other things.

2 I'm not quite sure I understand what the short-  
3 and long-term technical point of view in this regard is for  
4 Millstone 3, whether you think the current approach with  
5 your developing functional or symptomal emergency operating  
6 guidelines and so forth, whether the SPDS is adequate or  
7 whether you think other things should be seriously examined.

8 If the latter, I would be interested in knowing  
9 what, and in what time scale.

10 MR. ROBY: We have of course included in the  
11 Millstone 3 design the provision of an SPDS which identifies  
12 the critical functions, and I am sure you are well enough  
13 acquainted with what it does and how it does it, enough not  
14 to require any further information from me.

15 Hand-in-hand of course with the SPDS goes  
16 operator training programs which really attempt -- which  
17 really provides the information that operators would require  
18 to prevent them getting a mind set for particular scenarios  
19 for which they are provided information which has the  
20 adverse consequence of removing them from having a free  
21 thinking ability for other events.

22 I think hand-in-hand with SPDS with the  
23 instrumentation that we supply, the procedures that are  
24 available to him, and with the training programs that he is  
25 given, this enables the control room operating staff to have

1 WRBeb

1 a full and accurate cognizance of all plant events for which  
2 they are required to take action or be aware of.

3 DR. OKRENT: So your current program is pretty  
4 much it? You think it is satisfactory?

5 MR. ROBY: It has many layers associated with it,  
6 and in that respect it is satisfactory, yes.

7 DR. OKRENT: Well, now, let me take a look at a  
8 couple of things and see how you react.

9 There are ideas for signal validation, one or two  
10 different ones. I don't think they are currently in your  
11 scheme of things.

12 MR. ROBY: Yes, they are.

13 DR. OKRENT: Oh, they are?

14 MR. ROBY: Yes, they are.

15 DR. OKRENT: How are they done?

16 MR. ROBY: The SPDS information fed to the  
17 operator has signal validation associated with it. Each of  
18 the parameters which is input— Many of the parameters  
19 which are input to those critical safety functions are  
20 validated, and in fact the information is presented to the  
21 operator as either validated, invalid or validated. So he  
22 is aware when he sees that information of the accuracy of  
23 it, and the extent of course to which he should be  
24 cognizant.

25 DR. OKRENT: What is the approach used for



.1 WRBeb

1 validation in your SPDS?

2 MR. ROBY: We run a true-logic processes which  
3 compare the signals with one another which, through simple  
4 logic, then evaluates what other plant processes should be  
5 seen as a result of this particular signal. If those two  
6 don't match up, then of course there is obviously a  
7 disconnection or wrong information being provided.

8 So it's a comparison and also a logic process.

9 DR. OKRENT: So if they don't line up he is told  
10 there is an inconsistency?

11 MR. ROBY: Insofar as the information is  
12 available on the SPDS concerned. He of course then would  
13 use his control board instruments.

14 DR. OKRENT: Which may equally have the  
15 inconsistency?

16 MR. ROBY: Insofar as some may be fed from the  
17 same sensors, that is correct. But insofar as there is a  
18 much greater resource of information, individual information  
19 on the control board, he should be able easily to confirm  
20 his suspicions from the SPDS.

21 DR. OKRENT: Do you have any opinions on the pros  
22 and cons of alarm prioritization?

23 MR. ROBY: The main thing about alarms,  
24 prioritization or not, is that basically they provide some  
25 unambiguous displays to the operator, that we don't

1 WRBeb

1 suddenly surround him with so many alarms and so many colors  
2 and priorities that he is more confused about the situation  
3 than is made clear to him.

4 We believe that the process that we have used in  
5 Millstone 3 attempts to meet the process of clarifying the  
6 plant conditions. We have employed an exhaustive  
7 color-coding system, as you will have observed during your  
8 plant walk-through, but the presentation of the alarms, the  
9 ways in which they are grouped and their proximity to other  
10 information that he should be made aware of are all in a  
11 really honest attempt to use them as clarification to him.

12 DR. OKRENT: But there is no alarm suppression,  
13 as I understand it, or this sort of thing?

14 MR. ROBY: Not by color coding or not by  
15 different tones or whatever else may have been used in some  
16 other plants.

17 DR. OKRENT: I guess I'm wondering-- I'll just  
18 give a couple of examples of potential developments in the  
19 field.

20 People talk about response trees, for example.  
21 You get into a problem, you could display to the operator  
22 the seemingly success paths assuming there aren't some  
23 failures, one or more of them. Have you looked at all at  
24 the merits of that sort of approach?

25 MR. ROBY: I'm not quite sure that I understand

J WRBeb

1 what your question is.

2 DR. OKRENT: Given a loss of some— Well, let's  
3 just say you have signs of a small LOCA. There are various  
4 success paths for keeping things under control. That's a  
5 simple one; there are more complicated ones. And in a  
6 sense, part of that is in your EPG.

7 MR. ROBY: Yes.

8 DR. OKRENT: There may be situations that EPGs  
9 haven't been able to cover, and so forth, and I'm trying to  
10 see whether you have an active program to explore beyond  
11 what I now understand you to have, or whether you feel this  
12 is really adequate.

13 MR. ROBY: We have of course a simulator  
14 available for each of these units.

15 DR. OKRENT: Yes.

16 MR. ROBY: And we can use that to input  
17 situations and conditions which either demonstrate the  
18 adequacy of the procedures that we have or of course have  
19 the ability to identify their weaknesses.

20 We also can input situations which are abstract  
21 which contain numerous failure scenarios to identify the  
22 very features I think that you're talking about.

23 DR. OKRENT: By the way, do you have some kind of  
24 special EPG, given a severe earthquake?

25 MR. ROBY: I would have to defer that question to

1 WRBeb

1 Mr. Crockett.

2 MR. CROCKETT: Dr. Okrent, yes, we do have an  
3 emergency procedure to deal with an earthquake, which will  
4 be in place.

5 DR. OKRENT: That's a very general kind of  
6 description I must say.

7 How does it differ from an EPG.... Let me assume  
8 you're given a severe earthquake; you are going to trip your  
9 turbine. I mean you could say well, it's just like a  
10 turbine trip, or something. What is different about it?

11 MR. CROCKETT: Different from the ERG-based  
12 procedure?

13 DR. OKRENT: Yes, the procedure with EPG, yes.

14 MR. CROCKETT: The procedure is an emergency  
15 procedure that deals— In the event of an earthquake as  
16 felt or sensed by the operators, it requires them to take a  
17 number of actions, and primarily that action is based on  
18 looking at the plant status and looking at damage in the  
19 plant to see if we have had any damage from the earthquake.

20 DR. OKRENT: But that's I find a sort of narrow  
21 set of objectives to take, given a severe earthquake. Given  
22 a severe earthquake, I'm not sure you know which information  
23 in the plant is reliable enough, in very good shape to know  
24 which of the non-seismic equipment may or may not have  
25 malfunctioned or was subject to damage in some way, and

J WRBeb

1 even, if it's severe enough, some of the nominally seismic  
2 Class 1, I don't know how you know what the operator should  
3 trust and in fact, I guess there is some evidence which I've  
4 only heard by word of mouth, when they get severe enough you  
5 don't know how much you should trust the operator.

6 So I'm a little curious. What does it mean to  
7 say you have an emergency procedure guideline for a severe  
8 earthquake? Your answer is sort of too blithe for me.

9 MR. CROCKETT: Two points. First, we have  
10 instrumentation in the plant, our seismic monitoring  
11 instrumentation. That procedure requires that the operator  
12 run those tapes and provide those tapes for analysis to  
13 determine the actual g level.

14 Secondly, we do operate the plant in accordance  
15 with the technical specification and under that procedure,  
16 it's the responsibility of the shift supervisor to verify  
17 that our technical specification operability and indeed also  
18 the surveillance requirements are satisfied for the  
19 equipment necessary to operate the plant.

20 DR. OKRENT: You are giving me words but you  
21 really haven't, in my opinion, been responsive to whether he  
22 is able to even do those things, given— I'm talking about  
23 an SSE. I'm talking about a somewhat less probable  
24 earthquake, you know, the kind that we saw yesterday might  
25 be tickling Mr. Kennedy's fragilities, and he has a long

1 WRBeb

1 list of things that are not on his fragility curves either.

2 MR. CROCKETT: I guess the best way I can respond  
3 to that is that because of the way the emergency operating  
4 procedures are written, and they are symptom-oriented, that  
5 in the event of the severe earthquake they will lead you  
6 into a symptom-oriented emergency response procedure to deal  
7 with any of the accident states that are covered by the  
8 emergency procedures.

9 DR. OKRENT: You see, implicit in the statement  
10 is the assumption that the information given to the operator  
11 will be such as to lead him correctly. And I'm asking how  
12 hard you have looked.

13 But let me leave it at that for now for both the  
14 applicant and the staff.

15 DR. KERR: Are there further questions on this  
16 issue?

17 (No response.)

18 DR. KERR: This brings us to AC/DC power system  
19 reliability. Are there questions about that?

20 (No response.)

21 MR. ROBY: Would you like that I should address  
22 those questions, the two open questions at this time?

23 DR. KERR: After I determine whether there are  
24 questions.

25 I see none.

1 WRBeb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Go ahead and address the two open questions.

MR. ROBY: The first question which arose yesterday really centered around the testing program that the plant has to identify the operability of plant equipment under degraded or low voltage conditions.

I think essentially that was Dr. Okrent's question.

DR. OKRENT: And mal-design.

MR. ROBY: I'm sorry?

DR. OKRENT: Mal-design, as showed up recently in Indian Point 3.

MR. ROBY: I understand. I will deal with that one as well.

The second question, as I understood it, related to the considerations for establishing electrical cross-connections between the Millstone units and thus enabling one of the unit's path sources to support another unit.

I think that was Mr. Ebersole's question.

MR. EBERSOLE: Yes.

MR. ROBY: Fine.

Regarding the first question, we do have an extensive program to demonstrate the adequacy of the plant equipment and its performance under degraded or upset voltage concerns.

1 WRBeb

1

2

DR. OKRENT: Excuse me. Could I focus the question?

3

4

5

Why did the undervoltage situation that developed in Millstone in operation not show up in the pre-op or operational tests?

6

7

8

9

10

11

12

13

14

15

MR. ROBY: The one you're referring to, which of course takes us back to 1973, there were -- and it may have been and I guess ultimately all of us would have to agree that there was a loophole in the protection defenses that were provided in nuclear plants to protect against voltage conditions which were present on the grid system but were not sustained at a level to provide assurance that the safety-related equipment would perform its function. The whole of this question on degraded voltage centers around that loophole.

16

17

18

19

20

21

22

23

In fact, it was a very painful period personally for me as Millstone was the unit that experienced it. However, prior to that time the protection arrangements that were included in nuclear plants to deal with these conditions were essentially no voltage protection schemes. They had voltage settings that were so low that one could almost immediately say the grid, the outside sources could never sustain themselves at those levels.

24

25

The event that arose at Millstone at that time arose because of a particular grid-loading pattern and



1 WRBeb

1 generation pattern which allowed, on the loss of one unit,  
2 one large generating unit, the voltage to go to a level  
3 which could not or would not in fact sustain the correct  
4 operation of some of the equipment which was required for  
5 that unit.

6 Remember that although this was safeguard  
7 equipment, some safeguard equipment is used during normal  
8 shutdown functions. And it was in attempting to use that  
9 equipment that we discovered that it was inoperable.

10 Now that was how this arose. Does that answer  
11 your question?

12 DR. OKRENT: No, it doesn't, except partly.

13 What I'm really interested in knowing is in your  
14 opinion is there now a testing program for all  
15 electrical-related equipment which is sufficiently stringent  
16 that it covers the various combinations of events that might  
17 be of importance, and not only cover the no voltage and the  
18 full voltage, for example, but the variety of things that  
19 might be of interest so that in your testing program, in  
20 fact, you have carefully examined situations that might  
21 arise in degraded situations, and in ill-timing situations,  
22 in things going off and on as they might in an actual event,  
23 and so forth, to satisfy yourself that in fact your system  
24 will still be able to provide AC power where it is needed,  
25 or DC power?

1 WRBeb

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. ROBY: The testing program for Millstone 3 fully meets the requirements you have enumerated.

DR. OKRENT: So it would just be an astonishingly remote situation that anything should occur—

MR. ROBY: — which we have not tried to foresee. Yes, that's true.

DR. OKRENT: And you are able to simulate in a rather direct degree the kind of loading patterns that might occur under a range of accident conditions including things where not everything started and things start and went off, and so forth and so on?

MR. ROBY: Yes. As a matter of fact, I was prepared to address that somewhat more closely for the very considerations that you're talking about, remembering of course that the grid system is not available at low voltage levels for us to use it as a test vehicle.

I can tell you that it is done. I can spend a few minutes explaining to you how we do it.

DR. OKRENT: Well, let Mr. Ebersole take over.

MR. EBERSOLE: I was just going to say that this matter is really just a part of a generic problem where we have long had a hangup, believing that the only matter that we have to consider is the totality of the functional failure, and we don't look at the graduality of it, or the oscillatory characteristics of the failure as it goes down.

1 WRBeb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

And I want to ask you, having found it, and by bitter experience in the electrical area, do you look at it in other areas like air systems, et cetera?

MR. ROBY: Yes. I think when the question arose, of course, we quickly realized that it wasn't just concerned with electrical systems, and reviews of the other systems were performed in order to I guess really learn from the principles that were established on that degraded voltage condition.

MR. EBERSOLE: Well, in the course of doing that do you also find a corollary which is rather than have a total functional failure of some function or some system, in fact you have an excess of that which is the ultimate voltage or pressure or whatever you may be able to get, which is normally controllable by a thing that's called a control, not a safety function?

A case in point might be what is the upper limit that you can get if the regulatory system that controls DC charging voltage sticks at its utmost limit. What will be your terminal voltage you will get on your DC charging system if that occurs when the control system is locked up in the highest mode? Can you tell me what that is?

MR. ROBY: Yes. The analysis that we do to look at what might be those highest voltages takes the generator terminal voltage to its maximum level that the machine can

1 WRBeb

1 produce. We then do a calculation to ascribe the maximum  
2 voltage as it will appear throughout the station for those  
3 given terminal voltages.

4 MR. EBERSOLE: Well, in the DC system I believe  
5 you have 125 volts.

6 MR. ROBY: 125 volts, yes.

7 MR. EBERSOLE: If I apply the maximum available  
8 field current to the DC generators, what is the terminal  
9 voltage I get?

10 MR. ROBY: The voltage that will go at the DC  
11 battery?

12 MR. EBERSOLE: Yes.

13 MR. ROBY: It could go to 133 or 134 volts.

14 MR. EBERSOLE: That's nailed at that point then?  
15 It cannot go any more?

16 MR. ROBY: Not unless the generator can exceed  
17 its design voltage rating and the capability of the field  
18 current to produce that voltage.

19 MR. EBERSOLE: This is without the regulator in  
20 place. Right? This is with full, uninhibited current flow?

21 MR. ROBY: This is with full field current  
22 applied to the machine.

23 MR. EBERSOLE: Yes. So you have a nail in it?

24 MR. ROBY: Yes, absolutely.

25 MR. EBERSOLE: And correspondingly elsewhere you

1 WRBeb 1 have—

2 MR. ROBY: And it is very important to establish  
3 what those nails are.

4 MR. EBERSOLE: And that voltage thus then  
5 presumably is capable with the sustaining volage of the  
6 connecting equipment?

7 MR. ROBY: Yes. In fact, those today, the very  
8 things that you talk about, are step number one in the  
9 design. Whereas perhaps in many years past one would order  
10 equipment with voltage ratings, today we look at the full  
11 range of voltage which the plant can experience, and we  
12 procure and design the equipment for those voltages. So  
13 that you may see plant-important motors with voltages as low  
14 as 60 percent of normal capability instead of a 70, 75  
15 percent standard by which one would procure directly.

16 There is very close concern given to those very  
17 things that you're discussing now.

18 MR. EBERSOLE: Thank you.

19 DR. KERR: Any further questions in this area?

20 DR. MARK: Just a small one on the remote  
21 shutdown panel.

22 Let me assume that for some reason, unexpectedly  
23 but definitely, you have to transfer control from the  
24 control room. How long does it take to activate and get  
25 proper attention at the remote panel?

1 WRBeb

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. ROBY: The remote panel. The remote panel is of course located actually within the control building complex.

DR. MARK: It is downstairs?

MR. ROBY: Downstairs, along the passage.

DR. MARK: Yes, I've seen where it is.

MR. ROBY: So certainly the time to get there from the control room is only in the order of perhaps a minute or a minute and a half.

DR. MARK: Now you've got to do some transfer switching.

MR. ROBY: That's right. Once you get to the control -- to the auxiliary shutdown panel location, you have only one function to perform in order to get transfer to the auxiliary shutdown panel, and that is the manual operation of the control switches in the transfer switch panels which will then give you full control, an indication at the auxiliary switch panel.

Certainly within a minute, two minutes, of entering that room, you should be in the transfer position.

DR. MARK: So the total time might be between two and three minutes?

MR. ROBY: I would get that that's a good estimate to use.--

DR. MARK: Well, that was--

1 WRBeb

1 MR. ROBY: -- probably less.

2 DR. MARK: I just wanted a feeling for it.

3 MR. ROBY: Yes.

4 DR. MARK: Thank you.

5 MR. ROBY: Certainly.

6 DR. KERR: Mr. Michelson, did you have a

7 question?

8 MR. MICHELSON: Yes. Mine is more of a general

9 question.

10 I have a number of things I wanted to get cleared  
11 up as a result of the tour yesterday, and I believe the  
12 utility would be prepared to answer these questions today.  
13 But when the scheduled opportunity avails itself--

14 DR. KERR: The opportunity to ask?

15 MR. MICHELSON: To ask questions and get them  
16 answered--

17 DR. KERR: Well, let me get to Mr. Ebersole  
18 first.

19 MR. EBERSOLE: In the design of the remote  
20 shutdown panel, I would like to get what your general  
21 principles and rationale and logic is in building that  
22 thing. So far as I now know, the Staff -- and I may be  
23 wrong about this -- hasn't really gotten a Standard Review  
24 Plan or design concept set for this, but let me ask what you  
25 did.

1 WRBeb

1

2 You certainly must, at the shutdown control  
3 panel, have the ability to provide these critical shutdown  
4 functions that I referred to earlier, and I understand that  
5 is to be provided in spite of any chaotic condition in the  
6 spreading room or the control room or any localized point of  
7 common vulnerability elsewhere in the plant, like a cable  
8 tunnel. Am I correct?

8

MR. ROBY: Yes, you are.

9

10 Really to meet the regulatory requirements one is  
11 only bound — at least has been bound to provide for remote  
12 control in the event the control room is evacuated but the  
13 control room is undamaged.

13

MR. EBERSOLE: I understand the extension-cord  
14 logic from the control room. That is a decadent notion—

15

MR. ROBY: Yes.

16

MR. EBERSOLE: — that has I hope gone down the  
17 drain forever.

18

MR. ROBY: Yes.

19

MR. EBERSOLE: But anyway, let me go on.

20

21 In the design of the center you must therefore  
22 retain the critical functional needs of the plant to shut  
23 down.

23

MR. ROBY: Yes.

24

25 MR. EBERSOLE: In the course of doing that, do  
you have in your rationale the admission that in the



2 WRBeb

1 . control room or spreading room or wherever it might be there  
2 . will be a number of undesired spurious events, or could be,  
3 due to hot shorts is a case in point, and you must intercept  
4 their occurrence to preserve the notion that you are going  
5 to maintain the critical functions in that area, the  
6 preservation of function in the face of undesired  
7 malfunctions?

8           To what extent have you provided disconnects and  
9 cutoffs?

10           MR. ROBY: We have provided for that very  
11 scenario that you have described, the loss of either the  
12 control room or the cable spreading room or the instrument  
13 rack room, as you would have seen at Millstone, are really  
14 adjacent to one another.

15           We have provided alternate instrumentation on  
16 what we term in the fire instrument panels in the switchgear  
17 rooms associated with the auxiliary shutdown panels which  
18 provide alternate instrumentation paths to those paths which  
19 were used for the control room, so that in the event of a  
20 loss, a complete loss of the control room instrument rack  
21 room or cable spreading room, which is quite significant, we  
22 would have available instrumentation to us in the  
23 auxiliary shutdown panel area to be able to effect a safe  
24 shutdown.

25           MR. EBERSOLE: You are going down the same track

1 WRBeb

1 where we were a while ago with Dr. Okrent talking to you.  
2 You provide for the loss of.

3 MR. ROBY: The loss of, yes.

4 MR. EBERSOLE: I asked, though, not for the loss  
5 of but for the undesired presence of, or the continuing  
6 oscillatory or malperformance of the functions which you  
7 must guarantee the loss of in order to execute the safety  
8 function in an isolated way at this panel.

9 Take a case in point. What if you have circuitry  
10 that opens all four main steam line oscillation valves or  
11 closes them, or whatever?

12 MR. PITMAN: That review was part of the Fire  
13 Protection Review Branch Technical Position 951, similar to  
14 Appendix R. Our review looked at both aspects here.  
15 Mr. Roby talked to those features which must remain  
16 operable.

17 Regarding those that could now operate spuriously  
18 and interfere with shutdown, we looked in much detail at  
19 those. I can't give you every detail about how we handled  
20 every valve, but what I can say is that there is an Action  
21 Plan. There is a procedure on the street right now for  
22 comment that deals with what actions, what response to take,  
23 based on the symptom that is generated.

24 In the case of motor-operated valves, in most  
25 cases it's a matter of going down, removing power from the

1 WRBeb

1 .. motor control center, and randomly repositioning the valve.

2           In a case, an extreme case where that generates a  
3 large leak that needs to be taken care of in a hurry, that  
4 valve would be protected electrically.

5           PORVs is a procedure to close block valves before  
6 leaving the control room.

7           MR. EBERSOLE: Okay.

8           MR. PITMAN: Those kind of things. So it has  
9 been looked at in much detail.

10           MR. EBERSOLE: Right. That's all I wanted to  
11 know, that you had done an in-depth review of the undesired  
12 positive functions.

13           MR. PITMAN: Yes, we have.

14           MR. EBERSOLE: Thank you.

15           DR. OKRENT: One other question in the area of  
16 AC/DC power.

17           When I look at the May 30th report from Livermore  
18 et al. to the NRC concerning the PRA, they mention the  
19 following:

20           An important dependance of the vital AC main  
21 electrical system and emergency generator load sequencer on  
22 the vital DC system was not included in the corresponding  
23 fault trees. In the event of a loss of offsite power, the  
24 vital AC system would initially be dependent upon the  
25 batteries and the vital DC system.

1 WRBeb

1 This is an apparently critical dependence because  
2 the emergency diesels cannot transmit power to the emergency  
3 bus unless the load sequencer is operating but the sequencer  
4 requires vital AC to function. The real difficulty occurs  
5 in the individual fault trees of the vital AC and DC system.

6 The unavailability of each system is calculated  
7 assuming DC power is available on the emergency bus. This  
8 makes the results invalid for those cases where no power is  
9 available on the emergency bus. Thus the PSS provides no  
10 estimate of the unavailability of the vital AC and vital DC  
11 systems on demand for those cases in which offsite power is  
12 unavailable, yet such a case is precisely when the  
13 unavailability of these systems is extremely important.

14 I don't know. Is that an area in which you've  
15 been thinking, or is that something we have to wait to deal  
16 with in terms of the PRA?

17 MR. ROBY: I think you could -- we could respond  
18 to it now. Dr. Bickel could respond to it now, or you could  
19 have it covered in the PRA.

20 MR. BICKEL: John Bickel, PRA Section, Northeast  
21 Utilities.

22 DR. KERR: Will you lean into that mike, please?

23 MR. BICKEL: First of all, that was a heck of a  
24 question. Could we break it up into some pieces?

25 DR. OKRENT: Well, I was just reading from a

2 WRBeb

1 report which I'm sure you have seen as much as I have.

2 MR. BICKEL: Not exactly. We saw an earlier  
3 draft some time in March. I'm not familiar with the section  
4 you have.

5 DR. OKRENT: I see. Section 3, which I thought  
6 was in the earlier draft. I thought they just left out the  
7 conclusions sort of. But go ahead.

8 Are there any important dependencies sometimes,  
9 obscure dependencies, between the availability of DC power  
10 and emergency buses for starting diesels, et cetera, et  
11 cetera?

12 MR. BICKEL: Yes, there are, and they are  
13 described— I believe you will find it in Figure 1.1,  
14 Section 1, of the PSS.

15 DR. OKRENT: Well, I'm not quite sure how to take  
16 care of the response, and I guess I was sort of asking the  
17 question in terms of, since we're talking about testing more  
18 than PSS at the moment, does the testing program go through  
19 things in sufficient depth that each vital dependency in  
20 fact is known about and tested in such a testing program?

21 MR. ROBY: To the extent that the people that  
22 write the procedures are very knowledgeable, the testing  
23 procedures, that is, are very knowledgeable of all the  
24 aspects of the plant design and the plant design  
25 requirements, I think we cover the very features that you

1 WRBeb

1 talk about. Now that's—

2 DR. OKRENT: That's a tricky answer because I  
3 have just read where, in a system interaction study at  
4 Indian Point, they only turned up — an electrical systems  
5 interaction, they said in this report I read, by several  
6 different analysts putting their input together and grinding  
7 it through this master sets codes which puts together  
8 various fault and event trees, and the dependence turned  
9 up.

10 This was after the utility had spent some  
11 millions of dollars doing what I thought was and still think  
12 is a really good job in trying to uncover interactions. So  
13 I'm not fully impressed, let's say.

14 MR. ROBY: Well, really you answered the  
15 question. Even if you do a very thorough, absolutely  
16 first-class job, system interaction is such a complex review  
17 that you can't, with 100 percent certainty, identify that  
18 every interaction affecting the plant would have been  
19 recognized.

20 DR. OKRENT: You're leading—

21 MR. ROBY: I think you appreciate that.

22 DR. OKRENT: You're leading me into my \$64  
23 question:

24 What depth of systems interaction studies have  
25 you done or do you plan to do?

1 WRBeb 1

MR. ROBY: That is covered in the PSS.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. PITMAN: Dr. Okrent, I've requested one of the members of my staff to procure a copy of what we call our Systems Interaction Logic Diagram, which was the figure I mentioned earlier.

Now you-all I guess have a copy of the PSS. This diagram was the result of failure modes and effects analysis. It was carried out both as a part of control systems and protective systems failure modes and effects analysis, an additional FM&EA analysis which was carried out by NUSCO.

We combined the results of both of these failure modes and effects analysis into what we call a Systems Interaction Logic Diagram. What this diagram indicates on here is the impacts of the loss of AC, the loss of DC, and loss of vital AC, and how they are interrelated.

I believe your question— You know, possibly we can possibly defer it to the PRA section, but I would refer that there is a drawing that does illustrate how the various electrical functions are interrelated both in terms of vital AC being supplied by the batteries, how the diesel field is flashed by certain battery circuits, and how the unavailability of various batteries for vital AC circuits impacts the sequencer, the diesel, and all those type of things.

1 WRBeb

1

I believe your question is answered in the study.

2

DR. OKRENT: I see.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Should I understand then your answer to tell me that were Indian Point 3 to have taken your logic and applied it to their plant, they would have turned up this weakness?

MR. PITMAN: I can't guarantee what Indian Point would have done. I know that we think we did a fairly good job of trying to scrutinize the design and find out where such interactions were possible. We did identify two of them which were critical, and are found in what I guess you would call the dominant cut set list for the plant.

And additionally we have ranked them, and we have looked at them and their impacts in the design. And we have considered them in procedures, both in emergency restoration and in on-going efforts to try and assure that we have the issue pretty well covered.

DR. OKRENT: Thank you.

DR. KERR: Let me get some guidance from the Subcommittee.

We are now almost an hour into the morning meeting and we have not yet gotten to the morning's agenda. We have scheduled for the rest of the day an extensive discussion of PRA, and there are a great many people here I think just for that purpose.



2 WRBeb

1 It is up to the Subcommittee as to how we spend  
2 our time for the rest of the day, but I would point out that  
3 the more time we spend on non-PRA -- and I think we ought to  
4 be thorough -- the less time we have for presentations by --  
5 I started to say a "horde" of people, but that sounds  
6 pejorative -- a rather significant number of people who are  
7 here at the meeting.

8 Are there further questions on these items?

9 (No response.)

10 DR. KERR: I see none--

11 MR. EBERSOLE: Pardon me. Are you talking about  
12 Item 3.10?

13 DR. KERR: I'm talking about the items that we  
14 should have covered on yesterday's agenda and that we are  
15 covering this morning by questions. I'm not talking about  
16 the items on the Wednesday agenda.

17 MR. EBERSOLE: All right.

18 DR. KERR: Okay.

19 We are ready then I guess to go into--

20 You have not completed your response to the open  
21 question?

22 MR. ROBY: I had not completed my response to the  
23 electrical cross-connection question.

24 DR. KERR: Okay. Will you do that now, please?

25 MR. PITMAN: Mr. Roby?

2 WRBeb 1

MR. ROBY: Yes?

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. PITMAN: Could I take this opportunity to correct a misunderstanding on Mr. Ebersole's question? I think you are content with Mr. Roby's answer that has to do with the DC system overvoltage, and I think he gave you the right answer to the wrong question, so you might want to ask that question again.

But let me give you the answer that I believe is correct.

The DC regulators--

DR. KERR: Now to which question are you giving an answer?

MR. PITMAN: You asked a question earlier about the impact of a battery charger going into an overvoltage condition.

MR. EBERSOLE: Let me make it more general.

By and large many functions are looked at only in the context of when they fail. They are not looked at in the context of when you get too much of them. And whether you get too much is -- the control over that is frequently vested in a thing called -- whatever -- a controller, a modulator which is not of a safety grade characteristic.

It is designed so you can pick it up if it fails, but in many cases no one looks at it when it goes into its ultimate forcing mode, in this case to produce the highest

2 WRBeb

1 possible DC voltage.

2 MR. PITMAN: Right. And I believe the correct  
3 response to that for the specific example — let's just take  
4 that — a DC battery charger can indeed go into an  
5 overvoltage condition. If it can provide enough voltage at  
6 low AC input, it can provide too much at high AC input,  
7 naturally.

8 We do have individual overvoltage alarms set at a  
9 threshold level that would be indicative of a potentially  
10 damaging condition. A failure that caused this regulator to  
11 go astray would be alarmed; it would be an individual  
12 failure. We would have to address the consequence of that  
13 overvoltage at the time that it occurred and decide whether  
14 anything had been damaged.

15 I believe that's the correct response to that  
16 question.

17 MR. EBERSOLE: Well, what is the degree of  
18 overvoltage that you could get while the alarm is going on?  
19 What is happening to the parallel equipment in that  
20 interval?

21

22

23

24

25

2 AGBagb

1 MR. BICKEL: That's what I was trying to relate  
2 to, that the overvoltage can be there and accessible that  
3 the equipment is designed to normally function under. And  
4 recognize that most equipment can take short periods of  
5 overvoltage and not sustain. And at such time as a  
6 condition like that occurred, as could occur with diesel  
7 generators and anything else, you must then analyze what  
8 happened, what levels did I go to, what is the impact of  
9 that on the equipment and decide from there where do I go  
10 from here?

11 MR. EBERSOLE: But long before that you must  
12 establish by design what those terminal conditions are so  
13 that you don't have inadequate time to pick up the —

14 MR. BICKEL: That is indeed correct and we do  
15 have a specification, for example, for DC components —

16 MR. EBERSOLE: To get to the point what is the  
17 peak voltage you can get on the 125 DC system?

18 MR. BICKEL: I can tell you in absolute values,  
19 sir. All I can tell you is that it can go over the  
20 performance —

21 MR. EBERSOLE: And it would apply also to the  
22 4160's or whatever.

23 MR. BICKEL: And we indeed have alarms there.

24 MR. EBERSOLE: I don't like the having alarm,  
25 because alarm suggests that it could be anywhere above what

1 AGBagb 1 it should be and there may or may not be time enough to  
2 intercept damage to that paralleled equipment. Do you  
3 follow me?

4 Just the fact that there is an alarm leaves me  
5 cold.

6 MR. BICKEL: Yes. But it's the follow-up to the  
7 alarm and things can happen and will happen.

8 MR. EBERSOLE: Is there time? Perhaps the damage  
9 can occur in five seconds.

10 MR. BICKEL: Let's say for example this did  
11 occur, an isolated incident. It's going to be within a  
12 division. You're going to have the other division available  
13 and you will have time to --

14 MR. EBERSOLE: Stop just a moment. Remember  
15 earlier on in this session we said the typical design which  
16 the minimum required by NRC is that you have redundancy, and  
17 this applies to support systems. It's generally thought  
18 that you have redundancy in the context of meeting LOCA's on  
19 equipment which is in pure standby waiting to respond to  
20 something which will probably never occur.

21 In the service systems it's different, you don't  
22 have redundancy. You have -- for instance, this case here  
23 you throw an A train or whatever into disarray, perhaps you  
24 fail the whole thing. Now that almost invariably introduces  
25 a transient circumstance. You are not left with redundant

1 AGBagb

1 configurations to address that train.

2

MR. BICKEL: That's correct.

3

MR. EBERSOLE: And I just want to point out that  
4 it's not as beautiful as it seems. The redundancy is not  
5 there after this kind of accident.

6

MR. BICKEL: I agree.

7

MR. EBERSOLE: Well why don't you sooner or later  
8 prepare a list of the ultimate parametric levels of the  
9 several critical parameters that you can have which are  
10 controlled by non-safety grade upper limit controls. Do you  
11 follow me?

12

MR. BICKEL: I believe so. Within the electrical  
13 system.

14

MR. EBERSOLE: Well in the hydraulic system you  
15 usually put on relief valves.

16

MR. BICKEL: Sure.

17

MR. EBERSOLE: That would be enough.

18

MR. ROBY: I think the question that you really  
19 wanted me to address at this time was our ability and our  
20 thoughts on cross-connecting --

21

MR. EBERSOLE: It was. We haven't got to that  
22 yet.

23

MR. ROBY: Is that still one that you'd like me  
24 to talk about?

25

MR. EBERSOLE: Yes. You know, one of the more

1 AGBagb

1 critical areas in our considerations now is the reliability  
2 of AC power and it would be particularly true for you with  
3 these Westinghouse seals.

4 MR. ROBY: Yes.

5 MR. EBERSOLE: -- which we'll have to ask about  
6 later on, what are you going to do about the seals.

7 So when you have a multi-unit station like this  
8 certainly it enters into your mind that there are both  
9 merits and problems in providing system assistance from one  
10 of the units. I want to know what's your rationale, what  
11 protective logic do you use if you do translate power or  
12 services from one to the other.

13 MR. ROBY: I fully understand that question.

14 I think you have to remember that although the  
15 Millstone complex contains three nuclear units, each plant  
16 really has been designed in succession to the others  
17 starting in the mid-1960's. Hence basically we did not have  
18 the opportunity to designing a shared systems aspect into  
19 what essentially is a three-unit concept.

20 Now adding, of course, to that situation and  
21 making our position more difficult is that each of these  
22 three units is markedly different, even insofar as its basic  
23 type is concerned: we have one boiling water unit, one PWR  
24 and one Westinghouse PWR.

25 When Unit 1 was installed, it, of course,

2 AGBagb 1 accessed off-site power by one 345 Kv circuit and one 23 Kv  
2 circuit which is present at the station.

3 With the advent of Unit 2, its off-site power was  
4 supplied again from one new 345 Kv line and a connection to  
5 the 345 Kv circuit used by Unit 1.

6 Now as the design proceeded for Unit 3 -- and I'd  
7 rather like to stay Unit 3-specific from now on -- it was  
8 originally intended that it would access off-site power  
9 again with an additional 345 Kv line and use, as its second  
10 source, the 345 Kv line which had been provided for Unit 2.

11 However, in 1981 this concept really changed  
12 dramatically with the decision to use a generator breaker in  
13 the Millstone 3 generator main connections to the  
14 switchyard.

15 In that respect, of course, the generator breaker  
16 now enabled two immediate, automatically-operated full  
17 capacity circuits to be available to provide off-site power  
18 to the unit without recourse to any equipment located in  
19 other plant areas.

20 Although the question, of course -- although that  
21 concept has been used, this question of cross-tying the  
22 supplies between units is really still applicable. And we  
23 included -- in order to get a more rational understanding of  
24 its use and the degree to which it would enable us to have a  
25 more reliable source to Unit 3 -- we included in the PSS



1 AGBagb

1 considerations of what such a cross-connection would buy us.  
2 In fact it turned out -- we were interested -- it  
3 turned out that the PSS clearly demonstrated that there were  
4 insignificant gains in such a cross-connection. And it also  
5 established, which is perhaps as important, that there are  
6 real downside risks associated with such a cross-connection  
7 because in order to go to the ultimate to get this  
8 connection you're really talking about sharing DC -- sharing  
9 on-site power supplies between units. And in that instance,  
10 of course, these essential emergency supplies, which would  
11 be connected one unit to another unit, are such that a  
12 failure of such a connection raises the real prospect of  
13 adversely connecting the ability of both units to handle  
14 emergency situations.

15 MR. EBERSOLE: Pardon me just a moment.

16 In these cross-ties that you might have used, did  
17 you evoke the separative logic and the trip logic -- refusal  
18 to close on faults -- what one would say an enthusiastic  
19 attempt to prevent undesired translation of faults from one  
20 to the other.

21 MR. ROBY: Yes.

22 MR. EBERSOLE: Or did you just do it in the  
23 rudimentary way which almost always guarantees it will show  
24 bad on the PRA?

25 MR. ROBY: We included the requirements to

1 AGBagb 1 provide for such a connection: backup protection to the main  
2 protection — the failure, of course, of the backup  
3 protection would ultimately result in a loss of the diesel  
4 which would now be supplying both units. So those were  
5 considerations, full protection schemes.

6 MR. EBERSOLE: So in other words you use double  
7 breakers?

8 MR. ROBY: Breakers at both ends, yes.

9 MR. EBERSOLE: And you provided relay logic to  
10 not close on faults.

11 MR. ROBY: We provided relay logic which would  
12 not close on faults which would only be, in fact, available  
13 at the discretion of the operator. It would not be  
14 automatically accessed.

15 MR. EBERSOLE: And still this cross-tie was  
16 detrimental to the overall —

17 MR. ROBY: The gains were really insignificant.  
18 In fact, really equating the benefits of the emergency bus  
19 cross-tie with the risks and consequences of such systems,  
20 we came to the conclusion that such a scheme — that a  
21 better scheme is a well-designed, self-sufficient reliable  
22 power source engineered on a single-unit basis, that that  
23 provides a preferred power scheme —

24 MR. EBERSOLE: Yes, you mean like a gas turbine.

25 MR. ROBY: Pardon?

1 AGBagb 1

MR. EBERSOLE: Like a gas turbine?

2

MR. ROBY: An additional gas turbine you're talking about?

3

4

MR. EBERSOLE: Well what you're telling me, if you don't mean something like that is that two diesels are all that anyone needs.

5

6

7

MR. ROBY: In addition to the off-site sources --

8

MR. EBERSOLE: Yes.

9

MR. ROBY: Oh yes. Oh yes.

10

MR. EBERSOLE: Your conviction is two diesels and off-site power is a package which need not be improved upon.

11

12

MR. ROBY: -- which need not be improved on providing one diesel has the capability to provide one train of redundant safety equipment.

13

14

15

MR. EBERSOLE: You are aware of our current blackout study.

16

17

MR. ROBY: I am, yes.

18

MR. EBERSOLE: And the degradation of reliability that we see.

19

20

MR. ROBY: Yes, I have a --

21

MR. EBERSOLE: You must be at the top of the list.

22

23

MR. ROBY: I'm not sure about that, but I certainly -- loss of off-site is not the same as station blackout, of course. And I think frankly you're referring

24

25

1 AGBmpb

1 to that.

2

MR. EBERSOLE: We'll get into it with the

3

blackouts.

4

DR. KERR: Are there further questions on this?

5

(No response.)

6

DR. KERR: Thank you very much.

7

MR. ROBY: Thank you.

8

I would like to introduce Mr. Paul Blanch of the  
9 Generation Electrical Engineering Group to talk to you on  
10 Regulatory Guide 1.97 and Millstone 3 Unit's compliance with  
11 that guide.

12

## CONFORMANCE WITH REGULATORY GUIDE 1.97

13

MR. BLANCH: Good morning. My name is Paul

14

Blanch and I'm supervisor of the Instrumentation Engineering  
15 Group for Northeast Utilities.

16

(Slide.)

17

My talk this morning will address Northeast  
18 Utilities' position with respect to Reg Guide 1.97. As  
19 everyone is aware, I'm sure, the title of Reg Guide 1.97 is  
20 Instrumentation for Light Water Cooled Nuclear Power Plants  
21 to Assess Plant and Environs Conditions During and Following  
22 an Accident.

23

(Slide.)

24

Millstone Unit 3 is in full compliance with the  
25 guidance of Revision 2 of Reg Guide 1.97. The parameters

1 AGBmpb

1 selected to meet the guidelines of Reg Guide 1.97 were based  
2 on a detailed analysis conducted jointly between Northeast  
3 Utilities, Westinghouse and Stone and Webster.

4 This analysis was based on the FSAR accident  
5 analysis and also using the Westinghouse emergency response  
6 guidelines. This analysis was completed during the early  
7 design stages, which facilitated the incorporation of newly  
8 identified instrumentation into the design of the control  
9 room and control boards.

10 In design of the post-accident monitoring  
11 instrumentation special consideration was given to ensure  
12 that the same instrumentation is used both during normal and  
13 accident conditions.

14 Part of the accident monitoring instrumentation  
15 includes a system to monitor the status of inadequate core  
16 cooling. This inadequate core cooling system is in full  
17 compliance with the guidance given in NUREG-0737, Item 2F2.  
18 This is a fully redundant and a Class 1E electrical system.  
19 It includes a redundant reactor vessel level monitoring  
20 system using the Combustion Engineering heated junction  
21 thermocouple system. It includes a system that calculates  
22 both subcooling and superheat from reactor coolant system  
23 pressures and temperatures. The ICC system, Inadequate Core  
24 Cooling System, also monitors the status of all core exit  
25 thermocouples.

1 AGBmpb

1

The primary display for this Inadequate Core Cooling System is by the safety parameter display system and will be displayed as part of the core cooling critical safety function.

5

In summary, Millstone Unit 3 is in full compliance with the guidance of both Reg Guide 1.97 and NUREG-0737, Item 2F2.

6

7

8

This concludes my formal presentation.

9

DR. KERR: Thank you, Mr. Blanch.

10

Are there questions?

11

DR. OKRENT: Does the Staff concur?

12

13

MS. DOOLITTLE: The Staff has not yet completed its review of the Applicant's submittal.

14

15

16

DR. OKRENT: Would you remind me, is there some requirement for a continuous hydrogen monitoring system or not?

17

18

MR. BLANCH: Dr. Okrent, I believe I can answer that question.

19

20

21

22

23

There is a requirement within NUREG-0737 for hydrogen monitoring. It must be available within 30 minutes. Millstone Unit 3 has a hydrogen monitoring system which is capable of monitoring containment hydrogen concentration within the required 30-minute time.

24

DR. OKRENT: How does it work?

25

MR. BLANCH: It is a dual redundant independent

1 AGBmpb

1 system located outside the containment which takes a  
2 suction, a sample from the containment and analyzes the  
3 percent hydrogen in the containment and returns that sample  
4 back into the containment.

5 DR. OKRENT: Is that what everybody is doing, or  
6 do they have something in the containment?

7 MS. DOOLITTLE: I don't know the answer to that.

8 DR. KERR: Are there further questions?

9 (No response.)

10 DR. KERR: Thank you, Mr. Blanch.

11 MR. BLANCH: Thank you.

12 At this time I would like to introduce  
13 Dr. Rodgers.

14 DR. KERR: Excuse me. In light of our schedule  
15 and the time I'm going to ask the Subcommittee if we can  
16 handle the radiation protection program with questions. Is  
17 there any objection to that? I hope Mr. Rodgers won't feel  
18 slighted.

19 Are there questions on the radiation protection  
20 program?

21 (No response.)

22 DR. KERR: I see none. And I therefore would ask  
23 that we go now to -- Mr. Michelson said that he had some  
24 questions that he wanted to raise.

25 Carl, do you particularly want to read these

1 questions, or would it be possible for you to give them to  
2 the Applicant and ask for answers at the Full Committee  
3 meeting, or what?

4 MR. MICHELSON: Well, any of those that they  
5 can't answer yet, sure, the Full Committee is fine. Most of  
6 these are very short brief questions.

7 DR. KERR: Okay.

8 MR. MICHELSON: They were asked during the tour,  
9 and I suspect they've got the answers all ready to go.

10 RADIATION PROTECTION PROGRAM

11 MR. MICHELSON: The first question deals with the  
12 penetrations of primary containment, both the personnel and  
13 equipment airlocks. Are the seals there inflatable seals or  
14 the standard elastimer seals?

15 MR. COUNCIL: Bill Council, Northeast Utilities.  
16 They are standard elastimer seals.

17 MR. MICHELSON: Okay. Thank you.

18 The next question deals with the venting of the  
19 auxiliary feedwater room. It was not clear during the tour  
20 just how the pressurization of that room is handled in the  
21 case of a steam line break within the room.

22 MR. COUNCIL: Mr. DeBarba of Northeast Utilities  
23 will answer that question.

24 DR. KERR: Did you get the question, Mr. DeBarba?

25 MR. DE BARBA: Eric DeBarba, NUSCO. I did get



.1 AGBmpb

1 the question.

2 There are no high energy lines in the emergency  
3 safeguard features room. The line that you refer to, the  
4 steam line to the Terry turbine is not normally  
5 pressurized. The valve that controls that turbine is  
6 located outside of the ESF, and that is consistent with  
7 regulatory criteria.

8 MR. MICHELSON: In the unlikely event that you  
9 start up the auxiliary feedwater turbine and there is water  
10 accumulated in the line or whatever and you break the line,  
11 what provisions do you have for isolation and how do you  
12 assure that it doesn't overpressurize the room before it  
13 isolates?

14 MR. DE BARBA: We're not analyzing for that  
15 condition.

16 MR. MICHELSON: I guess you're saying that it's  
17 not a postulated line-break within the room?

18 MR. DE BARBA: That's correct.

19 MR. MICHELSON: I'd have to ask the Staff if they  
20 agree that that is not a high energy line-break.

21 DR. KERR: Do you understand the question, Mr.  
22 Youngblood?

23 MR. YOUNGBLOOD: I understand the question.

24 MR. MICHELSON: You may want to answer for our  
25 full Committee; it's not necessarily now. But that's an

2 AGBmpb

1 open issue, as I would see it.

2 The next question deals with the diesel generator  
3 room itself. The fire protection is a water spray at the  
4 ceiling. I'd like a clarification: Is that water spray  
5 automatically or manually actuated?

6 MR. RONCAIOLI: I'd like to answer that  
7 question. My name is John Roncaioli and I am the supervisor  
8 of fire protection engineering.

9 That water system for both diesel rooms is a  
10 manually actuated sprinkler system.

11 MR. MICHELSON: You might want to have the --  
12 There are several documents I've read which say it's  
13 automatic. Has it been recently changed to manual?

14 MR. RONCAIOLI: It has been recently changed --

15 MR. MICHELSON: Okay.

16 MR. RONCAIOLI: -- based on discussions with the  
17 Staff and --

18 MR. MICHELSON: So my documentation probably just  
19 hasn't quite caught up.

20 MR. RONCAIOLI: Okay.

21 MR. MICHELSON: Okay. Thank you.

22 MR. EBERSOLE: May I ask, if you actuate that  
23 water system is it mandatory that the diesel engine  
24 generator be shut down, or do you continue to roll it?

25 MR. RONCAIOLI: To my knowledge it is not

2 AGBmpb

1 mandatory that we shut the diesel down.

2 MR. MICHELSON: That was going to be my next  
3 question.

4 MR. RONCAIOLI: Oh, okay.

5 MR. MICHELSON: On page 9-26 of the SER it says  
6 that the engines can run with the water spray activated.  
7 Have you provided environmental qualification of all the  
8 equipment necessary in that room to run the engines with  
9 water spray?

10 MR. RONCAIOLI: The exciter commutator --

11 MR. MICHELSON: I looked around the room. There  
12 are a lot of things that seem to be no more than  
13 drip-proof.

14 MR. RONCAIOLI: I can defer that question to our  
15 electrical engineering staff on environmental qualification  
16 of equipment. But let me just say as far --

17 MR. MICHELSON: I would be happy if you want to  
18 answer it at the full committee meeting instead. You may  
19 want to go back and look into it. It didn't seem at all  
20 obvious.

21 MR. RONCAIOLI: No, I think we can handle that  
22 today.

23 MR. MICHELSON: Okay.

24 MR. RONCAIOLI: Let me just say the water  
25 sprinkler system for the diesel rooms would be our last line

1 AGBmpb 1 of defense to be used.

2 We have a very sensitive detection system in that  
3 room that gives us early warning, and our position would be  
4 we would fight the fire manually to the extent possible, and  
5 that's using portable extinguishers and, of course, hose  
6 stations as a backup. And if we used hose stations it would  
7 be very, very selectively.

8 Even if the water suppression system -- if the  
9 decision was made to energize the water suppression system,  
10 you have to understand that the system is such designed that  
11 it's got fusible link heads designed into the system. And  
12 that means the fire would have effected those heads that  
13 have been exposed to the fire, and not the entire room would  
14 be exposed to that water suppression system.

15 MR. MICHELSON: I'm surprised they are fusible  
16 links since they are 40 feet from the fire locations at  
17 least.

18 MR. RONCAIOLI: Fusible links, yes, some are at  
19 ceiling elevations, but some branch lines do drop down where  
20 we can postulate the presence of a fuel oil.

21 MR. MICHELSON: Well, the SER makes the statement  
22 -- and I'll ask the Staff:

23 Why does the SER make the statement that you can  
24 run these unless that is the case? I assume you've looked  
25 into it and have determined that they can operate with the

1 AGBmpb 1 fire protection activated.

2 DR. KERR: Do you understand the question?

3 MS. DOOLITTLE: Yes.

4 DR. KERR: You may want to answer it at a later  
5 time.

6 MS. DOOLITTLE: Yes. May I do that?

7 MR. MICHELSON: I'd be quite happy to do that.

8 Okay.

9 Let me go on to the next question: The turbine  
10 building vent. Apparently the ventilation for the charging  
11 pump, component cooling water pump and some other pumps in  
12 the auxiliary building are vented through the turbine  
13 building ventilation vent. Is that -- First of all, is that  
14 your understanding?

15 Well, let me tell you my problem. On page 9-32  
16 of the Safety Evaluation Report it does state that they are  
17 vented through the turbine building vent. And my question  
18 is simply this:

19 Is that turbine building vent seismically  
20 qualified? And again, just giving me a reply at the full  
21 committee meeting would be fine. I would prefer it to be  
22 right the first time.

23 DR. KERR: Do you have the question?

24 MR. COUNCIL: No.

25 DR. KERR: I don't mean the answer, but do you

1 AGBmpb 1 have the question?

2 MR. COUNCIL: We have the question.

3 MR. MICHELSON: Okay.

4 DR. KERR: Okay.

5 MR. MICHELSON: And just look at the SER, and  
6 maybe the SER isn't correct; I don't know.

7 The next question: On our tour we asked about  
8 the CO-2 system since it appears not to be seismically  
9 qualified, but there was some question. So my first  
10 question is:

11 Is the CO-2 system seismically qualified as far  
12 as the actuation and control aspects of it? And if it is  
13 not seismically qualified, how do you assure yourself that  
14 you don't overpressurize certain compartments with CO-2  
15 because you've lost the control system on it?

16 MR. RONCAIOLI: Okay. The first part of that  
17 question is our CO-2 system is not seismically designed to  
18 category one type criteria. Our systems are designed to the  
19 standards of NFPA and manufacturers' recommendations.  
20 That's all our suppression systems.

21 Your second question is how do we assure  
22 ourselves that discharge of the CO-2 system may not  
23 overpressurize our areas, and the answer to that question is  
24 we have provided pressure relief mechanisms in accordance  
25 with NFPA-12 on CO-2 to assure ourselves that no

1 AGBmpb 1 overpressurization will result in any of the areas that CO-2  
2 is being applied to.

3 MR. MICHELSON: Not being familiar with the  
4 details of the referenced code, could you tell me, does this  
5 simply mean that if the CO-2 comes on and stays on until the  
6 supply is exhausted that you still do not overpressurize the  
7 rooms?

8 MR. RONCAIOLI: That's correct.

9 MR. MICHELSON: Okay.

10 In view of your introduction of CO-2 into the  
11 spreading room -- I think you do that -- if this condition  
12 should occur what is there to prevent the egress of CO-2  
13 into the control room and thus drown all the operators?

14 MR. RONCAIOLI: Okay. The cable -- Our  
15 particular cable spreading room has been designed almost to  
16 a vault type condition, meaning it's a well-sealed area.  
17 Most penetrations going from the cable spreading room happen  
18 to enter into the instrument rack room, which is adjacent to  
19 the control room, although some penetrations do come into  
20 the control room. And we have a penetration seal program  
21 that would assure us that all openings between any areas in  
22 the control rooms would be sealed.

23 MR. MICHELSON: Do they have the pressure  
24 capability compatible with the relief panel?

25 MR. RONCAIOLI: They have the pressure capability

1 AGBmpb 1 that well exceed the capacity of the pressure relief  
2 venting, that's correct.

3 MR. MICHELSON: Okay.

4 DR. KERR: Further questions, Mr. Michelson?

5 MR. MICHELSON: Yes, I have a couple more.

6 The service water, which is a pretty critical  
7 function since it supplies essentially all cooling water to  
8 critical systems, uses backwash strainers. It's my  
9 understanding that the backwash strainer is not provided  
10 with a bypass in the unlikely event that it becomes clogged  
11 and cannot be backwashed.

12 I would like just a brief explanation of what  
13 thought you gave to the kinds of contamination in the water  
14 supply that might clog the backwash strainer. Particularly  
15 I have in mind bio-fouling of the strainer from fish runs or  
16 from whatever kind of small material that can get in. And I  
17 would also like a confirmation that you are using  
18 eighth-inch mesh strainers in the backwash strainer.

19 MR. RONCAIOLI: Okay. We'll try to find someone  
20 that can address that question.

21 MR. NECCI: I'm Ray Necci, manager, Mechanical  
22 Systems Engineering for Northeast Utilities.

23 The Millstone 3 service water strainers have  
24 incorporated in them our experience at Millstone 1 and at  
25 Millstone 2. And in that we have taken into account the



AGBmpb 1 bio-fouling experience that we have had at those units. I  
2 am not sure of the size of the mesh right now. We can get  
3 back to you on that today.

4 The type of bio-fouling that we normally see  
5 includes the normal mussel shell build-up and particles.

6 MR. MICHELSON: Is there any form of bio-fouling  
7 that will get through the traveling screens, which I  
8 understood were something of the order of a quarter- to a  
9 half-inch mesh, so they pass right through them where they  
10 will hang up on the backwash strainer?

11 Are there no small minnow runs, that sort of  
12 thing that you have ever experienced, or could have -- This  
13 is a low probability event we're talking about, but it's a  
14 potential core melt event also if you lose all service  
15 water.

16 MR. NECCI: No. Our experience has been in terms  
17 of mackerel type fouling that --

18 MR. MICHELSON: Have you given serious  
19 consideration to this unlikely event and taken the  
20 precaution -- or have you thought about taking the  
21 precaution of bypassing the strainers -- what you would have  
22 to do now with piping; you can't do it when it happens.

23 MR. NECCI: The strainers themselves have a  
24 backwash arrangement with a motor operator which can be  
25 manually operated in case there were problems with the

1 AGBmpb 1 backwash --

2 MR. MICHELSON: No, but that only runs the water  
3 back to the lake; that doesn't run it into the cooling  
4 equipment where it is needed.

5 MR. NECCI: But that is to ensure that the filter  
6 remains clean.

7 MR. MICHELSON: Yes, but of course the  
8 contamination we're talking about hangs up on these mesh --  
9 this type of filter. As you are probably well aware, not  
10 everything backwashes off of it.

11 MR. NECCI: Yes.

12 MR. MICHELSON: Okay. I believe that's all the  
13 questions I have now until we get to the Staff's  
14 presentation on fire protection.

15 MR. EBERSOLE: One final thing brought up by  
16 Carl's questioning.

17 You told us yesterday your diesel engines had  
18 tertiary cooling loops. They didn't use saltwater; typical,  
19 of course. Let me ask:

20 In the shutdown or trip logic of the diesel  
21 engines which protective features do you retain even in the  
22 emergency mode? For instance, you don't operate on low oil  
23 pressure. What about injected water?

24 What do you retain as a protective feature in the  
25 diesel logic even though it's being used in an emergency

1 AGBmpb 1 function?

2 And why I ask that is I want to know how hard you  
3 try to save the diesels for the long term.

4 DR. KERR: Do you understand the question?

5 MR. COUNCIL: Bill Council.

6 Yes, we understand the question. We'll have that  
7 answer momentarily.

8 DR. KERR: Okay.

9 Are there other questions on this topic?

10 (No response.)

11 DR. KERR: Before we get to the next  
12 presentation, which is by the NRC Staff, with comments from  
13 the Applicant, I want to ask the subcommittee members to  
14 take note of some material distributed by Mr. Duraiswamy,  
15 which is a suggested agenda for the full committee meeting.

16 Please look that over and give us any comments by  
17 about noon as to the appropriateness of the material that  
18 has been included or additions that you would like to see  
19 made.

20 This brings us then to a presentation by NRC  
21 Staff.

22 Ms. Doolittle, I will turn things over to you.

23 The hand-outs associated with this presentation  
24 were distributed yesterday, so you may want to forage into  
25 your stack of materials to find it.

2 WRBpp

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. COUNCIL: Dr. Kerr, before the staff starts, may I answer a couple of those questions that were just asked?

DR. KERR: Yes, sir. If you don't mind, Ms. Doolittle?

MS. DOOLITTLE: Not at all.

MR. COUNCIL: You asked particle size max that would pass the strainer. It's .0625 inches.

MR. MICHELSON: 1/16th inch?

MR. COUNCIL: Basically, yes. Mr. Ebersole, you asked me about which trips on the diesel remain in in the accident mode. There are only three. One is generator differential, one is a loss of two out of three on our low lube oil pressure, and the last one is overspeed.

MR. EBERSOLE: So you would run it then, without jacket water?

MR. COUNCIL: Yes, sir.

MR. EBERSOLE: How long would it last?

MR. COUNCIL: I believe that number on startup of the diesels is three to five minutes at full load.

MR. EBERSOLE: You regard that as prudent in view of the long-term value of the diesel?

MR. COUNCIL: If we are in an actual emergency condition.

MR. EBERSOLE: Oh, a large LOCA?

3 WRBpp

1

MR. COUNCIL: A large LOCA.

2

MR. EBERSOLE: But now you know that's got a new perspective.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. COUNCIL: Yes, sir. I realize it has a new perspective. If in fact we are in a large LOCA which could be determined rapidly, we are going to let that diesel run.

MR. EBERSOLE: But now you know the rationale is on a large LOCA we need not consider it to be — if we would think rationally — coincident with an AC power loss from outside. Now does that change your logic?

MR. COUNCIL: Let me answer that question personally, if I may.

I would rely upon my operators to go outside the bounds of their operating procedures and shut that diesel down. However, at this point in time I would not be permitted to do so, as you are quite well aware, by regulations.

MR. EBERSOLE: Yes.

MR. COUNCIL: Now, in order to get us to the point where such action would be required, or could be effected without going outside the bounds of what we are presently licensed to do, we would have to have numerous discussions with staff, and prove to the staff, for instance, that our emergency based operating procedures and the training of the operators was sufficient that, in fact,

2 WRBpp

i we could shut it down without jeopardizing the plant.

2 MR. EBERSOLE: I think that might be an  
3 interesting topic to subject to sort of a mini-PRA. And I'm  
4 almost dead certain when you get done with it you'll have a  
5 trip on jacket water temperature.

6 With that I'll close my questions.

7 MR. MICHELSON: Do think it would be suitable,  
8 Jesse, for the staff to tell us what their view is on this  
9 subject at the full committee meeting?

10 MR. EBERSOLE: I would indeed.

11 MR. MICHELSON: I would like to hear it myself  
12 because it's a little unique and operator action is required  
13 very quickly to prevent the total loss of all onsite power.

14 DR. KERR: Do you understand the question,  
15 Mr. Youngblood?

16 MR. YOUNGBLOOD: Yes. We'll be prepared.

17 DR. KERR: Are there further questions?

18 (No response.)

19 DR. KERR: Thank you, Mr. Council.

20 Ms. Doolittle.

21 NRC STAFF PRESENTATIONMS.

22 MS. DOOLITTLE: My name is Elizabeth Doolittle.  
23 Other members of the NRC staff here today are Mr. Joe  
24 Youngblood, Chief Licensing Branch No. 1, Mr. Jeff Kimball  
25 from the Geo-Sciences Branch, Mr. David Terao from the

2 WRBpp

1 Mechanical Engineering Branch, Mr. John Knox from the Power  
2 Systems Branch, Mr. Ashok Thadnani, Chief, Reliability and  
3 Risk Assessment Branch, Mr. Art Buslik and Mr. Glenn Kelly,  
4 also from Reliability and Risk Assessment Brnch, Mr. Rich  
5 Barrett from Reactor Systems Branch, Mr. Neil Choksi from  
6 Structural and Geo-Technical Engineering Branch, and Mr. Pat  
7 Easley from Accident Evaluation Branch.

8 DR. KERR: Who's left back to keep the store?

9 MS. DOOLITTLE: Here again today from Region I  
10 are Mr. Ted Rebelowski, Senior Resident Inspector, Mr. Dave  
11 Lipinski, also Resident Inspector of Millstone 3. I believe  
12 Mr. E. B. McCabe and Mr. Ed Greenman are also here again  
13 today.

14 (Slide.)

15 During my presentation yesterday I gave a brief  
16 overview of the staff's review of the safety portion of the  
17 operating license application, and then I highlighted the  
18 major items which currently remain unresolved due to  
19 differing technical positions between the applicant and the  
20 staff. Today I would like to begin by highlighting some  
21 important plant features which the staff identified during  
22 its review, and then I plan to discuss some of the  
23 significant unresolved items in the SER.

24 (Slide.)

25 The staff identified and addressed these five key

2 WRBpp

1 features in its safety evaluation report. The applicant  
2 discussed information on four of these during its  
3 presentation yesterday. I don't plan to discuss them any  
4 further today, although I would like to note that Millstone  
5 3 also will use loop isolation valves.

6 MR. MICHELSON: Could I ask a question, since  
7 you're not going to discuss them? The safety grade cold  
8 shutdown discussion, is it your understanding that this can  
9 be achieved with single failure?

10 MS. DOOLITTLE: Yes.

11 MR. MICHELSON: And it will be performed by  
12 safety grade systems?

13 MS. DOOLITTLE: Yes.

14 MR. MICHELSON: I guess that means that you  
15 define RHR then as a safety grade system?

16 MS. DOOLITTLE: Yes.

17 MR. MICHELSON: Okay, thank you.

18 MS. DOOLITTLE: Regarding the loop isolation  
19 valves, there are two double-disk remotely-controlled motor-  
20 operated valves in each loop. The function of the loop  
21 isolation valves is to isolate the reactor coolant pump and  
22 steam generator in each loop for maintenance. The applicant  
23 expressed the intent to operate in the N-minus-1 mode in a  
24 letter dated April 9, 1984, but must submit the necessary  
25 core thermal hydraulic analysis for the staff review.



2 WRBpp

1                   As I mentioned during my presentation yesterday,  
2 there are 19 items which have not yet been resolved as the  
3 result of the staff's review. They are: internally  
4 generated missiles, diesel generators, protection against  
5 postulated pipe breaks outside containment, loading  
6 combination, design and construction of component supports,  
7 inservice testing of pumps and valves, equipment  
8 qualification, flow measurement capability, loose parts  
9 detection program, subcompartment analysis, mass and energy  
10 release analysis, volumetric inspection of class 2  
11 components, power operated relief valve and block valve  
12 fire protection, functional capability of AC and DC  
13 emergency lighting, shift technical advisor training program  
14 and operating experience for startup, emergency plan,  
15 limitation on overtime, and Q list.

16                   (Slide.)

17                   Although your handouts contain information on  
18 each item, I only plan to discuss the ones for which there  
19 are differing technical positions between the staff and the  
20 applicant.

21                   Open item number 2, diesel generators, contains  
22 two items related to diesel generators which the applicant  
23 and staff do not agree on. The applicant has not shown its  
24 diesel generator exhaust piping is protected from tornado-  
25 generated missiles. Therefore the staff cannot conclude

2 WRBpp

1 that the design complies with GDC 4. The applicant's  
2 position with regard to this item is that damage to the  
3 backup exhaust path from tornado missiles is  
4 incredible, therefore, the exhaust will not be degraded as a  
5 result of tornado missiles.

6 (Slide.)

7 The staff is currently reviewing information  
8 submitted by the applicant on August 20, 1984. The expected  
9 schedule for resolution is November, 1984.

10 Also, the applicant has not shown that the diesel  
11 generators will maintain the capability to meet the  
12 load acceptance test requirements after 24 hours of  
13 operation at no load or light load. This does not meet the  
14 criteria of Section 6.4.2 of IEEE Standard 387, 1977.

15 In order to demonstrate this capability the staff  
16 required the applicant to either provide the results of a  
17 previously run weather watch test report showing closeup  
18 photographs of the cylinders, rings, and valves in order to  
19 observe accumulation of fuel oil and lube oil on these  
20 parts, or perform an onsite test by operating for 24 hours  
21 at no load then loading within 60 seconds to full load.

22 The applicant's weather watch test results did  
23 not contain the necessary information. His position now is  
24 that he does not plan to run the onsite test because it  
25 could either damage or cause excessive wear to the diesel.

3 WRBpp

1 The schedule for resolution of this item has not yet been  
2 determined.

3 DR. KERR: What is the staff's view of the  
4 applicant's response, that you don't care whether it damages  
5 the diesel or not or that you have to follow regulations no  
6 matter what? Or none of the above?

7 MS. DOOLITTLE: I'd like to ask Mr. John Knox  
8 from the NRC staff to respond to that.

9 MR. KNOX: Basically, we have not reviewed the  
10 item as yet. However, we will be sympathetic to the  
11 possibility that it will cause damage to the diesel  
12 generators by overtesting.

13 MR. EBERSOLE: May I ask before you sit down --  
14 this can get to be a sticky business. To what extent is  
15 this unique here? Is this requirement placed on all current  
16 diesel packages at our nuclear plants, that they execute a  
17 long term no-load run at 24 hours and then crash out full  
18 load?

19 MR. KNOX: Other vendors have done a similar type  
20 test. The vendor for PMD diesels has run a test for 7 days  
21 at no load and then loaded the diesel generator up to the  
22 full load.

23 MR. EBERSOLE: Is the problem basically  
24 accumulation in the exhaust systems?

25 MR. KNOX: I believe so, yes.

2 WRBpp 1

ME. KNOX: I believe so, yes.

2

MR. EBERSOLE: Can't you just bore some holes in them and fix it? Is it a matter of drainage of byproducts of combustion?

5

DR. KERR: Mr. Ebersole, let me suggest that we shouldn't solve that generic problem at this time.

7

MR. EBERSOLE: All right. I just want to know -- When we talk about it, we'll ultimately be interested in how well the other plants pass this test. It can be a sticky test depending on the design.

11

MR. MICHELSON: Let me ask a little different question then. What's unique about this engine that seems to indicate it might not do so well on this test and therefore might damage the equipment?

15

MR. EBERSOLE: I don't believe there's any real indication that that's the case.

17

MR. MICHELSON: I see. It's just a reluctance on the part of the utility then to take a chance?

19

MR. KNOX: That's right.

20

MR. MICHELSON: Thank you.

21

DR. KERR: Thank you, Mr. Knox. Please continue.

22

(Slide.)

23

MS. DOOLITTLE: There are two significant aspects of the component support item which remain open due to differing technical positions. They are load and load

25

3 WRBpp

1 combinations and stress limits.

2 For open item number 4, the applicant has not  
3 included LOCA loads in the evaluation of the faulted  
4 condition limits for ASME code class 1, 2, and 3 balance of  
5 plant piping and supports. The applicant has not addressed  
6 how the guidelines of NUREG 0609 "asymmetric blowdown loads  
7 on PWR primary systems" have been satisfied. Staff cannot  
8 conclude that the design meets the requirements of GDC 4.

9 MR. OKRENT: Don't run away from that. There are  
10 two items I have here: one is protection of postulated pipe  
11 breaks outside containment, and then I have another one:  
12 loading combinations. And I must confess I'm not sure  
13 whether item four is intended to apply to primary system  
14 piping or to lots more piping. So first will you answer  
15 that question?

16 MR. TERAQ: I'm with the Mechanical Engineering  
17 Branch.

18 DR. KERR: I can't hear you.

19 MR. TERAQ: With respect to the first item which  
20 is LOCA loads, basically in our review of the FSAR what we  
21 found is in their load combination tables there was an  
22 absence of the LOCA loads in the piping and pipe support  
23 area. So we had several discussions with the applicant  
24 regarding this. And it appears that their response  
25 indicates that they will ask for an exemption to GDC 4 by

2 WRBpp

1 using the leak before break approach.

2 Now the staff position, of course, has been  
3 established in their February 1, 1984 generic letter 8404.  
4 And our disagreement with the applicant at this time is  
5 really with the extent of the implementation of the leak  
6 before break approach. Basically, what the staff believes  
7 at this time is the leak before break approach can be used  
8 for the elimination of large pipe whip restraints and jet  
9 shields and also for the elimination of the asymmetric  
10 blowdown loads.

11 MR. OKRENT: In which piping systems?

12 MR. TERAQ: That's for breaks in the reactor  
13 coolant loop.

14 MR. OKRENT: All right.

15 MR. TERAQ: Now what the applicant is proposing  
16 is that -- well, the staff position there is that the margin  
17 should not change in any component supports and piping as  
18 the result of implementing this leak before break approach.  
19 The applicant has analyzed its large restraints on the  
20 reactor coolant loop for the original WCAP-8082 pipe  
21 breaks. But for the balance of the plant, the applicant is  
22 intending to extend the leak before break approach to the  
23 design of those piping and pipe supports, not the reactor  
24 coolant loop but for the balance of plant.

25 MR. OKRENT: And what is the staff position, and

4 WRBpp

1 does it have criteria?

2 MR. TERAQ: The staff position at this time is  
3 being developed in NUREG 1061. Right now it's in the second  
4 draft. But the position the staff is now taking is that for  
5 plants with OL -- operating license and construction permits  
6 that component and piping supports should maintain the same  
7 margin that currently control their design for structural  
8 integrity. The applicant is proposing to, instead of using  
9 the WCAP-8082 breaks for those support designs, they are  
10 intending to use a smaller worst case branch line break and  
11 that is what the staff disagrees with at this time.

12 MR. OKRENT: How will the ACRS know if it happens  
13 to write a letter on operation of this plant what it is that  
14 it's approving with regard to the treatment of piping?

15 MR. TERAQ: Well, we're having difficulty at this  
16 time because the applicant has not formally submitted its  
17 exemption from GDC 4.

18 MR. OKRENT: But I don't know what the staff's  
19 position is, do I?

20 MR. TERAQ: It has been established in generic  
21 letter 8404.

22 MR. OKRENT: It's not going to change on this  
23 plant?

24 MR. TERAQ: Not at this time.

25 DR. KERR: May I just clarify: When you talk

2 WRBpp

1 about violation or lack of violation of GDC 4, these other  
2 documents are interpretations of GDC 4? The only thing I've  
3 heard mentioned that was a regulation is GDC 4. These other  
4 documents are guidance or Reg Guides or whatever.  
5 Apparently there are varying interpretations of GDC 4.

6 MR. TERAQ: That's correct.

7 MR. KERR: So the disagreement is over the  
8 interpretation and not over the general idea that is  
9 contained in GDC 4? Is that it?

10 MR. TERAQ: That's correct.

11 MR. OKRENT: Well, you could say the same thing  
12 about fire protection, you know.

13 DR. KERR: I would indeed say the same thing  
14 about fire protection.

15 MR. OKRENT: That there should be protection  
16 against fires.

17 DR. KERR: But there's also a regulation,  
18 Appendix — whatever it is — R, Fire Protection.

19 MR. OKRENT: But until that, what we had was the  
20 GDC.

21 Are you able to tell me what the position is in  
22 the Federal Republic of Germany with regard to — for which  
23 plants they allow a departure from a full break, and then  
24 when they allow this, what they insist upon with regard to  
25 quality of piping, what they insist upon with regard to



2 WRBpp

1 protection, for example, with regard to environmental  
2 effects, what they insist upon with regard to separation; so  
3 that were there to be a rupture, you might or might not  
4 affect redundant systems, and so forth and so on? Does the  
5 staff have that information summarized succinctly?

6 MR. TERAQ: Not at this time. I do not have that  
7 answer for you.

8 MR. OKRENT: Well, I must say at the present time  
9 I find I don't know what the staff position is. I hear that  
10 there is some position today but my experience is there  
11 could be another position tomorrow. I don't know what the  
12 basis for the staff position is, whatever it is. I don't  
13 know how it relates to various kinds of, what I'll call  
14 risk considerations. And if you think about what the  
15 Germans are doing, as I understand it, there is in fact a  
16 broader picture than just saying we'll have a certain kind  
17 of criterion with regard to the size break we'll design for  
18 primary system piping.

19 There are other things that are being protected  
20 against, and so forth, and its in a context of a certain  
21 plant layout and so forth, as I understand it.

22 I'd like to see a comprehensive thoughtful  
23 presentation by the staff as to just when they think it's  
24 suitable to allow a departure from traditional approach of  
25 the past and why. And I object to having this done on an

3 WRBpp

1 ad hoc basis, because one applicant proposes one thing,  
2 another applicant proposes another thing without having a  
3 reasoned approach.

4 In fact, at the present time on this position I  
5 find myself unable to say I know what the position of the  
6 staff is eventually going to be, and therefore at the  
7 present time I would have to say I am unable to reach a  
8 conclusion on whether or not this plant should be operating  
9 or not, because I don't know what's going to happen here.

10 MR. TERAQ: We certainly agree that our position  
11 is more conservative than the applicant's.

12 DR. OKRENT: Today. But I don't know what it  
13 will be in 3 months or 6 months.

14 MR. TERAQ: Well, at this time the overall leak  
15 before break approach we believe should be implemented  
16 conservatively, in keeping with the commission's defense in  
17 depth principle. So in that sense all we're saying is that  
18 we did not want to see a reduction in the margin in  
19 piping supports due to the elimination of LOCA loads or a  
20 design double-ended guillotine break LOCA load.

21 MR. OKRENT: I want you to know I did not say we  
22 shouldn't, in various circumstances, no longer design  
23 against double ended breaks for certain aspects of the  
24 problem. I'd like to see a reasoned -- fully developed  
25 approach that gives reasons for each of the various aspects

2 WRBpp

1 that the staff thinks is okay and when and why. You know,  
2 I could envision something being okay for very good new  
3 piping and not okay for piping of unknown quality, et  
4 cetera, et cetera. And I must confess I can't tell where  
5 the staff is drifting.

6 MR. TERAQ: I guess I can only say at this time  
7 that we are trying to develop our position in NUREG 1061  
8 which is being developed by the NRC's Piping Review  
9 Committee. This is one of the four subtasks, and this one  
10 subtask is the evaluation of potential for pipe breaks. So  
11 this is being developed at this time. I'm only addressing  
12 the current staff position based on this second draft.

13 MR. BENDER: Could I ask for a little  
14 clarification of the present quantitative position for the  
15 primary loop setting aside the branch connections. The  
16 staff is willing to back away from a double ended pipe break  
17 requirement, to what? How big a break is the staff thinking  
18 about as being a basis for design?

19 MR. HERNAN: We are scheduled to make a  
20 presentation to the committee in October on the subject of  
21 pipe cracks.

22 MR. OKRENT: Should we defer review of Millstone  
23 until then?

24 MR. HERNAN: I guess it's my understanding that  
25 you were looking for a presentation from the staff which

2 WRBpp

1 would not be necessarily part of the Millstone licensing.

2 MR. OKRENT: But on Millstone I can't tell what  
3 the eventual design basis is intended with regard to not  
4 only primary system piping but other piping, and why.

5 You know, I might be willing to buy an approach,  
6 but I would like to see what it is and understand the logic  
7 for it.

8 I hope I'm not being unreasonable.

9 MR. HERNAN: I think I can speak for the NRR  
10 staff. We will try to present our position as it stands at  
11 the full committee meeting next week in connection with  
12 Millstone-3.

13 DR. KERR: Is it possible to respond to  
14 Mr. Bender's question other than the response you just made?

15 Mr. Bender, would you be willing to repeat your  
16 question?

17 MR. BENDER: I've been aware for some time that  
18 the staff has accepted probabilistic assessment of the  
19 primary loop failure criteria for Westinghouse plants, the  
20 understanding being that the double ended pipe break is  
21 probably beyond the limits which ought to be considered.  
22 But in backing away from it, it was unclear as to where you  
23 would back -- to what position you would move to. Some  
24 other break size might be controlling? But what is it?

25 MR. OKRENT: Let me go beyond that. As I

2 WRBpp

1 understand the German position, from a very rapid perusal,  
2 they, I think, say, 10 percent of the area so far as jet  
3 force and this sort of thing — full break so far as  
4 containment loading or environmental effects. I think they  
5 also have qualifications that whatever the break it doesn't  
6 knock out redundant systems that are vital for safe  
7 shutdown.

8 Well, you can start seeing a logic in a position  
9 like that. I may have misquoted them. I read it in a hurry  
10 but at least there's a package of some sort there. I  
11 haven't seen that element of a package in what I've heard  
12 from the staff up to now; okay?

13 MR. YOUNGBLOOD: We're only in the process of  
14 issuing our first exemption on this right now.

15 MR. OKRENT: But you should have some kind of a  
16 broad perspective on what it is you're doing and why.

17 MR. YOUNGBLOOD: I believe they do. I can't give  
18 it to you personally.

19 MR. OKRENT: I would like to know who "they" is.

20 MR. TERAQ: That's the Piping Review Committee.

21 MR. OKRENT: The Piping Review Committee in fact  
22 is a committee of people partly from the NRC and partly  
23 consultants and so forth. And what I have read in the past  
24 is interesting but I don't think it has given me the kind of  
25 perspective I'm talking about. If it is there, please send

2 WRBpp

1 the document to Dr. Savio and indicate the pages.

2 MR. BENDER: Just a point on the question I  
3 asked: I am persuaded that if the staff can rationalize  
4 reductions in the double break criteria for the large pipes  
5 they can have some criterion also for the connected pipe.  
6 But there has to be some logic to it. I don't see why it  
7 should limit its position only to the large piping. It  
8 seems to me that if you are going to make a review for this  
9 plant that you ought to look at the whole problem at one  
10 time, so you don't have a set of fragmented positions. And  
11 I would hope that you would give all of that some thought  
12 not just limit it to the primary circuitry.

13 MR. MICHELSON: I have a follow-up question in  
14 the same area. The environmental qualification of equipment  
15 outside of containment is based on certain postulated  
16 failures of pressure boundaries, high and low energy  
17 pressure boundaries. Is that approach in any way being  
18 modified now by these new thoughts concerning how you will  
19 calculate loadings on supports outside of containment, and  
20 is this a part of the overall plan? In postulating new  
21 break sizes are you going to change environmental conditions  
22 at the same time?

23 MR. TERAQ: No, sir. The staff leak before break  
24 approach is not to be used for setting design requirements  
25 for four things. One is the ECCS. Second is for

2 WRBpp

1 containment sizing. Third is other engineered safety  
2 features. And the fourth is the environmental qualification  
3 of equipment.

4 MR. MICHELSON: So you're still using the old  
5 branch positions concerning that?

6 MR. TERAQ: Yes.

7 MR. MICHELSON: Then keep that in mind when you  
8 answer my question on auxiliary feedwater at the full  
9 committee meeting.

10 MR. TERAQ: Yes.

11 MR. MICHELSON: Thank you.

12 DR. KERR: Mr. Ebersole?

13 MR. EBERSOLE: When you clarify this state of  
14 flux you're apparently in, I wish you'd put in there for  
15 final clarification the degree to which you accept damage to  
16 mitigating systems. A case in point: would you accept  
17 damage to mitigating systems as a result of these pipe  
18 breaks which leaves only a single functional train available  
19 to meet and mitigate the consequence? Or would you require  
20 post-accident redundancy in the mechanical, electrical, and  
21 all other contexts? And when you do that, you better be  
22 careful because there's a very muddy situation out in the  
23 field in which there's apparently no real consistent  
24 standard as to what degree of damage is imposed on the  
25 mitigative functions.

2 WRBpp 1

MR. TERAQ: As the result of implementing leak before break?

MR. EBERSOLE: As a result of — well, the integrating — in answer to whatever you do here, whether it's — you have moderate accidents with leak for before break, or however large they may be. The important thing is to define your acceptable degree of damage to mitigative functions.

DR. KERR: Mr. Mark?

MR. MARK: I find myself just not knowing the situation. Asymmetric blowdown loads are mentioned here. Is there something unique about this steam supply system which has not been discussed in connection with cylinder installations previously insettled there?

MR. TERAQ: There is one major area that is different from other Westinghouse plants, and that was the division of responsibility of the reactor coolant loop analysis. Apparently with the Millstone-3 plant the analysis was performed by Stone & Webster and not by Westinghouse. That was what partly originated our question, because the load combinations which eliminated the LOCA loads are found in the balance of plant piping which also included the reactor coolant loop.

DR. KERR: So that the plants aren't different, but the analysis was; is that it?



2 WRBpp

1 MR. TERAQ: That's correct.

2 MR. MARK: Well, if an identical plant had been  
3 analyzed by Westinghouse, would that not have answered the  
4 question, assuming the analysis was satisfactory?

5 MR. TERAQ: I'm not sure what the hypothetical  
6 question was again.

7 MR. MARK: I'm not hearing you.

8 MR. TERAQ: I'm not sure what your question was.

9 MR. MARK: I'm wondering why, when this question  
10 has been looked at with respect to plants quite similar, it  
11 is still a question.

12 DR. OKRENT: If I may interject: The committee  
13 talked about this for primary systems for Westinghouse.  
14 There are questions now of going beyond the primary system  
15 per se; and, if you do that, how, with what criteria, and so  
16 forth? This needs to be thought through.

17 MR. MARK: I would be in favor of that.

18 DR. KERR: Mr. Bender?

19 MR. BENDER: I wanted to ask the applicant --

20 DR. KERR: Will you get close to the microphone,  
21 please?

22 MR. BENDER: I wanted to ask the applicant: I  
23 presume that since this subject is a fairly recent one, for  
24 a long time you must have been designing on the basis of a  
25 double ended pipe break requirement for the primary loop.

2 WRBpp

1 What's the impact of this particular difference of view on  
2 the status of the plant? What are you planning to do if you  
3 get the approval to use these criteria?

4 MR. DeBARBRA: You're correct. We have included  
5 design of double ended breaks for many years. The impact of  
6 this exemption would be, essentially, to not complete the  
7 installation of the high energy pipe whip restraints on the  
8 primary coolant loops which for reasons -- for many reasons  
9 -- we think do not add a margin of safety to the plant. In  
10 fact, they do things like make inspections difficult. So we  
11 think there are very good reasons to not install those pipe  
12 whip restraints.

13 I just would like to take a moment to clarify a  
14 few points here. That is, the exemption that we're applying  
15 for to GDC 4 is only for the main loop pipe breaks. The  
16 basis for those exemptions specifically is WCAP-9558 which  
17 is the generic resolution of issue A2 which is the  
18 asymmetric blowdown LOCA loads. Additionally we have a  
19 Millstone 3 specific report, WCAP 10587, which looks in  
20 specific detail at the materials employed on Millstone 3 to  
21 justify, in fact, that this double ended pipe break is not  
22 likely to occur.

23 We are still in discussion with NRC staff  
24 relative to how we specifically treat branch lines. I think  
25 there are still some misunderstandings between ourselves and

2 WRBpp

1 them as to what precisely has been done on our unit. I  
2 don't think that we are actually that far away from them.  
3 Our position has been that we do postulate double ended  
4 failures in our branch lines, and that we will include those  
5 loads on all our supports.

6 There seem to be some misunderstanding relative  
7 to how we, in fact -- should we, in fact include some sort  
8 of break in our main coolant loop from a pipe load  
9 standpoint.

10 I would also just like to mention a little bit  
11 about the German criteria. We have had discussions with  
12 Dr. Karl Kousma from NPA who has been probably the outspoken  
13 person in the Federal Republic of Germany on pipe break  
14 criteria. And as you know, the Germans use much different  
15 material than we use here in the States. And that can be  
16 debated and has been for many, many years. They use Type  
17 347, we use something that we believe is much more ductile.

18 For those reasons we believe that the criteria of  
19 eliminating the pipe breaks is appropriate. If we were to  
20 use Type 347 we may not believe that to be true.

21 DR. KERR: Thank you, sir. I take it you do  
22 think you understand the staff position even though  
23 Dr. Okrent doesn't?

24 (Laughter.)

25 DR. KERR: Don't answer.

2 WRBpp

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DR. KERR: Thank you.

Are there other questions?

MR. EBERSOLE: One more.

MR. OKRENT: If the staff could define its position, I'd be quite happy to hear it.

MR. EBERSOLE: A point of clarification on the damage to mitigative apparatus: On a deterministic basis we put in duplicate trains, redundant trains, on the grounds we want to prevent the consequences of random failure to respond.

There is a substantial anomaly here in that having done that we then permit in the various designs in many cases for the consequences of an accident to wipe out 50 percent of our mitigative capability and destroy the thesis that we have in fact got protection against random failure to respond. It's this sort of thing I would like to see addresses in these mechanical piping failures.

What is the staff position? What do they desire? Are they satisfied with responding to one of these serious accidents with one functional train because the other was carried away by the very accident that it was supposed to mitigate?

MR. TERAO: Are you speaking in general or --

MR. EBERSOLE: In general.

MR. TERAO: I don't believe I can answer that in

2 WRBpp 1 general.

2 DR. KERR: I don't think he expects an answer  
3 now. He's suggesting that this become part of the  
4 consideration in the resolution of the question.

5 MR. EBERSOLE: That's correct.

6 MR. TERAQ: I will relay your concerns.

7 MR. OKRENT: While we're talking about approaches  
8 proposed or taken in other countries, I don't recall ever  
9 having seen from the staff a detailed evaluation and point-  
10 by-point disposition of the technical comments made  
11 concerning measures that should be taken in order to assure  
12 pressure vessel integrity. Does such document exist? The  
13 British have been very interested in the subject.

14 MR. TERAQ: I think you're getting into an area  
15 — I have reviewed the NRC piping document relative to the  
16 Millstone 3 criteria, and I believe the question you are  
17 getting to — the depth of the questions you are getting  
18 into should be more appropriately responded to by either  
19 representatives from the Piping Review Committee who are  
20 developing the pipe rate criteria at this time.

21 DR. KERR: Can you relay the question?

22 MR. TERAQ: Yes.

23 DR. OKRENT: Again, I was in this specific  
24 question, talking about pressure vessels; okay?

25 DR. KERR: This issue is obviously so popular

2 WRBpp

1 that I'm reluctant to leave it. Are there other questions?

2 (No response.)

3 DR. KERR: I guess we must go on then.

4 Ms. Doolittle?

5 (Slide.)

6 MS. DOOLITTLE: Again, regarding open item number  
7 5, the applicant has not shown that he has an appropriate or  
8 consistent code or standard for ASME code class 1, 2, and 3  
9 components of core construction and has not considered LOCA  
10 dynamic loads in the component support design.

11 The staff cannot conclude that the design meets  
12 the requirements of GDC 1, 2, and 4. The staff plans to  
13 perform an audit to review the program the applicant is using  
14 to design and construct component support.

15 (Slide.)

16 Another significant technical open item is fire  
17 protection in the cable spreading room. The primary means  
18 of fire protection in the cable spreading room is a total  
19 flooding automatic carbon dioxide system. The applicant  
20 does not plan to provide a fixed water suppression system as  
21 a backup to the carbon dioxide system. Therefore the staff  
22 cannot conclude that the guidelines of branch technical  
23 position CMEB 9.51, Section C7C will be met.

24 MR. MICHELSON: We're not going to pass this up  
25 yet, are we? Is that the end of your discussion on fire

3 WRBpp

1 protection?

2 MS. DOOLITTLE: Yes.

3 MR. MICHELSON: I've a couple of questions. One  
4 is, I will expect to hear an answer from the licensee  
5 either now or later. That deals with why CO2 is thought to  
6 be sufficiently effective for electrical fires in these  
7 areas. But the question for you is, if you put water  
8 suppression into these areas, particularly the spreading  
9 room area, why haven't you considered the switch gear area  
10 which has about as much cable spreading as the spreading  
11 room itself? And why is a fire in there okay to be  
12 addressed by CO2. Further, what do you think is going to  
13 happen to the suppression water in the spreading room after  
14 it reaches the floor or wherever?

15 MS. DOOLITTLE: Regarding those last two items,  
16 I'd like to postpone discussion of that to the full  
17 committee. At that time, I'll have someone available.

18 MR. MICHELSON: I think it will require a good  
19 explanation on how you think that it can be handled safely.  
20 I am neither pro or con. I'm just trying to figure this  
21 thing out.

22 I would also like to hear a good discussion from  
23 the licensee as to why he thinks CO2 is all you need. Maybe  
24 he would just as soon do that at the full committee also.  
25 If he's prepared now, that's fine.

2 WRBpp

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. COUNCIL: We are prepared to answer that question now. Mr. John Roncaioli, our fire protection group.

MR. MICHELSON: And I assume his reply will address the situation at Browns Ferry and why it didn't work there.

DR. KERR: Let me suggest there is on the schedule a response from the applicant. Why don't we let Ms. Doolittle continue?

MR. MICHELSON: As I understand it now, the staff will make its reply at the full committee meeting.

MS. DOOLITTLE: Yes.

MR. MICHELSON: Thank you.

MS. DOOLITTLE: The final significant open item that staff has identified is open item number 18, Limitation on Overtime. The applicant has not described a policy governing the limitation on working hours for other than on-shift licensed personnel who perform safety related functions.

The staff cannot conclude the guidelines of NUREG 0737 will be met. The schedule for resolution of this item has not yet been determined.



1 AGBmpb

1

MR. BENDER: Can I ask one question about that,

2

sir?

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Do you have a — Does the Staff have an understanding regarding the other two plants at Millstone? It seems to me that that particular matter is one which should be consistent between all three units.

MR. YOUNGBLOOD: I think that is being worked by the Staff at the present time.

MS. DOOLITTLE: It is also unresolved, I believe, on the other two plants as well. I think the Applicant is treating it the same way for all three of their units.

MR. BENDER: So it's a generic issue and not necessarily a Millstone 3 issue?

MS. DOOLITTLE: Generic to Northeast Utilities, yes.

(Laughter.)

MS. DOOLITTLE: I would also like to point out at this time that the Applicant discussed a little bit about their STA yesterday.

(Slide.)

And I would like to point out that the Staff still maintains the STA is an open item in the SER.

DR. KERR: What is the problem?

MS. DOOLITTLE: The Applicant does not plan to have an STA.

1 AGBmpb

1 DR. REMICK: I'd like to have the Applicant in  
2 response reply to that. I assume that they are under the  
3 assumption that the Commission's policy statement will be  
4 promulgated eventually, and I would like to have them  
5 indicate why at this time they do not plan to have — excuse  
6 me, they plan to have STAs; I assume the question is whether  
7 they are separate STAs or STAs that are a part of the  
8 operating staff, is that correct?

9 MS. DOOLITTLE: Yes.

10 DR. REMICK: And I would like to have the  
11 Applicant explain their position on that. I think I  
12 understand, but I'm not sure.

13 And suppose the policy statement was not  
14 promulgated; I assume that the Applicant then would plan to  
15 have separate STAs. So I would like to have that  
16 clarified. And that can come at the proper response time,  
17 not necessarily at this moment.

18 DR. KERR: Please continue, Ms. Doolittle.

19 (Slide.)

20 MS. DOOLITTLE: As a result of its review the  
21 Staff identified 70 items for which the technical resolution  
22 is clear, but the Applicant has not submitted certain  
23 confirmatory information. If this information does not  
24 confirm the Staff's preliminary conclusions the item will be  
25 treated as open and the Staff will address its resolution

1 AGBmpb 1 in the supplement to the SER.

2 The most significant of these items is  
3 confirmatory item number one, seismic capability beyond  
4 design basis. Since this information was discussed by the  
5 Applicant yesterday I will not discuss it further at this  
6 time.

7 DR. OKRENT: I have a question.

8 I'm not quite sure what the Staff believes is an  
9 acceptable set of results, or by what criteria the Staff  
10 will judge that things are okay. All I just see is the  
11 words "seismic capability beyond design basis." Can you  
12 help me?

13 MS. DOOLITTLE: I'd like to ask Jeff Kimball to  
14 respond.

15 MR. KIMBALL: I am Jeff Kimball, seismologist for  
16 the Staff.

17 This confirmatory issue is set up with the New  
18 Brunswick earthquake in mind. So the goal of the issue had  
19 accelerations for the high confidence low probability  
20 estimates and for looking at also these accelerations in  
21 terms of their contribution to core melt frequency or how  
22 much they impact consequences. And that acceleration is  
23 about .25g.

24 So we have that criteria in mind when we're  
25 looking at what the Applicant provides us.

1 AGBmpb

1 DR. OKRENT: If we can discuss the matter a  
2 little bit, as you are well aware, the ACRS on a variety of  
3 recent operating license reviews has asked sometimes is  
4 enough known to know that the seismic contribution to risk  
5 is not likely to be a dominant or a more significant one.  
6 It is not clear to me that answer would come out of what you  
7 just said. It would contribute to this but it wouldn't  
8 answer it.

9 Sometimes the ACRS has asked that Applicants look  
10 with special care at all equipment needed to accomplish safe  
11 shutdown, heat removal, given a fairly severe earthquake.

12 MR. KIMBALL: I think some of that we'll be  
13 getting into in the PSS.

14 The confirmatory issue specifically had in mind,  
15 though, what information is available in the PSS for  
16 accelerations that you would associate with an earthquake  
17 the size of the New Brunswick earthquake; not necessarily  
18 the bottom line number of core melt frequency associated  
19 with the seismic initiating events.

20 DR. OKRENT: Well, I'm not quite sure why you  
21 refer so frequently to the PSS since it is sort of an  
22 unreviewed document; in part it is a document in which your  
23 own reviewers have differences.

24 MR. KIMBALL: I think some of those issues will  
25 be clarified later. I don't think the Staff views it as an

1 AGBmpb

1 unreviewed document.

2 DR. OKRENT: Well, but you're referring to it in  
3 your discussion. So I'm just not sure.

4 MR. KIMBALL: Specifically the confirmatory issue  
5 is to assure the Staff that accelerations down lower than  
6 about .25g are not significant contributors to risk using  
7 available information in the PSS.

8 DR. OKRENT: If I can continue just with one more  
9 comment, it's my impression that except for oversights and  
10 deeds most of the seismic portions of PRAs where they have  
11 been done have suggested that the contributions start coming  
12 at something above twice the SSE. So you're looking in an  
13 area where prior experience, to the extent it's valid, says  
14 you shouldn't expect to find very much anyway unless they  
15 really have a big boo-boo.

16 MR. KIMBALL: I think the primary difference  
17 here, though, is that the documentation of that specific  
18 fact is far more comprehensive. The amount of material that  
19 we will receive in terms of conditional probability of  
20 failure for fragilities, in terms of actually providing  
21 tables of core melt breakdown for different acceleration  
22 ranges is far more extensive than has been documented for  
23 past PRAs, for example. I don't know of any past PRAs that  
24 have gone through the exercise of calculating the high  
25 confidence of low probability of failure for all the key

1 structures and equipment, for example. The consultant to  
2 the Applicant in this instance is documenting those numbers  
3 for us to look at.

4 DR. OKRENT: I must say, I'm a little bit  
5 chagrined at this big emphasis you're putting on the 95  
6 percent/5 percent, or whatever it is, corner on a topic  
7 where one of the big problems is to know what the  
8 uncertainties are. And you're acting like you're able to  
9 define something in the same way other people on the Staff  
10 are acting like they know how to calculate cost-benefit and  
11 say, yes, no.

12 Well, I'll leave it at that for today.

13 DR. KERR: Is that a promise?

14 (Laughter.)

15 DR. OKRENT: Oh, excuse me — for this minute.

16 (Laughter.)

17 DR. KERR: Please continue.

18 (Slide.)

19 MS. DOOLITTLE: Finally, the Staff identified  
20 seven license conditions as a result of its review. Item  
21 one, instrumentation for monitoring post-accident  
22 conditions, two, sediment control during fuel oil storage  
23 tank refill, and, seven, blockage of access hatch in diesel  
24 generator exhaust system, will be resolved prior to issuance  
25 of the operating license.

1                   Items two, heavy load handling, three,  
2 post-accident sampling system, and, five, moisture in the  
3 air start system, will be included in the license when it is  
4 issued.

5                   MR. MICHELSON: Could I ask a brief question on  
6 the moisture in the air start system?

7                   As I understand it, you want to ask the Licensee  
8 to do a certain amount of purging, I guess, or whatever,  
9 until such time as they can get their system in a clean  
10 condition and keep it that way, is that correct?

11                   MS. DOOLITTLE: Could you repeat that? I can't  
12 hear.

13                   MR. MICHELSON: Well, okay. Let me ask the  
14 question differently:

15                   What's the problem with moisture in the air start  
16 system?

17                   MS. DOOLITTLE: I'd like to refer to -- I'd like  
18 to postpone that discussion.

19                   MR. MICHELSON: Okay.

20                   MS. DOOLITTLE: I'm not able to answer that.

21                   MR. MICHELSON: In particular, when you give the  
22 reply at the full committee meeting, I would like to have  
23 addressed whether or not damage has already been done to the  
24 air start systems and how the precautions that you are  
25 perhaps going to ask for will alleviate what has already

1   AGBmpb   1    been damaged, if anything.

2                    Thank you.

3                    DR. KERR:  What is the basis for requesting that  
4   there be blowdown on each shift?  Is that a cost-benefit  
5   analysis result?

6                    MS. DOOLITTLE:  I don't know.  I'll have to find  
7   out.

8                    DR. KERR:  Okay, thank you.

9                    Please continue.

10                   (Slide.)

11                   MS. DOOLITTLE:  This concludes my presentation on  
12   SER unresolved items.

13                   DR. KERR:  Okay.  Let me ask about this number  
14   seven.

15                    Is the concern there that one has an ice storm  
16   simultaneously with or within a day or two of a severe ice  
17   storm?

18                    MS. DOOLITTLE:  You mean a tornado?

19                    DR. KERR:  Tornado.  Did I say...?

20                    So far as I could tell from reading the SER that  
21   was the case.  And since I didn't believe that that could be  
22   the case I'm asking the question.

23                    MR. YOUNGBLOOD:  I think there's also some  
24   concern about the missile protection as well, even without  
25   the ice storm.  But —



1 AGBmpb

1 DR. KERR: No, but the solution I thought  
2 proposed by the Staff -- I mean by the Applicant to -- the  
3 alternative to providing missile protection was to, you  
4 know, open a hatch. And so far as I could understand -- and  
5 correct me -- the NRC said, 'Well, okay, but if you do then  
6 you might have a tornado and an ice storm at the same time  
7 and freeze the hatch shut.'

8 So there is considered to be a reasonable  
9 probability of a tornado almost simultaneously with an ice  
10 storm. Is that the concern?

11 MR. YOUNGBLOOD: That evidently must be the  
12 concern.

13 MS. DOOLITTLE: I think that is the concern  
14 because that specification on the tornado alert would be  
15 removed once the diesel generator exhaust item is resolved  
16 with the Applicant.

17 DR. KERR: I would be interested in seeing those  
18 calculations of the probability of an ice storm and a  
19 tornado occurring within a day or two of each other. I  
20 thought sure I had misunderstood the SER. I guess I  
21 didn't. Okay.

22 That concludes your presentation?

23 MS. DOOLITTLE: Yes.

24 DR. KERR: Are there further questions?

25 (No response.)

.1 AGBmpb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DR. KERR: Then we have comments by the Applicant on the same topic, I believe, and then maybe some further comments from you on the original.

EFFORTS TAKEN BY THE STAFF AND THE  
APPLICANT TO RESOLVE THE ACRS COMMENTS

MR. COUNSEL: Bill Council, Northeast Utilities.

We would like to comment only on the two direct questions from the ACRS. On the other issues, we are working with the Staff to resolve those issues.

Now first I would like to answer Dr. Remick's question on our philosophy on the STA position. John Roncaioli will answer the fire protection questions of Mr. Michelson after mine.

In late 1979 and early 1980, when we had to come up with an STA position, we formulated at Northeast Utilities an interim STA position to get us through the first three years where we would have degree people available and so forth at our operating units. We also looked at what was going to be our long term position on the STA.

We felt that the best way to operate our units would be to incorporate the STA position into the shift supervisor's position. We set out on that course in early 1980 with a detailed training program that we in fact had developed with a university.

1 AGBmpb

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

How did we get to that position? Basically it was — and I can only give you what my experience and the experience of the various people with me that made that decision — how we arrived at that as our long term program.

Most of us graduated in the top of our class, including myself. The very first thing that happened to me when I entered the Navy Nuclear Power Program was I was told that wasn't good enough. In other words, an engineering degree is not good enough. So consequently I was put back into school.

We all underwent a very comprehensive program developed by the Navy. We all felt that program was very, very beneficial.

In looking at our program for our operators there were no college courses that could have taught what we would have taught. So consequently, we took that program and, with Memphis State University, developed a similar program for our high school educated shift supervisors. We put them through that program.

And in every step of the way since 1980 we have informed the Staff of our full intentions and what we were going to do and exactly what the program was. We had the program reviewed by INPO very early on. And in addition, throughout this process have informed the Staff both for the

1 AGBmpb

1 operating units and our intentions on Unit number 3.

2           Because of the constraints of trying to send all  
3 of our shift supervisors and supervising control operators  
4 to college while we were attempting to operate units, and  
5 also transfer operating experience to Unit number 3, we very  
6 early on decided that for the Unit 3 staff we would hire  
7 BS-trained operators, although that is not our intent for  
8 the full term operation of that unit.

9           Throughout this process of qualifications of our  
10 personnel — and it was described by Mr. Crockett yesterday  
11 — we kept the Staff informed of our position. We have not  
12 received any comments back from the Staff on that position  
13 to date. And this is over a four-year period now.

14           Most recently I provided that course and our  
15 position to the chairman of the CRGR, Mr. Vic Stello. He  
16 had not heard about it and what our plans were. To the best  
17 of my knowledge Mr. Stello has further provided that  
18 position as an alternative directly to the Commissioners as  
19 recently as two months ago.

20           Now we fully intend to continue on this course  
21 and we fully intend to keep the Commission apprised of what  
22 our position is. And we believe it is a good alternative to  
23 just requiring a BS degree on shift.

24           Further to our course, because of our removal or  
25 wanting to remove administrative requirements from the shift

1 AGBmpb

1 supervisors, we do have BS degrees on shift. However they  
2 are there only for communications purposes; they are there  
3 for a training and upgrading of them directly out of college  
4 in order to teach them nuclear technology, communications,  
5 remove the administrative burdens. And we fully intend,  
6 after a three-year training program, to phase them out and  
7 into the engineering department while new engineers come in  
8 in this training status. So there are engineers on shift.

9 In addition to that, though, we do have the full  
10 resources of Northeast Utilities in backup at all times to  
11 our operating stations.

12 Dr. Remick, does this basically answer the  
13 question you were asking?

14 DR. REMICK: Yes. I thank you very much.

15 The one question I would have remaining: As I  
16 would see it, if the Commission policy statement that is  
17 currently out for public comment were promulgated as  
18 proposed you would have no difficulty; there would be no  
19 difference between the Staff and the Applicant, am I  
20 correct? Is there any...

21 MS. DOOLITTLE: I'm not sure that is correct. I  
22 think the Staff would like to address that at the full  
23 committee meeting.

24 DR. REMICK: All right.

25 Now suppose that policy statement on engineering

1 AGBmpb

1 expertise and shift was not promulgated. I think the  
2 probability is very small. But if it wasn't then should I  
3 infer from what you're saying that you would ask -- you had  
4 planned to ask for an exemption to the STA requirement. Is  
5 that what your plans would be?

6 MR. COUNCIL: The policy statement and our  
7 position has no basis in regulation, and it would be very  
8 difficult to ask for an exemption from a non-regulation.

9 DR. REMICK: No, but --

10 MR. COUNCIL: However if asked to do so,  
11 definitely we would.

12 DR. REMICK: No, the exemption I was thinking of  
13 was the requirement of having STAs. You currently have a  
14 quasi-Commission requirement of STAs.

15 MR. COUNCIL: That's true.

16 DR. REMICK: And I assume that if the policy  
17 statement isn't promulgated which would permit you to have  
18 this alternative then it would be your plan to ask for an  
19 exemption of the requirement of separate STAs.

20 MR. COUNCIL: That's correct.

21 DR. REMICK: Thank you.

22 MR. EBERSOLE: May I comment on this STA business?

23 I guess I've got a hang-up on the desirability of  
24 STAs and I would like to have your thoughtful consideration  
25 of the fact it's just not engineering expertise or the

1 AGBmpb

1 relative abilities of operators versus some other kind; but  
2 it's what they're doing in the control room.

3 The absence of such a person leaves the plant  
4 operation in the active and probably vigorous manual and  
5 other controls pursuit of activities to get out of trouble.  
6 I think it's worth something, and needs evaluation, to have  
7 somebody stand back and say 'Are there system interactions  
8 taking place which cannot be viewed by these busy people; is  
9 the plant drifting to a state which they don't recognize;  
10 are we getting into trouble and just attending to the front  
11 but not the depth of the problem.'

12 And I invite you, in order to do this, to  
13 consider an interesting accident which I think is a good  
14 model. It's the 14th Street Bridge accident where the 737  
15 crashed into the bridge. It had two people, a pilot and  
16 co-pilot. They didn't know that they were attempting to fly  
17 an ice-laden airplane with 70 percent power. Had they not  
18 had the ice they would have got off. Had they had full  
19 power they would have got off.

20 The combinational aspects of having neither of  
21 these, or, rather, having the resources not of the full  
22 power was not noticed by them. They were busy handling the  
23 direct problems in front of them. Had there been a third  
24 party, such as is on a 727, they would never have been  
25 leaving without full power.

1 AGBmpb

1 I just use it as a model for you to reflect.  
2 It's not just the expertise, it is what is being done with  
3 it.

4 DR. KERR: Ms. Doolittle, we are now at a point  
5 at which you are going to comment on the ancient ACRS  
6 letter, I believe.

7 MR. COUNCIL: Dr. Kerr, we still have the answer  
8 to Dr. Michelson on fire protection, if we may address  
9 that.

10 DR. KERR: I'm sorry. I moved too soon.  
11 Please continue.

12 MR. RONCAIOLI: Good morning. My name is John  
13 Roncaioli and I am the supervisor of fire protection  
14 engineering.

15 (Slide.)

16 We would like at this time for the purpose of  
17 clarification to put on a very short presentation on why we  
18 prefer carbon dioxide for our primary suppression agent for  
19 the cable spreading room.

20 Assisting me in this presentation is Mr. Jim  
21 Naylor, our lead fire protection engineer from Millstone  
22 Unit 3.

23 As noted, to date we have not reached resolution  
24 with the Staff with respect to our philosophy of using CO-2  
25 as the primary suppression agent for the cable spreading



2 AGBmpb

1 room. The Staff recommends in their BTP 9.5-1 the primary  
2 fire suppression for the cable spreading room should be an  
3 automatic water system such as closed head sprinklers, open  
4 head deluge systems or open directional water spray  
5 systems.

6 Millstone Unit 3's position is the primary fire  
7 suppression for the cable spreading room is an automatic  
8 total flooding CO-2 system. The Staff is not challenging  
9 the design of our CO-2 systems.

10 (Slide.)

11 Please note in Section 9.5-1 under carbon dioxide  
12 systems in the SER on the basis of its evaluation the Staff  
13 concludes that the carbon dioxide extinguishing systems meet  
14 the guidelines of BTP 9.5-1 and are therefore acceptable.

15 Note there is no disagreement on the actual  
16 design of our CO-2 systems. The disagreement is in  
17 philosophy, in terms of the type of protection to be  
18 provided for the cable spreading room. The Staff prefers  
19 water and for our specific situation we prefer total  
20 flooding CO-2.

21 MR. MICHELSON: Excuse me. Did you say a little  
22 earlier, or did I misunderstand, that this is automatic or  
23 manual? I thought the slide said automatic, but I didn't  
24 really --

25 MR. RONCAIOLI: Yes. Earlier we were talking

1 AGBmpb 1 about the suppression system for the diesel rooms, which is  
2 a manually actuated water system. This is the cable  
3 spreading room and this is an automatic total flooding  
4 system.

5 MR. MICHELSON: It is a 60 second time delay  
6 automatic?

7 MR. RONCAIOLI: That's correct.

8 MR. MICHELSON: Thank you.

9 MR. RONCAIOLI: Okay. Why do we prefer CO-2?  
10 To begin with, as a fire service individual, I  
11 fully recognize that if I can apply water directly to a  
12 burning cable -- as can be done in control laboratory  
13 conditions -- it is the preferred agent. But real  
14 conditions, power plant environment cable systems are far  
15 from laboratory conditions. Existing cable tray arrangement  
16 and geometry significantly reduces the merits of water.

17 (Slide.)

18 With respect to the cable system layout of  
19 Millstone Unit 3's cable spreading room it should be noted  
20 that existing cable tray congestion, coupled with cable tray  
21 covers, make it extremely difficult for water to be  
22 effectively applied to a cable type fire. Even with the  
23 best in sprinkler system designs, water discharge patterns  
24 would be severely obstructed, and the best that can be  
25 expected is to establish a water curtain effect between

1 AGBmpb

1 cable tray systems. This, of course, would provide a  
2 passive fire protection feature, not an active  
3 extinguishing feature.

4 The use of CO-2, on the other hand, extinguishes  
5 fires by using a totally different mechanism.

6 (Slide.)

7 CO-2 extinguishes fires by inerting the entire  
8 volume, thus displacing the air-oxygen mixture necessary to  
9 support combustion. The significant advantage of CO-2 for  
10 cable spreading room type environments is its capability as  
11 a gas to effectively penetrate cable tray systems.

12 A second and equally significant feature of our  
13 CO-2 system is the detection and activation concept  
14 associated with the CO-2 suppression system.

15 (Slide.)

16 Fires in cable systems, especially IEEE-383 rated  
17 cables, generally develop as slow smoldering type fires. A  
18 considerable amount of smoke is generated before much heat  
19 is created in these type of fires. Automatic wet pipe  
20 sprinkler systems, as recommended by the Staff, basically  
21 depend on the fusible link element to melt when exposed to  
22 heat before becoming activated.

23 The fusible link concept depends on heat to  
24 activate and therefore considerable time can expire before  
25 the affected sprinkler head or heads become activated. To

1 AGBmpb

1 further compound this slow response, ceiling height, and  
2 already noted cable tray geometry could easily divert and  
3 dissipate heat away from those sprinkler heads, thus  
4 preventing or slowing considerably the activation of  
5 automatic water sprinkler systems.

6 The detection system in the CO-2 activation  
7 concept for Millstone Unit 3 has been designed to respond to  
8 smoke and products of combustion -- not heat -- and  
9 therefore application of the extinguishing agent will be  
10 much quicker than the fusible links of wet pipe sprinkler  
11 systems.

12 The point that should be obvious is that our CO-2  
13 detection and activation concept is designed for the hazard  
14 it serves and therefore will activate quicker, thus  
15 minimizing damage. But even more important, it will prevent  
16 that larger fire from developing and causing significant  
17 damage.

18 (Slide.)

19 In summary, our CO-2 system has been designed to  
20 respond quicker and more effectively than NRC's recommended  
21 water suppression system, and therefore we conclude that we  
22 have provided an equivalent level of protection for our  
23 cable spreading room.

24 That basically concludes our short presentation  
25 on why we prefer CO-2.

1 WRBwrb 1

2 MR. MICHELSON: I'm sure you're well acquainted  
3 with the Browns Ferry fire. Why, in that case, didn't CO2  
4 seem to be effective in putting it out?

5 MR. RONCAIOLI: Okay; the Browns Ferry fire, as I  
6 recall, their CO2 system was a manually activated system.

7 MR. MICHELSON: It's automatic. It was put on  
8 manually. But it is an automatic system.

9 MR. RONCAIOLI: That's right; but at the time it  
10 was needed it was deactivated and it was in a manual model.

11 My recollection of that fire is that there was a  
12 lot of confusion, and that system did not get activated  
13 until well into the fire scenario. And when it was  
14 activated it ultimately extinguished the fire in the cable  
15 spreading area.

16 What had happened was that at that point in time  
17 the fire was well advanced into the reactor building because  
18 of the pressure differential between the cable spreading  
19 room and the reactor building. The fire that was truly  
20 damaging was the fire that was in the reactor building, and  
21 there were no systems there to extinguish that fire.

22 As I recall, they tried to fight that manually,  
23 and they used a considerable amount of portable  
24 extinguishers.

25 MR. MICHELSON: I guess you're saying, then, that  
if CO2 had come on at the onset of the incident and had been

1 WRBwrb

1 left alone, that it was have effectively stopped the fire?

2 MR. RONCAIOLI: That's correct.

3 There are two points that should be taken from  
4 that lesson. First of all, if the fire -- if the CO2 system  
5 was activated when the fire was in its incipient stage the  
6 fire would have been suppressed very quickly and there would  
7 have been almost no damage at all. The fact that the fire  
8 was allowed to go on for such a long period of time and the  
9 CO2 finally became activated, the CO2 still put out that  
10 deep-seated fire in the cable spreading area.

11 MR. MICHELSON: Could I ask for clarification on  
12 an earlier reply on the question of what happens if the  
13 control system failed and the CO2 continues to pour into the  
14 room? You said you had vent arrangements whereby they would  
15 limit the pressure you would reach.

16 Could you tell me just a little bit about the  
17 vent arrangement -- where does it vent to, and so forth?

18 MR. RONCAIOLI: Okay. Pressure relief venting  
19 for our CO2 systems is now in the engineering design phase.  
20 For the cable spreading area specifically, the venting would  
21 be to outside.

22 MR. MICHELSON: Does that mean directly to  
23 outside?

24 MR. RONCAIOLI: That's correct.

25 MR. MICHELSON: How about in the case of the

1 WRBwrb 1 switch gear room?

2 MR. RONCAIOLI: I would like to have Mr. Jim  
3 Naylor address that specific question as to the switch gear  
4 room.

5 MR. NAYLOR: Jim Naylor, fire protection  
6 engineer.

7 With regard to the switch gear rooms, we are  
8 presently designing a scheme where we will be venting via  
9 the cable spreading room directly to the outside.

10 MR. MICHELSON: In no event are you planning on  
11 venting into the ventilation system?

12 MR. NAYLOR: We will use that as backup,  
13 additional venting.

14 MR. MICHELSON: Well, how are you isolating the  
15 ventilation system so that you don't back up CO2 into other  
16 areas? Because I think it's common with the control room  
17 ventilation system.

18 MR. NAYLOR: No; the switch gear rooms are  
19 separate, they are individual ventilation systems.

20 MR. MICHELSON: You do not isolate the  
21 ventilation system, then, in case of fire? --fire detection,  
22 that is.

23 MR. NAYLOR: Certain dampers will close on  
24 actuation of CO2, depending on the area.

25 MR. MICHELSON: I thought you were trying to

2 WRBwrb 1 build up CO2 in the room.

2 MR. NAYLOR: Our ventilation systems are high,  
3 and our dampers would be located high in the ceiling;  
4 therefore, it would be—

5 MR. MICHELSON: Well, I assume you've got to get  
6 enough CO2 high in the room to stop the cable tray fire in  
7 the highest cable tray, which is pretty near the ceiling.

8 MR. NAYLOR: Yes. CO2, being heavier than air,  
9 would not continue up the ductwork.

10 MR. MICHELSON: Well, CO2 is what is going to put  
11 out the fire in the highest cable tray. You've got to get  
12 enough CO2 to do that job, to inert the entire room.

13 MR. NAYLOR: We will be inerting the entire room.

14 MR. MICHELSON: And you can do that without  
15 isolating ventilation?

16 MR. NAYLOR: The ventilation will automatically  
17 shut down.

18 MR. MICHELSON: All the ventilation ducts are  
19 going to close, you're saying?

20 MR. NAYLOR: No; the fans will shut down in  
21 certain area.

22 MR. MICHELSON: But the ducts remain open?

23 MR. NAYLOR: Yes.

24 MR. MICHELSON: And none of those lead to any  
25 inhabited areas?



1 WRBwrb

1

MR. NAYLOR: The vent paths are high in the room,

2

so they would be leading up through the control building.

3

MR. RONCAIOLI: Let me provide some clarification

4

for that.

5

Our ventilation paths that will be left open are

6

those paths which we will be using for pressure relief only.

7

MR. MICHELSON: You said you're going to vent

8

your pressure directly to atmosphere and not through the

9

ventilation system.

10

MR. NAYLOR: We're going to have a special

11

ventilation system to take care of pressure relief.

12

MR. MICHELSON: Yes; so you don't have to-- I

13

thought you said you were going to vent directly to the

14

outside.

15

MR. NAYLOR: No; via the cable spreading room

16

with independent ductwork.

17

MR. MICHELSON: Right; and then directly outside?

18

MR. NAYLOR: Yes.

19

MR. MICHELSON: Now, the ventilation ducts in

20

the cable spreading room, are they all going to be isolated?

21

MR. NAYLOR: No; those are all closed systems,

22

there's no ventilation in the cable spreading room.

23

MR. MICHELSON: None at all?

24

MR. NAYLOR: None.

25

MR. MICHELSON: How do you take the heat out?

3 WRBwrb 1

2 So what we do on the initial discharge of CO2, we  
3 discharge over a certain time frame like seventeen tons of  
4 CO2. And then in order to maintain that concentration we  
5 provide a continuous discharged which is sized and  
6 calculated for the expected leakage that we can expect from  
7 that environment.

8 MR. MICHELSON: And you have one backup of  
9 another completely full charge available?

10 MR. RONCAIOLI: That's correct; we have another  
11 complete discharge available to us.

12 MR. MICHELSON: Thank you.

13 MR. BENDER: How does this system compare with  
14 the systems you have in the other two units?

15 MR. RONCAIOLI: With respect specifically to the  
16 cable spreading rooms?

17 MR. BENDER: Yes.

18 MR. RONCAIOLI: Our Millstone-2 installation has  
19 a water deluge system for the cable spreading room, and it  
20 has recently been backfitted based on the VTP reviews that  
21 we did back in the late seventies, to install an additional  
22 wet pipe sprinkler system in the areas of high cable  
23 concentration, which is basically below the main control  
24 board.

25 MR. BENDER: Now, why is it that you were able to  
do that for that installation and you find it unacceptable

3 WRBwrb

1 in this installation?

2 MR. RONCAIOLI: Okay; again, you have to look at  
3 both cable spreading environments on a case-by-case basis.  
4 The Millstone-2 installation does not lend itself to manual  
5 fire-fighting. Cable tray systems are relatively close to  
6 the ground, and it would severely restrict a manual  
7 fire-fighting effort. Therefore we went with two water  
8 suppression systems.

9 Also, the cable arrangement was such that it  
10 basically lent itself to being able to get water on those  
11 cable tray systems.

12 The Millstone-3 design, as you've seen yesterday  
13 morning, actually lends itself to manual fire-fighting as  
14 far as being able to walk around in there and get some fire  
15 brigade crews to do whatever activity they have to.

16 The Millstone-3 design also has an enclosed cable  
17 tray system, in which we feel the gas suppression agent  
18 would be much, much more effective.

19 MR. MICHELSON: An enclosed cable tray system?

20 MR. RONCAIOLI: Let me clarify that. It has  
21 cable covers.

22 MR. MICHELSON: Cable tops. And it will be on  
23 top, not on the bottom?

24 MR. RONCAIOLI: That's correct.

25 MR. MICHELSON: Another clarification which I

3 WRBwrb

1 asked yesterday and maybe you can give me: In the  
2 environmental qualification of the switch gear and other  
3 vital equipment in the basement underneath the spreading  
4 room, is the CO2 deluge included in considering the  
5 environmental qualification of that equipment?

6 MR. RONCAIOLI: I think I would like to let our  
7 electrical engineering manager discuss any questions on  
8 environmental qualification of equipment in the switch gear  
9 rooms.

10 MR. MICHELSON: But you are intending to dump a  
11 large amount of CO2 into the room if you get a smoke signal?

12 MR. RONCAIOLI: That's correct.

13 MR. MICHELSON: Now, is there any chance that the  
14 fire is in the spreading room but the smoke is getting into  
15 the switch gear room? Is there a good barrier between the  
16 spreading and switch gear rooms?

17 MR. RONCAIOLI: That's correct; it's definitely a  
18 three-hour rated barrier, and all penetrations will be  
19 sealed with our penetration seal program.

20 MR. BENDER: All of them will be?

21 MR. RONCAIOLI: That's correct.

22 MR. MICHELSON: So if you get a fire -- if you  
23 get a detection, it's presumably a fire in the switch gear  
24 room somewhere?

25 MR. RONCAIOLI: That's correct.

1 WRBwrb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. MICHELSON: And then you turn the deluge on. Both trains of equipment are in that switch gear room, aren't they?

MR. RONCAIOLI: Two separate switch gear rooms.

MR. MICHELSON: Okay.

Are they fully environmentally isolated from each other?

MR. RONCAIOLI: By environmentally you mean from physical barriers point of view?

MR. MICHELSON: From smoke.

MR. RONCAIOLI: Oh. That's correct, they are fully separated from each other.

MR. MICHELSON: So then the question simply is, Is the CO2 deluge included in the environmental qualification.

DR. KERR: Mr. Ebersole.

MR. EBERSOLE: Is this plant traversed by duct work which then is isolated by dampers that are operated by fusible links or whatever?

MR. RONCAIOLI: That's correct. The ductwork -- the cable spreading room is isolated by, I believe, two dampers, which is on a fusible link concept but electrically activated, not heat activated. Our detection system is such that the first detector will trigger an alarm locally, and remotely to the control room, to give early warning of the

2 WRBwrb

1 incipient type fire. When a second detector comes in on a  
2 totally separate, when that detector comes in, then the  
3 fusible link elements on those dampers fuse, and basically  
4 those dampers will close.

5 MR. EBERSOLE: Really, then, this is mechanically  
6 operated by a fusible--

7 MR. RONCAIOLI: Yes; they are spring-loaded with  
8 a fusible link holding them open; that's correct.

9 MR. EBERSOLE: So you could cause them to open at  
10 any temperature you wish -- I mean, to close -- and thus  
11 protect the overloads relays and systems of circuit breakers  
12 in distant room--

13 MR. RONCAIOLI: That's correct.

14 MR. EBERSOLE: --from seeing a too high ambient.

15 Let me ask this: I ran into paragraph  
16 8.3.3.1.9. on page 823 of the SER. It says that-- There  
17 was a little bit of a disturbing sentence. It says:

18 "Type SJ0 cords for lighting drops to fixtures  
19 are sized 12-AWG or smaller in supplying 120-volt AC  
20 or 120-volt DC low energy."

21 I got a vision from that that you might have  
22 cable trays with small wires on it, and I wanted to ask you:  
23 what is the basic rationale, when you use small wires like  
24 that in connection with -- if you present them with a hard  
25 bolted short, and you consider the short circuit

1 WRBwrb 1 availability to them? Will they fuse? Will they burn?

2 MR. RONCAIOLI: For a point of clarification:

3 Are we discussing the detection system associated  
4 with--

5 MR. EBERSOLE: No; we're talking about the fire  
6 potential of small cables under short circuit conditions,  
7 like lighting drops.

8 MR. RONCAIOLI: With very low voltage, I assume?

9 MR. EBERSOLE: I don't know. 125 AC, I reckon.

10 MR. RONCAIOLI: Mr. Pitman of Northeast Utilities  
11 will address that question.

12 MR. PITMAN: The low energy density of those  
13 circuits was considered, and we dealt with the staff on that  
14 issue because it did represent a deviation with respect to  
15 Reg Guide 175. We determined that you would not start a  
16 fire in those circuits, and, thus, the drops which come down  
17 to the light fixtures would be adequate without further  
18 protection.

19 MR. EBERSOLE: Well, let me ask a more general  
20 question: In full consideration of short circuit  
21 availability, and with hard shorts on small wires, and with  
22 time delays, if they are protected by circuit breakers  
23 instead of fuses, what is the damage level you accept in the  
24 cables?

25 MR. PITMAN: What is the damage level we would

1 WRBeb 1 accept?

2 MR. EBERSOLE: Yes.

3 MR. PITMAN: The criteria here was that it not  
4 burst into flames and create a hazard to adjacent circuitry.

5 MR. EBERSOLE: How close is the margin to doing  
6 that that you worked toward?

7 MR. PITMAN: I can't tell you at this moment.

8 MR. EBERSOLE: Would it depend on them being  
9 tightly bunched, maybe, or---

10 MR. PITMAN: They certainly are not tightly  
11 bunched. They are single drops to single fixtures.

12 MR. EBERSOLE: So your general criteria is if you  
13 have a voltage short on a cable, wherever, it will not  
14 ignite?

15 MR. PITMAN: This category of cables, sir, not  
16 just any cable. There may be some 41 60-volt cables where  
17 that could happen. Okay?

18 MR. EBERSOLE: That it will ignite?

19 MR. PITMAN: There's a lot of testing been done,  
20 and it is difficult to get a cable to ignite, but I can't  
21 say categorically that it would not.

22 MR. EBERSOLE: Would those be in the safety class  
23 cables?

24 MR. PITMAN: Yes, they could be. And in that  
25 respect we met the applicable criteria with respect to



1 WRBeb

1 separation.

2 MR. EBERSOLE: So the situation is upon the  
3 occurrence of a hypothetical but unlikely voltage short, you  
4 might ignite a cable?

5 MR. PITMAN: In the high density power circuit,  
6 that's correct.

7 MR. EBERSOLE: And then you depend upon the  
8 separative aspects of Reg. Guide 175?

9 MR. PITMAN: That's correct. Reg. Guide 175  
10 covers in situ fires as opposed to exposure fires.

11 MR. EBERSOLE: How many sets of cables are in  
12 that category? Are there many that are borderline to  
13 ignition on a voltage short?

14 MR. PITMAN: I would be guessing if I told you,  
15 sir. Rather than to deviate from the rule, which would save  
16 a lot of money and a lot of cable tray covers, we complied  
17 with the various criteria and incorporated the appropriate  
18 separation. You know, if we had decided to go out of  
19 conformance with the criteria, then a test would have been  
20 appropriate and we could have seen what actually would  
21 happen.

22 Our assumption is that there are some circuits  
23 that could cause a fire to start through a fault.

24 DR. KERR: Are there further questions?

25 MR. MICHELSON: I think he has an answer yet for

1 me.

2 MR. EBERSOLE: No, I understand him. He's got  
3 some cables that will potentially ignite on a voltage  
4 short. That's all I want to know.

5 DR. KERR: Thank you.

6 Please continue.

7 MR. MICHELSON: I think you were going to answer  
8 the environmental qualification question.

9 MR. PITMAN: Yes, I was.

10 That particular issue, equipment impact caused by  
11 CO2 discharge, came up as a late item. It really wasn't  
12 around when we first started considering mild environment  
13 qualification, which a switch gear room would be.

14 We did an assessment as to the impact on switch  
15 gear and it is our conclusion that because it does not  
16 contain sensitive electronic circuits, — there are  
17 electromechanical relays, high current buses and so on —  
18 that there would be no adverse impact.

19 Additionally the switch gear is located in  
20 enclosures, two divisions worth of them that are bonded by  
21 three-hour fire walls that are intended to prevent CO2 in  
22 one room from entering the adjacent room.

23 MR. MICHELSON: Maybe I misunderstood during the  
24 tour. I thought the switch gear has been modified in many  
25 cases to include solid-state control circuitry instead of

1 WRBeb

1 relay circuitry. Was I misinformed?

2 MR. PITMAN: I believe some of the 480-volt gear  
3 has some overcurrent relays which are solid state.

4 MR. MICHELSON: Yes, that's the equipment that is  
5 down there. A lot of it is 480.

6 MR. PITMAN: That is correct.

7 MR. MICHELSON: And so have you considered that  
8 in the environmental qualifications?

9 MR. PITMAN: I would have to get back to you on  
10 that.

11 MR. MICHELSON: Okay. Maybe for the full  
12 Committee meeting you can address it just a little more.

13 MR. PITMAN: Certainly.

14 MR. MICHELSON: Thank you.

15 DR. KERR: Any further questions?

16 (No response.)

17 DR. KERR: Thank you, sir.

18 MR. RONCAIOLI: Thank you.

19 DR. KERR: In view of the length of time that we  
20 are behind schedule, and in light of the long time ago that  
21 the construction permit letter was written, I am going to  
22 skip the response unless there are Subcommittee members who  
23 want to hear further about that.

24 Can you just provide us a written statement,  
25 Ms. Doolittle, about the response, and then you won't have

1 WRBeb 1 to--

2 MS. DOOLITTLE: There are slides in your packages  
3 that address each item.

4 DR. KERR: Okay. Thank you.

5 Any further comments or questions on the part of  
6 the Subcommittee before we end this part of the session?

7 Again I ask the Subcommittee members that they  
8 look at the proposed agenda for the full Committee meeting,  
9 and let Sam or me have comments by noon if possible.

10 Does the Applicant have any further comments on  
11 this part of the meeting?

12 MR. COUNCIL: The Applicant has no further  
13 comments.

14 DR. KERR: Does the Staff have any further  
15 comments?

16 MS. DOOLITTLE: No, the Staff has no further  
17 comments.

18 DR. KERR: Thank you.

19 I declare a ten-minute recess, after which we  
20 will begin consideration of the PSS.

21 (Recess.)

22 DR. OKRENT (Presiding): This meeting will  
23 reconvene, please.

24 The remainder of the Subcommittee meeting will be  
25 related to the Millstone 3 Probabilistic Safety Study and

1 WRBeb

1 associated things. I guess that means also anything done in  
2 the area of systems interactions.

3 My expectation is that we will break for lunch at  
4 12:15 as the agenda says, for one hour, and that the session  
5 will break a little before 3:45 for the day.

6 We don't expect to go through in great detail the  
7 entire or even part of the PRA since that's a job that takes  
8 considerably more time. I would say of primary interest for  
9 the purposes of today's discussion are what insight appeared  
10 to have arisen from the study itself, from reviews of the  
11 study and so forth, that may be suggestive of safety aspects  
12 that the full Committee should hear about and factor into  
13 their thinking, at least in a qualitative way, when they  
14 meet -- I guess it is in September, to review Millstone for  
15 operation.

16 It is planned at some time, probably after  
17 Election Day -- I'll put it that way -- to have a much more  
18 detailed discussion, examination, review of the Millstone  
19 PRA and the evaluation of it.

20 So what I would like most to have discussed today  
21 by all of the participants -- that means representatives of  
22 Millstone, those of the Staff, the consultants, members --  
23 are topics that seem to have some special significance, and  
24 that might be relevant to call to the full Committee's  
25 attention, one way or another, to the extent that one is

1 WRBeb 1 able to.

2 It may be the information is incomplete, but  
3 nevertheless it seems like an open issue or whatever.

4 Are there any comments from the Subcommittee?

5 (No response.)

6 DR. OKRENT: I'm assuming that we have received  
7 all of the documents that the Staff has in its possession  
8 that bear on the Millstone PSS; that if the Union of  
9 Concerned Scientists were to send in a Freedom of  
10 Information request, they would not come out with a fistful  
11 of other documents that the Staff has not provided us.

12 If the latter is the case, I urge that the  
13 situation be changed and that we do get the benefit of what  
14 are sometimes called letter reports, draft memoranda,  
15 memoranda from one Staff member to another, et cetera. But  
16 I don't expect to have them today, but certainly before we  
17 need to discuss this in more detail.

18 And if any of these things bear on what I would  
19 call the significant subjects, sooner is much better than  
20 later.

21 Okay.

22 INTRODUCTION TO THE MILLSTONE UNIT 3 PSS

23 DR. OKRENT: The first item on the agenda as it  
24 was laid out was an NRC Staff presentation, their views on  
25 the use of results of this PRA in the licensing process.

1 WRBeb

1 Who is the spokesperson?

2

MS. DOOLITTLE: Mr. Ashok Thadani will be making

3

the presentation.

4

## NRC STAFF PRESENTATION

5

MR. THADANI: Good morning. I am Ashok Thadani.

6

NRC Staff.

7

(Slide.)

8

In the next few minutes I will briefly describe

9

to you the status of the review, some very preliminary

10

insights that we have, as well as some short discussion of

11

how we intend to utilize this source of information.

12

If you recall a few years ago the Staff had a

13

perception that for certain plants, if the population

14

density were significantly higher than the normal or average

15

population density, that there was a perception that the

16

risk may indeed be significant from operation of these

17

facilities.

18

To get a somewhat better understanding, the Staff

19

decided perhaps the most useful way to address this concern

20

was to develop an integrated look at the plant design as

21

well as its operation.

22

The Staff requested Northeast Utilities to

23

perform a plant-specific probabilistic safety study,

24

requested that it be fairly complete, and indeed about a

25

year ago Northeast did submit a probabilistic safety study

1 WRBeb

1 which included internal as well as external events.

2           At the time of the submittal, Northeast indicated  
3 to us that certain aspects of their seismic analyses were  
4 perhaps incorrect, and that they had embarked on a course to  
5 revise their estimates. Specifically speaking, this related  
6 to some of the fragility estimates that were provided to us  
7 in the PSS.

8           Over the next seven or eight months the Applicant  
9 did conduct further studies, not only in the area of  
10 fragility considerations but they also provided us some  
11 revised information in terms of the hazard function.

12           Basically those are the key documents we received  
13 from the Applicant.

14           I am sure it is clear to you that the process has  
15 been interactive, and that we have in fact questioned the  
16 Applicant and received other documentation as well in  
17 response to our questions.

18           The Staff contracted the review out to two  
19 laboratories. Lawrence Livermore Laboratory-- We asked the  
20 Lawrence Livermore folks to critically evaluate the systems  
21 analysis, starting from initiating events on up to core  
22 damage considerations.

23           Further, the Staff has a contract with Brookhaven  
24 National Laboratory to look at the phenomenological aspects,  
25 what happens if one does end up with a molten core, as well



1 WRBeb

1 as containment performance.

2           Recently, in the last few months— Let me  
3 backtrack a little bit.

4           The Staff's reaction to the initial probabilistic  
5 safety study, in particular the seismic analysis, was pretty  
6 negative. There were a lot of concerns. Some of these  
7 were, in my view, shared by the Applicant in the area of  
8 fragilities. They had indicated to us that they were indeed  
9 doing some more work and would provide us with better  
10 estimates.

11           There were a bunch of questions in terms of  
12 systems analysis consideration of seismic issues, and  
13 generally the Staff feeling at this stage, although the  
14 review is not complete, is that in the area of fragility  
15 considerations and systems analysis, the later submittal by  
16 the Applicant was fairly good. There are still some issues  
17 hanging which I will touch upon in the next couple of  
18 slides.

19           In any case we do have a draft report from  
20 Lawrence Livermore. I trust you have copies of that. If  
21 you don't we will certainly make sure that you receive them  
22 immediately.

23           We are expecting to provide our thoughts and  
24 reactions to the Livermore report to Livermore in the next  
25 few weeks, so it does appear to us as though the Staff

1 WRBeb

1 cannot develop its carefully considered thinking on a number  
2 of issues until Livermore has addressed some of the Staff  
3 comments.

4 We do think that we will be ready to support your  
5 November meeting and that we should really have completed  
6 most our work, most of our technical evaluation at least.

7 Next slide, please.

8 (Slide.)

9 I thought it might be worthwhile making a few  
10 comments about some of the important things — at least I  
11 think they are important — that still need to be addressed  
12 by the Staff.

13 In the review process, Livermore as well as the  
14 Staff seems to have come to at least an initial judgment  
15 that several of the scenarios analyzed in the probabilistic  
16 safety study are much more important than the sort of  
17 importance that was given to these scenarios in the study.

18 The Staff is also looking at some new sequences  
19 and is in the process of evaluating them now to determine if  
20 these new sequences might not also deserve further  
21 attention.

22 So far, if I may just briefly describe what did  
23 we learn from this process, we did find that the design has  
24 some unique features, and I want to be really careful. It  
25 has some features; I'm not sure that they are necessarily

2 WRBeb 1 unique to this design.

2 It does have some features which do tend to  
3 suppress some of the dominant accident sequences, for  
4 example, number one, the large refueling water storage tank.  
5 If I remember correctly the capacity is about 1.2 million  
6 gallons versus traditional refueling water storage tanks,  
7 the capacity of which I believe is somewhere in the  
8 neighborhood of 300,000 to half a million gallons.

9 That, in conjunction with the type of  
10 recirculation system that this design has-- Basically let  
11 me describe what that is.

12 It's a four-train system. The function is core  
13 makeup as well as containment spray, but you can use any of  
14 the pumps to perform either of the two functions. And that  
15 system is actuated automatically and does not depend on a  
16 low refueling water storage tank level. That appears to be  
17 a pretty good feature.

18 DR. OKRENT: Is there a single line running from  
19 the refueling water storage tank, like in some of the plants  
20 I've seen?

21 MR. THADANI: I don't know the answer. Perhaps  
22 some of the Staff members--

23 MR. KELLY: I think it is a single line.

24 MR. THADANI: We'll check that.

25 MR. CROCKETT: Excuse me. Yes, there is a single  
26 line from the refueling water storage tank.

2 WRBeb

1 line from the refueling water storage tank.

2 MR. THADANI: From our past studies we had also  
3 come to certain judgments regarding the intersystem LOCA  
4 sequences. Obviously the concern there was if such an event  
5 were to occur where the integrity of the valves and the ECCS  
6 is compromised, that that sequence had the potential for  
7 bypassing containment.

8 And on this design it appears-- It's an area we  
9 are in the process of confirming, but it does appear that  
10 instead of the typical two valves that one sees in the  
11 high-pressure piping that there are three valves which would  
12 at least provide some additional protection for such a  
13 scenario.

14 DR. KERR (Presiding): Excuse me.

15 What are you-- You are looking to see whether  
16 there are three valves or not, or to see whether three  
17 valves are better than two?

18 MR. THADANI: Basically for this sequence, three  
19 valves should be better than two. The question-- And we  
20 have come to recognize this only recently. In our  
21 discussions with Northeast, we did discuss this scenario  
22 with them, and at the last meeting they indicated to us that  
23 they believe the design -- high-pressure piping actually  
24 incorporates three valves and not two. And we are in the  
25 process of confirming that.

1 WRBeb 1

2 DR. KERR: You are confirming that there are  
3 three valves? Is that it?

4 MR. THADANI: Yes. If there are three valves,  
5 the judgment would be that that would be a safer situation.

6 DR. KERR: It doesn't strike me that that should  
7 be very difficult to find out whether there are two or three  
8 valves, but I'm pleased it is being done thoroughly.

9 MR. THADANI: I cannot disagree with you.

10 (Slide.)

11 Ms. Doolittle described to you the loop-stop  
12 valves. Those I think are a useful feature to protect  
13 against or isolate certain types of small LOCAs such as pump  
14 seal failures. They appear to be an improvement in design.

15 There are some other plants which do have  
16 loop-stop valves, though.

17 MR. EBERSOLE: Do you at this time have criteria  
18 for when you do and when you don't isolate?

19 MR. THADANI: I'm sorry?

20 MR. EBERSOLE: Do you have any criteria for when  
21 you do and when you don't isolate those LOCAs?

22 MR. THADANI: To the best of my knowledge, I  
23 don't know of any such criterion.

24 MR. EBERSOLE: Well, I think there is a potential  
25 for an intermediate to large LOCA, having been isolated, to  
give you trouble in refloods.

1 WRBeb

1 MR. THADANI: That's correct. I do not know the  
2 details of it, but the Staff does look at such a potential  
3 for starting up another loop or an isolated loop, and so on.

4 MR. MICHELSON: I might suggest at the full  
5 Committee meeting you clarify this because I recall that  
6 those valves have their power disconnected. Therefore, they  
7 would not be in a good position to even address a large LOCA  
8 or even an intermediate one, because it is over so quickly.

9 Is it really true that the power is disconnected,  
10 and what is their position on when it would be reconnected?

11 MR. THADANI: I don't know.

12 MR. MICHELSON: For the full Committee meeting I  
13 think you ought to clarify that, and put that problem to bed  
14 I think.

15 MR. THADANI: Certainly.

16 But normally, as I understand it, the power is  
17 disconnected from these valves, at least in some of the  
18 plants where they do have loop-stop valves.

19 MR. MICHELSON: Well, you certainly wouldn't  
20 worry then on a large break, would you? You don't have time  
21 to run down and--

22 MR. THADANI: I would agree with you. But I  
23 think the only point here would be that if you have a leak,  
24 that you could isolate that leak.

25 MR. MICHELSON: Yes. And I think with a small

1 WRBeb

1 leak it makes no difference, on a small leak. You don't  
2 worry about isolating small leaks; you worry about isolating  
3 large leaks, and having the system repressurize.

4 MR. THADANI: I guess I'm not so sure that one  
5 wouldn't worry about small leaks. It depends on what size  
6 small leaks one is talking about.

7 We have seen leakages of perhaps hundreds of  
8 gallons per minute, which is certainly above some of the  
9 makeup capabilities. It would seem to me that one would  
10 want to worry about small leaks.

11 MR. MICHELSON: Well, for the full Committee I  
12 would like to hear a discussion of the potential for break  
13 isolation and why you would or would not worry about it. I  
14 don't know that I agree with your statements, but think it  
15 through and give us a statement on it.

16 MR. THADANI: Okay.

17 DR. OKRENT: You might let out just enough water  
18 that you didn't want to isolate and build up pressure.

19 MR. THADANI: There would be some situations  
20 where one would want to, yes, indeed.

21 Another feature — again it is not necessarily  
22 unique for this design — is the large dry subatmospheric  
23 containment which does provide some protection from certain  
24 type scenarios such as the likelihood of the containment  
25 being unisolated during an accident is reduced. You use a

1 WRBeb

1 lesser amount of oxygen for hydrogen burns. And this  
2 containment appears — as I understand it, has higher free  
3 volume as well, which should be of some help for  
4 overpressure events.

5 Those are some of the features which appear to  
6 influence some sequences and make them less important than  
7 they might have been otherwise, relatively speaking.

8 On the other hand there are things we are seeing  
9 that we think deserve some attention, some of them more than  
10 others, clearly.

11 One element that is again not terribly uncommon  
12 for Westinghouse-designed plants is the issue, every time  
13 you have a reactor trip, the main feedwater system is  
14 tripped as well. We have asked Northeast to see if there  
15 aren't ways to try to minimize tripping the main feedwater  
16 system every time the reactor trips.

17 Northeast has indicated that they are looking at  
18 this issue, but we haven't seen anything formal back from  
19 them. I think it does deserve some attention.

20 MR. EBERSOLE: We mentioned that yesterday, an  
21 aspect to why do you throw the baby out with the wash water  
22 when you want to ramp down. I understand that there is a  
23 substantial effort to investigate this as well as any other  
24 aspects of shutting down or tripping which require  
25 safety-grade equipment which probably don't really need to



2 WRBeb

1 require it.

2 I believe that's a characteristic of the APWR as  
3 well.

4 MR. THADANI: A characteristic of what?

5 MR. EBERSOLE: The APWR. It's a Westinghouse  
6 characteristic.

7 MR. THADANI: Yes, it is a Westinghouse  
8 characteristic. We thought it might be worth exploring to  
9 see if there aren't things one can do.

10 I'm sorry, I wasn't here yesterday, but at least  
11 my understanding is that the Applicant is looking at this  
12 issue to see if something can't be done.

13 DR. OKRENT: Is the control down to low enough  
14 flows satisfactory?

15 MR. THADANI: Well, there are plants where they  
16 are able to do that.

17 MR. EBERSOLE: But this plant has an unusual  
18 configuration, not at all standard. It has one motor-driven  
19 and two steam-driven pumps I believe.

20 MR. THADANI: It has, as far as I know.--

21 MR. EBERSOLE: Am I correct, one motor-- So the  
22 opportunities for doing something like this probably are a  
23 good deal-- Well, they may be unique.

24 MR. THADANI: Okay. That's issue number one. We  
25 are still pursuing it with the Applicant.

1 WRBeb

1 Our reaction to the probabilistic safety studies,  
2 particularly in the area of station blackout, is fairly  
3 negative. We thought the analysis was not as complete as it  
4 could have been. The consideration of the reactor coolant  
5 pump seal response to the blackout situation, in our  
6 judgment, was not done correctly.

7 The study was incomplete perhaps in taking into  
8 consideration the duration for which the diesel generators  
9 may be required, and that there may in fact be some  
10 potential for diesel generators to fail to operate for  
11 extended periods of time, that is, including in the analysis  
12 failure-to-run considerations, not just failure-to-start  
13 considerations.

14 Those are some examples of the sorts of  
15 difficulties that we see, or perhaps even deficiencies that  
16 we see in the analyses.

17 The Staff is doing its assessment taking into  
18 account the best understanding that we have of these  
19 scenarios.

20 The next issue that needs further attention is  
21 the big seismic issue. As you know, Lawrence Livermore has  
22 issued under the Seismic Hazard Characterization Program a  
23 set of hazard functions which, in this case, are somewhat  
24 different and perhaps significantly different in certain  
25 areas than what the Applicant had provided to us.

J WRBeb

1           The Staff is looking at both hazard functions,  
2 doing its estimates using both hazards or hazard functions,  
3 also looking at the fragilities of structures as well as  
4 components, to get an understanding of how fragile certain  
5 components may be, which components -- using systems  
6 analysis, which components seem to come to the forefront in  
7 terms of potential for severe consequences.

8           That process is not yet complete. There are some  
9 areas we haven't pursued yet. One in particular, at least  
10 it is my personal opinion, that needs further attention is  
11 the whole issue of what happens to relays if you do have  
12 some severe seismic event. What type of relays are present,  
13 sequencers, the whole logic? What sort of actions would be  
14 needed from an operator if relays were to chatter?

15           And that element was not analyzed in the safety  
16 study by Northeast. The Staff hasn't been able to analyze  
17 it. I think it is certainly our intention to pursue this  
18 matter because it might well be quite important.

19           Whether we pursue it on Millstone Unit 3 or in a  
20 more generic fashion, pick certain plants and proceed, it's  
21 not clear. The analysis would be fairly complicated, but  
22 something that at least I think needs to be done. We just  
23 have some scoping thoughts at this point which indicate that  
24 this issue may be important.

25           The Staff's review has also indicated the

1 WRBeb

1 importance of the role of the humans, whether they are  
2 operators or other crew members, in the event of fire  
3 scenarios. Because of the large uncertainties in  
4 performance of humans, the Staff is looking somewhat closer  
5 at the sorts of activities that may be involved if fires  
6 were to be initiated in specific locations such as cable  
7 spreading rooms, control room, instrument rack room, and so  
8 on. That area we are also looking at at this stage.

9 By this list I don't mean to imply that there  
10 aren't other things we are looking into also. We are also  
11 doing a fair amount of work in the containment analysis, and  
12 some other aspects such as potential common-cause failures  
13 in the service water system, and so on. But we have not  
14 completed our analyses. We have gone far enough to see that  
15 some of these elements we think are important, and we ought  
16 to pursue these, our analyses, plus interact with the  
17 Applicant.

18 DR. KERR: Mr. Thadani, let me understand your  
19 comments in terms of the licensing process.

20 Are you discussing areas which you think may not  
21 be in conformance with existing regulations on the basis of  
22 your look at the PRA, or are you discussing results of the  
23 PRA which may or may not be part of the licensing process?  
24 It is not clear to me how I should interpret this  
25 discussion.

3 AGBpp

1 MR. THADANI: Okay; in fact that element is  
2 addressed in the next few graphs. Most of the discussion  
3 that I went through is not necessarily part of licensing but  
4 there may be certain things that we learn from this  
5 process. And if indeed, we find in the dominant accident  
6 sequences that the sequence becomes dominant, and having  
7 looked at it we find that one or more of the regulatory  
8 requirements are not met, then it clearly becomes part of  
9 licensing consideration, and some sort of improvement would  
10 obviously be indicated then.

11 MR. OKRENT: There's always going to be some  
12 sequence that is dominant.

13 MR. THADANI: Clearly.

14 MR. OKRENT: Are you going to treat these in the  
15 context of an effort to find out whether the existing design  
16 meets existing regulatory requirements. Is that the  
17 principal thrust --

18 MR. THADANI: No, that is not the principal  
19 thrust. The principal thrust really is to see if once we  
20 look at the study to see what we can learn from it, do we  
21 think it poses really disproportionate risk.

22 MR. OKRENT: How are you going to determine what  
23 this proportionate risk is?

24 MR. THADANI: I might address that we're finding  
25 it very difficult to do that for a variety of reasons. We

2 AGBpp

1 have not looked —

2 MR. OKRENT: I'm more interested here in  
3 procedure than I am in philosophy. Philosophy is important  
4 but I think we need a longer time to discuss it. What I'm  
5 trying to understand is, how you're going use your  
6 conclusions in the licensing process.

7 MR. THADANI: Well, there are only two ways.  
8 Number one, as I say, if as a result of our review we  
9 identify that something is significant and it doesn't meet  
10 our regulatory requirements, action will be taken. The  
11 other way is if we find, as a result of this review, there  
12 is something significant to safety that really stands out  
13 like a sore thumb vulnerability, the staff would consider  
14 action depending on whatever regulatory authority is  
15 available — mechanism is available — to the staff.

16 MR. OKRENT: Okay. I interpret that answer to  
17 mean you haven't really decided yet how you're going to use  
18 the results?

19 MR. THADANI:

20 MR. THADANI: he two ways.

21 MR. OKRENT: I have heard what to me are  
22 generalities, which are, if we find something significant —  
23 and significant apparently doesn't mean that it violates the  
24 regulations because you dealt with that earlier. And so I  
25 don't know how to interpret significant.

3 AGBpp

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. THADANI: Well, I think if I understand regulations, and there is an element in there that talks about compensatory considerations for plants located in high population density sites.

MR. OKRENT: I'm trying to understand what you're going to look at. Are you going to look at numbers? For example, is there a risk number. A core mill probability number. A fragility number. What are you going to use as a basis for your decision as to whether something is significant?

MR. THADANI: It seems to me that it's a combination of those factors. You clearly would have to see if the sequence you think is important, is important, why is it important. Is it because of it's contribution to core melt as well as risk?

MR. OKRENT: No. I recognize -- what I'm saying is you're using generalities now and I don't think there's anything wrong with that. But at some point one has to decide what is the basis for a go or no go decision? Now, perhaps you haven't reached the point at which you know how you're going to make that decision.

MR. THADANI: The staff has discussed with you at several meetings this severe accident policy and the sort of thought process that's going into that policy development. That's generic. As far as the specific plant is concerned,

3 AGBpp

1 we are basically left with, as I see it, just two elements.  
2 And those are the two elements I described to you. Numbers  
3 which certainly influence the staff but I don't believe the  
4 staff would just rely on a certain estimate. The staff is  
5 going to have to bring in some other what-if type questions  
6 after we get through this process.

7 MR. OKRENT: Okay, so at this point you really  
8 have not reached a decision as to how you're going to use  
9 the results. But you will reach that decision after you've  
10 completed your review, is that a fair statement?

11 MR. THADANI: That's reasonable. A reasonable  
12 statement, yes.

13 MR. OKRENT: Thank you.

14 MR. THADANI: I can't predict -- if I knew today  
15 exactly, at least to the best of our abilities what  
16 significant safety issues might really be, what can I learn  
17 from the quantification process in spite of its  
18 limitations.

19 When I talk about safety it could be two ways.  
20 One could look at it two ways. Core melt or off site  
21 risks. Not knowing that, I can only tell you that it seems  
22 to me ultimately it'll have to be judgmental. If the  
23 judgment is that it's significant then certain actions would  
24 be indicated.

25 MR. OKRENT: Thank you.



2 AGBpp

1 MR. MICHELSON: Before you go on, let me pursue  
2 something with you just a moment. (On page 9-41 of the staff  
3 SER it is stated that the staff is concerned whether the  
4 mechanisms by which fire and fire protection systems may  
5 cause simultaneous failure redundant or diverse trains have  
6 been adequately considered in the design.

7 Now, I would like to know and maybe you can tell  
8 me who's pursuing this. Are you looking at this issue or  
9 are the fire protection people looking at it?

10 MR. THADANI: Well, basically that issue, I'm  
11 sure, is being pursued by chemical engineering branch in  
12 NRR. In terms of probabilistic safety study, we have  
13 contractors reviewing those kinds of considerations --

14 MR. MICHELSON: Is the specific question, though,  
15 for Millstone being considered which really is the subject  
16 of this SER?

17 MR. THADANI: I can't give you a definitive  
18 answer but we could get one. We do have the same people in  
19 the chemical engineering branch also working with us in the  
20 review of the probabilistic safety study but I can't tell  
21 you for certain that issue is being considered --

22 MR. MICHELSON: Are you doing the analysis,  
23 probabilistic analysis work, to determine whether or not  
24 there is a concern with simultaneous failure of redundant  
25 due to fire or fire protection methods, or are the fire

2 AGBpp

1 protection people doing that. I'd really like to know if  
2 the fire protection people are doing it. Are they  
3 adequately qualified to really go into this issue in terms  
4 of its overall effect on plant operation?

5 MS. DOOLITTLE: The fire protection people are  
6 doing that.

7 MR. MICHELSON: Now for the full committee  
8 meeting did we get a short presentation by the fire  
9 protection people on exactly what they're doing for  
10 Millstone to clear up this issue since it's stated as a  
11 concern in the SER?

12 MS. DOOLITTLE: Yes.

13 MR. MICHELSON: Thank you.

14 MR. THADANI: Next slide.

15 (Slide.)

16 MR. THADANI: I'll put up the slide and really —  
17 I won't really touch upon it in order to save time I'll  
18 forego this unless you have specific questions. I'll be  
19 glad to address questions.

20 MR. MICHELSON: I have a question in this general  
21 area. Maybe you can tell me how you're treating it.  
22 Among the design bases events that the licensee is now to  
23 address are the pipe failures outside of primary containment  
24 — pipe breaks outside of primary containment. In looking  
25 through the study, I could not find any treatment of this

3 AGBpp

1 other than in the flooding sense. Where is the treatment in  
2 the environmental sense, the release of steam. For  
3 instance, they discussed a letdown line break in terms of  
4 what it does to doses offsite and they point out that it  
5 dumps about 4,100 gallons of water, 39 percent of which  
6 flashes to steam. But they never discuss the environmental  
7 effect of that steam on, potentially, on vital equipment.  
8 But only point out there's no dose problem.

9           Where is this being picked up. Maybe you could  
10 tell me. What part of the probabilistic study includes  
11 this?

12           MR. THADANI: I can't specifically respond to  
13 that for Millstone Unit 3. Perhaps Glen, you can identify  
14 specifically where in this study is this type of issue  
15 considered, analyzed --

16           MR. KELLY: Glen Kelly, with the staff. My  
17 recollection is that pipe breaks outside of containment are  
18 primarily handled as a flooding issue --

19           MR. MICHELSON: Well, clearly there's more than  
20 flooding involved depending on whether it's a high or low  
21 energy break. So my question is why is it apparently  
22 ignored high energy breaks, other than from the viewpoint of  
23 flooding effects. There must be a justification for this.

24           DR. OKRENT: Could I ask is the SER dealing with  
25 that?

3 AGBpp

1 MS. DOOLITTLE: The SER does address pipe breaks  
2 outside containment but it's open right now so that review  
3 hasn't been complete.

4 MR. OKRENT: Well, would you give Mr. Michelson  
5 an answer other than we're studying it if you possibly can,  
6 when next we meet?

7 MS. DOOLITTLE: Yes.

8 MR. THADANI: Mr. Michelson, basically, I concur  
9 that one ought to consider if one postulates leaks, breaks,  
10 whatever, that the consequences of that event do knock out  
11 systems, that one needs to protect against that event. If  
12 that is not being considered in terms of our review, I think  
13 we'll make sure we pick it up.

14 MR. MICHELSON: Yes, that's what I'd like to  
15 clarify. You know, it's a very large amount of  
16 documentation and it may be buried somewhere in it. I could  
17 not find it in the materials. I looked in the more obvious  
18 places, I thought. I could not find it in there. Other  
19 than from the flooding viewpoint with no reflection on  
20 humidity changes or steam releases or whatever — I could  
21 only find it on the letdown line and then only from the dose  
22 viewpoint.

23 MR. THADANI: I'll certainly look into it.

24 MR. MUELLER: I'd like to get a point of  
25 clarification. On your Item A.1. you say the dominant

4 AGBpp

1 sequence is attributable to system performance that failed  
2 to satisfy NRC REG requirements must be corrected.

3 Is the implication there then that if system  
4 performance does not affect or it is in no way part of a  
5 dominant sequence that it might be relaxed?

6 I just don't know how to read that sentence.

7 MR. THADANI: No. Actually, it's a very simple  
8 point here that we are looking at the probabilistic safety  
9 study, not paying too much attention to what our regulations  
10 are and requirements are. We're looking at systems in terms  
11 of their availability and not necessarily the pedigree. A  
12 pedigree may well influence availability of systems but  
13 having gone through this analysis we identify a set of  
14 sequences which appear to us to be more important than  
15 others.

16 Having gotten to that point we say, well, what is  
17 causing certain systems to perhaps have lower availability  
18 than one might want to have. And if the cause is that this  
19 system or function does not meet our current regulatory  
20 requirement, then that situation must be corrected. But the  
21 reverse is not necessarily true.

22 DR. SIESS: So it then does meet regulatory  
23 requirements you don't do anything about?

24 MR. THADANI: I'm sorry. Dr. Siess. I can't  
25 hear you very well for some reason.

2 AGBpp

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DR. SIESS: I said if it is a dominant contributor but it does meet regulatory requirements, that you would do nothing?

MR. THADANI: No. I didn't say that. Then we go on to one of two other places. Item number 2 really says is it so significant that one ought to take immediate corrective action. And item number E there says, well if the judgment is that one doesn't need to take immediate action what can one do that would improve safety and would be cost effective. And I don't necessarily mean -- when I talk about cost effective I'm not talking about cost benefit ratio of one and that kind of precision. Because there may be alternative ways to improve the situation to make some of the sequences less significant.

And so you move from A.1. to A.2. and then come to E and that's the process we're in at this state. And that's the type of document I was talking about, that we would hope to develop over the next three months.

MR. BENDER: Excuse me.

MR. OKRENT: Mr. Bender?

MR. BENDER: I get the impression that you're going to have, in about three months, something for Millstone. This process is going on in a number of places and I guess I would have to conclude that to make a judgment about Millstone 3 without taking account of Millstone 1 and

2 AGBpp

1 2 somehow doesn't seem to deal with the whole site. I'm  
2 more than a little confused about how to view the staff's  
3 ultimate application of this probabilistic risk assessment  
4 business. It seems to me that if the staff is following its  
5 intent to establish licensing stability which means to make  
6 some decisions and have them stick for a while, then it has  
7 to be a little less mushy about it.

8 And maybe you're not the right guy to speak to  
9 but you're the only one here.

10 MR. THADANI: But that is indeed -- but that is a  
11 consideration that has gone into severe accident policy  
12 deliberations. And I'd like to think that over the next two  
13 years that the staff, NRC, with commission approval, would  
14 have developed that process. And decided how to deal with  
15 essentially all the operating reactors not just talk about a  
16 specific plant which may be going through a licensing  
17 process.

18 Intellectually, I agree with you that three units  
19 on the same site -- there are differences in their power  
20 rating and so on -- but a lot of their faults may turn out  
21 to be generic and they apply to other units as well.

22 MR. BENDER: We have been waiting patiently for  
23 the staff to issue its report on this state of the art of  
24 probabilistic risk assessment and its applications. And in  
25 a sense you would expect to have that report before you

2 AGBpp

1 attempt to make some judgment about whether this particular  
2 study is useable and useful.

3 But I think I'll leave it there and say I wonder  
4 whether that's coming about any time soon.

5 MR. THADANI: That document is to be issued, I  
6 believe, in the next month or two months. But I guess I  
7 would state my opinion and I think the study's useful. It  
8 doesn't matter if any improvements -- design improvements --  
9 are made, but the mere fact of having gone through and done  
10 this study, in my judgment, the plant is -- would be safer  
11 because of the knowledge gained through very detailed and, I  
12 would call these logic analyses. That's all they are.  
13 Logic models.

14 The quantification process discriminates,  
15 provides you with some additional information. But the  
16 knowledge one gets going through this analyses and then  
17 trying to filter that information to other sections of the  
18 organization at Northeast, I think, it may well be the  
19 biggest value.

20 And so I have a personal opinion. I think other  
21 plants should also proceed and do such analyses. At least  
22 safety systems analyses -- carry them on, look at common  
23 cost failures and systems interactions and so on. Get a  
24 better of understanding of more people's failures, where the  
25 operators are needed, the fault hazard analyses on human



1 AGBpp

1 performance, I think, would be very, very useful. Totally  
2 outside of numerical analyses. It's a strong tool for that.

3 MR. OKRENT: Mr. Ebersole?

4 MR. EBERSOLE: Mr. Tnadani, it seems almost 100  
5 years ago when I asked the staff if they had any rationale  
6 about designing an interval three-unit station versus three  
7 independent units as though they were 100 miles apart. And  
8 I found that they didn't want to undertake whatever the  
9 complications are considering a multiple unit interval  
10 station as such a station. They insisted that they be  
11 separate stalls. And they did not want to involve  
12 themselves in the pros and cons of helping the units help  
13 one another or being in danger of each of other, so to  
14 speak. Both these effects exist, or can exist.

15 At this station, if we're going to invoke the  
16 matter the severe accident considerations with high level  
17 releases much beyond the minute releases that are presently  
18 controlled by the thesis that the containments will always  
19 close and be tight. Then we have to look at such things as  
20 are the control rooms, in fact, impervious to new levels of  
21 contamination and radiation beyond the point in which the  
22 operators can sit there and run the other two plants,  
23 supposedly undamaged, to a safe state. I don't think any  
24 of these considerations have been given.

25 And I think you have to either say you will or

2 AGBpp

1 you won't consider such potential. You can do things about  
2 this. You can extend air intakes. There's lots of things  
3 you can do. But what to do is the issue and the staff has  
4 been on dead center for at least 20 years.

5 MR. THADANI: I really have no comment on that  
6 one.

7 Unless you have further questions, that was  
8 essentially all I intended to say.

9 MR. OKRENT: I have a few. If I recall  
10 correctly, some of the data that was used in the Millstone  
11 PSS, that is failure data I'm speaking about, is marked  
12 proprietary, is that correct?

13 MR. THADANI: I believe some of the data has been  
14 indicated to be proprietary, yes.

15 MR. OKRENT: And it's being handled now as  
16 proprietary?

17 MR. THADANI: At this stage, to the best of my  
18 knowledge, it is being handled as proprietary. Whether the  
19 staff has made a finding, I am not sure, that, indeed,  
20 there's ample justification for the information to be  
21 proprietary.

22 MR. OKRENT: When is the finding to be made?

23 MR. THADANI: Has it been made or is it --

24 MR. KELLY: To the best of my knowledge the only  
25 proprietary data that the staff has received directly

2 AGBpp

1 concerning the probabilistic safety study involves reactor  
2 coolant pump seals. Westinghouse's data base upon which  
3 some of the unavailabilities of equipment and failure rates,  
4 the actual data that that was gathered from, that is  
5 considered proprietary. The staff does not have that as  
6 background data in its hands. It just has the results of  
7 that data. That is considered proprietary.

8 MR. OKRENT: Why?

9 MR. KELLY: We have not requested it and  
10 therefore as far as I am aware we don't have the  
11 justification for its being considered proprietary.

12 MR. OKRENT: I'm sorry. You don't have the  
13 justification for it being proprietary?

14 I wonder, has the staff thought through  
15 carefully, would it make sense to allow it to be proprietary  
16 -- I'll put it in a commercial sense -- and also what it  
17 makes sense to permit to be proprietary in a public policy  
18 sense, and whether or not these two are always compatible.

19 MR. THADANI: Most of those judgments are made by  
20 our office of Executive Legal Director's Office with some  
21 information from us as to what the issue is about. The  
22 rules that govern what can be considered proprietary and not  
23 and we provide information but we don't make those  
24 findings. In any case the finding is made by the NRC where  
25 just the attorney's make that finding.

3 AGBpp

1

MR. OKRENT: It seems to me that that input data into these calculations -- there's a final aspect of it -- other groups are for the most part, if not entirely, publishing the basis for their choice of data. If data that is used for a PRA is permitted to be proprietary only the result but not the background for it is presented. This makes it completely inaccessible to evaluation, peer review, and so forth and so on.

9

I wonder, myself, whether this is a sound approach. Has it been taken to the commissioners?

10

11

MR. THADANI: Has what been taken to the commissioners?

12

13

MR. OKRENT: Whether or not data like it's being withheld in this case, should be withheld.

14

15

MR. THADANI: I don't believe it has. I think Glen Kelly made the point that the Livermore review did look at the results of what was presented to us in the safety study with other sources of information. That doesn't really address the question you're raising. It would seem to me that that information should be obtained and the decision made. As far as I know, the decision has not been made as to whether it's appropriate to maintain this information in that proprietary form or not.

16

17

18

19

20

21

22

23

24

25

And this is the second item I will look into to see where we are and if we didnt make a finding there has to

1 AGBpp

1 to be some judgment by the staff one way or another.

2 MR. OKRENT: While you're looking, will you look  
3 to see why it is that the General Electric GESAR can be  
4 proprietary in large part and other similar PRA's or  
5 portions thereof. And I'd like to have a written opinion  
6 that it is NRC policy and why, if at all possible.

7 I find it troublesome myself for the whole  
8 thing. Let's see, according to my watch, we're at 12:15.  
9 I said we would break at 12:15 for lunch for one hour, so  
10 we'll do that. I have a few more questions for you  
11 Mr. Inadani, so we'll begin with that at 1:15.

12 (Whereupon, at 12:15 p.m., the hearing was  
13 recessed, to reconvene at 1:15 p.m., this same day.)

14

15

16

17

18

19

20

21

22

23

24

25

J WRBmpb

## AFTERNOON SESSION

(1:20 p.m.)

1  
2  
3 DR. OKRENT (Presiding): Let's see. When last we  
4 were chatting the question of the proprietariness of the  
5 Westinghouse data was something it was suggested one look  
6 into, and also in the same breath I mentioned it might be  
7 worth looking into some of the other things that are said to  
8 be proprietary in PRAs, other PRAs.

9 Somewhere I think in a presentation you mentioned  
10 a Brookhaven report. Do I recall that correctly?

11 MR. TNADANI: No, I don't recall mentioning any  
12 Brookhaven report, but, rather, that Brookhaven was also  
13 assisting the Staff in the review.

14 DR. OKRENT: I know, it said they are consulting  
15 on accident phenomenology and containment phenomena.

16 MR. TNADANI: That's correct.

17 DR. OKRENT: This is all verbal?

18 MR. TNADANI: We do not, to the best of my  
19 knowledge, as yet have a report from Brookhaven. But let me  
20 confirm that from Rich Barret.

21 Rich, is that correct?

22 MR. BARRET: I'm Richard Barret, I am with the  
23 Reactor Assistance Branch, NRC Staff.

24 We have a preliminary report from Brookhaven  
25 which was basically a preliminary review for use in

1 WRBmpb

1 preparation of the draft environmental statement. It is a  
2 letter report.

3 DR. OKRENT: Do we have it?

4 MR. BARRET: I'm not sure that you have it. I'll  
5 be happy to provide you with it.

6 DR. OKRENT: I can't imagine that the Brookhaven  
7 people work for some period of time and everything is by  
8 word of mouth. It would be helpful if we could -- that is,  
9 the ACRS could get letter reports, draft reports, Brookhaven  
10 memoranda, memoranda within the NRC Staff that bear on a  
11 particular PRA. In this case we're talking about the  
12 Millstone PRA.

13 From time to time I've mused about how I learned  
14 about things a couple of things later because the Union of  
15 Concerned Scientists or some other group used the Freedom of  
16 Information Act, and I only half-heartedly asked that we  
17 should send in a Freedom of Information Act request every  
18 month in order to be kept up to date and not rely on others  
19 to do it.

20 MR. COUNCIL: Dr. Okrent, Bill Council of  
21 Northeast Utilities.

22 It would be nice also if the Applicant could have  
23 received those reports.

24 (Laughter.)

25 DR. OKRENT: I absolutely agree.

1 WRBmpb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

So I think the Staff really needs to tackle this problem.

MR. TNADANI: Yes, I agree.

DR. OKRENT: it's about time. It's been too long.

MR. TNADANI: No, I certainly agree with what you're saying, Dr. Okrent, and I understand your comment.

In terms of the information that we provide to the Applicant, whatever we provide to the Applicant will be put in the PDR. And if there are some areas where the Staff hasn't reached that point and there's some pre-decisional material, I believe we don't make a practice of sending that information to the Applicants. And it's resigned now, we intend to follow those prior policies.

DR. OKRENT: But if the Union of Concerned Scientists sends in a Freedom of Information request then you supply all kinds of things.

MR. TNADANI: Anything we supply to the Union of Concerned Scientists there is no doubt in my mind that we ought to be supplying to the applicant, licensee, ACRS and others. As far as I am concerned I don't see any question in that.

I was only trying to make a distinction of some of the information that may be provided to you versus what might be provided to the applicant. And I don't know



1 WRBmpb

1 myself what the restrictions are. Clearly I know of the  
2 restrictions in terms of what we're supposed to give to the  
3 applicant and not supposed to give to the applicant.

4 DR. OKRENT: And we get less or more?

5 MR. TNADANI: I would think you get more. That's  
6 what I would think. It may be that in the past we've not  
7 provided you all the information. Certainly I have heard  
8 your comment and we will try to do better.

9 DR. OKRENT: Thank you.

10 MR. HERNAN: Dr. Okrent, this is Ron Hernan on  
11 the Staff.

12 Do I interpret your comment to be limited to PRA  
13 issues, or is this any matters involving licensing action?

14 DR. OKRENT: This is what you would call a  
15 generic matter, an unresolved safety issue. Is there some  
16 other term?

17 (Laughter.)

18 DR. OKRENT: But I'm just wondering, maybe I had  
19 better go the legal route.

20 MR. HERNAN: I think I understand your question.  
21 Let me commit, on behalf of NRR, that I will discuss this  
22 with Mr. Denton and we will have a dialogue at some future  
23 time. I don't think we can give you a real clear answer now  
24 or a commitment that every draft document will be sent both  
25 to the applicant or licensee and the ACRS.

1 WRBmpb

1 DR. OKRENT: I can give you all sorts of  
2 examples, not necessarily that apply to Millstone, of things  
3 that have turned up because other people put in Freedom of  
4 Information requests, information that was certainly of  
5 interest which the Staff chose not to send to the ACRS, or  
6 late, or perhaps not at all.

7 MR. TNADANI: I think when you put it that way,  
8 information that was of interest to you that we did not  
9 provide to you, I understand your comment.

10 But the Staff -- almost on any study, the  
11 documentation is enormous and perhaps some fraction of it is  
12 of not much real value to you. Somehow there is a  
13 discrimination process that has to be gone through.

14 But, yes, we have received several requests from  
15 the Union of Concerned Scientists and we have made available  
16 to them about ten or twelve boxes of material; how much of  
17 it may be of value to you at least at this stage it's  
18 difficult for me to assess.

19 But I understand your comment and will certainly  
20 give it closer attention. As Ron said, we'll pursue this  
21 matter further ourselves.

22 DR. OKRENT: Well, that's about the fourth time  
23 I've had this question end up this way.

24 All right. Let's go on to another topic.

25 You mentioned something about looking at

1 WRBmpb 1 fragilities. But I guess I didn't know quite what you meant  
2 you were going to do.

3 MR. TNADANI: Fragilities? Seismic related  
4 fragilities for structures and components?

5 DR. OKRENT: Yes, what do you have in mind?

6 MR. TNADANI: Well, we basically -- our initial  
7 process, that we have to a large extent completed, was to  
8 review the Applicant's revised material. The next step is  
9 there are, we believe, some holes that need to be pursued.  
10 We would certainly look to see what the dominant scenarios  
11 are from systems analysis and which components might be most  
12 fragile.

13 That's the process. And we're not there, we're  
14 not at the end yet.

15 DR. OKRENT: In a sense, which components are the  
16 most fragile may tell you which are the dominant scenarios  
17 rather than vice versa.

18 MR. TNADANI: It could be that way too. But some  
19 fragile components may not result in a core-vulnerable  
20 state.

21 DR. OKRENT: But you don't seem to have any  
22 systematic way of evaluating the current base of fragility  
23 information.

24 MR. TNADANI: We have -- We're clearly in need of  
25 more information. We have requested, as I think you know,

.1 WRBmpb

1 the Office of Research to develop a better data base,  
2 identify areas where further experiments might be useful.

3 There is the seismic margins activity that is  
4 going on. I understand they are going to be developing  
5 their plan, if I remember correctly, by the end of this  
6 calendar year. And this element is critical to that  
7 process.

8 So, yes, there are some limitations, clearly.  
9 There is a need to do more. Where one should do more is a  
10 question that is being addressed as a part of the margins  
11 activity.

12 DR. OKRENT: Let me ask a different question.

13 Is it your intent to have the review being done  
14 for you of the Millstone PSS to be rather similar and  
15 equivalent in nature to that done for Zion, let's say, and  
16 Indian Point, or to be of a different nature, and, if so, of  
17 what different nature and why?

18 MR. TNADANI: The review is in many aspects  
19 similar to Zion and Indian Point. There are some  
20 differences. There is less of an emphasis on  
21 requantification by contractors and Staff; some greater  
22 attention to searching for potential combinations of events  
23 that might lead to undesired end conditions.

24 The resources are essentially limited, fixed, if  
25 you will --

1 WRBmpb 1

DR. OKRENT: Less resources.

2 MR. TNADANI: I don't think on Millstone the  
3 resources that we're spending are less. They are certainly  
4 less than the resources we have spent on Limerick. The  
5 trend may be in that direction. So the reviews have to be  
6 modified in some respects.

7 But on Millstone, if I compare Millstone to Zion  
8 and Indian Point I would say they are reasonably comparable  
9 in resource considerations. But there are some variations:  
10 Less emphasis on requantification, greater attention to  
11 searching for potential common cause failures, looking at  
12 room cooling, looking at service water systems and so on. I  
13 can't give you an answer which one is better. I'd like to  
14 think that as we learn more we do better.

15 DR. OKRENT: Do you find the draft Livermore  
16 report is useful to you in trying to judge whether certain  
17 systems or configurations should be at least examined in  
18 greater depth or perhaps are clear candidates for  
19 consideration for improvement, as was the case with the Zion  
20 and Indian Point reviews?

21 MR. TNADANI: I think there is a little bit of a  
22 difference here. We were in a great deal of rush to try to  
23 provide whatever information we could for completion of our  
24 draft environmental statement. For that reason Livermore  
25 didn't really have a lot of time; they had limited time.

2 WRBmpb

1 And for that reason their report was I believe marked draft,  
2 preliminary, incomplete. It had a lot of qualifiers to it.  
3 most of them I think appropriate.

4 DR. OKRENT: Well, there's a draft report out  
5 very earlier, like January or --

6 MR. TNADANI: It was out February-March, yes,  
7 that time frame, that's correct. And I thought that's the  
8 one you were referring to.

9 DR. OKRENT: I'm referring to what is now the--

10 MR. TNADANI: Oh, the June.

11 DR. OKRENT: -- the June draft or May draft.

12 MR. TNADANI: Yes. I think there are clear  
13 indications in two or three areas that we have to pay more  
14 attention to. I think seismic is one. Station blackout is  
15 another. In fact, I think the Staff might be a little more  
16 concerned than what is reflected in the Livermore report on  
17 station blackout. And those two areas, at least in my mind,  
18 seem to stand out as deserving special attention.

19 DR. OKRENT: Well, you know, Mr. Kerr frequently  
20 asks you what are you going to do with these PRAs, and so  
21 now I'm asking you what are you going to do with the review  
22 of the Millstone PRA and are you going to have more detailed  
23 follow-ups in some areas or what?

24 MR. TNADANI: I think clearly in some areas I  
25 think we're just -- I don't think there is much of an

1 WRBmpb

1 alternative but to have a follow-up effort. In the area of  
2 station blackout -- I think that's probably true in the area  
3 of seismic.

4 In the area of station blackout we do have, as  
5 you know, generic safety issue B-23 on reactor coolant pump  
6 seal performance, and there is some discussion, as you're  
7 well aware, of elevating that issue to an unresolved safety  
8 issue. At least we continue to believe that that's a very  
9 important issue and that it should indeed be pursued  
10 aggressively. Resolution should be obtained for that issue  
11 as early as is possible.

12 One way one might be able to accomplish that is  
13 to elevate it in terms of its importance, in terms of their  
14 resources that could be put on it. As part of that  
15 activity, as you know, there are some tests being run, there  
16 is some discussion going on now about running full-scale  
17 tests using blackout-like conditions to see what the  
18 performance would be.

19 I don't know, at least speaking from the Staff's  
20 side, that that would -- some more information is needed; we  
21 just don't have enough confidence as to the performance of  
22 the seals.

23 I think for some reasons offsite power may be  
24 more reliable for Millstone 3 than others. I don't know  
25 right now. But in terms of onsite AC power this unit has

3 WRBmpb

1 two diesel generators so that there is some redundancy as to  
2 what that means.

3 MR. EBERSOLE: Mr. Tnadani, why did you say it  
4 that way, 'it has two,' as though that were exceptionally  
5 good?

6 MR. TNADANI: No, I didn't mean it that way at  
7 all.

8 I meant to say we've looked at, as you know,  
9 several plants. There are some plants where they may have  
10 two units — two diesel generators per unit. But frequently  
11 they have the capability to utilize diesel generators from  
12 one unit for the next unit. They have some other kinds of  
13 capability in terms of component cooling water, which is  
14 essential, cross-ties, service water system cross-ties in  
15 some cases.

16 There are ways that, even if a unit had only two  
17 diesel generators there are ways one could improve or reduce  
18 the likelihood of losing seal cooling functions.

19 What I was suggesting was that I don't think I  
20 have seen any plant where they had less than two diesel  
21 generators except I do know of some two-unit sites where  
22 they have three diesels which are shared by two units. So  
23 in that regard having two diesel generators per unit might  
24 be better.

25 MR. EBERSOLE: These particular diesels, what is



1 WRBmpb

1 known about their standing reliability record? They are  
2 unusual machines, I think; they are of foreign make; maybe  
3 they're better than anything else, I don't know.

4 MR. TNADANI: They might be better. As I  
5 understand the preoperational experience to indicate that  
6 their reliability in terms of starting reliability might be  
7 better. But we have to temper that because in some other  
8 cases of diesels we found that preoperational testing to  
9 indicate higher reliability than actually seen during normal  
10 operation.

11 DR. KERR: Just a question of clarification. I  
12 thought they were Fairbanks-Morse diesels. Is that a  
13 foreign manufacturer?

14 MR. CROCKETT: They are Fairbanks-Morse diesels.

15 MR. EBERSOLE: They are foreign-manufactured?

16 MR. CROCKETT: No.

17 MR. EBERSOLE: They're not? They're domestic  
18 machines?

19 MR. CROCKETT: Yes.

20 MR. EBERSOLE: How many of those have been built?

21 MR. CROCKETT: There are over 1000 units in  
22 marine use. And if you want the exact numbers of nuclear  
23 use we have Mr. Ray Necci who can respond to that.

24 MR. NECCI: I'm Ray Necci, manager, Mechanical  
25 Systems Engineering.

J WRBmpb

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

There are currently five Colt-Peelstick engines in service. Colt Industries is the manufacturer in the U.S., Colt-Fairbanks-Morse. Peelstick is the name of the engine, and that is based on a French design by the company name of SENT-Peelstick.

MR. EBERSOLE: And there are how many that are carbon copies of those?

MR. NECCI: There are currently five Colt-Peelstick engines that have been in service since 1978.

MR. EBERSOLE: Five?

MR. NECCI: Five units, yes, sir. A total of 27 units have been sold for nuclear service.

MR. EBERSOLE: How does that compare with the 500 I heard a while ago?

MR. NECCI: The total industry experience of this type of engine -- I'm not sure about the 500, but there are approximately 1000 of these types of engines in service in marine applications and approximately 300 of these types of engines in stationary applications. And that is since 1964. The experience beyond that is much, much higher.

MR. EBERSOLE: When you say "this type" to what extent do you mean identical or not?

MR. NECCI: The model engine that we have at Millstone 3 is entitled a PC-2, and that designates a frame

2 WRBmpb

1 size that is based on horsepower per cylinder. The 1000 and  
2 300 number that I quote are of the PC-2 design.

3 MR. EBERSOLE: So they are a different design?

4 MR. NECCI: No, sir, they are the same frame  
5 design. They may have different numbers of cylinders but  
6 they are the same rating.

7 MR. EBERSOLE: Per cylinder?

8 MR. NECCI: Per cylinder, yes, sir.

9 DR. OKRENT: One last question:

10 Mr. Inadani, to what extent do you feel systems  
11 interactions were taken into account in the Millstone 3 PSS?

12 MR. INADANI: I think, not knowing the details of  
13 the Millstone probabilistic safety study, I would perhaps be  
14 better off asking either a Staff member or a consultant.

15 Perhaps, Abel, could you address Dr. Okrent's  
16 question?

17 MR. GARCIA: I'm Abel Garcia with Lawrence  
18 Livermore National Lab.

19 I think the answer to the question is that they  
20 were considered in the systems analyses that were folded  
21 into the evaluation.

22 A separate evaluation of systems interaction was  
23 partially considered in the dependency analysis that was  
24 conducted in the PSS. But I really can't answer beyond that  
25 at this time.

J WRBmpb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DR. OKRENT: Any other questions for Mr. Tnadani?

(No response.)

DR. OKRENT: Thank you.

MR. TNADANI: Thank you.

DR. OKRENT: I guess we'll go on to the next agenda item.

It's clear that we will not be able to cover all of the matters which were optimistically put in the tentative schedule. I will ask the Applicant to try to focus on those matters of most significance, as he sees them, resulting from the study.

#### SUMMARY OF THE MILLSTONE UNIT 3 PSS

MR. BONACA: Good afternoon. My name is Mario Bonaca. I am system manager of Reactor Engineering at Northeast Utilities.

The purpose of my presentation was to provide you with an overview of the Millstone 3 PSS and some of the intended applications.

My presentation was to be followed by a presentation of Dr. Bickel, who was the coordinator of the PSS study. We had left almost two hours go to into detail of the studies, and he was to cover particularly significant issues in the PSS such as systems interaction and results.

His presentation was to be followed by the one of Dr. Dube, who is a senior engineer in the PRA section of NU,

1 WRBmpb

1 who was intimately involved with containment and consequence  
2 analysis.

3           Since we have less time available I would propose  
4 that I will go through an overview to you that you will  
5 temper or cut back as you wish. And I would then like to  
6 call upon both Dr. Bickel and Dr. Dube to expand on those  
7 areas that you would want to cover today. Significant  
8 issues, for example, systems interaction, we may cover that  
9 if you wish, and so on.

10           But let me go on with my presentation to start  
11 with and see if it is of significance to an overview. I  
12 believe it is.

13           (Slide.)

14           DR. OKRENT: Why don't you assume that Millstone  
15 will have between now and about 3:10, including questions.  
16 And you can divide it up however you see fit. That's about  
17 an hour and twenty minutes. I'm sorry, but we'll have a  
18 long time some other time to go into details.

19           MR. BONACA: Okay.

20           Let me start by saying I want to point out that  
21 well before we received the request of the NRC for a plant  
22 specific PSS for Millstone 3 Northeast Utilities had been  
23 planning to perform probabilistic studies to core melt for  
24 all of our plants, and the intent was to use these PRAs as  
25 an engineering tool for the decisionmaking process. The

1 WRBmpb

1 reason why we set up, in fact, in 1980 a task force to  
2 assess how we could do that was because we had found in the  
3 late '70s significant insight into equipment performance  
4 and, at times, shortcomings in our operating units due to  
5 limited scope PSS performance.

6 In mid-1980 we recommended, in fact, an in-house  
7 performance, maintenance, end-use of PSS for all of our  
8 plants, and the Millstone 3 PSS was scheduled to have -- to  
9 be performed in the 1986-'87 time frame, essentially after  
10 construction.

11 (Slide.)

12 The 1981 NRC request for a Millstone 3 PSS  
13 modified our planned priorities, of course. And we assigned  
14 all of our resources to the Millstone 3 PSS. At that time  
15 these resources were five individuals in the PRA section,  
16 with some significant support in transient analysis and LOCA  
17 analysis, fully assigned to those functions.

18 The request of the NRC, as you know already, was  
19 for a PSS to address both internal and external  
20 consequences, and to address -- internal events, I mean --  
21 and to address external consequences.

22 In particular the PSS was to address what I would  
23 call a frozen design here. We had to freeze the plant to  
24 the 1982, February design stage in order to be able to  
25 perform an ordinate kind of study. And the objective of the

1 WRBmpb

1 study clearly was one of obtaining an assessment of risk of  
2 Millstone 3.

3 We performed the study in this fashion, pursuing  
4 this objective, and we submitted the study to the NRC on  
5 August 1, 1983.

6 It's clear that since we intended also to pursue  
7 our objective of having what we call a living-PRA, which is  
8 a PRA amenable to be updated and utilized in support of  
9 plant operation and safety, we were kind of concerned about  
10 what or how we would then be able to update this PSS to be  
11 usable during operations. So therefore we spent a  
12 significant amount of time in early 1982 to write  
13 specifications.

14 In particular Dr. Bickel spent several months  
15 reviewing past PSSs looking at shortcomings, areas where we  
16 felt we had to strengthen our process. And also we put in  
17 our specifications to our vendors the requirement for a  
18 technology transfer. We wanted to have a PSS installed on a  
19 computer-dedicated system in our office so that we could  
20 exercise this system.

21 (Slide.)

22 Also we had to think very deeply at that time  
23 because we felt unless we had a staff of knowledgeable,  
24 capable and experienced people truly trained into the  
25 understanding of the fault trees we will never understand

1 WRBmpb

1 the PSS sufficiently to utilize it in support of operation  
2 and safety. All this was built in up-front into this  
3 process.

4 We then hired Westinghouse as the main contractor  
5 to perform the job, and we had Stone and Webster performing  
6 most of the subcontractor functions, although we had also  
7 additionally eight subcontractors for this study.

8 (Slide.)

9 Here this overhead indicates some of the review  
10 functions that were essential to us. We assembled an  
11 in-house PRA team to supervise the study and to effect the  
12 technology transfer. This also was the most intimate review  
13 process we could implement in that -- And I must say that  
14 many of our engineers spent many, many weeks going back and  
15 forth between here -- between Berlin and Pittsburgh to  
16 assure that we were truly intimately involved both in the  
17 decisionmaking process in certain actions, and also into the  
18 understanding of the sequences.

19 DR. MUELLER: Are you going to say how much  
20 in-house effort was spent on this PRA?

21 MR. BONACA: Yes. I can summarize it right now  
22 by saying that we had a full time effort of approximately  
23 seven or eight engineers, fully-dedicated from Reactor  
24 Engineering into this effort, plus we had a plant scheduling  
25 individual who utilized computerized methodology to maintain



1 WRBmpb 1 this process on track.

2 We had mechanical, electrical and civil  
3 engineering support from our in-house staff as needed. We  
4 had significant support from the plant personnel in  
5 providing us with insights into the application of ERGs as  
6 well as providing us with insights into an ENICO practice,  
7 which we feel is significant to the way that the ERGs would  
8 be interpreted in support of the operation of Millstone 3.

9 MR. EBERSOLE: May I ask a question?

10 With all this intimate attention to detail, is it  
11 true that at this time that when you looked at the AC power  
12 failure, the total power failure, that you included that  
13 facet of it related to reactor coolant pump seal failure in  
14 aspect to containment pressure rise?

15 MR. BONACA: I'm sorry, I didn't understand  
16 fully your question.

17 MR. EBERSOLE: I say when you looked at the total  
18 AC power failure and picked up the fact that the seals may  
19 leak, you would almost intuitively look for a loss of core  
20 coolant in the context of losing the core, but not pick up,  
21 perhaps, that what was really happening faster than that was  
22 the containment pressure and temperature was becoming  
23 uncontrollable.

24 This was something that came out of a recent  
25 meeting; I think Mr. Michelson picked this up. It seems

1 WRBmpb

1 that the schedular aspects of recovering power may have to  
2 be vastly diminished because it's the containment pressure  
3 that's running away, not the core heating. Is that in your  
4 PRA?

5 MR. BONACA: I'll let Dr. Dube address this  
6 question because he performed those analyses on containment.

7 DR. DUBE: Dr. Donald Dube from NUSCO's PRA  
8 section.

9 If one looks at the generic Westinghouse ERGs, I  
10 believe there is some calculation of containment response as  
11 a result of reactor coolant pump seal leakage, and there was  
12 nowhere near what you seem to be indicating in terms of  
13 containment pressurization. And indeed, we have performed  
14 calculations for a wide spectrum of small LOCAs which  
15 indicate that the containments would not really pressurized  
16 that much; they would not even reach design pressure for  
17 some time.

18 MR. EBERSOLE: Right. Even though it has no heat  
19 removal?

20 DR. DUBE: That's correct.

21 MR. EBERSOLE: Thank you.

22 MR. BONACA: The other essential review process  
23 we viewed was the one of assembling, you know -- The expert  
24 review board was chaired by Professor Rasmussen and the  
25 other two members were Sol Levine of NUS and Dr. Wood of

1 WRBmpb

1 Wood, Leaver and Associates. We were very concerned about  
2 the function of this review board. We involved them very  
3 heavily in review processes, in particular where there were  
4 concerns raised with common cause and with the human  
5 factor. We assigned in-depth and extensive reviews to the  
6 organizations of Dr. Wood and Sol Levine to perform, and  
7 most of all to give us a statement of adequacy and to, if  
8 necessary, redirect the study.

9 I would want to say that this review board acted  
10 in this PRA at times as a steering group. We really used  
11 them in this particular fashion, allowing them to redirect  
12 the efforts of our contractor whenever we felt that there  
13 were shortcomings.

14 We also requested the review board to provide us  
15 with a statement of -- well, summarizing their findings at  
16 the end of the study, feeling that, well, if they had to put  
17 it in writing they probably would do a more in-depth  
18 review. And so we got a report on the study also.

19 I would like to summarize in the next overhead in  
20 a nutshell the conduct of the study.

21 (Slide.)

22 We looked at the external and internal events. I  
23 must say, from a management standpoint, that our major  
24 concern was the one of completeness. And, again, we do not  
25 pretend to be able to find everything there. But we were

2 WRBmpb

1 very much aware of the fact that significant initiators are  
2 not identified in Chapter 15, and that that's not news to  
3 anyone. We did whatever we could, and we had in mind  
4 systematically to utilize too to find initiators.

5 I think at some point I would like to have later  
6 on Dr. Bickel —

7 (Whereupon a fire alarm was sounded.)

8 MR. BONACA: Again here I am referring to  
9 completeness.

10 I would like to point out in the top five  
11 dominant contributor sequences to core-melt probability for  
12 this plant we find three which are known Chapter 15 events,  
13 essentially loss of vital AC, loss of vital DC. And we find  
14 many other of these sequences which really were part of the  
15 systems interaction study, which is part of the PSS. And  
16 Dr. Bickel can address that later. But again, completeness  
17 was a great concern to us.

18 We studied event trees and fault trees using  
19 techniques which are very consistent with PRA guides. We  
20 did do extensive work in containment. We felt that there  
21 were some features, such as the sizeable RWST, that provided  
22 the amount of, you know, delaying of certain sequences into  
23 containment challenge that would provide significant insight  
24 into accident management conditions. And I think we felt  
25 from the beginning that we could get a lot of insight for

1 operators into those conditions by studying the sequences.

2 And finally, we utilized the standard techniques,  
3 such as the CRAC-2 code, to evaluate external consequences.

4 I would like to summarize in this slide  
5 significant findings.

6 (Slide.)

7 Among all the sequences which we have identified,  
8 no individual accident sequence contributes more than ten  
9 percent of the internal core-melt frequency. And we  
10 conclude that there is no single plant feature that stands  
11 out as a risk outlier.

12 Thirteen separate accident sequences each  
13 contribute between one and nine percent, and in total they  
14 contribute approximately 50 percent to internal core-melt  
15 frequency.

16 You realize that in performing this evaluation  
17 and in making this statement we are as concerned as anybody  
18 can be about uncertainties. It is obvious that  
19 uncertainties can skew a risk profile as such, as we present  
20 here. And we are aware of that. And we feel that this  
21 statement I am making here is a first statement.

22 MR. EBERSOLE: There's a word up there that  
23 bothers me a little bit. It is "internal." I see it in two  
24 places. What does that mean?

25 MR. BONACA: Oh, yes. I am referring here to a

1 WRBmpb

1 core-melt frequency from internal events.

2 Then there are four dominant sequences in the  
3 seismic analysis that — but again the seismic contributor  
4 that we will present to you later on is as far as the  
5 results it is not a major contributor to the total melt,  
6 core melt frequency for this plant.

7 (Slide.)

8 I would like to summarize here in three overheads  
9 to you what I view as strengths of the Millstone 3 PSS —  
10 the strength of the Millstone 3 plant, as shown in the PSS.  
11 I'm not implying that these are not typical strengths of  
12 other plants too; I'm only saying that we see the effects of  
13 strengths into the systems, into the PSS analysis.

14 First of all, the auxiliary feedwater system. It  
15 is the system, as you have seen, which is made up of two  
16 electric and one steam driven pump. Each one of them has  
17 the capability of removing decay heat all by itself.

18 There is no dependency on instrument air,  
19 component cooling or service water. And loss of instrument  
20 air will auto-start — or DC power will auto-start the steam  
21 driven pump. And we feel that — Well, we see that there is  
22 sufficient redundancy, diversity and independence in these  
23 pumps to provide a net unavailability on demand for the  
24 system which is low, even assuming and considering in it  
25 common mode failure components. We still find a number of

1 WRBmpb

1 the order of 6.8 and ten-to-the-minus-five unavailability of  
2 demand for this system. And we consider this a strong  
3 system.

4 We have strength into the high pressure injection  
5 capability. By that I mean both charging pumps and  
6 self-injection pumps. The fact that they are all  
7 self-degrade pumps is significant. The fact that they are  
8 located in two different buildings I think is significant.  
9 The fact that they have dedicated and independent pump  
10 cooling is significant, although clearly there are two  
11 trains which are cooled by service water too insofar as the  
12 independent cooling loops.

13 Feed and bleed capability is a significant  
14 strength of this plant. And the one HPSI and two PORVs are  
15 sufficient to perform this function.

16 MR. EBERSOLE: May I ask, are those PORVs  
17 competent to withstand the environment within which they  
18 will have to work?

19 MR. BONACA: Yes, they are. They have been  
20 qualified.

21 MR. EBERSOLE: Thank you.

22 (Slide.)

23 MR. BONACA: I will not go over again the RWST  
24 capacity. It is true that it is required maybe for a large  
25 break LOCA scenario. The fact is that it is a large

2 WRBmpb

1 inventory of water and on many scenarios it provides an  
2 extra margin which is not found typically in other PWRs.

3 I mention here the dry --

4 DR. MUELLER: Mr. Bonaca, can I back you up a  
5 second on RWST?

6 In the very beginning of your PSS you state the  
7 RWST capacity as something that contributed favorably to low  
8 risk.

9 There is, then, a sentence in there that said  
10 something about your not taking benefit from that capacity  
11 in a quantitative sense.

12 And then when I read your results you said the  
13 reason one of the small LOCA scenarios was not a dominant  
14 was because of the RWST capacity.

15 Did you or did you not take credit in your  
16 accident recovery times for the RWST?

17 MR. BONACA: Yes, we did.

18 DR. MUELLER: Okay. Thank you.

19 MR. BONACA: I would like to point out here a  
20 combination of features that required extensive analysis on  
21 our part.

22 The original inspection of the plant at the  
23 beginning of the PSS showed a cavity which was dry design  
24 and yet it could be changed very quickly into a wet design  
25 because there was an opening and there was not a close on



2 WRBmpb

1 that to the sump.

2 Therefore we really performed extensive analyses  
3 in containment to understand whether or not a dry cavity was  
4 a benefit to us.

5 And we came to the conclusion that the  
6 combination of the dry cavity and the basaltic concrete,  
7 which managed to produce legal CO-2 caused the following:

8 In the early containment core melt situation we  
9 don't have the large overpressure plateau over which the  
10 pressure spike could challenge containment.

11 This is a generic statement, clearly. It does  
12 not apply to every sequence, but it applies to most, and it  
13 is a strength in this plant. It convinced us of staying  
14 with the dry cavity for most situations.

15 And, of course, the basaltic concrete is a  
16 benefit too in that a low production of CO-2 will give us a  
17 low pressure plateau based on CO-2 production and legal CO  
18 for CO burns.

19 Finally, the containment spray system --

20 DR. OKRENT: Excuse me.

21 Based on your studies would you suggest that Zion  
22 try to take steps to find a dry cavity with basaltic  
23 concrete if they could?

24 MR. BONACA: I'm sorry, could you rephrase the  
25 question? I can't hear you very well.

1 WRBeb

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

DR. OKRENT: As you well know, the Zion and the Indian Point 2 design say that under most circumstances, they expect to have a wet pressure vessel cavity and they find advantages, for the most part, maybe for all parts, as far as they're concerned.

You have a dry cavity. You found it is better than to try to make it a wet cavity.

MR. BONACA: Yes.

DR. OKRENT: I am asking, do you recommend that Zion change to the dry cavity?

MR. BONACA: Let me say first of all that it is a borderline recommendation. If Don Dube has time to show his results, it will show you that really it wasn't such a tremendous advantage, having a dry cavity. It showed, however, that in many sequences there was some advantage there in that there was no justification for going to a wet cavity.

It wasn't really such a strong-- Clearly looking at strict challenges versus hydrogen burns there, and there are a lot of considerations going behind the decision.

Containment spray systems. We have already described these systems, and Millstone Unit 3 employs a quench spray which has two pumps, as you know, and a recirculation spray with four pumps. The recirculation sprays do not utilize the decay heat removal pumps. They

1 WRBeb 1 utilize—

2                   What I mean, the low pressure injection is not  
3 provided through the decay heat removal system; it is  
4 provided through the recirculation pumps which can be  
5 utilized both to provide high pressure injection and  
6 recirculation or low pressure injection and recirculation.  
7 And these two spray systems delay substantially containment  
8 failure in many events.

9                   Each one of these systems has a significant,  
10 reasonably high unavailability — low, I mean,  
11 unavailability on demand, and the combination of the two is  
12 a strong feature of this containment safeguard.

13                   I would like to finally summarize these findings  
14 saying that we find the ultimate containment strength of  
15 117.7 psi to be pretty much in line with other evaluations  
16 for plants of similar design. We never took any credit for  
17 the enclosure building and yet there is a collection and  
18 release system in that building. And if there is a leak before  
19 break is to be the effect of a failure of containment, there  
20 will be some mitigation provided by the enclosure building,  
21 too.

22                   Meteorology is not a design feature but we like  
23 to have it always with a prevailing wind towards Long Island  
24 Sound. That's favorable.

25                   I have not mentioned here some of the strengths

1 WRBeb

1 such as the third valve for the increased sequence that  
2 Mr. Thadnani mentioned before, and loop-stop valves. I want  
3 to just state that the third valve is there. We are only  
4 evaluating whether or not the piping of the valve is  
5 qualified for high pressure. We believe it is.

6 And the loop-stop valves, the only use we would  
7 make of this valve at this stage would be I would say for  
8 long-term control and isolation of a break. It would not be  
9 considered a short-term mitigation of events. Clearly we  
10 will not operate those valves until the system is stabilized  
11 and safeguards are on standby.

12 MR. BENDER: I wonder if I can ask a question  
13 about the time available.

14 You have indicated that this RWST system gives  
15 you more time. It should, I suppose. But what is the  
16 target? What is a good time? What would you judge to be a  
17 good period of time to make a case for the safety of the  
18 Millstone plant, and what would be a bad time?

19 MR. BONACA: Let me explain, please.

20 MR. BENDER: Yes.

21 MR. BONACA: I cannot give you hard and fast  
22 numbers. All I want to say here is, for example, if we  
23 looked at the -- I don't know, as an example, the in-core  
24 instrument tube rupture event, we can show how we can  
25 withstand an event. I believe substantially it is about

1 WRBeb

1 24 -- 17 hours before seeing a core melt if we have  
2 utilization of the RWST.

3 Now if you compare that with what we are seeing  
4 for other plants of similar design, I consider 17 hours a  
5 significant amount of time for action. I would consider a  
6 few hours questionable.

7 MR. BENDER: Why?

8 MR. BONACA: Because--

9 MR. BENDER: What are you going to do in the 17  
10 hours versus four or three or two, or whatever the number  
11 is?

12 MR. BONACA: What you view I believe is also--  
13 What you see is a company which I believe since 1979 has  
14 given up a lot of capabilities also outside the control room  
15 of the plant itself. We have an emergency operating  
16 facility. We have an emergency operating center where --  
17 for example, typically doing exercises to, myself and my  
18 staff, provide inputs.

19 There is a way by which we can get outside  
20 expert insight on how to proceed, first of all in managing  
21 events from an engineering standpoint, and second, in  
22 providing resources right onsite to add water, and that kind  
23 of thing. Things can be done.

24 MR. BENDER: Well, are you looking at those  
25 strategies? I agree with the viewpoint that more time

1 WRBeb 1 should give you more opportunity. But in trying to  
2 understand the PRA and what the significance of the time is,  
3 I'm still left with the feeling that if you don't have a  
4 strategy that makes use of the time, you have only done an  
5 arm-waving exercise.

6 MR. BONACA: We have strategy. I can mention to  
7 you, and I believe it's a fact that in a drill that we had  
8 recently on Millstone 1 we already had a bulldozer lined up  
9 outside an auxiliary building wall, and the fire pump ready  
10 to pump water, and we knew exactly how to connect it and we  
11 have also nozzles to do so.

12 So there are backup actions that we have  
13 planned. They are more a part of what I would call the  
14 EOC/EOF support.

15 But I will show to you later and I think that is  
16 the significance then of the Millstone PSS. We have a lot  
17 of dialogue going on with the operator of these plants, and  
18 I really feel that that is where the Millstone 3 PSS is  
19 going to pay off.

20 MR. BENDER: I am only thinking of this in terms  
21 of, you know, what I can tell the public if I were sitting  
22 where you were about why this plant is safe, and being able  
23 to say that I've got some resources outside the containment  
24 that I can take advantage of that I haven't even taken  
25 credit for up to now would I think make the story a lot

1 WRBeb

1 better. But it is hard to get that out of the PSS at the  
2 moment.

3 All I can find out now is that you might have 17  
4 hours and that you can do a lot with them.

5 Thank you.

6 MR. EBERSOLE: May I ask for just a moment to  
7 return to that question a while ago about the reactor  
8 coolant pump seal leakage subsequent to AC power failure?

9 MR. BONACA: Yes?

10 MR. EBERSOLE: What number did you use for the  
11 totality of primary coolant leakage into the containment  
12 under this circumstance?

13 MR. BONACA: We looked at the spectrum of leak  
14 rates ranging all the way to 300 gpm.

15 MR. EBERSOLE: I'm sorry, I wanted the total, the  
16 total leakage from all four pumps.

17 MR. BONACA: 1200 in all. But of course there  
18 was one other value assumed.

19 MR. EBERSOLE: 1200 gpm?

20 MR. BONACA: Yes.

21 MR. EBERSOLE: That was the upper end of it?

22 MR. BONACA: The upper end of it, yes.

23 MR. EBERSOLE: Thank you.

24 MR. MICHELSON: I find your reply a little  
25 confusing. You're saying you are pouring out reactor

2 WRBeb

1 coolant at full pressure and temperature at the rate of 1200  
2 gallons a minute. And at what point in time did you reach  
3 the design pressure of the containment with no heat removal,  
4 including of course the heat loading you are getting from  
5 all of the hot materials within the containment after loss  
6 of cooling?

7 MR. BONACA: I will have Dr. Dube respond to the  
8 question.

9 MR. MICHELSON: I think you will find other  
10 people have done this calculation as well.

11 MR. BICKEL: In mind of your question, I will  
12 attempt to address that in my presentation.

13 MR. MICHELSON: I'm going to be leaving in about  
14 two minutes.

15 MR. BICKEL: Then let me try to give you one  
16 two-minute answer.

17 The scenarios we looked at concentrated on what  
18 was the most likely station blackout. Okay? The most  
19 likely station blackout would be a loss of offsite, a  
20 complete failure of the onsite AC power system, but with the  
21 auxiliary feedwater system still available, the steam-driven  
22 portion of it.

23 We have analysis that indicates that all the  
24 features needed in the control room to maintain both vital  
25 AC and vital DC following the station blackout should be



1 WRBeb 1 available. In other words, we've determined that there are  
2 no environmental considerations like in the steam turbine  
3 cubicle or in the areas such as the electrical switch gear  
4 room.

5 If one depressurizes the RCS using the single  
6 steam-driven feedwater pump, you can drop the coolant system  
7 pressure, you're going to drop the leakage rate into the  
8 containment over what it was initially, and even in the  
9 worst case, -- I'm talking about the 95th percentile leakage  
10 rate assumed out of all four pumps simultaneously -- you  
11 find that you don't get to core uncovering in that situation  
12 until a period of about two hours.

13 MR. MICHELSON: I think we're asking about  
14 containment pressure with the core uncovered.

15 MR. BICKEL: The containment pressure will of  
16 course be-- You are not adding as much mass and energy.

17 MR. MICHELSON: Two hours I will believe. I  
18 thought the inference from your reply was that it was a  
19 non-problem, and it becomes a problem-- It's a question of  
20 at what point in time it becomes a problem, because you see  
21 some people say I can stand a total loss of AC power for 20  
22 hours.

23 I think you'll find this feature has become a  
24 problem long before 20 hours.

25 MR. DUBE: We did calculations which we

1 WRBeb

1 provided to the NRC Staff in response to successful ECC  
2 injection but failure of recirculation before a large LOCA,  
3 not a small LOCA. And those calculations found containment  
4 cooling. The design pressure would be reached in eight  
5 hours, and ultimate containment pressure would be reached in  
6 something beyond a day.

7 MR. MICHELSON: Yes, but I'm not sure that's the  
8 comparable answer to the loss of all AC power.

9 MR. DUBE: I think this is more severe than the  
10 loss of all AC.

11 MR. MICHELSON: I would have to see your  
12 analysis to be sure. It doesn't correspond with some other  
13 replies that we've gotten on the same question.

14 Could we get a copy or a reference to that and  
15 our Staff people will look it up?

16 MR. BICKEL: We provided this information to the  
17 Staff I believe in October of last year.

18 MR. MICHELSON: Okay.

19 MR. BICKEL: And if you cannot get it from them,  
20 I'll send you a copy.

21 MR. MICHELSON: I think Savio can probably find  
22 it with that, or give you a call.

23 Thank you.

24 MR. BONACA: I thought you would like to see some  
25 of the results.

1 WRBeb

1

(Slide.)

2

I have summarized here in this overhead the results of the study.

3

4

I have provided here the frequency of core melt from different contributors.

5

6

The frequency of core melt from internal events, as you can see, is 4.5 in 10 to the minus 5 reactor years.

7

8

The frequency of core melt from earthquakes as the final result from the seismic analysis is 0.9 in 10 to the minus 5 reactor years.

9

10

11

The frequency of core melt from fires is approximately .5 in 10 to the minus 5 per year.

12

13

And we have a total core melt frequency from all causes of 5.9 in 10 to the minus 5 per year, with the risk curve early and latent fatalities consistently lower than the corresponding WASH-1400 curves.

14

15

16

17

I want to point out here that this number, the frequency of core melt from internal events, we have looked at the contributors, we have looked at what the Lawrence Livermore study has provided to us. The variations there between our estimate and their estimate we find to be very much connected to operator actions, particularly to small break LOCAs with assumptions of the operator turning off high pressure injection and then failing to restart any high pressure injection and leading to core melt, essentially a

18

19

20

21

22

23

24

25

1 WRBeb

1 Three Mile Island sequence.

2 This was-- We find that in the estimate of --  
3 you know, presented in the SER, that sequence per se  
4 contributes a very large amount to the Staff estimate, and  
5 we disagree with that kind of approach to that operator  
6 action, and we feel the contribution is less than that.

7 But these are the values we calculated in the  
8 study.

9 DR. OKRENT: If I could ask a question for  
10 clarification, your total core melt frequency is of the same  
11 order as WASH-1400, so if you are consistently lower it  
12 could be because the containment fails less frequently or  
13 with smaller release categories, given the same release for  
14 a particular failure mode, or it could be because given a  
15 certain kind of failure mode, you are predicting much lower  
16 amounts of radioactivity getting out of the containment when  
17 you put your probabilistic treatment in.

18 Is it both of those, the first or the second?  
19 And if it is both, which is the more important?

20 MR. BONACA: Are you talking about the  
21 differences between our estimate and the one--

22 DR. OKRENT: -- in WASH-1400.

23 MR. BONACA: I believe the significant-- There  
24 are two significant differences. One is in part due to the  
25 systems, and one is due to the different source term

1 WRBeb

1 assumed. Our source term is somewhat lower than the one  
2 assumed in the WASH-1400 study.

3 DR. OKRENT: Would you say that's the predominant  
4 reason for the substantially lower than WASH-1400 or not?

5 MR. BONACA: Yes, sir.

6 DR. OKRENT: Okay.

7 DR. MUELLER: Let me ask another point.

8 You are using the existing source term  
9 assumptions then from in-core or wherever? What source term  
10 assumptions are you using?

11 MR. BONACA: We do not use the in-core  
12 assumptions. I will let Dr. Dube give you the details of  
13 our source term input.

14 DR. DUBE: The source terms that we're using are  
15 consistent with what was used in the Seiswell BPRA. One  
16 actually looks at which -- at a particular action sequence  
17 and assigns a range of probabilities that the source terms  
18 is one, one-half, one-tenth, and what-have-you times the  
19 WASH-1400 methodology.

20 However, if one compares the effective average  
21 source term that we used in the study and compares it with a  
22 recently released draft report put out by Battelle,  
23 BMI-2104, we are extremely close to the source terms that  
24 they calculated in that report for the Surry Plant.

25 And that is for sequences such the interfacing

1 WRB:0

1 systems LOCA, the V sequence, effectively a source term  
2 reduction or a factor let's say of about one-half or  
3 one-third, something like that.

4 For sequences which result in intermediate type  
5 failures, a factor of one-fourth.

6 For a little bit later containment failure,  
7 factors of one-tenth; something like that.

8 So it is sequence-specific.

9 Does that answer your question?

10 DR. MUELLER: That's fine, yes.

11 DR. KERR: May I ask a question?

12 In this study it does not seem to me any account  
13 is taken of the fact that this plant is part of a  
14 three-plant grouping with whatever risks that introduces and  
15 whatever benefits it introduces. It would seem to me that  
16 that could have significant influence, possibly reducing the  
17 risk significantly, or possibly increasing the risk  
18 significantly.

19 How do you account for that, or did I miss  
20 something?

21 MR. BONACA: We have not, as far as I can tell,  
22 introduced or given consideration to the other units in the  
23 study. You realize the short term available to us for  
24 performing the study, and concentrating on that particular  
25 plant.

.1 WRBeb

1 I must say that we have been looking at the other  
2 plants in place. We are aware of the presence of other  
3 emergency power sources there. Our questions to ourselves  
4 are what benefits would there be from being able to  
5 interconnect. We have performed the study in-house that  
6 shows maybe the benefit on paper probabilistically not to be  
7 very high.

8 But these kinds of issues I can assure you are  
9 given consideration outside of the PSS right now, and within  
10 Reactor Engineering.

11 DR. KERR: I was thinking not only of the  
12 possibility of using mechanical resources but of human  
13 resources, because it would seem to me that we may well be  
14 in a state of development in the business where the risk  
15 contribution from people is likely to predominate that due  
16 to malfunctions of equipment.

17 And if you have extraordinarily good human  
18 resources available because of a multiple plant site, this  
19 is likely to have some influence on risk, it seems to me.

20 MR. BONACA: Yes,--

21 DR. KERR: And there are perhaps other negative  
22 contributions. When we talk about dominant sequences, I  
23 have a feeling that the existence of that complex may be  
24 perhaps as dominant as anything else that is being  
25 considered, yet there apparently doesn't seem to be any way

1 WRBeb

1 of introducing this into one's consideration of the totality  
2 of risk.

3 MR. BONACA: I think this is an opportunity for  
4 me to emphasize the objective of the study, and the short  
5 time again that we had to perform the study.

6 It is clear that when we had a program as I  
7 described it of utilizing probabilistic studies in support  
8 of all plants, this kind of almost I would say  
9 infrastructure considerations are essential. Here the  
10 essential point was to look at the plant to qualify the  
11 design of this plant. Essentially to me it was a design  
12 evaluation of Millstone 3 in 1982 and had to be performed in  
13 a very short term. Okay?

14 And so we limited ourselves insofar as the scope  
15 we could cover.

16 DR. KERR: Perhaps I was influenced somewhat by  
17 the correspondence that I saw. But the NRC picked this site  
18 as one which, by some method of calculation estimation, they  
19 considered to be possibly above average in risk.

20 And hence it seems to me in one's consideration  
21 of the question as to whether it is or is not above average  
22 in risk, one certainly takes into account equipment, but one  
23 also would want to take into account other possible  
24 contributors, either to risk or lack thereof.

25 DR. OKRENT: A different question, if I might:



2 WRBeb 1

2 Earlier on this morning there was a presentation  
3 by a small set of representatives for Millstone concerning  
4 the seismic aspect of the risk. I am sure you are well  
5 aware that there are differences of opinion concerning the  
6 hazard curve chosen, the best estimate, or whatever you want  
7 to call it in your study, and other best estimate curves.

8 I am interested in knowing how you decided to go  
9 ahead or not with the material being supplied to you with  
10 your own chosen set of consultants when I have to assume it  
11 was clear to you and to them that there were indeed previous  
12 and going to be upcoming hazard curves substantially  
13 different and larger.

14 MR. BONACA: I must say that we commissioned the  
15 study of the hazard curve I believe in 1982, early 1982, and  
16 it may be a limitation on my side, but I was not aware of  
17 the higher connotation of seismic risk at the site by some  
18 other organization at that time.

19 DR. OKRENT: And the people whom you hired didn't  
20 advise you of this?

21 MR. BONACA: We went back and reconsidered the  
22 Coleman zone into the study and we reperformed the hazard  
23 curve study at that time. But there was no— At that time  
24 I didn't feel there was any inadequacy about the curve, and  
25 I don't see there is yet now any inadequacy.

There are two points of view there I believe that

1 WRBeb 1 have been brought to bear, and there are still what I would  
2 call arguments among experts on whether or not in fact one  
3 representation of the site is more accurate than the other.

4 Again in my mind the PSS has to be a  
5 best-estimate evaluation of the plant, and I am not looking  
6 for a conservative approach to the seismic profile of that  
7 site, so I cannot say that the one provided by Livermore is  
8 more correct because it is more conservative.

9 DR. OKRENT: The Coleman theory only applies to  
10 part of the picture. If there were no such theory and  
11 Livermore were getting a bunch of experts together, trying  
12 to get some mean estimate of acceleration that corresponds  
13 to a one in 10,000 or 100,000 per year, I'm sure there would  
14 be a considerable spread among their experts. Furthermore,  
15 I have little doubt that it would come out larger than what  
16 you had in your own.

17 Now you used the term "best estimate," but I'm  
18 interested in knowing how you choose to define the term  
19 "best estimate." Is it "best estimate" from a restricted  
20 set of consultants? Is it "best estimate" from the whole  
21 field of knowledgeable people in the area? What does the  
22 word "best estimate" mean when you use it?

23 You used it and you sent it into the NRC. You  
24 present it here. You use it to the public. What does it  
25 mean to use that term "best estimate"?

2 WRBeb 1

2 MR. BONACA: "Best estimate" means to look at a  
3 convergence of opinions on a certain issue, that that is in  
4 fact a best-estimate representation of the site.

5 My contention here is that we do not have a  
6 convergency of opinion of what the best estimate is for that  
7 site. And I would say in our justification the choice made  
8 in 1982 is that the issue of seismicity on the East Coast  
9 has been growing through the years since that time, and I  
10 think we are much more sensitized today than we were two  
11 years ago to that particular issue.

12 DR. OKRENT: Again I'm trying to ascertain what  
13 it is you think you're saying when you use the term "best  
14 estimate."

15 MR. BONACA: I told you I think it is a general  
16 assessment by a broad team of experts with also divergent  
17 views on an assessment for a certain site.

18 The point is we don't have any convergence of  
19 different opinions.

20 DR. OKRENT: Well, I will word the question  
21 another way:

22 You pick a group of what you say are experts that  
23 diverge a little, and you come up with a best estimate.

24 Another group picks a larger set of experts and  
25 comes up with a mean or mean estimate of the same  
parameters, and they vary by an order of magnitude. Each

1 WRBeb

1 one now has a best estimate. If differs, but it differs by  
2 an order of magnitude.

3 What does it mean if either of you puts out a  
4 document that says this is a best-estimate calculation? I'm  
5 at a loss.

6 MR. BONACA: Let me answer it this way:

7 We didn't have the benefit of the time to sit  
8 back and wait for numerous experts to spend months of time  
9 to tell us what the best estimate was. We hired what we  
10 felt were competent individuals to provide us with this  
11 estimate. We inputted that into the study.

12 We do believe that also there are uncertainties  
13 in the study that covers very specifically for that kind of  
14 weakness you are mentioning. That's a weakness in the PSS  
15 methodology which is a weakness in the input. And all we  
16 can do at this time is to acknowledge the fact that there  
17 are these weaknesses in the PSS, in the PRA, in the  
18 methodology in that it is attempting to bring to bear so  
19 much information and knowlege about so many different areas.

20 I think that scientifically it's a way that  
21 typically covers for some of this inherent problem.

22 DR. OKRENT: I'm sorry but I have to disagree  
23 that uncertainty as it is used in your PSS covers for a  
24 situation where you have really a broad disagreement between  
25 two different sets of experts. It is intended in a sense to

1 WRBeb

1 deal with another kind of situation, unless you were to put  
2 uncertainties in of a factor of a hundred each way or, you  
3 know, something which says in effect I have a flat curve; I  
4 don't know what the answer is.

5 MR. BONACA: Let me say this, Dr. Okrent.

6 You will agree with me that the PSS is an  
7 interative process. I do not believe that this particular  
8 PSS is a finalized document sitting on a shelf because it is  
9 not. Clearl: it is an iterative process. We are still  
10 studying it. We are performing analyses. We are looking  
11 forward to seeing the reviews performed.

12 We are going to answer to those comments, and  
13 yes, we will maybe zero in one of these days on what is a  
14 proper treatment of the whole seismic issue for that plant.

15 All I'm saying here is that when we were  
16 requested to perform this study we had less than a year and  
17 a half to perform it, and we had to make very hard and fast  
18 decisions on how to move, and we made them as best we could  
19 within that time.

20 DR. OKRENT: Okay.

21 But let me concede you are not alone in using the  
22 term "best estimate" where in fact, if you go to different  
23 sets of experts, you get big differences. I have been a  
24 little hard on you. I could have been equally hard on  
25 others. Okay? Let me put that up front.

1 WRBeb

1 It seems to me everyone involved has to rethink  
2 what information he is conveying when he does a calculation,  
3 puts out a result, and says "And this is the best estimate,"  
4 or even "This is my best estimate," or something. Let me  
5 leave it at that for the moment. It is a problem that does  
6 not have to be answered, obviously.

7 But people I think are using the term "best  
8 estimate" too loosely. That's what concerns me. Okay?

9 DR. POMEROY: Can I ask you for a point of  
10 clarification?

11 With regard to the question that Dr. Okrent has  
12 been posing, you gave us a bottom-line figure on the  
13 previous slide that was .9 times  $10$  to the minus 5 I believe  
14 for the frequency of core melt from earthquakes.

15 Yesterday we were given some indication of the  
16 fact that you had considered the Lawrence Livermore  
17 results. Could you just refresh my memory as to what that  
18 frequency of core melt from earthquakes might be if the  
19 hazard input were an order of magnitude different as  
20 Lawrence Livermore--

21 MR. BONACA: Okay.

22 Let me state that in the review performed, the  
23 value, the frequency of core melt from earthquakes assuming  
24 the same input that we used is actually lower than what we  
25 got. It is 0.6 times  $10$  to the minus 5 per year.

3 WRBeb

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

And I have here Mr. Jain of the PRA Section to provide you with the information assuming the Livermore curve.

MR. POMEROY: Can I just clarify though? I would like to have the information in terms of the way Livermore stated it originally, not as you modified it, as I understood some modifications of Livermore numbers were made, but as the way the original Livermore numbers came out. That is an order of magnitude higher in terms of seismic hazard.

MR. JAIN: This is Jain, PRA Section.

Using the hazard curve which Lawrence Livermore came out with without any modification, a rough estimate for the core melt frequency is 2.8 times 10 to the minus 4 per year.

MR. POMEROY: 10 to the minus 4.

MR. JAIN: It's about a factor of 30.

MR. POMEROY: Thank you very much.

MR. BONACA: Okay.

(Slide.)

What I have done here, we have integrated those curves of early and latent fatalities to obtain a Millstone Unit 3 public risk total. We are providing here for all events, median, and 90 percent confidence.

Clearly there are medians, 1.6 times 10

2 WRBeb

1 to the minus 6 and 2.0 times 10 to the minus 3. And if you  
2 look at the two numbers, latent fatalities dominate the  
3 representation of the expected fatalities at the site.

4 MR. REMICK: In getting the latent fatalities,  
5 how far out did you integrate the consequences? In  
6 distance? How far from the site?

7 MR. BONACA: Three hundred and fifty miles.

8 DR. OKRENT: Is that number multiplied by thirty,  
9 or something? What does "per reactor year" mean?

10 MR. BONACA: It means that each year of operation  
11 that's the number. It's specifically a total per reactor  
12 year of operation.

13 DR. OKRENT: For all future times?

14 MR. BONACA: Per year for the license years of  
15 the plant, which is thirty years.

16 (Slide.)

17 I would like to summarize here in this overhead  
18 what I view as the important thing about Millstone-3 and  
19 what I view as the strengths of this plant. --of this PSS,  
20 actually.

21 I'm not mentioning here what the strengths of the  
22 PRA methodology is, or the limitations of it. I think you  
23 are familiar with those. I feel, however, that the  
24 Millstone PSS is an important tool in our hands, because it  
25 is now in a form which is amenable to be updated and



1 WRBeb

1 exercised. It is, in fact, implemented on our computer  
2 system which is dedicated to the PSS, and is being  
3 repeatedly exercised in support of the PSS.

4 It is supported by specialized personnel  
5 knowledgeable of the strengths, limitations and the  
6 uncertainties. And I believe that, to me as an engineer, is  
7 the most significant thing. I don't think there is any hard  
8 and fast rule in treating uncertainties except engineering  
9 judgment when you come down to evaluating sequences and  
10 equipment. And that kind of intimate knowledge with the  
11 uncertainties assumed in the sequences is important to make  
12 judgments.

13 I think it is important also to say it is managed  
14 by a staff which is equally skilled in deterministic as well  
15 as probabilistic analysis. That's critical, too, because,  
16 again, we're talking about equipment and the performance of  
17 equipment, we're talking about twenty years of nuclear  
18 engineering experience we want to bring to bear in the PSS;  
19 I don't think we want to look only at the probabilistic  
20 aspect of it.

21 I think the most important statement I must make  
22 about the strength of the PSS is that it is supported by a  
23 management organization which is committed to using it to  
24 support the plant in operation, and that's significant: it  
25 is not a document on a shelf right now, but is being

1 WRBeb

1 exercised and utilized for judgments.

2 I have two slides here to summarize to you the  
3 insights and practical benefits we found in performing the  
4 PSS.

5 (Slide.)

6 These are just examples.

7 MR. MUELLER: Excuse me; are you going to  
8 continue, and then go into your living PRA program?

9 MR. BONACA: Yes.

10 First of all, in performing the study, we are  
11 concerned, first of all, to assess the adequacy of the  
12 systems as built. And we feel that we did perform this  
13 assessment. I don't think we are identifying any specific  
14 weakness in the mitigative systems as installed.

15 However, we also got insights in certain  
16 situations. For example, we found that the emergency  
17 generator load sequencer input logic was erroneous; in  
18 particular, the EGLS was tied in such a way that turbine  
19 trip or reactor trip would cause the EGLS to sense the loss  
20 of off-site power and, in turn, to lose off-site power. So  
21 we corrected that.

22 We also found that the EGLS was--

23 DR. KERR: Excuse me; just a matter of my own  
24 curiosity: Was this a new control system designed for  
25 Millstone, or is this same flaw likely to be in other

1 WRBeb

1 similar plants?

2 MR. BONACA: This was a plant-unique design, and  
3 the critical thing was that there have been upgrades in the  
4 design, actual improvements in the ties that caused this  
5 logic error there.

6 Clearly, these logic errors would have been  
7 surfacing in the testing phase.

8 Yes, there is a lot of time-saving just in the  
9 fact of identifying the short-comings this early.

10 DR. KERR: Thank you.

11 MR. BONACA: The other issue was that EGLS was  
12 being powered by an incorrect power supply that was planned  
13 to be set in case of off-site power. In so doing, it would  
14 have defeated the EGLS. We corrected those errors.

15 In reviewing boron dilution events, we found they  
16 were really dominated, insofar as probability, by operator  
17 actions. Although they were unlikely as events, a  
18 specific recommendation in administrative procedures and  
19 control would definitely reduce the probability of these  
20 events. We have provided those recommendations to  
21 Operations.

22 We performed extensive analyses in the dry  
23 reactor cavity effect, and particularly on the impact of  
24 deliberate hydrogen igniters in this plant, to assess the  
25 effect of deliberate burns, and Dr. Dube has an extensive

WRBeb

1 presentation that he won't be able to provide to you today,  
2 to support this.

3 DR. OKRENT: Can you tell me in fifteen seconds  
4 whether it was good or bad to have deliberate burns?

5 MR. BONACA: Dr. Dube will address the question.

6 DR. DUBE: Obviously it has an impact the core  
7 melt frequency, but in terms of the impacts of risk, and we  
8 used two measures, early fatality and latent, it's  
9 a negligible impact.

10 (Slide.)

11 MR. BONACA: Where we found the best benefit  
12 really is in operator actions. Reactor Engineering has the  
13 problem of supporting review of procedures for all our  
14 plants, and also provides a lot of cross-information about  
15 different designs and objectives. --designs, really.

16 The important thing that we found also is that  
17 operator action clearly dominates certain sequences, and  
18 it's important that we bring to bear the PSS experience into  
19 the operator training.

20 I here list only a few of the many insights which  
21 were received in operation actions which are critical. I  
22 list here the cutting back on quench spray to conserve RWST  
23 for a smallk LOCA with failure of recirculation. This  
24 particular action is identified by the ERGs. We tend to  
25 strengthen this into direct operator training information of

1 WRBeb

1 the way the systems work in mitigating certain conditions  
2 beyond the design basis.

3 We looked at the use of isolation valves. We're  
4 trying to provide a recommendation on those. They're  
5 critical. We feel that although we did not cover them in  
6 the study, they're significant in the long term mitigation  
7 of reactor coolant pump seal LOCA or steam generator tube  
8 rupture induced core melt.

9 Again, we are moving cautiously, because we don't  
10 view this isolation valve as a mitigative system you can  
11 just throw in in the middle of a transients, but as a system  
12 which you can intelligently use when you have a system  
13 already stabilized and you have safeguards which are on  
14 stand-by there ready to provide mitigation.

15 We looked at alternate means of charging and  
16 pump cooling in case you lose service water. It was  
17 important. That's a direct finding of the PSS. It's a way  
18 of cooling those loops, and the way it is to open up the  
19 drain from the component cooling water drainage tank that  
20 will result in a backflow and provide cooling to those pumps  
21 in case you lose service water. We feel that's a  
22 significant insight.

23 Finally, monitoring containment sump levels for  
24 in-core instrument tube rupture, a small LOCA. These are  
25 insights of other PSS's, too, but they are significant if we

a470 08 12

1 WRBeb

1 can have a means of directly feeding back this information  
2 to the operators.

3 (Slide.)

4 I just want to point out in two slides here,  
5 that this is not the first time we are feeding back into  
6 design procedure evaluations this kind of insight from PRA.  
7 This is just a list of recent applications of insights into  
8 design evaluations.

9 I mention to you at the top of the slide the ones  
10 related to Millstone-3. I mention on Millstone-1 that we  
11 were requested to look at the scram discharge level  
12 instrumentation in Millstone-1, which is a BWR. And we had  
13 no problems with the instrumentation whatsoever. We found  
14 that, in fact, that the issue of instrumentation and  
15 detection of the level in the volume was typically tied to  
16 the manipulation of all the valving that we have doing  
17 testing for that system. We came up with an alternative  
18 proposal to the NRC for modifications in the valving system  
19 which would reduce probability of unavailability of the  
20 system much more than changing instrumentation. And that,  
21 for example, was a typical input to design which resulted in  
22 a design change, resulted in what we feel is a significant  
23 improvement in plant safety.

24 I'll not go through all these others. Some of  
25 these studies were extensive, in particular, the limited

1 WRBeb

1 scope Connecticut Yankee decay heat removal system in the  
2 Millstone-1 study. Again a lot of insights. Some of them  
3 led to significant reduction in core melt probability  
4 directly because of the studies performed. In particular,  
5 for example, changing from an AC to a DC power source, and  
6 valves that go to the isolation condenser for Millstone-1.

7 (Slide.)

8 These are other examples of things we have done  
9 in support of procedures evaluations, safety evaluations,  
10 best estimate safety analysis.

11 (Slide.)

12 Time is short. I would like to go on just to say  
13 a few words about what we are doing with the Living PRA  
14 program. By "Living PRA" I mean having a PRA which is an  
15 effective engineering tool. By that I mean it is installed  
16 on a computer, it is somewhat modified to make it  
17 accessible so that evaluations can be performed, and it is  
18 handled by a number of engineers who are experienced in the  
19 PSS, understand the limitations and uncertainties, and can  
20 provide, therefore, significant answers from evaluations.

21 We have installed the Millstone-3 PSS on an  
22 in-house computer. We have answered NRC questions with our  
23 computer with in-house staff.

24 We have two problems under way: one is to  
25 utilize the PSS for plant support, which I'll provide to you

1 WRBeb

1 in the next slide, and then Northeast Utilities has made a  
2 corporate commitment at the corporate level for utilization  
3 of a plant-specific PRA through all of NU's plants as a  
4 safety management tool.

5 MR. MUELLER: Yesterday Mr. Council said that you  
6 have a fairly extensive data management system where you  
7 have computerized your maintenance records, and so forth.  
8 And root cause attack, if you will, was credited for a lot  
9 of your success with respect to the trip issue.

10 How much did -- if any -- did you take failure  
11 data from that in-plant management system and apply it to  
12 your probabilistic safety study? That's Question No. 1.

13 No. 2, Do you see that replacing more and more  
14 the generic data that you obviously had to use for your PRA.

15 No. 3, Do you see yourselves being able to take  
16 credit for your attack of root causes, if you will, in order  
17 to reduce failure data in your PRA that you can't really  
18 support with records, but which should be better than  
19 generic data because of your attacking?

20 MR. BONACA: Let me answer first of all Question  
21 No. 2 and Question No. 3, and I will let Dr. Bickel answer  
22 Question No. 1.

23 Question No. 2 has to do with when we utilize a  
24 data base plant-specific for our plant. That's absolutely  
25 an objective that we have. I have it on one of the next



1 WRBeb

1 slides. It's essential that this PSS become plant-specific  
2 as much as it can.

3 The second question, No. 3, had to do with...

4 Could you refresh my recollection? I lost track

5 of it.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 WRBwrb 1

MR. MUELLER: No. 3 refers to—

2

MR. BONACA: Oh, I recall.

3

I would like to make a distinction between regulatory use of this PSS for which we will have to have NRC accepting the credit, and internal use that we intend to have for the PSS. If we have a judgment that there is an improvement in using the data base, we will use that. It doesn't matter really what kind of credit we may receive on the regulatory level; unless, of course, there is a licensing requirement that we have to respect, and then, clearly, we will clear that issue with NRC.

12

But, in general, you know, credit is going to be taken, because we feel that that's important.

13

14

Dr. Bickel will address the issue of data base specific to the plant in the PSS.

15

16

DR. BICKEL: I'm John Bickel, Supervisor of PRA.

17

18

19

20

21

My group currently has a current formal program for the systematic collection and analysis of operating plant data based on a wide variety of sources. I was going to discuss what we intend to do on Unit 3, but I don't think there is really the time.

22

(Slide.)

23

24

25

I would like to show you some examples of data which we have collected and analyzed from the Millstone Unit 1 plant. We are currently doing the same effort for the

1 WRBwrb 1 Connecticut Yankee plant. We will be doing the same effort  
2 for Millstone-2 shortly.

3 What I have shown up here in the very solid lines  
4 are the mean values and the 95th percentile values obtained  
5 from WASH-1400 for specific types of plant components.  
6 Beneath them I have shown statistically-derived values for a  
7 large number of plant-specific type components for Millstone  
8 Unit 1.

9 One of the ones I think are very interesting, if  
10 you take a look at the very bottom, the breakers, the AC  
11 breakers, the collection and analysis of the data we found  
12 has indicated that 4160-volt breakers have a reliability  
13 that is tremendously better than WASH-1400 has ever  
14 assumed. We can back this up by a computerized record of  
15 all the failure events that have occurred. And we,  
16 additionally, know the exact number of cycles of every one  
17 of the breakers in our plants.

18 If you take a look at that you'll notice that  
19 there is about, say, a full decade.

20 (Slide.)

21 Another example. We have here the failure rates  
22 per hour for a large number of the pumps. Again, the solid  
23 line up on the top is the failure rates per hour which are  
24 tabulated out of WASH-1400. The chart is a little  
25 cock-eyed, but the number — the lower number is, again, the

1 WRBwrb

1 Connecticut Yankee plant. We will be doing the same effort  
2 for Millstone-2 shortly.

3 What I have shown up here in the very solid lines  
4 are the mean values and the 95th percentile values obtained  
5 from WASH-1400 for specific types of plant components.  
6 Beneath them I have shown statistically-derived values for a  
7 large number of plant-specific type components for Millstone  
8 Unit 1.

9 One of the ones I think are very interesting, if  
10 you take a look at the very bottom, the breakers, the AC  
11 breakers, the collection and analysis of the data we found  
12 has indicated that 4160-volt breakers have a reliability  
13 that is tremendously better than WASH-1400 has ever  
14 assumed. We can back this up by a computerized record of  
15 all the failure events that have occurred. And we,  
16 additionally, know the exact number of cycles of every one  
17 of the breakers in our plants.

18 If you take a look at that you'll notice that  
19 there is about, say, a full decade.

20 (Slide.)

21 Another example. We have here the failure rates  
22 per hour for a large number of the pumps. Again, the solid  
23 line up on the top is the failure rates per hour which are  
24 tabulated out of WASH-1400. The chart is a little  
25 cock-eyed, but the number — the lower number is, again, the

2 WRBwrb

1 mean and the upper bar at the top is the 95th percentile  
2 value.

3 If you look at that, the failure rates per hour  
4 based on actual plant experience, again, fall below what is  
5 assumed in WASH-1400.

6 This data base, I would point out, was collected  
7 using fourteen years of plant-specific experience that was  
8 collected by my staff. We intend to do the same type of  
9 effort as part of our on-going activities with Millstone  
10 Unit 3. However, as you can recognize, the statistic will  
11 not become significant on Unit 3 until we probably have  
12 accumulated at least five years of operation. What I'm  
13 trying to point out is that we have a formal program to  
14 collect it, to analyze it, and to do analyses.

15 Thank you.

16 MR. MUELLER: Does that include root cause  
17 tracking and trending?

18 DR. BICKEL: That's correct.

19 (Slide.)

20 One of the interesting trends that we have  
21 observed is the differences in performance of specific  
22 locations of valves. We have noticed-- We intend to  
23 probably publish some of this next February at the ANS  
24 meeting.

25 We've noticed that there are, if you look at the

2 WRBwrb 1 data and have the ability on a computer to split it all out  
2 as to location of the valves and systems, and so on, we've  
3 identified the fact that certain motor-operated valves seem  
4 to work better than others. And this type of information we  
5 do intend to accommodate in our living PRA program.

6 Therefore, the estimates that come up from the  
7 quantification of fault trees and reliability analysis point  
8 the way to where there are the historical weak links in the  
9 system.

10 We think this is a very strong corrective action  
11 program.

12 MR. MUELLER: Thank you.

13 ACRS CONSULTANT COMMENTS

14 DR. OKRENT: I think because of the ending time,  
15 which is somewhat inflexible, I'm going to switch now to see  
16 what comments of a more general nature the consultants that  
17 we have sitting at the table here may wish to make that may  
18 be useful at this stage of the Committees' review of  
19 Millstone operations, recognizing a more detailed look at  
20 the PRA itself is to come.

21 Then if we have time before 3:25 or so, we'll  
22 look for other information as we can get it.

23 So why don't I just start at the far right?

24 Mr. Mueller?

25 MR. MUELLER: There were two issues as far as

1 this ACRS meeting is concerned. One is the information  
2 relating to the operating license, and the second was a  
3 review of the probabilistic safety study. With respect to  
4 both, of course, this heavily involves the credibility of  
5 the licensee -- or the applicant, rather.

6 I must say I've been tremendously impressed with  
7 the presentation today. The level of detail that upper  
8 management seems to be capable of addressing off the top of  
9 be well wired into industry and technical committees. That  
10 impression, if you will, seems to be supported by the NRC  
11 and INPO report cards that they've received, the SALPs,  
12 their response report card to identify problems. More  
13 numeric or quantitative measures seem to be stop work orders  
14 and the number of reactor trips that apparently Northeast  
15 Utilities is performing excellently on.

16 With respect to the probabilistic safety study,  
17 from all appearances it was well done. I have-- My  
18 problems with the probabilistic safety study are the same  
19 problems that I've been having with probabilistic safety  
20 studies in general. I'll identify a few specific comments  
21 and their general applicability.

22 In the first section, or the summary of the  
23 probabilistic safety study it was stated that the key safety  
24 systems in Millstone-3 are the main reason why public risk  
25 is lower than in WASH-1400. It was stated within the last

1 WRBwrb

1 hour that a stronger reason might be source term  
2 assumptions. Obviously, if we take the risk -- if we change  
3 the risk assumption....I'm sorry; the seismic risk  
4 assumptions around, we have a higher core melt risk than  
5 WASH-1400.

6 Where all this is leading to, as far as I'm  
7 concerned, is that I would like to see for all these PRAs an  
8 identification of not just the key sequences but the key  
9 assumptions that make those sequences key.

10 Clearly, if I take a probably equally defensible  
11 set of source term assumptions I can change your results --  
12 I can change the thrust of your results. I can do the same  
13 with seismic, I can do the same with accident recovery. And  
14 there's one more that I'm thinking of that escapes me right  
15 now. It would be very useful if the NRC in their review  
16 provided a list of such key assumptions and the kinds of  
17 sensitivities that can be "defensibly supported" in light of  
18 today's technical knowledge.

19 Second comment on the PSS: This refers to the  
20 size of the reactor -- the RWST and the associated credit  
21 that was taken for recovery actions. That's really embodied  
22 within my first. I would like to see that identified as to  
23 how much credit was actually taken. I notice that the RWST  
24 capacity came across a number of the sequences. Obviously,  
25 if I changed the rules there I'm going to get different



WRBwrb 1 answers.

2           Along the same lines, the PSS said that  
3 independent reviews for reasonableness and consistency of  
4 subjective judgment was included. Obviously these reviews  
5 were somewhat limited with respect to seismic risk: there  
6 just ain't that many experts. It would be interesting to  
7 have seen more elaboration on the probabilistic safety study  
8 of how you assigned your source term assumptions and your  
9 CRAC-2 assumptions in which you reduced your point estimates  
10 down to your distributions, if you will. The DPD arithmetic  
11 is shown, but really the support for that is not shown.

12           As partial defense for your DPDs, the Zion  
13 probabilistic risk assessment was mentioned, while the Zion  
14 PRA got the same rap for not defending their DPDs, as is  
15 evident here, or as I'm bringing across here.

16           A fourth comment refers to a comment within the  
17 PSS that estimates of initiating event frequencies --  
18 blah-blah-blah -- are based largely on domestic PWR  
19 experience. It wasn't clear to me how much of the  
20 uniqueness of Millstone-3 was brought into these initiating  
21 frequencies. I did notice there was a considerable amount  
22 of difference between initiating event frequencies assumed  
23 for Millstone-3 vis-a-vis Zion.

24           In short, I would like to see -- whether it be a  
25 living PRA or a reliability assurance program, or whatever

1 WRBwrb

1 it's called -- be used very much to support plant-specific  
2 frequencies very much akin to your intention of using  
3 in-plant data to support your failure probabilities.

4 Finally, the last comment:-- Let me end on a  
5 positive note. The last comment is that I think it is  
6 commendable that the PRA, if you will, is intended to be a  
7 living document. And I would very much like to see not only  
8 your input published in the literature starting with the PRA  
9 in February, but I would like very much also to see just  
10 what -- well, perhaps a summary of what Dr. Bonaca stated in  
11 his last presentation on what management insights are into  
12 using a livingt PRA to make safety decisions and how you  
13 perceive that to be affecting you in costs and manpower.

14 That concludes my comments.

15 DR. OKRENT: Dr. Pomeroy.

16 DR. POMEROY: I'm going to confine my comments  
17 primarily to the seismic hazard analysis, primarily because  
18 I haven't had the opportunity to review the entire PSS in  
19 detail.

20 In view of the importance, and perhaps the  
21 dominance of the seismic external event initiator, it seems  
22 to me that there has been a disproportionately small  
23 percentage of resources devoted to trying to define the  
24 seismic hazard model. I believe that some significant  
25 additional work and documentation of the siesmic hazard

1 WRBwrb 1 would be extremely useful.

2 I'd like to indicate some of the areas that I  
3 think might be important.

4 We've had an indication that there have been a  
5 variety of expert opinion samples in the case of the  
6 assignment of source parameters. It's true that this  
7 seismic hazard study involves more seismic source zones  
8 and/or hypotheses than any previous one I've seen, and I  
9 think that is commendable.

10 However, the weights that were assigned to each  
11 of those hypotheses were correctly identified in the PSS as  
12 a subjective evaluation of Dames and Moore. And I believe  
13 that each of those weights which do enter into this  
14 calculation in a significant way should be associated with  
15 an uncertainty also.

16 I believe you can find other seismologists that  
17 might assign quite different weights to the various  
18 hypotheses. And, in fact, you do see that in the Lawrence  
19 Livermore -- the first Lawrence Livermore study and/or the  
20 second Lawrence Livermore study.

21 Yesterday Dr. Kennedy indicated that one of the  
22 significant sources of differences between the Lawrence  
23 Livermore study and this study had to do with the selection  
24 of a lower magnitude cut-off; that is, MB minimum. If that  
25 is the case, certainly there is little document to indicate

1 WRBwr 1 the importance of that in the PSS. And if it is important,  
2 we should be able to clearly see its importance, not solely  
3 on the basis of a damage criteria.

4 The third area I'd like to stress is in terms of  
5 attenuation relationships. There has been an on-going  
6 discussion of this particular problem, and in the Lawrence  
7 Livermore study there has been a rather complete evaluation  
8 of the attenuation relationships that are used in this type  
9 of analysis.

10 In the present study, the present PSS, four  
11 relationships are selected, given equal weights, again; but  
12 other people might not choose to give those four  
13 relationships equal weight. And, in addition, there are a  
14 selection of relationships which would result in further  
15 divergence of the hazard curves, in my estimation.

16 We really need documentation on this. The  
17 current EPRI is drawing from the Lawrence Livermore study.  
18 I believe that it would be important to incorporate some of  
19 that Lawrence Livermore developed work into this present  
20 study.

21 The question of truncation of acceleration is  
22 certainly an open question. In the PSS, in the seismic  
23 hazard input, truncations of .6, .8, and, in some cases, no  
24 truncations were used. I would like to be able to trace  
25 through and find the reasons why different truncations were

1 WRBwrb

1 used, and what effect this particular truncation has on the  
2 seismic hazards curve.

3 Finally, at the end of the hazards analysis, the  
4 184, I think, curves were aggregated according to a  
5 methodology that was discussed in a document which I didn't,  
6 and do not, have access to. I would like to have access to  
7 that document, if it were possible. But that aggregation in  
8 itself may result in a difference -- certainly will result  
9 in a difference in the median hazard curve. And I believe  
10 that that should be clearly documented within the seismic  
11 hazards study itself.

12 I'd like to repeat that in my estimation the PSS,  
13 the seismic hazards analysis that I read, which is Amendment  
14 2 in an appendix, is the best one that I've seen to date in  
15 the PRAs that I've read. I do believe it can be  
16 significantly improved. I'm pleased to see there is an  
17 effective use of the PSS, it seems to me, on the part of  
18 Northeast Utilities.

19 I'm not still clear in my own mind how the staff  
20 intends to use the PSS, and, in particular, the seismic  
21 hazard analysis that's associated with that. I would  
22 appreciate at some point a clear statement on that issue.

23 That's all I have.

24 DR. OKRENT: Thank you.

25 Mr. Bender.

1 WRBwrb 1

2 MR. BENDER: I won't comment much more about the  
3 PSS. Let me say a couple of things about the general  
4 picture as I see it from having heard these presentations.

5 First, there's evidence here that having run two  
6 plants that the management has learned quite a bit about how  
7 to run nuclear power plants, and that's likely to reflect  
8 favorably on the operation of Millstone-3, and I think it  
9 shows in the presentations that were made here today and  
10 yesterday.

11 From the standpoint of public risk, the fact that  
12 three plants are here and two already operating leads me to  
13 feel fairly relaxed about the third. If the NRC feels  
14 comfortable with the first two which were built some time  
15 ago to less rigorous standards, I don't see any reason to  
16 think this one shouldn't be equally safe.

17 I did find some value in hearing about how the  
18 PSS is being used to evaluate operating procedures, which I  
19 think for the purposes of an operating utility may be the  
20 most useful thing that can be done with it. It's obviously  
21 useful in design, but at this stage of the game it's mostly  
22 hindsight. And the only thing that really can be effective  
23 is finding out whether there are any glitches in the design  
24 that might be fixed. Evidently some of that has been done,  
25 from the presentations that were just made.

I do believe that knowing more about the time

1 WRBwrb

1 available to do something in the event of a severe accident  
2 has an effect on what the emergency planning actions can  
3 be. And I was pleased to hear that might thought had been  
4 given to that than I might have expected from reading the  
5 PSS. In fact, the public, I think, will be more comfortable  
6 if they know that there is something on the outside that can  
7 be done as well as relying on what may seem to some people  
8 uncertain reliability of the equipment.

9           With regard to the data used in the plant  
10 assessment, I think it was useful to know that you're  
11 collecting data from Millstone-1 and -2, and that other data  
12 exists that you'll probably take advantage of. I think it  
13 would be useful to go and discuss with INPO how to get  
14 comparable information on other plants to blend with the  
15 information you've got. And I think the NRC would be --  
16 would find that information of use to them as well as to  
17 you.

18           We're looking, I think, to the concept of having  
19 the whole industry provide a data base, and not for each  
20 element to provide its own data base. But integrating the  
21 information is a difficult thing. And I find the work going  
22 on there certainly to be constructive to safe nuclear power  
23 plants.

24           A few observations that seem to me to still a  
25 a little fuzzy. One, how to deal with station blackout

1 WRBwrp 1 still seems to me to be a little vague, and how long you've  
2 got and what the actions are, and how much reliability you  
3 can put in to restoring equipment that didn't operate that  
4 caused the blackout seems to me to be something that needs  
5 more study, and could be done in a probabilistic way. It's  
6 good to do it in just a planning sense, but dealing with  
7 operator actions and their response could tell us more  
8 about how likely we are to be successful if something  
9 happens.

10 The other point I think I'd like to emphasize is  
11 that the steam generator issue is not closed because you've  
12 got a new design. And I would think that more knowledge  
13 exists than we were told about yesterday, and it might be  
14 well to get that story in a form that we could all  
15 understand. It might be well even to write it down and  
16 explain to use why the Model F steam generator is so much  
17 better than all the others that we can stop worrying, and  
18 that might make a few people comfortable as well.

19 On the whole, my belief is that the organization  
20 here is large enough and has enough diversity to handle  
21 whatever problems might arise here, and I'm quite  
22 comfortable with what I've heard so far.

23 Thank you.

24 DR. OKRENT: Are there any comments from  
25 Subcommittee members at this time?



1 WRBwrb

1 MR. EBERSOLE: I guess I will make a somewhat  
2 standard statement about the PRA in aspect to utilization of  
3 what is called reliability of test data which doesn't  
4 reflect the utilization of equipment in duress or emergency  
5 states. Maybe the best example of that is valves.

6 If you look at the valve data you'll find it's  
7 hollow; it shows valves that swing from full open to closed  
8 shut, essentially with no load. They are just sort of  
9 bi-stable devices, and you get red and green, and you record  
10 successful operations. In no way with that show you, nor  
11 will you accumulate a record of what it will do when it is  
12 actually having to work under duress, such as intercepting  
13 full mass flow of fluids through a faulted pipe. So you put  
14 a number down and the machine cranks out a degree of safety  
15 which is an illusion. I think you have to look at not just  
16 the numbers for valves but for whatever other pieces of  
17 equipment are operating not in the mode in which you test  
18 them and accrue the reliability data base but in a mode  
19 perhaps which you haven't even operated them once, and then  
20 properly temper the reliability numbers to reflect the  
21 lowered reliability that certainly must exist.

22 That's all I have to say.

23 DR. OKRENT: Any other comments?

24 Yes, Mr. Bohn.

25 MR. BOHN: This is Mike Bohn of Sandia.

1 WRBwrb

1 I just had a couple of comments in regard to the  
2 documentation. There was considerable documentation on the  
3 internal event analyses, and it was relatively easy to  
4 follow through, and I just had a cursory look at this before  
5 we came out here.

6 The seismic part of it was not nearly as well  
7 documented; in fact, I was not really able to separate out  
8 the effects of initiating events, the dominant components,  
9 and that sort of thing, in a very simple fashion. Now,  
10 maybe that's because I didn't spend enough time. But it  
11 seemed like there was considerable difference in the level  
12 of documentation. It would help if more was provided.

13 In particular, it was not clear to me where the  
14 concepts of damage effective acceleration were used, and to  
15 what extent they were used for functional failures rather  
16 than structural failures of equipment.

17 A second area was in the regard to the responses,  
18 what responses were assumed for different pieces of generic  
19 equipment, because different pieces of equipment might have  
20 some response correlation even though they were not located  
21 side-by-side in a plant, especially yard-mounted equipment.  
22 If that information was available so that one could know how  
23 the accident sequences were evaluated, that would be very  
24 helpful.

25 I guess those are my main comments.

1 WRBwrb

1 One other comment that I was just a little  
2 confused about was this idea of having high confidence, low  
3 probability numbers that have been expressed. I haven't  
4 traced through this, so I don't know: it's more of a  
5 question. Presumably one goes through some sort of culling  
6 process in getting the final accident sequences and which  
7 accident sequences are dominant. Typically the culling  
8 process for internal events is probabilistic. And I  
9 wondered if there's any possibility that-- There's no  
10 reason to believe that the 90 percent values for all the  
11 failure rates should be correlated, therefore, if one did a  
12 lot more calculations, is it possible that some of the  
13 release categories would change if higher confidence levels  
14 were use, and it might change the result.

15 I think the assumption here is that the high  
16 probabilities that the 90 percent confidence failure rates  
17 for all the components are in effect correlated. That's a  
18 question that I'm confused about?

19 DR. OKRENT: Thank you.

20 Well, time is getting short. I will only note in  
21 passing that I didn't get to hear about how your testing  
22 program would have turned up some of those things that  
23 developed in the past on electrical systems. Maybe you can  
24 include a couple of minutes when next we meet.

25 Since I don't know that my plane is late, I'm

1 WRBwrv

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

going to adjourn the meeting.

(Whereupon, at 3:30 p.m. the Subcommittee meeting was concluded.)

## CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings  
before the UNITED STATES NUCLEAR REGULATORY COMMISSION  
in the matter of:

NAME OF PROCEEDING:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS


COMBINED MILLSTONE NUCLEAR POWER STATION  
UNIT 3/RELIABILITY AND PROBABILISTIC  
ASSESSMENT SUBCOMMITTEE MEETING

DOCKET NO.:

PLACE: Windsor Locks, Connecticut

DATE: Wednesday, August 29, 1984

were held as herein appears, and that this is the  
original transcript thereof for the file of the  
United States Nuclear Regulatory Commission.



William R. Bloom

Official Reporter

ACE-FEDERAL REPORTING, INC.

Reporter's Affiliation

## CERTIFICATE OF OFFICIAL REPORTER

This is to certify that the attached proceedings  
before the UNITED STATES NUCLEAR REGULATORY COMMISSION  
in the matter of:

NAME OF PROCEEDINGS:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS


COMBINED MILLSTONE NUCLEAR POWER STATION  
UNIT 3/RELIABILITY AND PROBABILISTIC  
ASSESSMENT SUBCOMMITTEE MEETING

DOCKET NO.:

PLACE: Windsor Locks, Connecticut

DATE: Wednesday, August 29, 1984

were held as herein appears, and that this is the  
original transcript thereof for the file of the  
United States Nuclear Regulatory Commission.




Anne G. Bloom

Official Reporter


ACE-FEDERAL REPORTERS, INC.

Reporter's Affiliation

# RISK DIAGRAM FOR EARLY FATALITIES DUE TO EXTERNAL EVENTS



# RISK DIAGRAM FOR LATENT CANCER FATALITIES DUE TO EXTERNAL EVENTS



NU



**NORTHEAST UTILITIES SERVICE COMPANY**

**PROBABALISTIC SAFETY STUDY**

**CONTAINMENT AND CONSEQUENCE**

**ANALYSIS**

**DR. DONALD A. DUBE**

**PRA SECTION**

**SAFETY ANALYSIS BRANCH**




# OUTLINE

- **IMPORTANT CONTAINMENT FEATURES**
- **DEGRADED CORE AND CONTAINMENT ANALYSIS**
- **SOURCE TERM ANALYSIS**
- **CONSEQUENCE ANALYSIS**
- **ADDITIONAL STUDIES**




# MP-3 CONTAINMENT SAFEGUARDS



**NU**

# MP-3 REACTOR CAVITY DESIGN



# DEGRADED CORE AND CONTAINMENT ANALYSIS

- CONTAINMENT FAILURE MODES ANALYSIS
- HYDROGEN BURN CONSIDERATIONS
- CONSIDERATION OF THE S<sub>2</sub>C SEQUENCE
- SUMMARY OF CONTAINMENT RESPONSE RESULTS



# **CONTAINMENT FAILURE MODES ANALYSIS**

## **STRUCTURAL**


- **AS-BUILT MATERIAL PROPERTIES AND LOADINGS**
- **FAILURE CRITERIA**
  - **ANY SECTION IN A GENERAL STATE OF YIELD**
  - **ANY SECTION FAILS IN SHEAR OR CONCRETE FAILS IN COMPRESSION**
  - **LOCAL DEGRADATION OF LINER MATERIALS AT DISCONTINUITIES**
- **THIN SHELL AXISYMMETRIC FINITE ELEMENT MODEL**
- **NUMEROUS FAILURE LOCATIONS INCLUDING MAJOR PENETRATIONS CONSIDERED**



# UNCERTAINTY ANALYSIS


- MEANS AND VARIANCES FOR EACH FAILURE MODE ESTABLISHED
- VARIANCES REPRESENT
  - UNCERTAINTIES IN MATERIAL STRENGTH
  - VARIATIONS IN CONSTRUCTION PRACTICES
  - UNCERTAINTIES INHERENT IN THE STRUCTURAL ANALYSIS
- WEIBULL DISTRIBUTION WITH CUTOFF AT 52 PSIG (TEST PRESSURE) USED
- 4 MOST DOMINANT FAILURE MODES CONSIDERED
  - YIELD AT CYLINDER MIDHEIGHT
  - MAIN STEAM LINE PENETRATION
  - MAIN FEEDWATER PENETRATION
  - GENERAL YIELD AT SPRINGLINE







$$P_{CF}/P=P_0(P_0)$$




# **HYDROGEN BURN CONSIDERATIONS**

- **SINGLE AND MULTIPLE BURNS "FORCED" AT VARYING TIMES IN ACCIDENT SEQUENCES**
- **CONTAINMENT GENERALLY INERTED FOR STEAM VOL PERCENT >60**
- **FLAME PROPAGATION SPEED 2.2 TO 9.0 M/S**
- **HYDROGEN IN EXCESS OF 100% ZIRC-WATER MAY BE PRODUCED BECAUSE OF SIGNIFICANT CORE/CONCRETE INTERACTION**
- **RESULTS USED IN THE QUANTIFICATION OF CONTAINMENT EVENT TREE**



# LARGE LOCA FAILURE OF ECC INJECTION, FULL CONTAINMENT SAFEGUARDS



**NU**

# **INCORE INSTRUMENT TUBE RUPTURE**

**(S<sub>2</sub>C IN WASH-1400)**

- **SMALL LOCA, QUENCH SPRAY FAILURE**
- **ONE OF THE TOP 3 CONTRIBUTORS TO RISK IN WASH-1400**
- **PECULIAR TO SUB-ATMOSPHERIC CONTAINMENTS**
  - **REACTOR CAVITY CONFIGURATION**
  - **RECIRCULATION SPRAY ACTUATION LOGIC**
- **CONTAINMENT FAILS EARLY AND BEFORE CORE MELT**



# S<sub>2</sub>C ACCIDENT SEQUENCE COMPARISON

	<u>RSS</u>	<u>MP-3</u>
RWST CAPACITY (10 <sup>6</sup> GAL)	0.34	1.2
DEPLETION OF RWST (HR) (1 TUBE FAILURE)	4	16
CONTAINMENT SPRAY ACTUATION (HR)	0.5	1
CORE MELT TIME (HR)	5	17
CONTAINMENT FAILURE TIME (HR)	4	>30



# CONTAINMENT RESPONSE TO CORE MELTS

## INTERNAL EVENTS

● NO CONTAINMENT FAILURE	76%
● LATE (>24 HR) FAILURE	15
● BASEMAT PENETRATION	5
● CONTAINMENT BYPASS (V)	4
● OTHER EARLY FAILURE	<< 1

## SEISMIC EVENTS

● LATE FAILURE	83%
● INTERMEDIATE (4-7 HR) FAILURE	7
● BASEMAT PENETRATION	7
● NO FAILURE	2
● CONTAINMENT ISOLATION FAILURE	0.4
● OTHERS	<< 1

## FIRE

● NO FAILURE	59%
● LATE FAILURE	35
● BASEMAT PENETRATION	6
● OTHERS	<< 1



# **SOURCE TERM METHODOLOGY**

- **THIRTY CORRAL-2 RUNS (ONE FOR EACH CONTAINMENT ANALYSIS)**
- **CSI PREDOMINANT CHEMICAL FORM OF IODINE**
- **GROUPING INTO 13 RELEASE CATEGORIES BASED ON SELECTION OF MOST CONSERVATIVE RELEASE FRACTIONS**
- **ASSIGNMENT OF ACCIDENT SEQUENCES TO RELEASE CATEGORIES CONSERVATIVELY BIASED**



# SOURCE TERM UNCERTAINTIES

## BASED ON

- SRD R256 (SIZEWELL-B PRA)
- NUREG-0772
- NUS-3808

## DISCRETE PROBABILITY DISTRIBUTIONS (DPD'S):

- GIVE PROBABILITIES THAT SOURCE TERMS HAVE MAGNITUDES OF 1, 1/2, 1/10, ETC., TIMES THAT OF WASH-1400 (EXCEPT NOBLE GASES).
- EFFECTIVELY, THEY ACCOUNT FOR FISSION PRODUCT PLATEOUT IN THE PRIMARY SYSTEM, AEROSOL AGGLOMERATION, AND OTHER PHYSICAL REMOVAL MECHANISMS NOT TREATED EXPLICITLY.
- RESULTS CONSISTENT WITH BMI-2104 (DRAFT) FOR SURRY





# **IMPORTANT ASPECTS OF CONSEQUENCE MODELING**

- **CRAC-2 USED**
- **1980 AND PROJECTED 1990 CENSUS DATA**
- **SITE-SPECIFIC METEOROLOGY**
- **SEASONAL POPULATION CONSIDERED**
- **THOROUGH EVALUATION OF EVACUATION  
FOR SEISMIC AND NON-SEISMIC EVENTS,  
AND ADVERSE WEATHER CONDITIONS**
- **IMPROVED "BIN SAMPLING" OF METEOROLOGICAL  
DATE FOR MOST SERIOUS RELEASE CATEGORIES**
- **CALCULATIONS PERFORMED FOR WIDE  
VARIATION OF SOURCE TERM MAGNITUDES**




## **ADDITIONAL STUDIES**

- **DRY VERSUS FLOODED LOWER REACTOR CAVITY**
- **RISK IMPACT OF DELIBERATE HYDROGEN IGNITERS**

**NU**

# STATION BLACKOUT WITH FAILURE OF AUXILIARY FEEDWATER



**NU**

# SUMMARY

- **COMPREHENSIVE CONTAINMENT ANALYSES PERFORMED**
  - DETAILED CONTAINMENT FAILURE MODES ANALYSIS INCLUDING UNCERTAINTIES
  - PLANT SPECIFIC CONTAINMENT RESPONSE ANALYSIS
  - HYDROGEN BURN STUDIES
- **SOURCE TERM ANALYSIS ACCOUNTS FOR**
  - PLANT SPECIFIC CONTAINMENT RESPONSE
  - WIDE BAND OF UNCERTAINTIES
- **CONSEQUENCE ANALYSIS ACCOUNTS FOR**
  - UNCERTAINTIES
  - IMPACT OF SEISMIC EVENTS
- **MANY ADDITIONAL STUDIES PERFORMED AND INSIGHTS OBTAINED**



NU ACRS Presentation on use of CO<sub>2</sub> in  
the Cable Spreading Room

*Are these slides  
for the presentation  
6/29*

SLIDE 1

NRC'S BTP CMEB 9.5-1, SECTION C.7.5.C

STATES IN PART:

"THE PRIMARY FIRE SUPPRESSION IN THE CABLE SPREADING ROOM SHOULD BE AN AUTOMATIC WATER SYSTEM SUCH AS CLOSED-HEAD SPRINKLERS, OPEN-HEAD DELUGE SYSTEM, OR OPEN DIRECTIONAL WATER SPRAY SYSTEM."

MILLSTONE UNIT NO. 3'S POSITION

"THE PRIMARY FIRE SUPPRESSION FOR THE CABLE SPREADING ROOM IS AN AUTOMATIC, TOTAL FLOODING CO<sub>2</sub> SYSTEM."

SLIDE 2

SER 9.5-1

PAGE 9-48:

CARBON DIOXIDE SUPPRESSION SYSTEM

"...ON THE BASIS OF ITS EVALUATION, THE STAFF CONCLUDES THAT THE CARBON DIOXIDE EXTINGUISHING SYSTEMS MEET THE GUIDELINES OF BTP CMEB 9.5-1, SECTION C.6.D, AND ARE THEREFORE ACCEPTABLE."

SLIDE 3

DISADVANTAGES OF WATER SYSTEMS FOR CABLE SPREADING ROOM

- o CABLE TRAY CONGESTION COUPLED WITH CABLE TRAY COVERS MAKE IT EXTREMELY DIFFICULT FOR WATER TO BE EFFECTIVELY APPLIED.
  
- o SPRINKLER DISCHARGE PATTERNS WOULD BE SEVERELY OBSTRUCTED.

SLIDE 4

ADVANTAGES OF CO<sub>2</sub> SYSTEM

- o INERTS ENTIRE VOLUME OF ROOM AND THEREFORE NOT AFFECTED BY CABLE TRAY CONGESTION.
- o CAN PENETRATE COVERED/CONGESTED CABLE TRAY SYSTEMS.



SLIDE 5

DETECTION AND ACTIVATION CONCEPT

POSTULATED FIRE FOR CABLE SPREADING ROOM (CABLE FIRE)

- o SLOW DEVELOPING
- o CONSIDERABLE SMOKE
- o LOW HEAT DEVELOPMENT

WATER SYSTEM CONCEPT OF ACTIVATION

- o HEAT
- o SPRINKLER HEAD-FUSIBLE LINK

CO2 SYSTEM CONCEPT OF ACTIVATION

- o SMOKE
- o PRODUCT OF COMBUSTION

SUMMARY

- o MP-3'S CO2 SYSTEM HAS BEEN DESIGNED TO RESPOND QUICKER AND MORE EFFECTIVELY.
- o MP-3'S CO2 SYSTEM REPRESENTS AN ACCEPTABLE LEVEL OF FIRE PROTECTION FOR THE CABLE SPREADING AREA.

Stick to it

## MILLSTONE-3 PROBABILISTIC SAFETY STUDY

### CHRONOLOGY

#### - THE STUDY

- SEPTEMBER 1981 STAFF REQUESTED NORTHEAST UTILITIES (NU) TO PERFORM DESIGN-SPECIFIC PRA. CONCERN OVER HIGH POPULATION ZONE SITE.
- AUGUST 1983 MILLSTONE-3 PROBABILISTIC SAFETY STUDY SUBMITTED TO STAFF - INCLUDES EXTERNAL EVENTS. (FULL SCOPE)
- APRIL 1984 REVISIONS TO SEISMIC ANALYSIS, INCLUDING SEISMIC HAZARD AND FRAGILITY ANALYSIS, SUBMITTED.

#### - STAFF REVIEW

- LLNL - STAFF CONSULTANT ON PLANT DAMAGE STATE FREQUENCIES.
- BNL - STAFF CONSULTANT ON ACCIDENT PHENOMENOLOGY AND CONTAINMENT PHENOMENA
- JUNE 1984 LLNL DRAFT REPORT RECEIVED
- SEPT./OCT. 1984 FINAL LLNL REPORT TO STAFF
- NOV. 1984 STAFF "INSIGHTS" DRAFT REPORT

## INITIAL REVIEW RESULTS

- SOME SEQUENCES MAY BE MORE SIGNIFICANT THAN JUDGED IN THE MPSS
- SOME STRENGTHS OF THE DESIGN
  - LARGE RWST, 4 TRAIN RECIRCULATION
  - THIRD VALVE FOR EVENT V
  - LOOP STOP VALVES
  - LARGE DRY SUBATMOSPHERIC CONTAINMENT
- FURTHER STAFF FOCUS
  - TRIP MFWS FOR ALL REACTOR TRIPS
  - SPECIFIC STATION BLACKOUT SCENARIOS
  - SEISMIC ISSUES
  - SPECIFIC FIRE SCENARIOS

MILLSTONE UNIT 3 PSS USES

- A. USE IN SAFETY REVIEW
  - 1. DOMINANT SEQUENCES ATTRIBUTABLE TO SYSTEM PERFORMANCE THAT FAIL TO SATISFY NRC REGULATORY REQUIREMENTS MUST BE CORRECTED.
  - 2. CONSIDER ADDITIONAL MEASURES TO CORRECT A UNIQUE DESIGN ASPECT IN THE EVENT THIS ASPECT IS SIGNIFICANT TO OVERALL PLANT SAFETY.
- B. USE IN MILLSTONE-3 DES AND FES
- C. USE IN SEVERE ACCIDENT POLICY CONSIDERATIONS
- D. USE IN VOLUNTARY IMPROVEMENTS IN DESIGN AND OPERATION
- E. INSIGHTS

**NORTHEAST NUCLEAR ENERGY COMPANY**

**MR. J.O. CROCKETT  
MP3 UNIT SUPERINTENDENT**

**ANTICIPATED TRANSIENTS  
WITHOUT SCRAM**

**NU**

# ANTICIPATED TRANSIENTS WITHOUT SCRAM

## POST-SALEM REVIEW

- **GENERIC LETTER 83-28**
  1. **POST-TRIP REVIEW (PROGRAM)**
  2. **POST-TRIP DATA**
  3. **EQUIPMENT CLASSIFICATION/VENDOR INTERFACE**
  4. **POST-MAINTENANCE TESTING**
  5. **RTS RELIABILITY**
  6. **SHUNT TRIP**
  
- **GENERIC LETTER 83-32**
  - **EOP TO DEAL WITH FAILURE TO TRIP**
  - **ENTRY IF TRIP NOT VERIFIED OR MANUAL TRIP NOT EFFECTIVE**

**NU**

**NORTHEAST UTILITIES SERVICE COMPANY**

**MR. ARNOLD R. ROBY**

**SYSTEM MANAGER,**

**GENERATION ELECTRICAL ENGINEERING**

**CONTROL ROOM**





# **MILLSTONE UNIT 3 - CONTROL ROOM DESIGN REVIEW**

## **REVIEW PROCESS**

### **INVESTIGATION**

- **CRITERIA & STANDARDS ALREADY INCLUDED**
- **RELEVANT OPERATIONAL EXPERIENCE**
- **CONTROL ROOM SURVEY**
- **OPERATOR TASKS DURING EMERGENCY SITUATIONS**

### **ASSESSMENT**

- **IDENTIFY DISCREPANCIES**
- **DETERMINE THE DISPOSITION OF DISCREPANCIES**

### **REPORTING**

- **SUMMARIZE REVIEW FINDINGS**
- **PROVIDE REFERENCE DATA**



# **CONTROL ROOM HABITABILITY**

## **SYSTEM DESIGN FEATURES**

- **VENTILATION**
- **EMERGENCY PRESSURIZATION**
- **EQUIPMENT LOCATION**
- **MINIMUM LEAKAGE**

**NU**

# **AUXILIARY SHUTDOWN PANEL DESIGN FEATURES**

- **DESIGNED TO WITHSTAND A SEISMIC EVENT**
- **COMPLIES TO APPLICABLE PORTIONS OF IEEE STANDARDS AND NRC REGULATORY GUIDES**
- **DESIGNED TO MAINTAIN SAFETY TRAIN SEPARATION THROUGH THE USE OF METAL ENCLOSURES AND PHYSICAL SEPARATION**



# REMOTE SHUTDOWN CAPABILITY

- **AUXILIARY SHUTDOWN EQUIPMENT PROVISIONS**
  - **EMERGENCY SWITCHGEAR FOR EACH SAFEGUARD TRAIN**
  - **TWO TRANSFER SWITCH PANELS, LOCATED ONE IN EACH SWITCHGEAR ROOM**
  - **AUXILIARY SHUTDOWN PANEL, LOCATED IN THE PURPLE SWITCHGEAR ROOM**
  
- **FIRE PROTECTION PROVISIONS**
  - **FIRE TRANSFER SWITCH PANEL, LOCATED IN THE ORANGE SWITCHGEAR ROOM**
  - **FIRE INSTRUMENT PANEL, LOCATED IN THE ORANGE SWITCHGEAR ROOM**



**NORTHEAST UTILITIES SERVICE COMPANY**

**MR. ARNOLD R. ROBY**


**SYSTEM MANAGER,**

**GENERATION ELECTRICAL ENGINEERING**


**POWER SYSTEMS RELIABILITY**




# POWER SYSTEMS RELIABILITY



# 345KV SWITCHYARD CONNECTIONS



# 345KV & 416KV UNIT CONNECTIONS





**NORTHEAST UTILITIES SERVICE COMPANY**

**MR. RAY P. NECCI**

**EMERGENCY DIESEL GENERATOR**



# EMERGENCY DIESEL GENERATOR

- DESIGN
- MANUFACTURE
- PREOPERATIONAL TESTING
- STARTUP TESTING
- INSERVICE TESTING



**NORTHEAST UTILITIES SERVICE COMPANY**

**MR. PAUL M. BLANCH**

**REGULATORY GUIDE 1.97 IMPLEMENTATION**



# **REGULATORY GUIDE 1.97 IMPLEMENTATION**

- **COMPLIES WITH GUIDANCE OF R.G. 1.97**
- **PARAMETERS SELECTED BY DETAILED ANALYSIS**
- **FULLY INTEGRATED SYSTEM**
- **USED FOR NORMAL AND ACCIDENT CONDITIONS**
- **ICC SYSTEM COMPLIES WITH GUIDANCE OF  
NUREG-0737, ITEM II.F.2**



**NORTHEAST UTILITIES SERVICE COMPANY**  
**R.C. RODGERS**  
**MANAGER RADIOLOGICAL ASSESSMENT**  
**RADIATION PROTECTION**

**NU**

# **OPERATING RADIATION PROTECTION EXPERIENCE**

**1967 HADDAM NECK NUCLEAR STATION**

**1970 MILLSTONE UNIT 1**

**1975 MILLSTONE UNIT 2**

**= 42 REACTOR YEARS OF OPERATIONAL EXPERIENCE  
(25 YEARS AT MILLSTONE SITE)**

## **INPUT INTO**

- **PROGRAM DEVELOPMENT AND MANAGEMENT**
- **DESIGN OF MILLSTONE UNIT 3**



**OPERATING EXPERIENCE INPUT INTO THE  
DEVELOPMENT AND MANAGEMENT OF THE  
RADIATION PROTECTION PROGRAM  
AT MILLSTONE UNIT 3**

**NU**

# **STANDARDIZED CORPORATE PROGRAMS**

## **OBJECTIVES**

- **ESTABLISH UNIFORMLY HIGH QUALITY PROGRAMS AND PRACTICES TO MEET NU'S STANDARDS OF EXCELLENCE**
- **ACHIEVE COLLECTIVE LEARNING CURVE GROWTH BY BOTH SITES THROUGH SHARING OF LESSONS LEARNED**
- **OPTIMIZE COST BY SHARING RESOURCES AND PROGRAMS BETWEEN SITES**






# **CORPORATE MANAGEMENT COMMITMENT**

- **CORPORATE POLICY STATEMENT**
- **IDENTIFICATION OF RESPONSIBLE CORPORATE OFFICERS**
- **COMMITMENT TO PROVIDE NECESSARY RESOURCES**
- **SUPPORT IN THE IMPLEMENTATION AND ENFORCEMENT OF POLICY AND PROCEDURES**

**NU**

# NORTHEAST UTILITIES RADIATION PROTECTION



# **PROGRAM ELEMENTS**

- **STANDARDIZED HEALTH PHYSICS PROCEDURES**
- **STANDARDIZED HEALTH PHYSICS EQUIPMENT LISTS**
- **STANDARDIZED ALARA PROGRAM**
- **STANDARDIZED HP TECHNICIAN AND SUPERVISOR'S TRAINING AND CERTIFICATION PROGRAMS**

**NU**

# PROGRAM ELEMENTS

- STANDARDIZED RADIATION WORKER TRAINING PROGRAM
- CENTRALIZED COMPUTER BASED RADIATION EXPOSURE DATA SYSTEM
- PERSONNEL RADIATION DOSIMETRY LABORATORY
- ROVING INTERPLANT HP SUPERVISORY STAFF
- AUDIT AND EVALUATION PROGRAM

**NU**

**OPERATING EXPERIENCE INPUT  
INTO THE ALARA DESIGN  
OF MILLSTONE UNIT 3**

**NU**

- **INCREASED SPACE/SEPARATION OF SYSTEMS & COMPONENTS**
- **INCREASED USE OF SHIELDED CUBICLES**
- **NEUTRON STREAMING SHIELD**
- **FUEL TRANSFER TUBE SHIELD**
- **STEAM GENERATOR DESIGN**
- **MAIN CONDENSER - TITANIUM ALLOY TUBES**

**NU**

**NORTHEAST UTILITIES SERVICE COMPANY**

**DR. M.V. BONACA  
SYSTEM MANAGER,  
REACTOR ENGINEERING**

**PROBABALISTIC SAFETY STUDY**

**NU**

# CHRONOLOGY OF EVENTS

- 1980 NORTHEAST UTILITIES (NU) TASK FORCE DEVELOPED PRA PLAN WHICH INCLUDED ALL NU NUCLEAR UNITS
- PLAN RECOMMENDED IN-HOUSE PERFORMANCE, MAINTENANCE, AND USE OF PROBABILISTIC SAFETY STUDIES (PSS) FOR ALL OF NU'S REACTORS
- MILLSTONE UNIT 3 MP-3 PSS TO BE PERFORMED IN 1986-1987 TIME PERIOD

**NU**



# **CHRONOLOGY OF EVENTS (CON'T)**

- **SEPTEMBER 1981 NRC REQUEST FOR MP-3 PSS MODIFIED PLANNED PRIORITIES**
- **ALL AVAILABLE NU PRA RESOURCES AND A SUPPORTING TEAM WERE ASSIGNED TO MP-3 PSS**
- **PSS TO INCLUDE INTERNAL AND EXTERNAL EVENTS**
- **PSS TO ADDRESS EXTERNAL CONSEQUENCES**
- **MP-3 PSS SUBMITTED TO NRC ON SCHEDULE ON AUGUST 1, 1983**

**NU**

# **CHRONOLOGY OF EVENTS (CON'T)**

- **NU DEVELOPED PSS SPECIFICATIONS SATISFYING SHORT TERM NRC REQUEST AND LONG TERM NU OBJECTIVE**
- **SPECIFICATIONS INCLUDED TECHNOLOGY TRANSFER AND PSS INSTALLATION ON DEDICATED COMPUTER SYSTEM AT NU**
- **WESTINGHOUSE CORPORATION SELECTED AS MAIN CONTRACTOR**
- **STONE & WEBSTER CORPORATION SELECTED AS MAIN SUBCONTRACTOR**

**NU**

# **CHRONOLOGY OF EVENTS (CON'T)**

- **NU ASSEMBLED IN-HOUSE PRA TEAM TO SUPERVISE STUDY AND TO EFFECT TECHNOLOGY TRANSFER**
- **EXPERT REVIEW BOARD WAS FORMED, WHICH INCLUDED DR. P. WOOD, MR. S. LEVINE, AND WHICH WAS CHAIRED BY PROF. RASMUSSEN**
- **BOARD MEMBERS WERE ASSIGNED IN-DEPTH REVIEWS OF SELECTED CRITICAL PSS AREAS**
- **REVIEW BOARD REQUESTED TO SUMMARIZE FINDINGS IN LETTER TO NU FOLLOWING PSS SUBMITTAL**

**NU**

# **CHRONOLOGY OF EVENTS (CON'T)**

- **EXTERNAL AND INTERNAL EVENTS INITIATORS WERE ANALYZED. INTERNAL INITIATORS WERE SCREENED USING A MASTER LOGIC DIAGRAM**
- **ACCIDENT SEQUENCES WERE STUDIED USING STANDARD EVENT TREE AND FAULT TREE ANALYSIS TECHNIQUES**
- **DETAILED BEST ESTIMATE MODELS WERE EXTENSIVELY UTILIZED TO ASSESS CONTAINMENT RESPONSE TO SEVERE CORE DAMAGE**
- **EXTERNAL CONSEQUENCES WERE EVALUATED THROUGH THE USE OF THE "CRAC-2" CODE**

**NU**

## **SIGNIFICANT FINDINGS**

- **NO INDIVIDUAL ACCIDENT SEQUENCE CONTRIBUTES MORE THAN 10% OF THE INTERNAL CORE MELT FREQUENCY**
- **THUS, NO SINGLE PLANT FEATURE STANDS OUT AS A RISK OUTLIER**
- **13 SEPARATE ACCIDENT SEQUENCES EACH CONTRIBUTED BETWEEN 1% AND 9%. THEY CONTRIBUTED IN TOTAL ABOUT 50% TO THE TOTAL INTERNAL CORE MELT FREQUENCY**

**NU**

# MILLSTONE UNIT 3 DESIGN FEATURES

- **AUXILIARY FEEDWATER SYSTEM**
  - 2 ELECTRIC/1 STEAM DRIVEN, 100% CAPACITY PUMPS
  - NO DEPENDENCY ON INSTRUMENT AIR, COMPONENT COOLING OR SERVICE WATER
  - LOSS OF INSTRUMENT AIR OR DC WILL AUTO-START THE STEAM DRIVEN PUMP
- **HPSI CAPABILITY**
  - 3 CHARGING PUMPS (2600 PSIG SHUTOFF HEAD)
  - 2 SI PUMPS
  - DEDICATED, INDEPENDENT PUMP COOLING
  - 2 HPSI MITIGATE LOCA IF LPSi FAIL
- **FEED AND BLEED CAPABILITY**
  - ONE HPSI AND TWO PORV'S ARE SUFFICIENT

**MU**

## **DESIGN FEATURES (CON'T)**

- **RWST CAPACITY**

- **1.2 MILLION GALLONS VS. 0.3-0.4 MILLION GALLONS  
TYPICAL OF U.S. PWR'S**

- **DRY CAVITY DESIGN AND BASALTIC CONCRETE**

- **DRY CAVITY PRECLUDES EX-VESSEL STEAM SPIKING AND  
EARLY CONTAINMENT OVERPRESSURE**
- **CAVITY CONFIGURATION ACTS AS TRAP FOR CORE DEBRIS**
- **UNDER MCCI CONDITIONS, BASALTIC CONCRETE RESULTS  
IN NO APPRECIABLE CO<sub>2</sub> PRODUCTION AND REDUCES  
RISK OF CO BURNS**

**NU**

## **DESIGN FEATURES (CON'T)**

- **CONTAINMENT SPRAY SYSTEMS**

- **MILLSTONE UNIT 3 EMPLOYS 2 DIVERSE SPRAY SYSTEMS:  
QUENCH SPRAY (SHORT TERM COOLING)  
RECIRC. SPRAY (LONG TERM COOLING)**
- **EITHER SPRAY DELAYS SUBSTANTIALLY CONTAINMENT  
FAILURE**

- **ULTIMATE CONTAINMENT STRENGTH**

- **DESIGN PRESSURE IS 45 PSIG**
- **BEST ESTIMATE MEDIAN ULTIMATE PRESSURE CAPABILITY  
IS 117.7 PSIG**

- **METEREOLOGY**

- **PREVAILING WINDS TOWARDS LONG ISLAND SOUND**

**NU**



## RESULTS OF THE STUDY SHOW:

- FREQUENCY OF CORE MELT FROM INTERNAL EVENTS  $4.5 \times 10^{-5}$  /YR
- FREQUENCY OF CORE MELT FROM EARTHQUAKES  $0.9 \times 10^{-5}$  /YR
- FREQUENCY OF CORE MELT FROM FIRES  $.48 \times 10^{-5}$  /YR
- FREQUENCY OF CORE MELT FROM ALL OTHER EXTERNAL EVENTS EXCEEDINGLY SMALL
- TOTAL CORE MELT FREQUENCY, ALL CAUSES  $5.9 \times 10^{-5}$  /YR
- RISK CURVES, EARLY AND LATENT FATALITIES, CONSISTENTLY LOWER THAN THE CORRESPONDING WASH-1400 CURVES



MILLSTONE UNIT NO. 3 PUBLIC RISK

EARLY FATALITIES  
PER REACTOR YEAR

LATENT FATALITIES  
PER REACTOR YEAR

ALL EVENTS

MEDIAN.....	1.6 x 10 <sup>-6</sup> .....	2.0 x 10 <sup>-3</sup>
90% CONFIDENCE .....	2.6 x 10 <sup>-5</sup> .....	1.2 x 10 <sup>-2</sup>

**NU**

# **STRENGTHS OF MILLSTONE UNIT 3 PSS**

- **AN EFFECTIVE MODEL IN A FORM AMENABLE TO BE UPDATED AND EXERCISED**
- **SPECIALIZED PERSONNEL KNOWLEDGEABLE OF STRENGTHS, LIMITATIONS, AND UNCERTAINTIES**
- **MANAGED BY A STAFF EQUALLY SKILLED IN DETERMINISTIC AS WELL AS PROBABILISTIC ANALYSIS**
- **SUPPORTED BY A MANAGEMENT ORGANIZATIONS COMMITTED TO USING IT IN SUPPORT OF PLANT SAFETY AND OPERATION**



## DESIGN CHANGES AND INSIGHTS DUE TO PSS

---

- IDENTIFICATION OF EMERGENCY GENERATOR LOAD SEQUENCER (EGLS) INPUT LOGIC ERROR
- IDENTIFICATION OF INCORRECT EGLS AC POWER SUPPLY
- RECOMMENDATION OF ADMINISTRATIVE CONTROLS TO REDUCE THE PROBABILITY OF A BORON DILUTION EVENT
- INSIGHTS INTO DRY REACTOR CAVITY EFFECTS
- INSIGHTS INTO IMPACT OF DELIBERATE HYDROGEN IGNITERS

# EXAMPLES OF CRITICAL OPERATOR ACTIONS

---

## IDENTIFIED BY PSS

---

CUT BACK QUENCH SPRAY TO CONSERVE RWST WATER FOR SMALL LOCA WITH FAILURE OF RECIRCULATION

USE OF LOOP ISOLATION VALVES (NOT CREDITED INTO STUDY) IN THE LONG TERM FOR RCP SEAL LOCA AND SGTR-INDUCED CORE MELT

ALTERNATE MEANS OF CHARGING AND SI PUMP COOLING IN THE EVENT OF TOTAL LOSS OF SERVICE WATER

MONITOR CONTAINMENT SUMP LEVEL FOR INCORE INSTRUMENT TUBE RUPTURE/SMALL LOCA

# "LIVING PRA" PROGRAM

- THE MP-3 PSS WAS INSTALLED ON THE IN-HOUSE PRA-DEDICATED COMPUTER
- IN-HOUSE STAFF HAS ANSWERED NRC QUESTIONS ON PSS
- PROGRAM UTILIZING PSS FOR PLANT SUPPORT IS UNDERWAY
- 1984 NU CORPORATE GOAL ESTABLISHED FOR APPLICATION OF PLANT SPECIFIC PRA OF ALL NU'S PLANTS TO MAINTENANCE, OPERATION, AND AS A SAFETY MANAGEMENT TOOL



# RECENT PRA APPLICATIONS AT NORTHEAST UTILITIES:

## DESIGN EVALUATIONS

- MILLSTONE-3 HYDROGEN IGNITER
- MILLSTONE-1 SCRAM DISCHARGE LEVEL INSTRUMENTATION
- MILLSTONE-3 REACTOR CAVITY FLOODING
- MILLSTONE-3 C.V.C.S. (BORON DILUTION)
- MILLSTONE-1,2, CONNECTICUT YANKEE, FIRE PROTECTION
- MILLSTONE-1 DECAY HEAT REMOVAL SYSTEMS
- CONNECTICUT YANKEE DECAY HEAT REMOVAL SYSTEMS
- CONNECTICUT YANKEE OFFSITE POWER TRANSMISSION TOWER PLACEMENT
- CONNECTICUT YANKEE R.W.S.T. AIR VENT
- MILLSTONE-3 SERVICE WATER SYSTEM (FLOODING PROTECTION)
- MILLSTONE-1 L.N.P. LOGIC MODIFICATIONS
- MILLSTONE-1,2 R.P.S. LOGIC



# RECENT PRA APPLICATIONS AT NORTHEAST UTILITIES: (CON'T)

## PROCEDURE EVALUATIONS:

- MILLSTONE-1 L.P.C.I./CORE SPRAY INJECTION VALUES TESTING INTERVALS (INTERFACING SYSTEM LOCA)
- CONNECTICUT YANKEE HEAVY LOAD CONTROL

## SAFETY EVALUATIONS FOR P.O.R.C./N.R.B.:

- MILLSTONE-2 STEAM DRIVEN AFW PUMP UNAVAILABILITY
- CONNECTICUT YANKEE D.C. BATTERY CELL UNAVAILABILITY
- CONNECTICUT YANKEE VITAL A.C. BUS UNAVAILABILITY
- MILLSTONE-1 IMPACT OF I.G.S.C.C.

## BEST ESTIMATE SAFETY ANALYSIS:

- MILLSTONE-1 ISOLATION CONDENSER RESPONSE AT OFF-NORMAL PRESSURE/TEMPERATURE
- MILLSTONE-3 CONTAINMENT RESPONSE DURING H<sub>2</sub> BURNS





# **SHORT TERM PROGRAM FOR PLANT SUPPORT**

- **"PSS LESSONS LEARNED" TRAINING FOR PLANT OPERATORS REFLECTED IN BOTH CLASSROOM AND SIMULATOR TRAINING**
- **EMERGENCY AND OFF-NORMAL OPERATING PROCEDURES TO BE REVIEWED IN LIGHT OF PSS EXPERIENCE**
- **STARTUP TEST PROCEDURES TO BE REVIEWED FOR VALIDATION OF MODES OF OPERATION AND SUCCESS CRITERIA ASSUMED IN PSS**
- **STARTUP TEST RESULTS NOT MEETING ACCEPTANCE CRITERIA TO BE EVALUATED FOR SIGNIFICANCE AND CORRECTIVE ACTION**
- **PRA EXPERTISE INCORPORATED INTO MP-3 NUCLEAR REVIEW BOARD**

**NUJ**

## **PLANT SUPPORT (CON'T)**

- **IMPLEMENTATION OF THE CORPORATE GOAL ON PRA INCLUDES THE DEVELOPMENT OF:**
  - **A SHORT TERM PLAN TO COMPLETE THE PRA'S IN SUPPORT OF THE MP-1 AND CONNECTICUT YANKEE ISAP (APRIL 1984)**
  - **A LONG TERM PLAN IDENTIFYING PROCEDURES TO ALLOW PERIODIC UPDATE OF THE LIVING PRA'S TO REFLECT PLANT CHANGES (OCTOBER 1984)**
  - **A LONG TERM PLAN OUTLINING MODALITIES OF APPLICATION OF LIVING PRA'S FOR OPERATIONAL AND SAFETY SUPPORT (OCTOBER 1984)**

**NU**

# **MAINTENANCE OF LIVING PRA**

- **TIE IN PSS TO PLANT DESIGN CHANGE PROCESS**
- **TIE IN PSS TO PROCEDURES WHICH COULD IMPACT PSS MODEL**
- **TIE INTO THE OPERATIONAL ASSESSMENT PROCESS**
- **TIE INTO EQUIPMENT DATA ASSESSMENT**

**NU**

# **CURRENT APPLICATIONS OF PRA AT NU**

- **MP-3 PSS IN INITIAL STAGE OF APPLICATION**
- **MP-1 PSS SCHEDULED TO BE COMPLETED BY DECEMBER 1984 IN SUPPORT OF THE INTEGRATED SAFETY ASSESSMENT PROGRAM (ISAP)**
- **CONNECTICUT YANKEE (CY) PSS SCHEDULED TO BE COMPLETED BY DECEMBER 1985 IN SUPPORT OF ISAP**

**NU**

# RESOURCE COMMITMENTS

- PERMANENT STAFFING MORE THAN DOUBLED
- ADDITIONAL SPECIALIZED PERSONNEL HIRED FOR TEMPORARY SUPPORT
- PRA COMPUTER SYSTEM EXPANDED

**NU**

**NORTHEAST UTILITIES SERVICE COMPANY**

**PROBABILISTIC SAFETY STUDY  
SYSTEMS ANALYSIS**

**DR. JOHN H. BICKEL, SUPERVISOR,  
PRA SECTION,  
SAFETY ANALYSIS BRANCH**



## **MILLSTONE-3 PSS ADDRESSES:**

- **BEST ESTIMATE CORE MELT FREQUENCY AND RISK**
- **INTERNAL AND EXTERNAL INITIATING EVENTS**
- **FULL POWER AND SHUTDOWN MODES OF OPERATION**
- **AIRBORNE AND LIQUID PATHWAY CONSEQUENCES**



## **MILLSTONE-3 PSS USED:**

- **STATE OF THE ART RISK ASSESSMENT TECHNOLOGY**
- **METHODS ADDRESSING MAJORITY OF ITEMS FROM CRITIQUE OF WASH-1400**
- **INSIGHTS FROM PAST AND RECENT PRA STUDIES**





## **MILLSTONE-3 PSS CONSIDERED:**

- **FROZEN PLANT DESIGN AS OF FEBRUARY, 1982**
- **COMPONENT FAILURE RATES BASED ON OPERATING PWR EXPERIENCE**
- **BEST ESTIMATE LOCA AND TRANSIENT RESPONSE**
- **WESTINGHOUSE EMERGENCY RESPONSE GUIDELINES**
- **BEST ESTIMATE CONTAINMENT, SOURCE TERM, CONSEQUENCE ANALYSIS**
- **MILLSTONE SITE RELATED CHARACTERISTICS:**
  - **HISTORICAL WEATHER CONDITIONS**
  - **OFFSITE POPULATION DENSITY**
  - **OFFSITE EMERGENCY PLANNING**



# **STRENGTHS/LIMITATIONS OF PRA**

## **STRENGTHS INCLUDE:**

- **CONSIDERATION OF OUTCOME OF MULTIPLE FAILURES**
- **INCORPORATION OF OPERATOR INTO OVER ALL UNDERSTANDING OF SAFETY/RISK**
- **CONSIDERATION OF ACTUAL EQUIPMENT PERFORMANCE VS. DESIGN BASIS**
- **UNDERSTANDING OF DOMINANT CAUSES OF ACCIDENT SEQUENCES IN CERTAIN AREAS**
- **ABILITY TO EVALUATE IMPORTANCE OF ISSUES BASED ON ACTUAL STATISTICS FROM PAST EXPERIENCE**

## **LIMITATIONS:**

- **STATISTICS FROM CERTAIN AREAS ARE NON-EXISTENT**
- **RELIABILITY ANALYSES IN SOME CASES YIELD NUMBERS TOO SMALL TO COMPREHEND**
- **CERTAIN FAILURE MODES MAY BE BEYOND ABILITY OF ANALYSTS TO CONSIDER**
- **SEVERE ACCIDENT SEQUENCE PROGRESSION INVOLVES PROCESSES FOR WHICH THERE IS A LACK OF KNOWLEDGE OF INTEGRATED EFFECTS**



# TREATMENT OF SPECIAL ISSUES:

- INITIATING EVENTS
- SUCCESS CRITERIA
- SYSTEMS ANALYSIS
- COMMON CAUSE FAILURE
- SUPPORT SYSTEMS
- SYSTEMS INTERACTIONS
- HUMAN ERROR
- UNCERTAINTY ANALYSIS



# **INITIATING EVENT SELECTION CONSIDERED:**

- **FULL SPECTRUM OF LOCA EVENTS**
- **US PWR EXPERIENCE**
- **MILLSTONE SITE EXPERIENCE**
- **BOP FMEA (STONE AND WEBSTER)**
- **SUPPORT SYSTEM FAILURES**
- **SUPPORT SYSTEMS INTERACTIONS**
- **CONTROL-PROTECTIVE INTERACTIONS**
- **POSTULATED EXTERNAL INITIATING EVENTS**



# LIVING PRA IMPLEMENTATION:

- EPRI DATA INDICATES GREATER THAN 10 PLANT TRANSIENTS PER YEAR
- N.U. DATA SHOWS A DECREASE TO <3 EVENTS/YR. FOR MATURE PLANTS
- FORMAL PROGRAM EXISTS TO COLLECT FAILURE DATA
- FORMAL PROGRAM EXISTS TO ANALYZE INITIATING EVENTS AND IDENTIFY CAUSES AND SAFETY IMPLICATIONS
- THESE MEASURES ASSURE THAT:
  - NATURE OF EVENTS CONSISTENT WITH P.S.S.
  - FREQUENCY OF EVENTS CONSISTENT WITH P.S.S.
- SIGNIFICANT DIFFERENCES WITH LIVING PRA MODELS WILL BE UPDATED
- DATA BASES:
  - P.I.R.S.
  - B.E.A.R.D.S.
  - P.M.M.S.
  - PLANT MAINTENANCE RECORDS
  - SHIFT SUPERVISOR'S LOG BOOKS
  - NUSOERS
  - L.E.R.S.



# SUCCESS CRITERIA

- FSAR SUCCESS CRITERIA USED FOR MOST PART
- CERTAIN SUCCESS CRITERIA REFLECT NEW WESTINGHOUSE EMERGENCY RESPONSE GUIDELINES
- EXAMPLES:
  - MITIGATING LARGE LOCA WITH ACCUMULATORS AND H.P.S.I. IF L.P.S.I. FAILS
  - MITIGATING SMALL LOCA WITH L.P.S.I. FOLLOWING MANUAL DEPRESSURIZATION USING A.F.W. IF H.P.S.I. FAILS
  - MITIGATING TRANSIENTS VIA FEED AND BLEED CORE COOLING USING H.P.S.I. AND P.O.R.V.s IF A.F.W. FAILS



# **SYSTEMS ANALYSIS:**

- **LARGE EVENT TREE/SMALL FAULT TREE APPROACH**
- **EVENT TREES EXPLICITLY MODEL SECONDARY FAULTS AND TRANSFERS TO OTHER EVENT TREES**

**EXAMPLES: ATWS  
PORV LOCA**

- **EVENT TREES EXPLICITLY MODEL OPERATOR ACTIONS PER WESTINGHOUSE ERGs**
- **EVENT TREES QUANTIFIED FOR EACH OF THE EIGHT SUPPORT SYSTEM CONFIGURATIONS**



## **FAULT TREES AND RELIABILITY ANALYSIS:**

- **FAULT TREES DEVELOPED FOR ALL CRITICAL SYSTEMS**
- **FAULT TREES QUANTIFIED FOR EACH OF EIGHT INITIAL CONDITIONS DEFINED BY SUPPORT STATES**
- **STANDARD RELIABILITY ANALYSIS TECHNIQUES UTILIZED**
- **WESTINGHOUSE PWR RELIABILITY DATA BASE UTILIZED**
  - **STATISTICAL POPULATION IS GREATER THAN THAT IN WASH-1400**
  - **INCORPORATES ACTUAL FAILURES VS. L.E.R. DATA**
  - **INCORPORATES ACTUAL DEMANDS/RUN-HOURS**






# COMMON CAUSE FAILURE

## HISTORY:

- REDUNDANCY AND SOUND DESIGN PRACTICES MINIMIZES UNAVAILABILITY DUE TO RANDOM FAILURES
- SYSTEM DIVERSITY AND GOOD MAINTENANCE/TESTING PRACTICES REDUCES UNAVAILABILITY DUE TO COMMON CAUSE FAILURES
- COMMON CAUSE IS KNOWN TO BE THE DOMINANT FAILURE MECHANISM FOR REDUNDANT SYSTEMS



# COMMON CAUSE FAILURE



**NU**


# SYSTEMS INTERACTION

## HISTORY:

- OPERATING PLANT EVENTS:
  - ELECTRICAL BUS FAULTS
  - SPURIOUS DELUGE SYSTEM OPERATION
  - CONTROL/PROTECTIVE INTERACTIONS
- INDUSTRY DESIGN STANDARDS IMPROVED
- UNRESOLVED SAFETY ISSUE A-17
- NUMEROUS INDEPENDENT SYSTEMS INTERACTION STUDIES UNDERTAKEN FOR MILLSTONE 3
- P.S.S. HAS INTEGRATED RESULTS OF THESE STUDIES IN AN INTERDISCIPLINARY FASHION
- P.S.S. HAS SYSTEMATICALLY IDENTIFIED, RANKED, AND PROVIDED SIGNIFICANT INSIGHTS



# SYSTEMS INTERACTION



**NU**

## **EXAMPLES OF PLANT UNIQUE INITIATORS DERIVED FROM F.M.E.A.:**

- 1. LOSS OF A VITAL DC BUS**
  - LOSS OF MAIN FEEDWATER
  - STEAM DRIVEN AFW PUMP INLET VALVES FAIL OPEN
  - REACTOR/TURBINE TRIP
  - INABILITY TO OPERATE 1/2 OF AC BREAKERS
  - LOSS OF 1/2 ESF CABINETS/SYSTEMS
  - LOSS OF 1/2 PORVs
  
- 2. LOSS OF A VITAL AC BUS**
  - LOSS OF MAIN FEEDWATER TO 1/4 STEAM GENERATORS
  - AUTO CONTROL ROD INSERTION (WRONG INDICATED T AVG)
  - REACTOR/TURBINE TRIP
  - LOSS OF 1/2 ESF CABINETS/SYSTEMS
  - LOSS OF 1/2 EMERG. GEN. LOAD SEQUENCERS
  - LOSS OF AUTO STEAM DUMP/BYPASS CAPABILITY
  - MALFUNCTION OF AUTO PRESSURIZER LEVEL CONTROL SYSTEM
  - LOSS OF AUTO PRESSURIZER SPRAYS
  - LOSS OF AUTO PORV CAPABILITY



## **TREATMENT OF OPERATOR ACTIONS/HUMAN ERROR:**

- **CONSERVATIVE SCREENING VALUES USED**
- **RELIANCE ON WESTINGHOUSE ERGs**
- **OPERATOR ACTIONS APPEAR EXPLICITLY IN EVENT TREES**
- **RECOVERY OF FAILED ACTUATING SYSTEMS CONSIDERED**
- **HUMAN ERRORS APPEAR EXPLICITLY ON FAULT TREES**

**NU**

## **TREATMENT OF UNCERTAINTIES:**

- **TECHNIQUES FOR MATHEMATICAL PROPAGATION WELL UNDERSTOOD**
  - MEANS AND VARIANCES
  - METHOD OF MOMENTS
  - D.P.D. ARITHMETIC
- **IDENTIFICATION OF UNCERTAINTIES IS MORE DIFFICULT**
  - RANDOMNESS
  - MODELING UNCERTAINTY
- **SOURCES OF UNCERTAINTY:**
  - INITIATING EVENTS
  - SUCCESS CRITERIA
  - EVENT TREES
  - FAULT TREES
  - RELIABILITY ANALYSIS
  - HUMAN ERROR ANALYSIS
  - INTERNAL EVENT COMMON CAUSE ANALYSIS
  - EXTERNAL EVENT COMMON CAUSE ANALYSIS
  - QUANTIFICATION PROCESS
- **UNCERTAINTY ANALYSIS MUST BE TAILORED TO END USES**



# **ENGINEERING INSIGHTS**

- **DOMINANT ACCIDENT SEQUENCES**
  - **INTERNAL**
  - **EXTERNAL**
- **CRITICAL SYSTEMS**
- **CRITICAL ISSUES**

**NU**



# DOMINANT INTERNAL EVENT ACCIDENT SEQUENCES CONTRIBUTING TO CORE MELT

SEQUENCE DESCRIPTION	MEAN ANNUAL FREQUENCY	PERCENT CONTRIBUTION TO CORE MELT FREQUENCY
MEDIUM LOCA: FAILURE OF HIGH PRESSURE RECIRCULATION	3.87E-6	6.6
LOSS OF VITAL DC BUS 1 OR 2: FAILURE OF AUXILIARY FEEDWATER, FAILURE OF BLEED AND FEED COOLING (SYSTEMS INTERACTION)	2.20E-6	3.7
LOSS OF VITAL AC BUS 1 OR 2: FAILURE OF AUXILIARY FEEDWATER, FAILURE OF HIGH PRESSURE RECIRCULATION (SYSTEMS INTERACTION)	1.98E-6	3.4
LOSS OF VITAL AC BUS 3 OR 4: FAILURE OF AUXILIARY FEEDWATER, FAILURE OF HIGH PRESSURE RECIRCULATION (SYSTEMS INTERACTION)	1.98E-6	3.4
INTERFACING SYSTEMS LOCA: FAILURE OF RHR INLET VALVES	1.90E-6	3.2

**NU**

# DOMINANT INTERNAL EVENT ACCIDENT SEQUENCES CONTRIBUTING TO CORE MELT

SEQUENCE DESCRIPTION	MEAN ANNUAL FREQUENCY	PERCENT CONTRIBUTION TO CORE MELT FREQUENCY
LOSS OF OFF-SITE POWER: FAILURE OF BOTH DIESEL GENERATORS, FAILURE TO RECOVER POWER IN 6 HOURS, FAILURE OF QUENCH SPRAY RECOVERY (STATION BLACKOUT)	1.65E-6	2.8
LOSS OF OFF-SITE POWER: FAILURE OF ONE ESF BUS, STEAM LINE BREAK INSIDE CONTAINMENT, FAILURE OF AUXILIARY FEEDWATER, FAILURE OF PRIMARY BLEED THROUGH PORV'S	1.63E-6	2.7
STEAM LINE BREAK OUTSIDE CONTAINMENT: FAILURE TO ISOLATE MAIN STEAM LINE, FAILURE OF PRIMARY BLEED THROUGH PORV'S	1.55E-6	2.6
SMALL LOCA: FAILURE TO CONTROL PRIMARY DEPRESSURIZATION, FAILURE TO HIGH PRESSURE RECIRCULATION	1.39E-6	2.4



# DOMINANT INTERNAL EVENT ACCIDENT SEQUENCES CONTRIBUTING TO CORE MELT

SEQUENCE DESCRIPTION	MEAN ANNUAL FREQUENCY	PERCENT CONTRIBUTION TO CORE MELT FREQUENCY
LARGE LOCA: FAILURE OF LOW PRESSURE RECIRCULATION	1.37E-6	2.3
LOSS OF VITAL AC BUS 1 OR 2: FAILURE OF OPPOSITE TRAIN ESF CABINET, FAILURE OF AUXILIARY FEEDWATER, FAILURE OF BLEED AND FEED COOLING, FAILURE OF QUENCH SPRAY (SYSTEMS INTERACTION)	7.23E-7	1.2
PRIMARY TO SECONDARY POWER MISMATCH: FAILURE OF BOTH ESF CABINETS, FAILURE OF AUXILIARY FEEDWATER FAILURE OF BLEED AND FEED COOLING, FAILURE OF QUENCH SPRAY	6.15E-7	1.0
REACTOR TRIPS: FAILURE OF BOTH ESF CABINETS, FAILURE OF AUXILIARY FEEDWATER, FAILURE OF BLEED AND FEED COOLING, FAILURE OF QUENCH SPRAY	4.87E-7	0.8
TURBINE TRIPS: FAILURE OF BOTH ESF CABINETS, FAILURE OF AUXILIARY FEEDWATER, FAILURE OF BLEED AND FEED COOLING, FAILURE OF QUENCH SPRAY	3.74E-7	0.6




# DOMINANT INTERNAL EVENT ACCIDENT SEQUENCES CONTRIBUTING TO CORE MELT

SEQUENCE DESCRIPTION	MEAN ANNUAL FREQUENCY	PERCENT CONTRIBUTION TO CORE MELT FREQUENCY
PRIMARY TO SECONDARY POWER MISMATCH: COINCIDENT STATION BLACKOUT, SMALL LOCA, FAILURE OF HIGH PRESSURE INJECTION, FAILURE OF SECONDARY DEPRESURIZATION AND LOW PRESSURE INJECTION, FAILURE OF QUENCH SPRAY RECOVERY	2.43E-7	0.4
REACTOR TRIP: COINCIDENT STATION BLACKOUT, SMALL LOCA, FAILURE OF HIGH PRESSURE INJECTION, FAILURE OF SECONDARY DE- PRESSURIZATION AND LOW PRESSURE INJECTION, FAILURE OF QUENCH SPRAY RECOVERY	1.92E-7	0.3
TURBINE TRIP: COINCIDENT STATION BLACKOUT, SMALL LOCA, FAILURE OF HIGH PRESSURE INJECTION, FAILURE OF SECONDARY DE- PRESSURIZATION AND LOW PRESSURE INJECTION, FAILURE OF QUENCH SPRAY RECOVERY	1.48E-7	0.2
LOSS OF VITAL AC BUS 1 OR 2: FAILURE OF AUXILIARY FEEDWATER, FAILURE OF HIGH PRESSURE RECIRCULATION, FAILURE OF CONTAINMENT RE- CIRCULATION SPRAY (SYSTEMS INTERACTION)	9.36E-8	0.1



PERCENTAGE CONTRIBUTION TO CORE MELT



## **P.S.S. INSIGHTS INTO CRITICAL SYSTEMS:**

- **ACCIDENT SEQUENCES INVOLVING AUXILIARY FEEDWATER FAILURE COMPRISE 40% CORE MELT FREQUENCY**
- **ACCIDENT SEQUENCES INVOLVING HIGH PRESSURE RECIRC. FAILURE COMPRISE ~27.5% CORE MELT FREQUENCY**
- **ACCIDENT SEQUENCES INVOLVING FAILURE OF FEED AND BLEED COOLING COMPRISE ~24.5% CORE MELT FREQUENCY**




## **P.S.S. INSIGHTS INTO CRITICAL SAFETY ISSUES:**

- **352 SEQUENCES INVOLVING SYSTEMS INTERACTIONS**
  - **COMPRISES 18% CORE MELT FREQUENCY**
  - **BREAKDOWN:**

VITAL AC BUS 1, 2	7%
VITAL AC BUS 3, 4	5.8%
VITAL DC BUS 1, 2	3.9%
VITAL DC BUS 3, 4	0%
SERVICE WATER	1.2%
- **SEISMIC EVENTS COMPRISE 15.4% CORE MELT FREQUENCY**
- **440 SEQUENCES INITIATED BY LOSS OF OFFSITE POWER**
  - **COMPRISES 11.2 % CORE MELT FREQUENCY**
  - **STATION AC BLACKOUT WITHOUT RECOVERY: 2.7%**
- **FIRES COMPRISE 8.1% CORE MELT FREQUENCY**
- **264 SEQUENCES INVOLVING STEAM GENERATOR TUBE RUPTURE**
  - **COMPRISES 2.7% CORE MELT FREQUENCY**
- **TOTAL LOSS OF DC POWER WITHOUT RECOVERY**
  - **INSIGNIFICANT CONTRIBUTOR**
- **PRESSURIZED THERMAL SHOCK**
  - **INSIGNIFICANT CONTRIBUTOR**



# COMPARISON OF RISK CURVES FOR LATENT FATALITIES WASH-1400 VS. MILLSTONE 3





# COMPARISON OF RISK CURVES FOR EARLY FATALITIES WASH-1400 VS. MILLSTONE 3

