



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

January 4, 1996

TVA-SQN-TS-95-22

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of	)	Docket Nos. 50-327
Tennessee Valley Authority	)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS)  
CHANGE 95-22, "RADIATION MONITORING INSTRUMENTATION SURVEILLANCE  
FREQUENCY REVISION"

In accordance with 10 CFR 50.90, we are enclosing an amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change will extend the radiation monitoring instrumentation surveillance period in accordance with Generic Letter 93-05, "Line-Item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation," dated September 27, 1993.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

TVA requests that this TS be considered a cost beneficial licensing action. Extension of the radiation monitoring instrumentation surveillance interval is estimated to save TVA \$1,008,000 over the life of the plant. This is a significant manpower saving since two-thirds of the functional tests for the subject monitors will be deleted.

TVA requests a 45-day implementation period for this TS change following issuance to revise appropriate procedures and update the Surveillance Instruction Database.

160013

9601160223	960104
PDR	ADOCK
P	U5000327
	PDR

*DD30*

U.S. Nuclear Regulatory Commission  
Page 2  
January 4, 1996

Please direct questions concerning this issue to W. C. Ludwig at (423) 843-7460.

Sincerely,

*R. H. Shell*

R. H. Shell  
Manager  
SQN Site Licensing

Sworn to and subscribed before me  
this 4<sup>th</sup> day of January 1996

*George M. Billingsley*

Notary Public

My Commission Expires Oct 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission  
Page 3  
January 4, 1996

(Enclosures):

Mr. D. E. LaBarge, Project Manager  
Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)  
Division of Radiological Health  
3rd Floor  
L & C Annex  
401 Church Street  
Nashville, Tennessee 37243-1532

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-2711

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION (TS) CHANGE

SEQUOYAH NUCLEAR PLANT (SQN) UNITS 1 AND 2

DOCKET NOS. 50-327 AND 50-328

(TVA-SQN-TS-95-22)

LIST OF AFFECTED PAGES

Unit 1

3/4 3-35

3/4 3-42

Unit 2

3/4 3-35

3/4 3-43