

MAY 02 1992

Docket Nos. 50-317
50-318

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
ATTN: Mr. George C. Creel
Vice President, Nuclear Energy
MD Rts 2 and 4, Post Office Box 1535
Lusby, Maryland 20657

Dear Mr. Creel:

Subject: Combined Inspection Report Nos. 50-317/92-10 and 50-318/92-10

This refers to the safety inspection conducted by Messrs. G. A. Koch and R. A. McBrearty of this office on March 23 through April 3, 1992 at the Calvert Cliffs Nuclear Power Station, Lusby, Maryland of activities authorized by the NRC and to the discussions of our findings held by Mr. McBrearty with Mr. R. Wenderlich of your staff at the conclusion of the inspection.

The inspection was directed toward the inservice inspection program and related activities, and the steam generator tube eddy current examination program. These inspections are used to determine that programs you have in place to detect in-service degradation satisfy your commitments and regulatory requirements. Generally, we found your program implementation satisfactory. Areas examined during this inspection are described in the NRC Region I inspection report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Within the scope of this inspection, no violations were observed. However, weaknesses were identified in the inservice inspection program in that the Baltimore Gas & Electric Company evaluation of acceptance examination results were not documented, the inservice inspection program implementing procedure lacked guidance for carrying out defined responsibilities, and guidance was lacking regarding the need for requesting relief from code requirements in cases of partial examinations.

9205123123 920502
PDR ADOCK 05000317
Q PDR

11
IE:01

MAY 04 1992

Baltimore Gas and
Electric Company

2

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
Clifford J. Anderson

Clifford J. Anderson, Acting Chief
Engineering Branch
Division of Reactor Safety

Enclosure: Combined Inspection Report Nos. 50-317/92-10 and 50-318/92-10

cc w/encl:

G. Detter, Director, Nuclear Regulatory Matters (CCNPP)
R. McLean, Administrator, Nuclear Evaluations
J. Walter, Engineering Division, Public Service Commission of Maryland
K. Burger, Esquire, Maryland People's Counsel
R. Ochs, Maryland Safe Energy Coalition
K. Abraham, PAO (2)
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
W. Lanning, DRS
C. Cowgill, DRP
J. Yerokun, DRP
L. Nicholson, DRP
S. Greenlee, DRP
P. Wilson, SRI - Calvert Cliffs
R. Lobel, OEDO
R. Capra, NRR
D. McDonald, NRR
DRS SALP Coordinator
G. Johnson, NRR
B. Brown, EG&G

MAY 02 1992

Baltimore Gas and
Electric Company

3

GAK

RI:DRS

Koch

04/ 192

RI-DRS C/H

McBride

R/B

RI:DRS

Gray

4/24/92

04/21/92

C/G

RI:DRS

Anderson

04/2/92

5

OFFICIAL RECORD COPY
A:BG&E9210.GK