

August 23, 1995

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-95-49

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by Region II staff (Atlanta, Georgia) on this date.

Facility

Georgia Power Co.
Hatch 2
Baxley, Georgia
Dockets: 50-366

Licensee Emergency Classification

Notification of Unusual Event
X Alert
Site Area Emergency
General Emergency
Not Applicable

Subject: ALERT DECLARED (THIS IS A DRILL)

At 0823 on August 23, 1995, Hatch Nuclear Plant in Baxley, Georgia declared an ALERT due to a primary coolant leakage greater than 50 gallons per minute. The leak is into the containment with no unplanned radiological releases to the environment at this time. In addition, control rod 06-03 was not fully inserted after Unit 2 was scrammed and the site lost all AC power (on and offsite) as of 0932.

Unit 1 is currently shut down and is in a refueling status.

The licensee activated its emergency organization at 0852 and the NRC entered stand-by at 0932.

Contact: ANN BOLAND
(404)331-5089

160056

9601170120 950823
PDR I&E
PNO-II-95-049 PDR

DF01
0/1