

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER * 400 NORTH OLIVE STREET, L.B. 81 * DALLAS, TEXAS 75201

Log # TXX-4290
File # 905.4

August 29, 1984

Mr. B. J. Youngblood, Chief
Division of Licensing
Licensing Branch No. 1
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
PRESERVICE INSPECTION PLAN UPDATE

Dear Mr. Youngblood:

Enclosed are three (3) copies of new relief requests C-5 and C-6, and revised relief requests B-8 and B-10. These relief requests contain the information required by NRC Question 121.13. Copies of these relief requests are also being sent to the CPSES resident inspector and Tom Taylor at Battelle Northwest Laboratories.

Should you have any questions, please contact me directly.

Sincerely,


H. C. Schmidt

BSD:t1s
Enclosures

c - J. J. Stefano
J. A. Cummins
T. Taylor

8409050088 840829
PDR ADOCK 05000445
Q PDR

Boo!
11

RELIEF REQUEST B-8

Component: Pressurizer B5.20
Steam Generators B5.30

CODE CLASS: 1

Examination Requirement:

Table IWB-2500-1 Category B-F requires a volumetric and surface examination of the nozzle to safe end welds, including 1/3 wall thickness for volumetric examination.

Basis for Relief:

The geometric configuration of the nozzle prevents ultrasonic examination from being performed on the base metal on the nozzle side of the weld to the extent required by Figure IWB-2500-8 for all welds listed in Table B-8.

Alternative Examination:

One hundred percent of the weld volume up to 1/3T and the required amount of base metal on the pipe side of the weld will be examined. The base metal on the nozzle side of the weld will be examined to the extent practical. Surface examinations will be performed on essentially 100% of the required area. Also see Table B-8.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Steam Generators B-FPage 1 of 2

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------|----------|------------------------|--------|---|---------------|
| TBX-1-4100 | Loop 1 RC | 4DM | Pipe to nozzle | 90% | Metallurgy obstruction, weld contour @ toe, nozzle taper | RT, PT |
| TBX-1-4200 | Loop 2 RC | 4DM | Pipe to nozzle | 85% | Metallurgy obstruction, nozzle taper, weld crown | RT, PT |
| TBX-1-4200 | Loop 2 RC | 5DM | Pipe to nozzle | 85% | Metallurgy obstruction, nozzle taper, weld crown | RT, PT |
| TBX-1-4300 | Loop 3 RC | 4DM | Pipe to nozzle | 85% | Metallurgy obstruction, nozzle taper, weld crown | RT, PT |
| TBX-1-4300 | Loop 3 RC | 5DM | Pipe to nozzle | 85% | Metallurgy obstruction, nozzle taper, weld crown | RT, PT |
| TBX-1-4400 | Loop 4 RC | 4DM | Pipe to nozzle | 95% | Metallurgy obstruction, nozzle taper, rough surface, weld crown | RT, PT |
| TBX-1-4400 | Loop 4 RC | 5DM | Pipe to nozzle | 95% | Metallurgy obstruction, nozzle taper, weld crown, rough surface | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Pressurizer B-FPage 2 of 2

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|--------------------------|----------|------------------------|--------|--------------------|---------------|
| TBX-1-4501 | Pressurizer Safety | 1DM | Nozzle to safe-end | 90% | Nozzle restriction | RT, PT |
| TBX-1-4501 | Pressurizer Safety | 12DM | Nozzle to safe-end | 90% | Nozzle restriction | RT, PT |
| TBX-1-4502 | Safety Relief | 1DM | Nozzle to safe-end | 90% | Nozzle restriction | RT, PT |
| TBX-1-4503 | Pressurizer Safety Spray | 31DM | Nozzle to safe-end | 75% | Nozzle restriction | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

RELIEF REQUEST B-10

Component: Piping Systems

CODE CLASS: 1

Examination Requirement:

Table IWB-2500-1 Category B-J requires volumetric examination of branch pipe connection welds exceeding 2 inches diameter.

Basis for Relief:

The configuration of the pipe branch connections prevents meaningful volumetric examination of the entire weld and heat affected zone for welds listed in Table B-10. Practical alternative techniques to volumetrically examining the entire areas of these welds which would produce meaningful results are not presently available.

Alternative Examination:

A volumetric examination will be performed on butt welded branch connections only. A surface examination will be performed as required. Also see Table B-10.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-JPage 1 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|------------------------|--------|--|---------------|
| TBX-1-4100 | Loop 1 RC | 2 | Pipe to pipe | 60% | Metallurgy obstruction, adjacent weld, weld contour | RT, PT |
| TBX-1-4100 | Loop 1 RC | 13 | Pipe to pipe | 50% | Metallurgy obstruction, elbow taper, adjacent weld, weld contour | RT, PT |
| TBX-1-4100 | Loop 1 RC | 21BC | Branch connection | 50% | Metallurgy obstruction 4" nozzle 1" from weld | RT, PT |
| TBX-1-4101 | RHR Take-off | 7 | Valve to pipe | 80% | Valve body restriction | RT, PT |
| TBX-1-4101 | RHR Take-off | 8 | Valve to pipe | 80% | Valve body restriction | RT, PT |
| TBX-1-4101 | RHR Take-off | 13 | Valve to pipe | 80% | Valve body restriction | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 2 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 5 | Pipe to elbow | * | Welded name plate | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 6 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 7 | Pipe to valve | * | Weld toe, pipe to valve | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 8 | Pipe to valve | * | Weld toe, pipe to valve | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 9 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4102 | Accumulator Discharge | 10 | Pipe to elbow | * | Weld toe | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

TABLE B-10
SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-J

Page 2 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|------------------------|--------|---|---------------|
| TBX-1-4102 | Accumulator Discharge | 11 | Pipe to tee | * | Weld toe | RT, PT |
| TBX-1-4104 | SIS | 1BC | Branch connection | 70% | Branch connection collar | RT, PT |
| TBX-1-4104 | SIS | 3 | Pipe to elbow | 80% | Weld crown, weld toe | RT, PT |
| TBX-1-4104 | SIS | 4 | Pipe to elbow | 85% | Weld crown, weld toe | RT, PT |
| TBX-1-4104 | SIS | 5 | Pipe to elbow | 85% | Weld crown, weld toe | RT, PT |
| TBX-1-4200 | Loop 2 RC | 2 | Pipe to pipe | 60% | Metallurgy obstruction, adjacent weld contour, weld crown | RT, PT |
| TBX-1-4200 | Loop 2 RC | 19BC | Branch connection | 70% | Metallurgy obstruction, weld crown | RT, PT |
| TBX-1-4200 | Loop 2 RC | 11 | Pipe to nozzle | 95% | Metallurgy obstruction, weld crown | RT, PT |
| TBX-1-4200 | Loop 2 RC | 13 | Pipe to pipe | 50% | Weld crown, elbow taper, adjacent weld, weld contour | RT, PT |
| TBX-1-4201 | Accumulator Discharge | 2 | Pipe to elbow | * | Weld buildup, weld toe | RT, PT |
| TBX-1-4201 | Accumulator Discharge | 5 | Pipe to elbow | * | Welded nameplate, weld toe | RT, PT |
| TBX-1-4201 | Accumulator Discharge | 6 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4201 | Accumulator Discharge | 7 | Pipe to valve | * | Weld toe | RT, PT |
| TBX-1-4201 | Accumulator Discharge | 8 | Pipe to valve | * | Weld toe | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-JPage 3 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|------------------------|--------|---|---------------|
| TBX-1-4201 | Accumulator Discharge | 11 | Pipe to tee | * | Weld toe | RT, PT |
| TBX-1-4202 | SIS | 5 | Pipe to elbow | 90% | Elbow | RT, PT |
| TBX-1-4202 | SIS | 12 | Pipe to tee | 85% | "T" connection | RT, PT |
| TBX-1-4300 | Loop 3 RC | 2 | Pipe to pipe | 60% | Metallurgy obstruction, adjacent weld contour, weld crown | RT, PT |
| TBX-1-4300 | Loop 3 RC | 13 | Pipe to pipe | 50% | Metallurgy obstruction, adjacent weld contour, weld crown | RT, PT |
| TBX-1-4300 | Loop 3 RC | 11 | Pipe to nozzle | 95% | Metallurgy obstruction, nozzle tape, weld crown | RT, PT |
| TBX-1-4300 | Loop 3 RC | 19BC | Branch connection | 70% | Metallurgy obstruction, weld crown | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 2 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 5 | Pipe to elbow | * | Welded nameplate, weld toe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 6 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 8 | Pipe to valve | * | Valve to pipe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 9 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 10 | Pipe to elbow | * | Weld toe | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

TABLE B-10
SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-J

Page 4 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|------------------------|--------|---|---------------|
| TBX-1-4301 | Accumulator Discharge | 11 | Pipe to tee | * | Weld toe | RT, PT |
| TBX-1-4301 | Accumulator Discharge | 7 | Pipe to valve | 60% | Valve restriction | RT, PT |
| TBX-1-4400 | Loop 4 RC | 2 | Pipe to pipe | 60% | Metallurgy obstruction, adjacent weld, weld contour | RT, PT |
| TBX-1-4400 | Loop 4 RC | 13 | Pipe to pipe | 50% | Metallurgy obstruction, adjacent weld, weld contour | RT, PT |
| TBX-1-4400 | Loop 4 RC | 22BC | Branch connection | 60% | Metallurgy obstruction, 4" nozzle 3/4" from weld | RT, PT |
| TBX-1-4401 | RHR Take-off | 6 | Pipe to valve | 75% | Weld crown, valve body | RT, PT |
| TBX-1-4401 | RHR Take-off | 7 | Pipe to valve | 75% | Weld crown | RT, PT |
| TBX-1-4401 | RHR Take-off | 12 | Pipe to valve | 75% | Weld crown, valve body | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 2 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 5 | Pipe to elbow | * | Welded nameplate, weld toe | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 6 | Pipe to elbow | * | Weld toe | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 7 | Pipe to valve | * | Weld toe | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 8 | Pipe to valve | * | Weld toe | RT, PT |
| TBX-1-4402 | Accumulator Discharge | 10 | Pipe to elbow | * | Weld toe | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

TABLE B-10
SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-J

Page 5 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|------------------------|--------|-------------------------------|---------------|
| TBX-1-4402 | Accumulator Discharge | 11 | Pipe to tee | * | Weld toe | RT, PT |
| TBX-1-4403 | SIS | 7 | Pipe to elbow | 90% | Hanger restriction | RT, PT |
| TBX-1-4501 | Pressurizer Safety | 22 | Pipe to nozzle | 90% | Nozzle restriction | RT, PT |
| TBX-1-4502 | Safety Relief | 8 | Pipe to elbow | 95% | Weld crown, elbow restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 11 | Pipe to reducer | 90% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 12 | Pipe to pipe | 80% | Weld crown | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 13 | Pipe to pipe | 80% | Weld crown | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 14 | Pipe to reducer | 90% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 25 | Pipe to reducer | 90% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 18 | Pipe to valve | 80% | Valve restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 21 | Pipe to reducer | 80% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 15 | Pipe to reducer | 85% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 26 | Pipe to reducer | 85% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 30 | Pipe to nozzle | 80% | Nozzle restriction | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping B-JPage 6 of 6

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-------------------|----------|------------------------|--------|---------------------|---------------|
| TBX-1-4503 | Pressurizer Spray | 19 | Pipe to valve | 80% | Valve restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 22 | Pipe to reducer | 85% | Reducer restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 23 | Pipe to tee | 80% | Tee restriction | RT, PT |
| TBX-1-4503 | Pressurizer Spray | 24 | Pipe to tee | 80% | Tee restriction | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

RELIEF REQUEST C-5

Component: Piping Systems

CODE CLASS: 2

Examination Requirements:

Table IWC-2520 Category CF requires volumetric examination of 100% of the subject pipe welds.

Basis for Relief:

The configuration of the pipe connection welds prevents meaningful examination of the entire volume required to be inspected for welds listed in Table C-5.

Alternative Examination

See Table C-5.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping C-FPage 1 of 2

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-----------------------|----------|-----------------------------|--------|---------------------------------------|---------------|
| TBX-2-2100 | Main Steam | 1 | Pipe to nozzle | 95% | Nozzle restriction | RT, MT |
| TBX-2-2100 | Main Steam | 26 | Pipe to cap | 95% | Pipe cap restriction | RT, MT |
| TBX-2-2100 | Main Steam | 37 | Branch connection to flange | 12% | Configuration restriction, weld crown | RT, MT |
| TBX-2-2101 | Feedwater | 17 | Pipe to valve | 98% | Valve restrictions | RT, MT |
| TBX-2-2200 | Main Steam | 25 | Pipe to cap | 95% | Pipe cap restriction | RT, MT |
| TBX-2-2200 | Main Steam | 32 | Branch connection to flange | 37% | Configuration restriction, weld crown | RT, MT |
| TBX-2-2201 | Feedwater | 32 | Pipe to valve | 95% | Valve restriction | RT, MT |
| TBX-2-2300 | Main Steam | 35 | Pipe to cap | 95% | Pipe cap restriction | RT, MT |
| TBX-2-2301 | Feedwater | 28 | Pipe to valve | 50% | Valve restriction | RT, MT |
| TBX-2-2400 | Main Steam | 1 | Pipe to nozzle | 95% | Nozzle restriction | RT, MT |
| TBX-2-2401 | Feedwater | 15 | Pipe to valve | 98% | Valve restriction | RT, MT |
| TBX-2-2500 | RHR | 1 | Pipe to valve | 80% | Valve restriction | RT, PT |
| TBX-2-2523 | Accumulator Discharge | 7 | Pipe to valve | 96% | Valve restriction weld crown | RT, PT |
| TBX-2-2534 | Safety Injection | 8 | Pipe to tee | 90% | Tee restriction, weld toe, weld crown | RT, PT |
| TBX-2-2561 | HP SIS | 36 | Pipe to elbow | 90% | Elbow restriction, weld crown | RT, PT |
| TBX-2-2564 | HP SIS | 40 | Pipe to tee | 80% | Weld crown | RT, PT |
| TBX-2-2566 | HP SIS | 2 | Pipe to elbow | 90% | Elbow restriction, weld crown | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Piping C-FPage 2 of 2

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|--------|----------|------------------------|--------|---------------------------------|---------------|
| TBX-2-2566 | HP SIS | 3 | Pipe to elbow | 90% | Elbow restriction weld crown | RT, PT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.

RELIEF REQUEST C-6

Component: Vessels

CODE CLASS: 2

Examination Requirement:

Table IWC-2500-1 Category C-A requires 100% volumetric examination of the pressure retaining vessel welds.

Basis for Relief:

Geometric restrictions prevent meaningful examination of 100% of the required inspection volume for welds listed in Table C-6.

Alternate Examinations:

See Table C-6.

TABLE C-6
SUMMARY OF PARTIAL VOLUMETRIC EXAMINATIONS

CATEGORY: Vessels C-A

Page 1 of 1

| SKETCH NO. | SYSTEM | WELD NO. | PHYSICAL CONFIGURATION | % EXAM | REASON FOR PARTIAL | OTHER EXAM ** |
|------------|-------------------------------|----------|------------------------|--------|---|---------------|
| TBX-2-1110 | Excess Letdown Heat Exchanger | 1 | Head to flange | 50% | Nozzle restrictions, flange restrictions | RT |
| TBX-2-1110 | Excess Letdown Heat Exchanger | 2 | Flange to shell | 95% | Flange restrictions, drain line, weld crown | RT |
| TBX-2-1120 | Residual Heat Exchanger | 1 | Head to torus | 79% | Welded support | RT |
| TBX-2-1120 | Residual Heat Exchanger | 2 | Torus to flange | 58% | Welded support, flange restriction | RT |
| TBX-2-1120 | Residual Heat Exchanger | 3 | Pipe to torus | 95% | Pipe weld restriction | RT, PT |
| TBX-2-1120 | Residual Heat Exchanger | 4 | Pipe to torus | 95% | Pipe weld restriction | RT, PT |
| TBX-2-1140 | Letdown Heat Exchanger | 1 | Head to flange | 80% | Flange restrictions | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 3 | Vessel Girth | 98% | Weld crown, tee restriction | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 4 | Vessel Girth | 98% | Weld crown, tee restriction | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 5 | Vessel Girth | 92% | Weld crown, reducer restriction | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 6 | Vessel Girth | 92% | Weld crown, reducer restriction | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 7 | Vessel to nozzle | 78% | Weld crown, nozzle restriction | RT |
| TBX-2-1150 | Regenerative Heat Exchanger | 8 | Vessel to nozzle | 78% | Weld crown, nozzle restriction | RT |

* PAR - % Examination not recorded, this is one of 30 welds examined to 74 Code.

** MT and PT examination per Section XI and RT examination per Section III.