



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 8, 1992

Docket
File

Docket No. 50-336

LICENSEE: Northeast Utilities

FACILITY: Millstone, Unit 2

SUBJECT: SUMMARY OF MEETING OF APRIL 22, 1992, WITH REPRESENTATIVES OF
NORTHEAST UTILITIES CONCERNING THE PROGRAM FOR THE REPLACEMENT OF
THE STEAM GENERATORS FOR MILLSTONE 2 IN 1992

INTRODUCTION

On April 22, 1992, representatives of the NRC and Northeast Utilities met in the NRC offices in Rockville, Maryland, to discuss the Millstone 2 steam generator replacement project. The purpose of the meeting was to specifically address the integrated safety evaluation that will determine that the modification can be implemented within the criteria of 10 CFR 50.59. The attendance list is provided in Enclosure 1. Enclosure 2 provides the agenda and copies of the viewgraphs supporting the licensee's presentation.

DISCUSSION

This was the sixth meeting with the staff on the steam generator replacement project. The focus of this meeting was the integrated safety evaluation that will support the licensee's determination that the modifications can be made under the criteria of 10 CFR 50.59. Enclosure 2 provides a good discussion of this scope.

Individual safety evaluations have been prepared by different disciplines and the integrated safety evaluation will bring all these together to form an integrated safety evaluation which will make the determination that the replacement can be accomplished under the requirements of 10 CFR 50.59. The licensee has tentative plans to provide the PCDR to the PORC members during the week of April 26 and present it to PORC for approval in mid May 1992. The shutdown for replacement is scheduled for May 30, 1992.

All FSAR accident analyses, nozzle dam failure, fuel assembly/vessel internals uplift, heavy loads drop, and the seismic analysis have been considered with many being redone. The operational activities have been studied with the simulator. The licensee believes operational response will be improved with the wide range level instrumentation. They do not believe the slight difference in inventory will be significant. However, as requested by the staff, the licensee will take another look at the plant response and provide its testing program prior to start up. Since the travel route of the old and the new steam generators in and out of the plant will not be over the spent fuel pool or its equipment, heavy loads over the spent fuel pool will not be a concern. The licensee has determined that there will be no change in EOPs or

DEF 111

9205130194 920508
PDR ADOCK 05000336
P PDR

NRC FILE CENTER COPY

technical specifications. Also, the licensee does not anticipate any request for relief from the ASME Code requirements. The most sensitive weld is the girth weld joining the upper drum sections of the steam generators to the new lower tube sections. This large weld could be subject to cracking. The annealing of the weld and heat control during the welding will be controlled more conservatively than Code requirements.

/s/

Guy S. Vissing, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:

- Docket File
- NRC & Local PDRs
- PD i-4 Memo
- TMurley/FMiraglia
- JPartlow
- SVarga
- JCalvo
- GVissing
- SNorris
- OGC
- EJordan
- JECarrasco
- KKolnczyk
- KDesai
- JTatum
- HShaw
- JWiggins
- JRaval
- GHornseth
- ACRS (10)
- RLobel, EDO
- CWHehl, RI

OFFICIAL RECORD COPY

Document Name: MEETSUM

OFC	:LA:PDI-4	:PM:PDI-4	:D:PDI-4	:	:	:	:
NAME	:SNorris	:GVissing	:cn:JS-01z	:	:	:	:
DATE	:5/7/92	:5/7/92	:5/7/92	:	:	:	:

John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 2

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear, Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Nuclear Station Director
Millstone Nuclear Power Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 376
Waterford, Connecticut 06385-0376

J. S. Keenan, Nuclear Unit Director
Millstone Unit No. 2
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Charles Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Pkwy, Suite 300
Rockville, Maryland 20852

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

MEETING ATTENDANCE
4/22/92Name

Steve Routh
Peter Wielhouwer
John Resetar
Tim Honan
Forrest Kocon
John Rhodes
Raymond Necci
Prem Godha
R. Hal Young
A. J. Silvia
J. E. Carrasco
Guy S. Vissing
Kenneth S. Kolnczyk
Kulin D. Desai
James Tatum
Horace Shaw
Jim Wiggins
Janak Raval
G. Horiseth

Organization

SERCH - Bechtel
ABB Comb. Engineering
NU
NU
NU
NU
NU
NU
NU Licensing
NU
USNRC, Reg. I
USNRC/NRR/PD I-4
USNRC, Resident Inspector, MP-1
SRXB/NRR
NRR/SPLB
NRR/DET/EMEB
NRR/EMCB
NRR/SPLB
NRR/EMCB



Millstone 2 Steam Generator Replacement Project



NRC Safety Assessment Presentation

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Agenda

- Introduction & Review R. Necci
- Integrated Safety Evaluation
(System Interface Reconciliation) T. Honan
- PDCR / 10CFR50.59 Conclusion J. Resetar
- Project Conclusion R. Necci



Introduction



MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Purpose

**‘To Present the Results of the
Integrated Safety Evaluation’**

Conclusion

**‘The Replacement Can be
Accomplished via 10CFR50.59’**



Project Status

- **Staffing**
 - **Fluor**
 - **Approximately 200 Craft**
 - **Approximately 106 Staff**
 - **NU**
 - **Approximately 40 Staff**

- **Training**
 - **Basic Site Training**
 - **Welder Qualification**
 - **Mock-up Training**


- **Outage Status**
 - **May 30, 1992 Start Date**

MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992



MP2 SGRP Pre-Installation Activities



MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992



Open Communications With NRC

- 1. NRC / NU Counterparts Meeting**
 - **Project Overview**

- 2. NRC / SGRP**
 - **Project History**
 - **New S/Gs' Design & Maintenance**

- 3. NRC / SGRP**
 - **Rigging**
 - **S/G Fit-up Measurements**
 - **Cutting / Welding**
 - **ASME Code**

MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992




Open Communications With NRC (continued)

- 4. NRC / SGRP**
 - Radiation Protection
 - Quality Programs
 - NRC Procurement Audit

- 5. NRC / SGRP**
 - Safety Evaluation (New S/G's)
 - Safety Evaluation (Installation)

- 6. Other Meetings**
 - Audit of B&W-C
 - S/G Disposal



SGRP PDCR's

- **Support Facilities**
- **Polar Crane Upgrade**
- **Structural Modification**
- **Wide Range Monitoring**
- **Haul Route Upgrade**
- **S/G Replacement**

MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992



S/G Replacement PDCR Format



- Component Design Reconciliation
- Installation
- System Interface Reconciliation
- Integrated Safety Evaluation



Safety Evaluation

- **Input - NU, ABB/CE, Siemens (ANF), Bechtel, F/D, B&W**
- **Safety Evaluation - NU Engineering**
- **Review - NNECO PORC**
- **Summary**
 - **Final Assessment - MP2 SG Replacement Meets 10CFR50.59**
 - **Final Assessment - No Unreviewed Safety Questions**

MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992



Integrated Safety Evaluation



(System Interface Reconciliation)

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Overview

- **Integration of Wide Range of Safety Evaluations**
 - NU
 - ABB/CE
 - Siemens (ANF)
 - B&W
 - Fluor Daniel

- **Conclusion**
 - Safe
 - Not an Unreviewed Safety Question



Accidents Considered

- **All FSAR Chapter 14 Events**
- **Nozzle Dam Failure**
- **Fuel Assembly/Vessel Internals Uplift**
- **Heavy Loads Drop**
- **Seismic Analysis**



Basic Considerations

- **Replacement S/G's Similar to Original**
 - **Heat Transfer**
 - **Liquid Mass**
 - **Structural Characteristics**
- **Plant Will Return to Original Unplugged Condition**



Effect of Change in Plugging Level

- **Current Analysis Assumptions**
 - **Max Plugging Where Low Heat Transfer is Conservative**
 - **Zero Plugging Where High Heat Transfer is Conservative**
- **Cooldown Analyses Unaffected**
- **Heatup Analyses Less Severe**



Analyses of Interest

- **Steam Line Break (Core Response)**
- **Steam Generator Tube Rupture**
- **Loss of Coolant Accident (Core Response)**
- **DNB Analysis**
- **Heatup Events**
- **Containment Analysis**
- **Nozzle Dam Failure**
- **Fuel Assembly / Internals Uplift**
- **Heavy Loads Drop**
- **Seismic Analysis**



Steam Line Break (Core Response)

- **Current Analysis Assumes Zero Plugging**
- **Similar Liquid Masses**
- **Thermal-Hydraulics Similar**
- **Integral Flow Restrictors**
 - **Substantial Analytical Credit**
- **Decrease in Severity**



Steam Generator Tube Rupture


- Increased Reliability
- Greater Tube I.D.
 - Flow Area 1.2% Higher
 - Increased Leak Rate
 - Maximum Dose Increase
 - 1% Whole Body
 - 3.4% Thyroid
- Increase in Doses Must be Greater Than 10% Value to be a USQ



Loss of Coolant Accident (Core Response)

- **Large Break**
 - **Max Plugging is Conservative**
 - **Delays Blowdown**
 - **Reduced Plugging Levels Decrease Severity**

- **Small Break**
 - **S/G is Heat Sink Early in Transient**
 - **Second Order Effect**
 - **No Significant Change in Severity**



DNB Analysis

- **Limited by Loss of Flow**
 - **No Change in Core Power Distribution**
 - **Reduced Plugging Decreases Flow Coastdown**
 - **Slight Improvement in Minimum DNBR**



Heatup Events

- **Loss of Load**
 - **Reduced Plugging Improves Heat Transfer**
 - **Increased Secondary Pressure Minimizes Heatup**
 - **Slight Decrease in Peak Pressure**
- **Loss of Feedwater**
 - **Slight Decrease in Secondary Side Inventory**
 - **Accommodated with Available Minimum Inventory**



Containment Analysis

- **Considered Both LOCA and Steam Line Break**
- **Identical Cases Considered for Current & Replacement Generators**
- **Cases Are Those Considered for Current FSAR Analysis**



Containment Analysis

(Continued)

- **Steam Line Break**
 - **Limiting Temperature Case**
 - **Hot Full Power**
 - **Less Limiting Due to Flow Restrictors**
 - **Limiting Pressure Case**
 - **Hot Zero Power**
 - **Peak Pressure - 50.8 psi**
 - **Slightly (<0.3 psi) Higher**
 - **Peak Pressure Still Well Below Design Limit of 54 psi**



Containment Analysis

(Continued)

- **Loss of Coolant Accident**
- **Hot Leg Break Limiting**
- **Peak Pressure - 52.0 psi**
 - **Slightly (<0.6 psi) Higher**
 - **Peak Pressure Still Below Design Limit of 54 psi**
- **Peak Temperature - 281.0 °F**
 - **Slightly (<0.8 °F) Higher**
 - **Peak Temperature Still Below Design Limit of 289 °F**



Nozzle Dam Failure

- **Substantially Different Design**
- **Less Susceptible to Mispositioning**
- **Includes Passive Seal**
- **No Increase in Worst Case Leakage**
- **New Design is Acceptable**



Fuel Assembly/Internals Uplift

- **Fuel Assembly**
 - **Function of Top Nozzle Spring Force**
 - **Fuel Assembly Design Flow Exceeds Max Expected Flow**
- **Internals Uplift**
 - **Bounded by Original Component Analysis**
 - **Hold-down Ring to be Inspected**



Heavy Loads Drop & Seismic Analysis

- **Heavy Loads Drop**
 - Core to be Removed
 - Core Damage Precluded
 - No Significant Safety Equipment Affected

- **Seismic Analysis**
 - Increased Mass & Raised Center of Gravity
 - Impact Evaluated on Reactor Coolant Loops
 - All Design Criteria Met



PDCCR / 10CFR50.59 Conclusion



MS... S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Plant Review

- **Plant Design Change Record (PDCR)**
- **10CFR50.59 Determination**



Steam Generators

- **Meet Current & Original Standards**
- **Address Health & Safety**

MP2 S/G REPLACEMENT PROJECT

NRC - APRIL 22, 1992



Replacement

- **Meets Design Code**
- **Addresses Construction Issues**
- **Highest Safety Standards**

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Design Change Criteria

- **Safe**
- **Review Against
10CFR50.59**

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992



Plant Design Change Record (PDCR) PORC Review

- **Detailed Design of New Sub-Assembly
& Installation Activities**
- **All Safety Evaluations**
- **Integrated Safety Evaluation**
- **PORC Concurrence / Acceptance of
Conclusions That S/G Replacement is
Not an Unreviewed Safety Question**

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992




10CFR50.59 Determination

- **Submitted to PORC for Preliminary Review**
- **Special PORC Held to Discuss PDCR (NRC Resident Inspector & Project Manager Present)**
- **Final PORC Meeting for Approval of Complete PDCR**



Conclusion



Summary

MP2 S/G REPLACEMENT PROJECT
NRC - APRIL 22, 1992