

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

AUG 28 1984

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Limerick Generating Station, Units 1 & 2
Information for Materials Engineering Branch (MTEG)
Regarding SER Confirmatory Issue #12 - Preservice
Inspection (PSI) Program

References: 1) Telecon between M. Hum (NRC/MTEB), B. Brown
(EG&G Lab.) and D. Schmidt (PECo), 8/17/84
2) Telecon between M. Hum/C. Cheng (NRC/MTEB) and
D. Schmidt (PECo), 7/20/84
3) Letter, J. S. Kemper (PECo) to A. Schwencer (NRC),
dated 7/17/84

Attachment: Limerick Unit 1 PSI Relief Request No. 15, Rev. 1

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

As discussed in the reference 1) and 2) telecons, the attachment provides a revision to Relief Request No. 15. Originally transmitted by reference 3), Relief Request No. 15 has been revised to provide the requested clarification and additional information.

Sincerely,

*V. S. Boyer
for JSK*

DLS/pd08278402

See Attached Service List

8409050133 840828
PDR ADOCK 05000352
Q PDR

Boo!

cc: Judge Lawrence Brenner (w/o enclosure)
Judge Peter A. Morris (w/o enclosure)
Judge Richard F. Cole (w/o enclosure)
Troy B. Conner, Jr., Esq. (w/o enclosure)
Ann P. Hodgdon, Esq. (w/o enclosure)
Mr. Frank R. Romano (w/o enclosure)
Mr. Robert L. Anthony (w/o enclosure)
Maureen Mulligan (w/o enclosure)
Charles W. Elliot, Esq. (w/o enclosure)
Zori G. Ferkin, Esq. (w/o enclosure)
Mr. Thomas Gerusky (w/o enclosure)
Director, Penna. Emergency (w/o enclosure)
Management Agency
Angus R. Love, Esq. (w/o enclosure)
David Wersan, Esq. (w/o enclosure)
Robert J. Sugarman, Esq. (w/o enclosure)
Martha W. Bush, Esq. (w/o enclosure)
Spence W. Perry, Esq. (w/o enclosure)
Jay M. Gutierrez, Esq. (w/o enclosure)
Atomic Safety & Licensing (w/o enclosure)
Appeal Board
Atomic Safety & Licensing (w/o enclosure)
Board Panel
Docket & Service Section (w/o enclosure)
Mr. James Wiggins (w/o enclosure)
Mr. Timothy R. S. Campbell (w/o enclosure)

Limerick Generating Station, Unit 1
Preservice Inspection Relief Request
ASME B&PV Code, Section XI

15. Class 2 Pressure Retaining Welds in Piping
Code Item Nos. C2.1 and C2.2, Category C-F

Code Requirement

Those pipe circumferential butt welds and those longitudinal weld joints in pipe fittings included in Code Category C-F of Table IWC-2520 shall be volumetrically examined per Item Nos. C2.1 and C2.2 of Table IWC-2600. The examinations shall include 100% of the C-F welds and shall be performed completely, once, as a preservice examination requirement. Table IWC-2520 requires the examination volume to include the weld plus the base metal for distance of one-wall thickness beyond the edge of the weld.

Relief Request:

Relief is requested from the base metal volume requirement of Table IWC-2520. Radiography was utilized as the volumetric examination technique. The examination volume included the weld plus the base metal for a minimum distance of $\frac{1}{4}$ inch beyond the edge of the weld. There are 40 circumferential and 80 longitudinal welds associated with 20 Main Steam elbows included in this relief request.

Justification for Granting Relief:

The integrity of the piping pressure boundary has been verified by construction code testing requirements. Shop welds were radiographed in accordance with that edition of ASME Section III in effect at the time of procurement. Field weld examinations, which include radiography and hydrostatic pressure tests, were performed in accordance with the 1974 Edition of Section III including the Addenda through Winter 1974.

Laminar indications throughout the base metal of the 20 Main Steam elbows have precluded ultrasonic testing from providing a meaningful Section XI Volumetric examination. The construction radiographs for the welds in question were reviewed and additional radiography was performed to achieve coverage in excess of the requirements of the 1980 Edition of Section XI, including the Addenda through the Winter 1981, per Figure IWC-2500-7 (Anticipated Code Edition for ISI Program). Radiography will be used for subsequent ISI. The preservice volumetric examinations have been augmented by complete liquid penetrant tests, which were performed in accordance with the 1977 Edition of Section XI, including the Addenda through Summer 1978.

Limerick Generating Station, Unit 1
Preservice Inspection Relief Request
ASME B&PV Code, Section XI

15. Additional Information:

These 20 Main Steam elbows were fabricated from SA 515 Gr. 70 rolled carbon steel plate with specified design minimum wall thickness of .928 inches. Many of these elbows exhibit a condition of stacked mid plate indications, detectable by 0° longitudinal wave ultrasonic testing (UT). These indications are dispositioned as a combination of laminations and planar non-metallic inclusions throughout the elbow base metal. Though not rejectable to the applicable base material Code testing requirements, this condition limits the effectiveness and completeness of the angle beam UT.

The preservice examination of the welds in these 20 elbows is divided into 120 volumes. Fifty-six (56) of the volumes were examined ultrasonically (0°, 45° ax, 45° circ). A breakdown of the examinations is as follows:

Number Complete	29
Number Incomplete	27
Number with Recordable Indications	21

The majority of these UT examinations were performed from the pipe side due to the laminar indications detected in the elbow base metal during the 0° straight beam examination.

When the decision was made to use the construction radiographs for the preservice inspection, additional radiography was required to achieve ASME Section XI, 1980 coverage. Based on an evaluation of the radiographs and the limited UT examinations, it was determined that additional angle radiography, down the fusion line, would not be of any benefit.

For inservice inspection, both the required volumetric and surface examination will be performed. However, radiography will be used in lieu of ultrasonic testing. UT will be used for interrogative purposes when possible when a change is noted during comparison of the baseline radiographs with the subsequent inservice inspection radiographs.

Attached are the UT examination data for two welds. This information is typical of the condition found in the base metal of the 20 elbows.

Plant/Unit Limerick I
 Comp/System MS

CALIBRATION DATA SHEET

Data Sheet No. 1546-253
 Procedure No. 80A1566
 Subject Piping Welds
 Rev/Change No. L.FCA1
 Calibration
 Block No. Lim 26.928CS
 Surface OD
 Block Temp 70 °F
 Comp. Temp 68 °F


INSTRUMENT SETTINGS	
Mfg/Model No.:	<u>Sonic MK1</u>
Serial No.:	<u>785039</u>
Sweep Length:	<u>2.10</u>
Sweep Delay:	<u>1.90</u>
Pulse Length/Damping:	<u>Min</u>
Freq. Rep. Rate:	<u>2 1K</u>
Filter:	<u>MFD Video</u>
DEC/Gate Switch:	<u>AF Range: 2</u>
Mode Select:	<u>Reject: AF</u>
Gain (coarse):	<u>50 (fine): 2</u>

SEARCH UNIT	
Scan Angle:	<u>0°</u> Mode: <u>L</u>
Fixturing (if any):	<u>NA</u>
Style or Type No.:	<u>Accuscan</u>
Size & Shape:	<u>1.0 Round</u>
Frequency:	<u>2.25 MHz</u>
Serial No./Brand:	<u>6102</u>
Measured Angle:	<u>NA</u>
Cable Type & Length:	<u>RH7A-447'</u>
Couplant Brand:	<u>Sonotrace 30</u>
Couplant Batch:	<u>8783</u>

holes IDENT	DEPTH in.	AMPL. dB	ATTEN. dB
<u>1/4t</u>	<u>.286</u>	<u>80</u>	<u>52</u>
<u>3/4t</u>	<u>.858</u>	<u>60</u>	<u>↓</u>
/			

INSTR. LINEARITY CAL.					
Amplitude					
	High	Low	High	Low	
1	<u>100</u>	<u>50</u>	5	<u>40</u>	<u>20</u>
2	<u>80</u>	<u>40</u>	6	<u>31</u>	<u>15</u>
3	<u>64</u>	<u>31</u>	7	<u>25</u>	<u>12</u>
4	<u>50</u>	<u>25</u>	8	<u>20</u>	<u>10</u>

SCAN AREA	
0° WRV	<input checked="" type="checkbox"/>
0° Mat'l	<input checked="" type="checkbox"/>
↳ to Weld	<input type="checkbox"/>
≡ to Weld	<input type="checkbox"/>



AMPL. CONTROL LINEARITY		
Initial	Δ dB	Result
<u>80</u>	<u>-6</u>	<u>40</u>
<u>80</u>	<u>-12</u>	<u>31</u>
<u>40</u>	<u>+6</u>	<u>80</u>
<u>20</u>	<u>+12</u>	<u>78</u>

EXAMINATION WELD/AREA	RECORDABLE INDICATION		COMMENTS/REASON FOR INCONFORMITY(S)
	Yes	No	
<u>M5A 031</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>REVIEWED BY (S)</u> <u>[Signature]</u>
<u>M5D 032</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>AUG 24 1979</u>
<u>M5B 034</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>HARTFLOW STEAM BLR</u>
<u>M5B 035</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>INSP. CO</u>
<u>M5C 031</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
<u>M5C 033</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>one way due to configuration</u>
<u>M5D 031</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
<u>M5A 032</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	


CALIBRATION CHECKS	TIME
Initial Cal.	<u>1:00</u>
Intermediate	<u>-</u>
Intermediate	<u>-</u>
Intermediate	<u>-</u>
Final Cal.	<u>1:45</u>

ADDITIONAL SHEETS? (CHECK BOX)			
Continuation	<input type="checkbox"/>	Beam Plot	<input type="checkbox"/>
Supplements	<input checked="" type="checkbox"/>	None	<input type="checkbox"/>

EXAMINERS 1 Eugene Valley Date 10/79 Level I
 2 [Signature] Date 10/79 Level I
 REVIEWED Robert H. Zapp, P.E. Date 1-10-80 Level III
 NUCLEAR ENERGY SERVICES INC

SUPPLEMENT A


INDICATION REPORT SHEET
STRAIGHT BEAM



Procedure No. 80A 1566
Subject PIPE WELDS
Weld No. MSD 032
Page 2 of 3
Attached to Cal.
Data Sheet No. 1566-253

Notes:

- (1) X-axis increments not to exceed allowable scan increments.
 - (2) End points shall be: (a) 50% of DAC (6db) for WRV Straight Beam exam, (b) equal to Remaining Back Reflection (RBR) for base material lamination exam.
- This column for WRV Straight Beam exam only.
- (4) This column for base material lamination exam only.



REVIEWED BY:

[Signature]
AUG 24 1979

INDICATION NO.	SIDE OF WELD	D (in T/8s)	HARTMAN INSP X	SILENT MAX ←-DAS ←-DBT	BLR CO (4) RBR & PSH	Y @ MAX & DAC	FORWARD	BACK
							ENDPOINT	ENDPOINT
							y ₁ (2)	y ₂ (2)
1	U	4/8	1/2"	35%	35%	1/2"	—	—
				65	30	3/4"	—	—
				40	30	1"	—	—
				40	40	1 1/4"	—	—
1	U	4/8	3/4"	20	20	3/4"	—	—
				50	30	1"	—	—
				70	50	1 1/4"	—	—
				70	30	1 1/2"	—	—
				40	40	1 3/4"	—	—
1	U	4/8	1"	35	35	1 1/2"	—	—
				75	50	1 3/4"	—	—
				100	60	2"	—	—
				60	35	2 1/4"	—	—

COMMENTS

Essexwell EL
Midwall (1/8t) base metal lamination. Not included on graph paper.

EXAMINERS


1. *Eugene Tabery* Date 7/6/79 Level III
2. *Simon R. [unclear]* Date 7/2/79 Level I

REVIEWER:

Robert H. [unclear] PEC
Date 1-16-80
NUCLEAR ENERGY SERVICES INC

SUPPLEMENT A


INDICATION REPORT SHEET
STRAIGHT BEAM



Procedure No. 80A1566
 Subject Piping welds
 Weld No. HSD 092
 Page 2 of 3
 Attached to Cal. _____
 Data Sheet No. 1566-253
 continued

Notes:

- (1) X-axis increments not to exceed allowable scan increments.
- (2) End points shall be: (a) 50% of DAC (6db) for WRV Straight Beam exam, (b) equal to Remaining Back Reflection (RBR) for base material lamination exam.
- (3) This column for WRV Straight Beam exam only.
- (4) This column for base material lamination exam only.



REVIEWED BY

Paul Russell

Section A-A

AUG 24 1979

WAVELENGTH 5150M RBR

INDICATION NO.	SIDE OF WELD	D (in T/8s)	INSP. (1) X	MAX. ⁽³⁾ DAC (±db)	(4) RBR % FSH	Y @ MAX % DAC	FORWARD	BACK
							ENDPOINT	ENDPOINT
							y ₁ (2)	y ₂ (2)
1	V	4/8	↓	40	40	2 1/2	—	—
	V	4/8	1/4	40	40	1 1/4	—	—
				100	60	1 1/2	—	—
				100	60	1 3/4	—	—
				80	35	2	—	—
				45	45	2 1/4	—	—

COMMENTS

EXAMINERS

1. *Gregory Stober* Date 7/6/79 Level II

2. *Steve P. [unclear]* Date _____ Level _____

REVIEWER *Robert H. Jorg, PEC, Level III* Date 1-10-80





REF.

Down stream pipe

UPSTREAM elbow

WELD MSD C.32
plan view of Base metal lamination

Vertical dashed line with a circled 'E' in the middle.



Engine facility

Plant/Unit LIMERICK I
 Comp/System MAIN STEAM
 ISO 03-03 Loop A

CALIBRATION DATA SHEET


Page 1 of 8
 Data Sheet No. _____
 Procedure No. 80A1567
 Subject: FITTING TO FITTING WELDS
 Rev/Change No. 3
 Calibration
 Block No. LIM-26-.928-CS
 Fabrication No. N/A
 Surface OP
 Block Temp 70 °F
 Comp. Temp 71 °F
 Thickness .928
 CRT Calibrated in INCHES
OF METAL PATH 2.0" SCREEN
 Each Maj. Screen Div = .20"

INSTRUMENT SETTINGS	
Mfg/Model No.	<u>x SONIC MK I</u>
Serial No.	<u>: 03182E</u>
Sweep Length	<u>: 1.02</u>
Sweep Delay	<u>: 1.39</u>
Pulse Length/Damping	<u>MIN</u>
Freq.	<u>5</u> Rep. Rate: <u>3K</u>
Filter	<u>HI Video</u> Jack <u>R/T</u>
DEC/Gate Switch	<u>OFF</u> Range: <u>2</u>
Mode Select	<u>THRU</u> <u>TRANS</u> Reject <u>DIF</u>
Gain (coarse)	<u>50</u> (fine) <u>13</u>
Scan Sensitivity	<u>69</u>

SEARCH UNIT	
Scan Angle	<u>0°</u> Mode: <u>LONG</u>
Fixturing (if any)	<u>N/A</u>
Style or Type No.	<u>FAMMA DUFF</u>
Size & Shape	<u>.5" ROUND</u>
Frequency	<u>5.0 MHz</u>
Serial No/Brand	<u>KB3274/ACOTECH</u>
Measured Angle	<u>N/A</u>
Cable Type & Length	<u>DUAL ATTACHED</u>
Couplant Brand	<u>ULTRAGEL II</u>
Couplant Batch	<u>8226</u>

5MHz USED FOR BETTER RESOLUTION.

INSTR. LINEARITY CAL.					
Amplitude					
	High	Low	High	Low	
1	102	51	5	38	19
2	80	40	6	30	15
3	61	30	7	22	11
4	48	24	8	17	8



SCAN AREA	
0° WRV	<input checked="" type="checkbox"/>
0° Mar'l	<input checked="" type="checkbox"/>
= To Weld	N/A
⊥ To Weld	N/A
Calibration	
Axial	N/A
Circ	N/A

AMPL. CONTROL LINEARITY		
Initial	dB	Result
80	-6	38
80	-12	17
40	+6	85
20	+12	86

EXAMINATION WELD/AREA	Recordable Indications			COMMENTS/REASON FOR INCOMPLETED SCAN (S)
	Yes	No	Geom	
MSA-029-LD-MIN	<input checked="" type="checkbox"/>	N/A	N/A	COMPLETE FITTING TO FITTING
MSA-029-LD-MAX	<input checked="" type="checkbox"/>	N/A	N/A	COMPLETE FITTING TO FITTING
MSA-030-LU-MIN	<input checked="" type="checkbox"/>	N/A	N/A	COMPLETE FITTING TO FITTING
MSA-030-LU-MAX	<input checked="" type="checkbox"/>	N/A	N/A	COMPLETE FITTING TO FITTING

CALIBRATION CHECKS	TIME
Initial Cal.	<u>1740</u>
Intermediate	<u>2130</u>
Intermediate	<u>0125</u>
Intermediate	<u>—</u>
Final Cal.	<u>0515</u>

EXAMINERS 1 John W. Jell Date 5-21-83 Level II
 2 Patricia Spindler Date 5-21-83 Level I



REVIEWERS 1 _____ Date _____
 2 _____ Date _____
 3 _____ Date _____

ADDITIONAL SHEETS? CHECK BOX			
Continuation	<u>N/A</u>	Beam Plot	<u>N/A</u>
Supplements	<input checked="" type="checkbox"/>	None	<u>N/A</u>



NUCLEAR ENERGY SERVICES, INC.

Project No. 5551	Site Limerick	L _o Location Butt weld	Date: (Mo/Day/Yr) 5-21-83
Item Identification MS4029 LDP-W		W _o Location weld E	Page 2 of 8
Examiner: TC-IA Level John Nigrelli level II	Angle Used 0° 45° 1 45° 2	Attached Cal. Data Sheet	
Examiner: TC-IA Level Steve [unclear]	Scanning dB 69 NA NA	Thickness .928"	
		Diameter (nom.) .26"	



MP Metal Path
 RBR Remaining Back Reflection
 L Distance from Datum 0

W max Distance from ζ to S.U. at maximum response.
 W₁ Distance from weld ζ at 50% of DAC (fwd)
 W₂ Distance from weld ζ at 50% of DAC (backward)

Ind. No.	Z of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L ₁ 50% DAC	L max	L ₂ 50% DAC	RBR amp	S.U. Loc.
		W	MP	W ₁	MP	W ₂	MP					
1	150%	5/8"	500 660	NA	NA	NA	NA	10 3/4"	75"	20"	NA	CCW Toe
2	50%	3/4"	580	NA	NA	NA	NA	NA	2.0"	NA	NA	CW Toe
3	50%	5/8"	800	NA	NA	NA	NA	5 3/4"	6 1/4"	7.0"	NA	CW
4	50%	5/8"	600	NA	NA	NA	NA	5 3/4"	6 1/4"	7.0"	NA	CW
5	50	3/4"	600	NA	NA	NA	NA	NA	3 3/4"	NA	35	CW
6	50	2 1/2"	520	NA	NA	NA	NA	NA	7 3/4"	NA	40	CW
7	60	2 1/4"	660	NA	NA	NA	NA	NA	9"	NA	35	CCW
8	150%	1 1/4"	580	NA	NA	NA	NA	NA	10 3/4"	NA	NA	CCW

REMARKS


DRAW FULL SCALE PLOT HERE:

REVIEWER _____ DATE _____


REVIEWER _____ DATE _____

REVIEWER _____ DATE _____

Project No. 5551	Site Limerick	L ₀ Location Buttweld	Date: (Mo/Day/Yr) 5-21-83
Item Identification MSA029LDMW		W ₀ Location weld E	Page 3 of 8
Examiner: TC-1A Level John Nigroli level II	Angle Used 0° 45° 45°	Attached Cal. Data Sheet	
Examiner: TC-1A Level Steve Spindler I	Scanning dB 69	NA	Thickness .928"
		NA	Diameter (nom.) 26"



MP Metal Path W max Distance from ζ to S.U. at maximum response.
 RBR Remaining Back Reflection W₁ Distance from weld ζ at 50% of DAC (fwd)
 L Distance from Datum 0 W₂ Distance from weld ζ at 50% of DAC (backward)




Ind. No.	Z of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L ₁	L	L ₂	RBR	S.U.
		W	MP	W ₁	MP	W ₂	MP	50% DAC	max	50% DAC	amp	Loc.
9	100%	1 3/4"	600	NA	NA	NA	NA	10 1/2"	12 1/4"	14"	NA	CCU
10	100	2 3/4"	600	NA	NA	NA	NA	NA	19"	NA	40	CCU

REMARKS

DRAW FULL SCALE PLOT HERE:

REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____

Project No. 5551	Site Limerick	L ₀ Location Butt weld	Date: (Mo/Day/Yr) 5-21-73
Item Identification MSA029LDMAX		W ₀ Location weld E	Page 4 of 8
Examiner: TC-1A Level John Nigrelli Level II	Angle Used 0° 45° 45°	Attached Cal. Data Sheet	
Examiner: TC-1A Level Steve Spindler I	Scanning dB 69 NA NA	Thickness .928"	
Diameter (nom.) 26			



MP Metal Path
 RBR Remaining Back Reflection
 L Distance from Datum 0

W max Distance from ζ to S.U. at maximum response.
 W₁ Distance from weld ζ at 50% of DAC (fwd)
 W₂ Distance from weld ζ at 50% of DAC (backward)

Ind. No.	% of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L ₁ 50% DAC	L max	L ₂ 50% DAC	RBR amp	S.U. Loc.
		W	MP	W ₁	MP	W ₂	MP					
1	50%	3/4"	480"					23"	26"	29"		CCW Top
2	50%	1/2"	680"					6 1/4"	8"	9 5/8"		CW Top
3	150%	1/2"	600"					24 3/4"	26"	27 3/8"		CW Top
4	100%	3/4"	460"					3 1/2"	35 1/2"	40"		CW
5	100%	2.0"	800"						27 1/4"			CCW
6	200+	2.0"	500"						2.0"			CCW
7	100%	1 1/4"	640"					8.0"	8 3/8"	9 3/4"		CW
8	100+	2 1/4"	680"					8.0"				CW

REMARKS

See sketch for Dim.

DRAW FULL SCALE PLOT HERE:


REVIEWER _____ DATE _____

REVIEWER _____ DATE _____

REVIEWER _____ DATE _____

80A 1567 Rev 3
Pages 7 & 8
Fitting to Fitting

MSA 029 LD MAX




John W. Weyell

Level II


5/21/83

Project No. 5551	Site Limerick	L ₀ Location Butt weld	Date: (Mo/Day/Yr) 5-21-83
Item Identification MSA020Lumw		W ₀ Location weld E	Page 6 of 8
Examiner: TC-1A Level John N. Grell level II	Angle Used 0° 45° 1 45° =	Attached Cal. Data Sheet	
Examiner: TC-1A Level Steve Spindler I	Scanning dia 69 NA NA	Thickness 928"	
		Diameter (nom.) 26"	



MP Metal Path
RBR Remaining Back Reflection
L Distance from Datum 0

W max Distance from C to S.U. at maximum response.
W₁ Distance from weld C at 50% of DAC (fwd)
W₂ Distance from weld C at 50% of DAC (backward)



Ind. No.	I of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L ₁ 50% DAC	L max	L ₂ 50% DAC	RBR amp	S.U. Loc.
		W	MP	W ₁	MP	W ₂	MP					
1	150%	3/4"	640	NA	NA	NA	NA	16 1/4"	18"	20"	NA	CCW Toe
2	100%	1/2"	800	NA	NA	NA	NA	15"	15 5/8"	16 1/4"	NA	CW Toe
3	50%	1/2"	420	NA	NA	NA	NA	NA	14"	NA	NA	CW
4	50%	2"	520	NA	NA	NA	NA	NA	19 1/2"	NA	NA	CW
5	60%	2 5/8"	400	NA	NA	NA	NA	NA	10 3/8"	NA	45	CW
6	80%	3"	400	NA	NA	NA	NA	NA	9 1/2"	NA	40	CW
7	75%	1 1/2"	540	NA	NA	NA	NA	NA	18"	NA	NA	CCW

REMARKS


DRAW FULL SCALE PLOT HERE:

REVIEWER _____ DATE _____

REVIEWER _____ DATE _____

REVIEWER _____ DATE _____


Project No. 5551	Site C. merick	L Location Buttwell	Date: (Mo/Day/Yr) 5-21-87
Item Identification MSA030LUMAX		W Location weld E	Page 8 of 8
Examiner: TC-1A Level John Nigall level II	Angle Used 0° 45° 1 45° 2	Attached Cal. Data Sheet	
Examiner: TC-1A Level Steve Spindel I	Scanning dB 65 NA NA	Thickness .928"	
		Diameter (nom.) 26"	



MP Metal Path
 RBR Remaining Back Reflection
 L Distance from Datum O

W max Distance from C_L to S.U. at maximum response.
 W_1 Distance from weld C_L at 50% of DAC (fwd)
 W_2 Distance from weld C_L at 50% of DAC (backward)

Ind. No.	Z of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L_1 50% DAC	L max	L_2 50% DAC	RBR amp	S.U. Loc.
		W	MP	W_1	MP	W_2	MP					
9	100f	3 1/4"	520	NA	NA	NA	NA	16"	16 1/2"	17"	30	CU
10	100	4 1/2"	560	NA	NA	NA	NA	NA	25"	NA	70	CU




REMARKS

DRAW FULL SCALE PLOT HERE:

REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____

Project No. 5551	Site Limerick	L ₀ Location Buttweld	Date: (Mo/Day/Yr) 5-21-83
Item Identification MSA 030Lumar		W ₀ Location weld 6	Page 7 of 8
Examiner: TC-1A Level John Niggell Level II	Angle Used 0° 45° 45°	Attached Cal. Data Sheet	
Examiner: TC-1A Level Steve Spindle I	Scanning dB 69 NA NA	Thickness .925"	
MP Metal Path	W _{max} Distance from ϵ to S.U. at maximum response.		
RBR Remaining Back Reflection	W ₁ Distance from weld ϵ at 50% of DAC (fwd)		
L Distance from Datum 0	W ₂ Distance from weld ϵ at 50% of DAC (backward)		



Ind. No.	% of DAC	W MAX		FWD 50% DAC		BACKWARD 50% DAC		L ₁ 50% DAC	L max	L ₂ 50% DAC	RBR amp	S.U. Loc.	
		W	MP	W ₁	MP	W ₂	MP						
1	50 to 100+	3/4"	600-580	NA	NA	NA	NA	Toe of Buttweld	6 1/2"	13 3/8"	NA	CCW Toe	
2	50 to 100+	3/4"	420-600-540	NA	NA	NA	NA	Intermittent Length of 5' long Sec - Vertical Depth 300 & Amp	NA	NA	NA	CW Toe	
3	100%	1 1/2"	640"	NA	NA	NA	NA	Toe of Buttweld	1"	2"	NA	CCW	
4	50%	1 1/2"	560"	NA	NA	NA	NA		2"	3"	4"	NA	CCW
5	100%	1 1/2"	720"	NA	NA	NA	NA		NA	2 1/2"	NA	NA	CW
6	50	2 1/2"	760"	NA	NA	NA	NA		NA	4 1/2"	NA	35	CW
7	70	4 1/4"	800"	NA	NA	NA	NA		NA	5 1/2"	NA	60	CW
8	120%	1 3/4"	500"	NA	NA	NA	NA		NA	13 1/2"	NA	NA	CW

DRAW FULL SCALE PLOT HERE:

REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____
 REVIEWER _____ DATE _____