NRC Fwm (9-43)			LICENSEE EVENT REPORT (LER)							U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0164 EXPIRES: 8/31/85							
FACILITY NAME (1)							DOCKET NUMBER	(2)		PAGETE							
Vermont Yankee Nuclear Power Station						0 15 10 10	10121711 1 0			0 12							
TITLE 141		r Sci	ram Wh	ile Shut	down for	r Maintena	ance										
eve	NT DATE	(8)		LER NUMBER I	1)	REPORT DAT	£ (7)		OTHER	FACILITIES INVO	LVED (8)						
MONTH	DAY	YEAR	YEAR SE	SEGUENTIAL	ALVINON MUMBER	MONTH DAY	YEAR		FACILITY NA	LWES	DOCKET NUMBER(S)						
											0 151010101 1 1						
0 7	48	8 4	8 4 -	01116	- 00	98214	8 4				0 ,5	1010	101	1 1			
	DMITAR	N. 1	THIS REPO	AT IS SUBMITTE	D PURSUANT 1	TO THE REQUIREM	ENTS OF 10	CFR 9: 10	Dack one or more	of the following) (1	11						
20.406		2(b) 6(c)(1)(0 6(c)(1)(b) 6(c)(1)(w) 6(c)(1)(v)	20.406(e) 60.38(e)(1) 80.38(e)(2) 60.73(e)(2)(ii) 60.73(e)(2)(iii)			X 80.73(a)(2)(v) 80.73(a)(2)(v) 90.73(a)(2)(vii) 80.73(a)(2)(viii)(A) 90.73(a)(2)(viii)(B) 80.73(a)(2)(viii)(B)			73.71(b) 73.71(a) OTHER (Soacity in Abrovet below and in Text, NRC Form 366A)								
						ICENSEE CONTACT	FOR THIS	LER (12)									
NAME											TELEPH	ONE NUME	ER				
J	amesP	. Pe	lletie	r, Plant	Manage	r				8 0 2	2 5	7,-	7 , 7	1,1			
				COMPLETE	ONE LINE FOR	EACH COMPONEN	T FAILURE	DESCRIBE	D IN THIS REPO	AT (13)				-			
CAUSE	SYSTEM	COMPO	NENT	MANUFAC- TURER	REPORTABLE TO NPROS		CAUSE	SYSTEM	COMPONENT	MANUFAC TURER		RTABLE					
	,		1-	111					111	111							
	1							1	111	1111							
SUPPLEMENTAL REPORT EXPECTED (14)						EXPECT		MONTH	DAY	YEAR							
YES IIF you, complete EXPECTED SUBMISSION DATE! X NO							SUBMISSION DATE (15)										

On 7/28/84 the reactor was shut down with the mode switch in shutdown. Maintenance was being performed on the Reactor Protective System Motor Generators (RPSMG). The "B" side of the Reactor Protective System was being powered from the alternate source. When "A" Recirc MG set was started a voltage dip on the 480V bus caused the alternate supply breaker to trip resulting in a reactor scram.

8409050184 840824 PDR ADDCK 05000271 S PDR IE22

NRC Form 386A (9.83).	LICENSEE EVENT REP	ORT (LER) TEXT CONTIN	RT (LER) TEXT CONTINUATION						U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85					
FACILITY NAME (1)		DOCKET NUMBER (2)		L	ER NUMBER (6)			PAGE (3)						
			YEAR		SEQUENTIAL NUMBER	REVISIO		T		_				
Vermont Yanke	e Nuclear Power Statio	0 5 0 0 0 2 7	1 8 4	_	0 1 6	-010	0 0 12	OF	0 1	2				

TEXT (If more apace is required, use additional NRC Form 366A's) (17)

On 7/28/84 the reactor was shut down for maintenance with the mode switch in shutdown. The reactor was in a half scram condition due to maintenance being performed on the "A" Reactor Protective System Motor Generator (RPSMG). The "B" side of the Reactor Protective System was being powered from the alternate supply due to maintenance on the "B" RPSMG. When "A" Recirc MG set was started for testing at 1300 a voltage dip on the 480V bus caused the alternate supply breaker to trip on undervoltage resulting in a full scram due to loss of power to the protective system. The breaker was reclosed and after verifying the "B" side of the Protective System was functioning properly the scram was reset.

There have been no similar occurrences reported to the Commission.

There were no potential adverse effects to public health and safety.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157 GOVERNOR HUNT ROAD VERNON, VERMONT 05354

VYV 84-431

August 24, 1984

U. S. Nuclear Regulatory Commission Document No. 50-271 Washington, D. C. 20555

REFERENCE: Operating License DPR-28

Docket No. 50-271

Reportable Occurrence No. LER 84-16

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 84-16.

Very truly yours,

James P. Pelletier Plant Manager

RDP/cjm

cc: Regional Administrator
USNRC Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

IE22