


*Southern California Edison Company*



SAN ONOFRE NUCLEAR GENERATING STATION  
P.O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES  
STATION MANAGER

TELEPHONE  
(714) 492-7700

August 21, 1984

U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
Follow-up Report, Inoperable Fire Doors - July 1984  
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),  
dated July 19, 1984

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in July 1984.

Fire doors found inoperable during the July routine surveillances are identified in the Attachment and include: 5 latching mechanism failures; 10 closure mechanism failures; and 7 doors blocked open typically for construction or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established.

We are continuing the corrective actions to upgrade door latches and closure mechanisms. A disciplinary action policy was implemented August 15, 1984, by Station Management, in order to eliminate occurrences of blocked open fire doors without the required Fire Barrier Removal and Reinstallation Request.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in August 1984 will be submitted by September 20, 1984.

REGIONAL

1984 AUG 27 PM 12:05

8409050230 840821  
PDR ADOCK 05000361  
S PDR

RECEIVED  
RUC

IE-28


Mr. J. B. Martin

-2-

August 21, 1984

If you require any additional information, please so advise.

Sincerely,



Enclosure

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission  
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 5, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-122	7/9	7/12
FH2-302	7/17	7/31
AC-316	7/19	7/20
AC-348	7/30	Work in Progress
AR-402	7/1	7/5

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362  
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 10, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH2-103	7/12	7/13
AR-104	7/1	7/2
AC-106	7/9	7/12
AC-110	7/28	7/30
AC-111	7/7	7/8
FH2-207	7/12	7/17
FH3-302	7/1	7/25
FH2-304	7/12	7/13
	7/15	7/20
AC-345	7/27	Work in Progress
AR-501	7/20	7/23

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1984  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362  
(Continued)

III. Doors Blocked Open:

Number of doors inoperable - 7, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AC-133	7/11
AC-260	7/1
AC-331	7/1
AC-344	7/1
C2-403	7/27
C2-404	7/21
AR-501	7/27