



1650 CALVERT CLIFFS PARKWAY • LUSBY, MARYLAND 20657-4702

GEORGE C. CREEL
VICE PRESIDENT
NUCLEAR ENERGY
(410) 260-4450

May 8, 1992

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
NRC Bulletin No. 88-01; Defects in Westinghouse Circuit Breakers
(TAC Nos. M67650; M67651)

- REFERENCES:
- (a) Letter to NRC Document Control Desk from Mr. J. A. Tiernan (BG&E), dated July 13, 1988, same subject
 - (b) Letter to Mr. J. A. Tiernan (BG&E) from Mr. S. A. McNeil (NRC), dated September 29, 1988, Request for Additional Information - BG&E Response to NRC Bulletin 88-01
 - (c) Letter to NRC Document Control Desk from Mr. J. A. Tiernan (BG&E), dated December 1, 1988, NRC Bulletin 88-01; Defects in Westinghouse Circuit Breakers

Gentlemen:

Reference (a) was our response to NRC Bulletin 88-01. Reference (b) requested a schedule for, and description of, corrective actions for breaker inspection failures reported in Reference (a). Reference (c) described when the corrective actions would be complete.

The pole shafts for all Unit 2 breakers needing corrective action were replaced by February 1991. No Unit 1 breakers required corrective action. This completes all of our actions to address Bulletin 88-01.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

Handwritten notes: "Call No PB07376353" and "TEI 1/0"

9205140048 920508
PDR ADDCK 05000317
G PDR

GCC/JMO/dim

Document Control Desk

May 8, 1992

Page 2

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
R. A. Capra, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
P. R. Wilson, NRC
R. I. McLean, DNR
J. H. Waker, PSC