



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

MAY - 4 1992

L-92-91
10 CFR 50.54

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Dockets Nos. 50-250 and 50-251
Request for Relief From Commitments Made
Prior to Submi^t of Physical Security Plan, Rev. 0

By letter L-91-146, dated June 5, 1991, Florida Power and Light Company (FPL) submitted to the Nuclear Regulatory Commission (NRC) Rev. 0 of the new Physical Security Plan (PSP) for Turkey Point Units 3 and 4. By letter dated July 18, 1991, (William E. Cline to J. H. Goldberg) the NRC forwarded to FPL its acceptance of the Turkey Point Units 3 and 4 PSP, Rev. 0. Some of the major changes identified in the plan were related to the completion of the security upgrade project. This included hardening of vital areas, installation of intrusion detection, surveillance and access control systems, and the construction of new access control facilities. PSP, Rev. 0, has been implemented through Procedures, Security Force Instructions, and Post Orders.

Prior to the June 5, 1991 submittal of PSP, Rev. 0, a number of commitments were made in response to findings and recommendations made in past NRC Inspection Reports (NIRs). A listing of these commitments, with references to the NIRs and FPL correspondence, is provided in Attachments 1 and 2. Attachment 1 lists the items implemented in accordance with the commitments made in the referenced FPL correspondence. Attachment 2 lists the items whose implementation differs from the original commitment in the referenced FPL correspondence. Justification for changes from the original commitment is provided for each item in Attachment 2. Accordingly, the PSP, Rev. 0, in conjunction with its implementing procedures and instructions, has incorporated the commitments listed in the attachments.

9205140259 920504
PDR ADOCK 05000250
FDR

an FPL Group company

NON-SAFEGUARDS
per NRC/DRL/RSGB

5003 |

L-92-91
Page 2

As of November 4, 1991, the upgrade of the Protected Area perimeter at Turkey Point was completed. By NRC Inspection Report Nos. 50-250/91-43 and 50-251/91-43 dated November 25, 1991, (Douglas M. Collins to J. H. Goldberg), the NRC verified full implementation of the PSP, Rev. 0, and requested removal of the interim security plan supplements. Therefore, by copy of this letter, FPL confirms the deletion of the six PSP Supplements which addressed the compensatory measures that were in place until completion of the Protected Area perimeter.

Should there be any questions, please contact us.

Very truly yours,



J. H. Goldberg
President
Nuclear Division

Attachments

cc: Stewart D. Ebneter, Regional Administrator, Region II, USNRC
R. C. Butcher, Senior Resident Inspector, USNRC, Turkey
Point Plant

ATTACHMENT 1 TO

L-92-91

<u>SOURCE</u>	<u>NRC CONCERNS</u>	<u>FPL COMMITTED CO. ACTIVE ACTION</u>	<u>RELEVATION</u>
1 NIR83-25	Failure to maintain protected area (PA) alarms and surveillance system in operable condition	L-83-465: Procedure to be written on policy for how long equipment may be out of service	* Now have ISC staff dedicated to security - have a Security Systems Coordinator who tracks and expedites equipment repair, as referenced in the Physical Security Plan (FSP), section 3.1.1.5. A prioritized Work Order system is in place for repair of security equipment, as referenced in O-ADM-701.
2 NIR84-39	Improper compensatory control of vital area (VA) door due to lack of communications at shift change	L-85-25: Commits to written temporary instructions for compensatory posts to be carried over from shift to shift	* Checklists are used to control the opening and closing of compensatory posts, as referenced in Security Force Instruction (SFI) 2006.
3 NIR85-21	Scheduled security system computer outage not properly compensated for	L-85-326: Procedures reviewed and modified as necessary to ensure proper notifications and postings for compensatory posts. Independent review of contractor records to verify accuracy of notification and posting times	* Actions for planned and unscheduled computer outages are addressed in SFI 2501.
4 NIR86-38	Plant work degraded security lighting	L-86-440: Plant procedures to be modified to require notification or security before security lighting is altered	* Procedure O-ADM-701 [Plant Work Order (PWO) Preparation] requires security notification/review prior to work on lighting.
	No procedures in place to implement devitalization and ensure area search before revitalization	Plant procedures to be developed to control devitalization and revitalization	* Procedure O-ADM-404 stipulates requirements for control of devitalization and revitalization.
5 NIR86-40	VA barrier and compensatory controls circumvented by scaffolding	L-86-493: Plant procedures changed to require security review/evaluation before scaffolds are erected	* Plant procedure O-ADM-012 (Scaffold Control) requires security notification/approval before erection of scaffolding
6 NIR86-47	Material in isolation zone	L-87-38: Lines are painted on interior roadways to mark isolation zones. No-parking signs are placed on PA fencing to prevent parking in isolation zones.	* PSP, section 4.1.6, identifies objects which are located in isolation zones and commits to keeping zones clear. A number of different methods, including signs and nuisance fencing, are employed to preclude encroachment of isolation zones. Observation of isolation zones is addressed in SFI 2201.

SOURCE	NRC CONCERNs	FPL COMMITTEE CORRECTIVE ACTION	RESOLUTION
7 NIR87-05	Security Officer (S/O) asleep at VA compensatory post	L-87-213: Supervisors to make hourly checks of comp posts at night	* Commitment was modified per L-90-193, to state that S/O at comp posts are rotated periodically throughout their duty shift to assure attentiveness to duty. Post Instruction (PI) 6921 requires frequent post visits by the Supervisor.
8 NIR87-11	Unescorted visitor	S/O working hours restricted to IE Notice 86-88 guidance Security events to be reported and tracked by management Monthly quality improvement meetings to be held by plant and corporate security management and security contract management	* The security force contractor has adopted IE Notice 86-88 guidelines. * PSP, section 3.1.1.2, addresses trending of security events as part of the Security Operations Supervisor's duties. * Meetings between licensee and contract security management are held and are required by contractual agreement with Security Bureau Incorporated (SBI).
9 NIR87-25	Improper material search and access control at containment	L-87-213: Signs posted on-site to indicate that visitors require escort L-87-362: A system to determine access authorization based on job description and need for access to be developed Both plant and corporate security to review procedures prior to implementing revisions	* Signs are posted on site. SFI 2201 directs S/O to be observant for unescorted visitors. * Access Authorization Request Forms (Procedure 9-AUM-402, Access authorization and Control) are used to determine access based on job description. * As described in the PSP, section 3.2.6, procedures are developed and modified at the plant level.

SUBJECT	SNIC OFFICERS	ITEMS SUBMITTED CORRECTIVE ACTION	REVISION
10	Failure to control access to containment.	L-88-21/J/15: the inspection will focus on the containment personnel batches at emergency exits will be included in seven (7) day operability checks.	* SEI 2004 requires that looks on containment personnel batches and emergency exits be seven (7) day operability tested.
	Lighting did not meet 0.2 footcandle commitment.	Routine lighting checks will be made and patrols will be instructed to observe lighting.	* SEI 2302 requires periodic assessment of 7A lighting.
	S/b asleep on static post.	Intend commitment to thirty (30) minute radio checks and hourly rotation of static posts.	* Reduction in static posts due to updated changes in shift schedule and reduction of personnel turnover have reduced need for frequency of radio checks and hourly rotation. Commitment was modified in L-90-293.
11	intrusion Detection System (IDS) alarm on section of PA fence not working (construction related)	L-88-149: plant procedures for construction project and work activities involving security barriers/equipment to be reviewed by security before work begins. The procedures will be revised to assure the identification of any degradation of security effectiveness.	* Plant procedures, Q13-PTB-1, Q-2004-012, and Q-006-701, requires security review of plant change modifications (PM) packages and PMs before work starts.
	Tamper alarms not functionally tested before deactivated alarms returned to service.	Plant procedures revised to require tamper alarm testing before returning alarms to service.	* NRC Work Orders carry directions for tamper testing. SEI 2004 am SEI 2300 require tamper testing following deactivation of IDS/Door Control Unit (DCU) equipment for maintenance.
12	NIDS-03	Failure to notify SIC in timely manner of change to PA configuration.	L-88-365: will establish requirements for review, approval, and submittal to NRC of PTP Changes.
			Will have a corporate procedure for defining control for Plan review, approval, submittal of plan changes.
	NIDS-16		* PSP, section 10.4, commits to mechanism for plan changes due to construction work or redesign.
			* As referenced in JNSC-PSP-1, the Manager - Nuclear Security (Corporate) must review and sign plan revisions prior to their submittal to the Commission.

SOURCE

REC. COMM-FORCEFPL COMMITTED CORRECTIVE ACTIONAttachment #1
Page 4 of 4

RESOLUTION

- 13 Comp. post left unattended due to L-88-436, Post relief instructions revised to * The mechanics of post openings and closings
misunderstanding during post require: 1) On-coming S/O to sign post log, 2) are stipulated in SFI 2006.
Supervisors must Sign S/O log, and 3) CAS must be notified of relief.
- 14 Degraded VA barrier. L-89-84, detailed drawings of VA barriers to * VA drawings are maintained by the Plant
be maintained by security. Security Supervisor.
- A Security Barrier procedure to be developed by FPL security management to review/approve compensatory posting and changes.
- 15 Failure to control VA containment L-89-112, FMO modified to require assurance of * The plant environmental entry procedure, Q-ADM-009, contains requirements for security stand-by for containment opening.
- Unmarked, unsecured Safeguards centralized control of safeguards documentation.
- 16 Inadequate VA barriers (louvers in some VA doors). L-89-112, Security will review future design * Requirements for security review of 2006
change and modification packages. packages are contained in Plant Procedures Q33-
PTB-1, Q-ADM-012, and Q-ADM-701.
- Security barriers will be addressed in General Employee Training (GET) to increase awareness * PSP section 3, 4 commits to security training as a part of GET.

ATTACHMENT 2 TO

L-92-91

SOURCE	NRC CONCERN	AFFL COMMITTED CORRECTIVE ACTION	RESOLUTION
1 NIR83-02	Vital area (VA) alarm failed to annunciate audible in CAS/SAS	L-83-115: Alarm annunciator checks to be conducted once per shift.	* Complete new system installed and the reliability of the system is such that alarm annunciator checks do not need to be conducted once per shift.
2 NIR87-05	Security Officer (S/O) asleep at VA compensatory post	L-87-213: Thirty (30) minute radio checks to be made with posts during nights	* S/O at posts are rotated periodically to assure alertiveness to duty. Supervisors are required by Post Instruction (PI) 6901 to make frequent post visits. Sleeping S/O problems have been resolved by reduction in compensatory posts and changes in shift schedule. Therefore, thirty (30) minute radio checks are not necessary.
3 NIR87-11	Unescorted visitor	L-87-215: Distinctive visitor badges and hard hats used to identify visitors who must be accompanied by an escort.	* This commitment was further reevaluated with the inception of the new security system and new visitor processing techniques. Only the distinctive colored badges were committed to in the new PSP. section 5.2-2. Plant procedure O-AD8-402 (Access Authorization and Control) requires escorts to wear and sign an Escort Responsibilities form.
4 NIR87-25	Inadequate vehicle search	L-87-362: Number of K-9s and handlers will be expanded and vehicles will be both K-9 and manually searched.	* Because of the security upgrade and the new vehicle entrainment search areas, K-9s are no longer used for vehicle searches. S/O search vehicles in accordance with SFI 2100.
		A vehicle entrainment area will be constructed at the South Gate	* A permanent vehicle entrainment area was completed with the Security Upgrades, and is located at the Main Truck Gate.
		Improper material search and access control at containment	* The method for controlling access to containment has been changed to ensure positive identification and S/O are required to inspect materials entering the containment, as referenced in the Physical Security Plan (PSP), section 5.1-2.4, and SFI 2108.

RESOLUTION

FPL COMMITTED OBJECTIVE ACTION

NRC CONCERN

SOURCE

- 5 S/O asleep on static post
NIRS87-38747
L-88-120/153: Security force supervisor training conducted quarterly. Random on the job task performance evaluations conducted by supervisors. All members of security force to receive task performance evaluation quarterly.
- 6 Topoper protected area access control (PA) Security personnel who have submitted resignations will be reassigned to non-critical duties prior to last work day.
- Employees who are to be disciplined must be separated while inside the PA.
- 7 Newly constructed storm drain passing under PA fence not secured.
- 8 Procedural violation in verification of out-of-service equipment before devitalization.
- L-88-149: Security to maintain a log of security related construction and work activities.
- L-91-050: Devitalization procedure revised to temporarily require Nuclear Safety Committee and Plant Manager approval for devitalization.
- * Task performance evaluations conducted at random by supervisors and documented and tracked by Training. Security force training is conducted in accordance with the Training and Qualifications Plan (TQP).
 - * Supervisory Fitness for Duty containing observation program helps to identify any potential poor job performance. The poor job performance on the part of an Officer who had submitted a resignation was an isolated case.
 - * FSP, section 3.1.2.5, commine to escorting persons who are suspended or terminated for cause.
 - * Because of mechanism in place for Security to review all construction or plant change modifications (PCMs). (O-ADM-701 and Q13-PTN-1) maintenance of a log is not necessary.
 - * O-ADM-404 has been revised to clearly state the conditions for devitalization and re-vitalization. The temporary commitment for Nuclear Plant Safety review is no longer necessary. The Nuclear Plant Supervisor (NPS) signature is required.