

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-6531

August 29, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station, Unit 1
Docket No. 50-413

Dear Mr. Denton:

This letter is to supplement the technical justification for the Auxiliary Feedwater System Technical Specification amendment request.

The proposed amendment was based on the FSAR Chapter 15 accident analysis which requires an Auxiliary Feedwater flow rate of at least 492 gpm. The flow rate of 492 gpm is the minimum flow rate required of the Auxiliary Feedwater System, given an initiating event (e.g. feedwater line break) and a single failure (e.g. failure of one motor-driven pump).

The Technical Specification surveillance requirements proposed in my July 31, 1984 letter were based on these requirements. By testing each Auxiliary Feedwater pump through the test loop to assure a flow of at least 400 gpm it is assured that the Auxiliary Feedwater System will be capable of supplying at least 492 gpm to at least two effective steam generators in an accident situation coupled with a single failure.

Very truly yours,

Hal B. Tucker
er

Hal B. Tucker

RWO:slb

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Catawba Nuclear Station

8409050400 840829
PDR ADDCK 05000413
P PDR

Aool
1/0

Mr. Harold R. Denton, Director
August 29, 1984
Page 2

cc: Mr. Robert Guild, Esq.
Attorney-at-Law
P. O. Box 12097
Charleston, South Carolina 29412

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health & Environmental Control
2600 Bull Street
Columbus, South Carolina 29201