



International Agreement Report

Assessment of RELAP5/MOD2 Cycle 36.04 with LOFT Large Break LOCE L2-3

Prepared by
Y. S. Bang, H. J. Kim, Korea Institute of Nuclear Safety
S. H. Kim, Korea Atomic Energy Research Institute

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejoni 300-31
Republic of Korea

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

April 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information.* Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents
U.S. Government Printing Office
P.O. Box 37082
Washington, D.C. 20013-7082

and

National Technical Information Service
Springfield, VA 22161

NUREG/IA-0070



International Agreement Report

Assessment of RELAP5/MOD2 Cycle 36.04 with LOFT Large Break LOCE L2-3

Prepared by
Y. S. Bang, H. J. Kim, Korea Institute of Nuclear Safety
S. H. Kim, Korea Atomic Energy Research Institute

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejoni 300-31
Republic of Korea

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

April 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

NOTICE

This report is based on work performed under the sponsorship of The Korea Advanced Energy Institute of Korea. The information in this report has been provided to the USNRC under the terms of an information exchange agreement between the United States and Korea (Agreement on Thermal-Hydraulic Research between the United States Nuclear Regulatory Commission and The Korea Advanced Energy Research Institute, May 1, 1986). Korea has consented to the publication of this report as a USNRC document in order that it may receive the widest possible circulation among the reactor safety community. Neither the United States Government nor Korea or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report or represents that its use by such third party would not infringe privately owned rights.

ICAP

ASSESSMENT OF RELAP5/MOD2 CYCLE 36.04
USING LOFT LARGE BREAK LOCE L2-3

Abstract

The LOFT LOCE L2-3 was simulated using the RELAP5/MOD2 Cycle 36.04 code to assess its capability to predict the thermal-hydraulic phenomena in LBLOCA of the PWR. The reactor vessel was simulated with two core channels and split downcomer modelling for a base case calculation using the frozen code. From the results of the base case calculation, deficiencies of the critical flow model and the CHF correlation at high flow rate were identified, and the severity of the rewetting criteria were also found. Additional calculation using an updated version of RELAP5/MOD2 Cycle 36.04 including modifications of the rewet criteria shows a substantial improvement in the core thermal response.

List of Contents

	Page
Abstract	iii
List of Tables	vi
List of Figures	vii
1. Introduction	1
2. Facility and Test Description	3
2.1 Facility Description	3
2.2 Test Description	3
2.3 Measurement Uncertainty	4
3. Code and Modelling Description	5
3.1 Input Modelling	5
3.2 Initial Conditions and Boundary Conditions	6
4. Base Case Calculation	8
4.1 Loop Behavior	8
4.2 Secondary Side Behavior and ECCS Performance	9
4.3 Reactor Vessel Behavior	10
4.4 Fuel Rod Thermal Response	12
5. Sensitivity Study	14
6. Run Statistics	16
7. Conclusions	17
References	18
Appendix A Update List for RELAP5/MOD2 Cycle 36.04	A-1
Appendix B A Base Case Input Deck for A Steady State Calculation	B-1
Appendix C A Base Case Input Deck for a Transient Calculation	C-1
Appendix D Update List for PSI-EIR 83 based on RELAP5/MOD2 C 36.04	D-1

List of Tables

	Page
Table 1 Summary of comparison of the initial conditions between the measured and the calculated in base case	19
Table 2 Summary of comparison of the sequence of events between the measured and the calculated in base case	20
Table 3 Uncertainties of measurements	21
Table 4 Summary of reactor vessel modelling in base case calculation	22
Table 5 Run statistics data in base case calculation	23

	List of Figures	Page
Fig.1	Axonometric configuration of LOFT L2-3 test	24
Fig.2	Nodalization diagram for base case calculation of LOFT L2-3 test	25
Fig.3	Axial power distribution in base case calculation of L2-3 test	26
Fig.4	Comparison of mass flow rate at broken loop cold leg between the base case calculation and the experiment	27
Fig.5	Comparison of mass flow rate at broken loop hot leg between the base case calculation and the experiment	28
Fig.6	Comparison of mass flow rate at intact loop cold leg between the base case calculation and the experiment	29
Fig.7	Comparison of net mass flow rate into the core between the base case calculation and the experiment	30
Fig.8	Comparison of steam dome pressure at S/G secondary side between the base case calculation and the experiment	31
Fig.9	Comparison of accumulator injection flow rate between the base case calculation and the experiment	32
Fig.10	Comparison of accumulator liquid level between the base case calculation and the experiment	33
Fig.11	Comparison of HPSI flow rate between the base case calculation and the experiment	34
Fig.12	Comparison of LPSI flow rate between the base case calculation and the experiment	35
Fig.13	Comparison of primary system pressure between the base case calculation and the experiment	36
Fig.14	Comparison of coolant temperature in lower plenum between the base case calculation and the experiment	37
Fig.15	Collapsed liquid levels calculated in the base case calculation for the broken side downcomer, intact side downcomer, hot core channel and average core channel of the reactor vessel	38
Fig.16	Comparison of cladding temperature at 5 inches of hot fuel between the base case calculation and the experiment	39
Fig.17	Comparison of cladding temperature at 16.5 inches of hot fuel between the base case calculation and the experiment	40
Fig.18	Comparison of cladding temperature at 27.5 inches of hot fuel between the base case calculation and the experiment	41

	Page
Fig.19 Comparison of cladding temperature at 39 inches of hot fuel between the base case calculation and the experiment	42
Fig.20 Comparison of cladding temperature at 49.5 inches of hot fuel between the base case calculation and the experiment	43
Fig.21 Comparison of cladding temperature at 60 inches of hot fuel between the base case calculation and the experiment	44
Fig.22 Wall heat transfer coefficients calculated in the base case calculation at volume 2 and 3 of hot fuel	45
Fig.23 Liquid fractions calculated in the base case calculation at volume 2 and 3 of hot fuel	46
Fig.24 Flow regimes predicted in the base case calculation at volume 2 and 3 of hot core channel	47
Fig.25 Comparison of cladding temperature at 16.5 inches of hot fuel between the base case calculation and the sensitivity calculation	48
Fig.26 Comparison of cladding temperature at 27.5 inches of hot fuel between the base case calculation and the sensitivity calculation	49
Fig.27 Comparison of cladding temperature at 39 inches of hot fuel between the base case calculation and the sensitivity calculation	50
Fig.28 Comparison of cladding temperature at 49.5 inches of hot fuel between the base case calculation and the sensitivity calculation	51
Fig.29 Comparison of void fraction at volume 5 of hot core channel between the base case calculation and the sensitivity calculation	52
Fig.30 The required CPU time versus the advanced time in the base case calculation	53
Fig.31 Time step size of base case calculation	54

Executive Summary

This report documents the assessment calculations using the RELAP5/MOD2 Cycle 36.04 to predict thermal-hydraulic response of Loss of Fluid Test (LOFT) system during the Loss of Coolant Experiment (LOCE) L2-3. LOCE L2-3 simulated a 200 % offset shear at the discharge of the Primary Coolant Pump (PCP) in the four loop commercial PWR.

To simulate LOFT system specific to L2-3 experiment, the reactor core was modelled with two separate flow channels and the reactor vessel downcomer was described by two equally-split channels. Three heat structures were used to describe the LOFT fuel assemblies.

The results of the base case calculation using the frozen code of the RELAP5/MOD2 were compared with the experimental data in terms of loop flows, secondary side pressure, Emergency Core Cooling System (ECCS) performance, reactor vessel behavior and fuel rod thermal response. As result of comparisons, the overall hydraulic behavior was well-predicted, while fuel rod thermal response was poorly predicted.

Major reasons of the discrepancies in the prediction were identified as the code deficiencies in the thermal-hydraulic models : (1) underprediction of cold leg break flow due to the deficiency of critical flow model, (2) poor prediction of the core early heatup during blowdown due to the deficiency of CHF correlation at high flow rate, and (3) poor prediction of rewetting phenomena due to the severeness of the rewet criteria in the frozen code.

To reidentify the deficiencies found in the base case calculation and to determine the effectiveness of the rewet criteria change in the frozen code, a sensitivity calculation was performed using an updated code with the PSI modification. The result of the sensitivity calculation shows that the rewet phenomena was well-predicted by the PSI-modified criteria.

1. Introduction

RELAP5/MOD2[1], a frozen version by US Nuclear Regulatory Commission (USNRC), has been assessed through the International Code Assessment and Application Program (ICAP) for its capability and deficiencies in the prediction of the postulated Large Break Loss of Coolant Accident (LBLOCA) in Pressurized Water Reactor (PWR).

This report is one of the Korean ICAP contributions to support code assessment, code deficiency identification and code improvement. In this study the RELAP5/MOD2 Cycle 36.04 was assessed for the Experiment L2-3 conducted in the Loss of Fluid Test (LOFT) at Idaho National Engineering Laboratory (INEL) [2].

The Experiment L2-3, as one of the Integral Effect Test (IET), was a Large Break Loss of Coolant Experiment (LBLOCE), which represented the postulated LBLOCA in the typical Westinghouse type PWR with four loop. During LOCE L2-3, two Primary Coolant Pumps (PCP) in LOFT system were set to operate without coastdown, this PCP running was found to have significant effect on the reactor core thermal response, i.e., the early core quenching in blowdown phase. This blowdown quenching phenomena was called as 'rewet' which was due to a quick return to the nucleate boiling heat transfer regime from the post dryout regime and was one of the important assessment items in the previous LBLOCA calculations [3, 4].

The objectives of this study are to predict the major hydraulic behavior and thermal response of the LOFT system during the LOCE L2-3 and to identify deficiencies of the frozen RELAP5/MOD2 Cycle 36.04 code in simulating thermal-hydraulic phenomena specific to LBLOCA by comparing the calculation results with the experiment data. From the findings obtained by ICAP activities [5], it was known that the major deficiencies of RELAP5/MOD2 were summarized as the Critical Heat Flux (CHF) correlations, the critical flow model and the

interfacial drag correlations. This study, therefore, is focused to confirm whether the deficiencies as stated above are still found in the Experiment L2-3 simulation. And to investigate the sensitivity of the rewet criteria in the RELAP5/MOD2, an updated version from Cycle 36.04 using the modified rewet criteria by Aksan [6], at Paul Scherer Institute (PSI), Swiss was tested in this study.

The descriptions for LOFT facility and L2-3 experiment are presented in chapter 2, the RELAP5 input modelling in chapter 3 and the results of a base case calculation and their discussions in chapter 4. In chapter 5, a result of sensitivity calculation is described and the conclusions obtained from the present study are summarized in chapter 6.

2. Facility and Test Description

2.1 Facility Description

The LOFT facility is an experimental 50 Mwt PWR designed to simulate LOCA's and anticipated transients and to provide data on the thermal-hydraulic phenomena occurring throughout the system [7]. It is a scaled representation of a commercial PWR of Westinghouse type having 4 loops with a volume ratio of 1/60. The LOFT system consists of five major systems : reactor system, primary coolant system, blowdown suppression system, emergency core cooling system and secondary coolant system, and also includes instrumentations. The height of the core and reactor vessel is 1.68 and 7 m, respectively. The overall configuration is shown in Fig.1.

2.2 Test Description

Experiment L2-3 was performed as part of LOFT program Power Ascension Series (L2), which was designed to investigate the response of LOFT nuclear core to the blowdown, refill and reflood transient during LOCA.

Experiment L2-3 represents a postulate 200 % double ended offset shear of the pump discharge piping in the cold leg of commercial PWR. The specific objectives of L2-3 test were to determine the corewide and spatial variation of fuel rod cladding thermal response, to identify thermal-hydraulic phenomena and their effect on the core of LOFT and to determine the ECRS performance and core reflood characteristics. During L2-3 experiment, primary coolant pumps were set to continue to operate, which results in early quenching during blowdown, called rewet. The phenomena of rewet is currently known as early return to

nucleate boiling in the core, which has been a common interesting point of code assessment [3, 4].

Prior to Experiment L2-3, LOFT facility was set to be a primary system pressure of 15.06 MPa, primary system cold leg and hot leg temperature of 560.7 K and 592.9 K respectively, and a loop mass flow rate of 199.7 kg/sec. Initial reactor power level was 36.7 MW with a maximum linear heat generation rate (LHGR) of 39.4 kW/m. Table 1 presents a summary of initial conditions of Experiment L2-3.

The experiment was initiated by opening the Quick Opening Blowdown Valves (QOBV) both in hot leg and cold leg. Reactor was scrammed at 0.103 sec after initiation of the experiment by operator signal. Identifiable phenomena in the experiment are listed in Table 2. Injection from accumulator began at 17 sec, approximately when primary system pressure moved down to 4.18 MPa. High Pressure Safety Injection (HPSI) system and Low Pressure Safety Injection (L PSI) system started to inject at 14 sec and 29 sec and LOFT core volume was finally reflooded at approximately 55 sec.

2.3 Measurement Uncertainty

Uncertainties of the experimental data and computed variables were fully discussed in reference [2] for L2-3 test. Uncertainties on the measured values and computed values used for comparisons with calculation in this report are presented in Table 3.

3. Code and Modelling Description

RELAP5/MOD2 Cycle 36.04, frozen version of the code by USNRC, was used in the present calculation with modifications of some indexing schemes. An update procedure is listed in Appendix A, which is exactly the same as that in L2-5 assessment report [8]. Since any RELAP5 input specific to L2-3 experiment was not obtained from INEL, a reference input was developed by the authors based on the input used in the previous L2-5 experiment assessment [8].

3.1 Input Modelling

All components except a reactor core and a reactor vessel downcomer of LCFT for L2-3 experiment were geometrically modelled as the same as those for L2-5 case [8] i.e., equal volumes, junctions and heat structures. A nodalization diagram used in the present calculation is shown in Fig.2. Total number of hydrodynamic volumes, junctions and heat structures are 128, 149 and 27.

The reactor core was modelled by two flow channels: a hot channel and an average channel representing the central fuel assembly (numbered by 5 in the reference [7]) and the other peripheral fuel assemblies, respectively. Each flow channel was divided by six volumes with equal lengths. Two flow channels were linked by six crossflow junctions to allow crossflow in the core with a specified junction loss coefficient of 4.69 for all crossflow junctions. These junction loss coefficients were selected as the same as those in the Best Estimate Prediction for L2-5 experiment [9].

The reactor vessel downcomer was modelled by two split flow channels : an intact side downcomer and a broken side downcomer. Each downcomer has five volumes including a volume representing an upper annulus part above the cold leg nozzles. To describe an azimuthal flow across the downcomer, four

crossflow junctions were used to link four volumes between the intact-side downcomer and the broken-side one with exception of the volumes representing the cold leg nozzles. Loss coefficients at the downcomer crossflow junctions were tuned to match the measured loop flow behavior, according to the reference [9]. The values used in the present calculation ranges from 18.0 to 98.0 with their junction elevations.

Originally LOFT fuel rods had two types of axial power profile : a high power shape for central fuel assembly and a low power shape for peripheral fuel assemblies. Both of them have almost identical shapes but have different magnitudes in LHGR. During L2-3 input preparation, however it is found that an actual summation of rod power integrated over the full length of rod did not match and was lower than the experimental total power level, 36.7 MW. In the present study, three heat structure component were used to model the LOFT fuel rods: 204 hot rods in the central fuel assembly, 572 average rods and 574 intermediate rods in the peripheral fuel assemblies respectively. And the axial power shapes can be determined by the experimental LHGR distributions [2] for the hot rods and average rods. For the intermediate fuel rods heat structure, a mean LHGR distribution of hot and average rods can be used. This modelling scheme of fuel rods can match a given total power. The profiles of LHGR's were shown in Fig.3 and Table 4 presents a summary of reactor vessel modelling.

3.2 Initial Conditions and Boundary conditions

To provide all initial conditions of the whole system prior to transient, a steady state run was carried out with seven steady state controllers : two primary coolant pump speed controllers, a pressurizer heater power controller a pressurizer spray valve area controller, a letdown and charging valve area controller, a main steam control valve (MSCV) area controller and a feedwater

flow rate controller. A steady input deck was provided in Appendix B.

The result obtained from the steady state run was compared with the measured initial conditions in Table 1. The RELAP5 calculated results generally agree with the experimental conditions.

Boundary conditions required to simulate the L2-3 experiment are almost the same as those in L2-5 experiment except PCP running. The PCP speed during the transient was assumed to be constant, which was a simple approximation of the real PCP running behavior showing oscillations around a fixed speed during the transient [2].

Based on the experiment data [2], the reactor power history and containment pressure were described as time dependent tables. Performance curves for HPSI and LPSI flow rate as function of cold leg pressure were provided in the input. Feedwater flow rate was reduced to be zero in 2.5 seconds after LOCE initiation using a time-dependent junction as the same as the L2-5 experiment. And the steam generator secondary side air-cooled condenser was modelled as a time-dependent volume with a constant pressure of 2.069 MPa during the transient. All informations of the boundary conditions were provided in the steady and transient input deck. The transient input deck was listed in Appendix C.

4. Base Case Calculation

The L2-3 LOCE was calculated up to 100 sec using all initial conditions obtained from steady state run. Some additional components such as pressurizer spray, letdown and charging systems used for the steady state calculation are deleted in transient input deck.

The sequence of events during transient calculation are presented in Table 2 as compared with L2-3 experiment chronology. In this chapter, the predicted important thermal-hydraulic parameter such as system pressure, loop mass flow rates and cladding temperatures are compared with the measured data.

4.1 Loop Behavior

Fig.4 shows a comparison of the calculated mass flow rate with the measured one at the broken loop cold leg up to 40 sec. An overall behavior of break flow was well predicted by RELAP5/MOD2 except the underprediction during a short period from 3 sec to 9 sec. This period corresponded to the transition phase from the subcooled break flow to the two-phase break flow. The subcooled break flow was completed at about 3 sec both in calculation and in experiment as shown in Table 2. After that time the break flow was well simulated by the RELAP5 calculation. The underprediction of break flow during the phase transition period can be considered as a deficiency of the RELAP5/MOD2 critical flow model. This led the reactor vessel to contain more coolant inventory than the experiment, which amounts to 400 kg approximately. This overestimated coolant inventory may suppress the core heatup discussed in later chapter.

Fig.5 presents a comparison of mass flow rate in the broken loop hot leg. As expected, the magnitude of break flow was less than that in the cold leg due

to higher flow resistance in the hot leg. The calculated break flow in hot leg was well-agreed with the experimental result.

Mass flow rate in the intact loop cold leg was shown in Fig.6. The predicted mass flow rate was almost similar to the measured one. However, the calculation did not show several jumps which can be found in the experimental behavior with high frequencies after 20 sec. It was regarded as the effect of void oscillation phenomena induced by the highly subcooled ECC injection water during the reflood phase.

Fig.7 indicates a comparison of the net flow into the core, i.e. intact loop cold leg flow minus broken loop cold leg flow. The intact loop cold leg mass flow, driven by the operating pumps, exceeded the broken loop flow from 3 sec to 6 seconds causing an increase in positive core flow, which had reversed after saturation in the lower plenum at about 7 sec. The calculation result was in good agreement with the experimental data.

In general, the predicted loop behaviors agreed well with the experiment data within the range allowed by the instrument uncertainty except the underprediction of cold leg break flow during the transition period.

4.2 Secondary Side Behavior and ECCS Performance

Fig.8 shows a comparison of the steam dome pressure of the steam generator secondary side. The experimental data used in this comparison was not fully qualified one but accurate for initial condition only. The predicted pressure was fairly well-agreed to the measured one up to 40 sec. Difference after 40 sec was considered to have little effect on the primary side behavior since the transient was fast enough to neglect the heat transfer from the secondary side.

Fig.9 presents a comparison of accumulatator injection flow rate and Fig.10

a comparison of accumulator liquid level. The calculated injection flow rate was larger before 42 sec and then lower than the experiment, while the accumulator liquid level was well agreed to the experiment. The overprediction of mass flow rate during 20 to 40 sec can be due to an underprediction of the primary system cold leg pressure discussed in later chapter. The overpredicted injection mass amounts to 180 kg approximately. The experiment shows that the injection continued until 60 sec, while the calculation shows that the injection was completed at 42 sec. From the fact that the measured liquid level was almost stationary at 42 sec as shown in Fig.10, it can be stated that the jump and oscillation in the injection mass flow rate is not a real situation but a measurement error.

Figs. 11 and 12 show comparisons of mass flow rates through a HPSI line and LPSI line. During the early period of injection, some overpredictions were found in both injection flow rates, whose total amount was about 65 kg. This overprediction was also due to the primary system pressure. However, the overall injection behaviors were comparatively close to the experiment.

4.3 Vessel Phenomena

Fig.13 shows a comparison of primary system pressure at the upper plenum. The predicted behavior agreed with experiment data very well. A little earlier depressurization was found in calculation than that in the experiment before 10 sec, which was resulted partly from an underprediction of cold leg break flow (Fig.4). The calculation also presented a little lower pressure after 20 sec than the experiment. It resulted in the early high ECC injection behavior as stated in the previous chapter and yielded a underestimation of the liquid coolant temperature in the lower plenum as shown in Fig. 14, which was a saturation temperature at the corresponded pressure.

Fig.15 shows the collapsed liquid levels in the two downcomer channels and in the two core channels of reactor vessel. Since no experiment data for these items were available, the predicted levels are plotted only.

The liquid level behaviors in core were found to be almost identical in both average channel and hot channel. From these level behaviors, it is shown that the LOFT core was almost empty in 5 sec and then filled with liquid up to 2.36 m in 8 sec by the positive net flow into the core as explained in the previous chapter. This substantial liquid filling up for a short period yielded a corewide rewet, and the rewet was completed in 8 sec. A core re-empty was predicted at 14 sec, a lower plenum was fully refilled by ECC water injection at 35 sec, and a core-reflood was completed at 43 sec, approximately. The end of reflood was predicted to be quite earlier than the measured time as shown in Table 1. This earlier end of reflood, i.e., earlier core quenching, than the experiment was due to the overestimated coolant inventory, which was mainly caused by underprediction of cold leg break flow.

The liquid level in the broken side downcomer were predicted to be different from that in the intact side one due to the split nodalization of vessel downcomer. In the early blowdown period up to 3 sec, the broken side liquid level dropped more rapidly than the intact side one due to less flow resistance. Both levels ceased to drop and increased a little slightly at the time of the transition from subcooled break flow to two-phase break flow. The increase of level is caused that the break flow was reduced significantly at the transition time, while the incoming flow was still maintained by the operation of the intact loop pumps. During core rewetting period, downcomer liquid levels decreased again. The slope of the broken side liquid level was slower than that in intact side one, which was due to upward water flow from the lower plenum to the broken side downcomer. At the time of accumulator injection, 16 sec, both levels moved up again with some time delay in the broken side.

4.4 Fuel Thermal Response

Figs. 16, 17, 18, 19, 20 and 21 present comparisons of cladding temperatures of hot fuel rods at 5, 16.5, 27.5, 39, 49.5 and 60 inch elevations from the bottom of core, respectively. From these comparisons, the following features were found,

- 1) For a lower part (5 in and 16.5 in), the predicted DNB(departures from nucleate boiling) times were later than the measured values during blowdown phase. And the calculated cladding temperatures during blowdown heatup period were appreciably lower and core rewet was completed earlier than the measured data.
- 2) The predicted thermal response during reflood heatup period were also later in timing and smaller in heatup amounts than the experimental data. Consequently, core quenching times were predicted as substantially earlier than the experiment.
- 3) For a middle part(27.5 in and 39 in), the prediction shows earlier DNB's, higher heat up's and earlier core quenchings than the experiment, and the absences of blowdown rewets. The peak cladding temperature (PCT) was predicted as 950 K at 27.5 inch elevation in blowdown phase, which was higher than the experiment, 891 K at 24 inch elevations.
- 4) For a higher part (49.5 in and 60 in), core was not heated up both in blowdown and reflood phases.

To find out some reasons of such thermal responses that deviated from the experimental behaviors, the calculated fuel surface heat transfer coefficients were presented as shown in Fig.22 for a volume 2 (16.5 in) and a volume 3 (27.5 in). For a volume 3, heat transfer coefficient rapidly dropped as soon as

the experiment was initiated (transition from the saturated nucleate boiling to the film boiling) and the film boiling heat transfer mode was sustained until 20 sec, while for a volume 2, the saturated nucleate boiling remained for 4 or 5 sec, and then changed to the film boiling during a short period (rewet).

Fig.23 shows liquid fractions at volume 2 and volume 3. Both volumes had experienced an almost similar transient in liquid fraction for the first 2 sec, as shown in this figure, however a DNB was not predicted in volume 2 as shown in Fig.17. As a result of poor prediction of DNB, flow regimes at these two volumes were different during the same period as shown in Fig.24. Therefore, it can be stated that the deficiency of CHF correlation in the frozen RELAP5/MOD2 was also found in the LOCE L2-3 simulation in the condition of high flow rate (the predicted mass flux into the core was about 1000 kg/m² sec).

The increasing behavior of liquid fraction at volume 3 was almost the same as that in volume 2 during 5 to 8 sec except some time delay, however no rewetting was found at the volume 3. This indicates the severeness of rewet criteria in the frozen RELAP5/MOD2 Cycle 36,04.

Some features found in reflood heat up calculation can be regarded as an over prediction of coolant inventory as mentioned in the previous chapter. Total amount of coolant inventory overestimated by the present calculation was 545 kg, approximately. This amount was not so small when compared to the primary coolant system inventory 5646.8 kg at the steady state condition. This added inventory can be considered to suppress the core heat up during reflood period.

5. Sensitivity Study

From the findings in the base case calculation, the severeness of the rewet criteria in the frozen code was one of the most noticeable problems in the point of the fuel cladding thermal response. In this study, to investigate the sensitivity of rewet criteria, an updated code with PSI modification from the RELAP5/MOD2 Cycle 36.04 was used in the re-calculation with the same input as in the base case calculation. The PSI modification [6] includes three major changes : interfacial friction formula, rewet criteria and heat transfer correlations in reflood phase. A whole list of the updates was presented in the Appendix D. Especially in the rewet, three independent criteria was checked as follows :

- 1) $(T_w + T_{sat}) < 1250 \text{ K}$
- 2) Equilibrium quality less than 0.99
- 3) Mass flux less than -100 kg/sec m^2

Figures 25, 26, 27 and 28 show comparisons of the calculated cladding temperatures by the frozen Cycle 36.04 with those by PSI updated version at 16.5, 27.5, 39 and 49.5 inch elevation, respectively. The predicted thermal responses at 5 and 60 inch elevation were not plotted since almost the same result was obtained as base calculation. Even at 16.5 inch location (Fig.25), a similar thermal response to the base case calculation was obtained except a little higher heat up in blowdown phase. And both calculation still show differences from the experimental cladding temperature.

At the middle elevations, 27.5 inches in Fig.26 and 39 inches in Fig.27, the sensitivity calculation shows the blowdown rewet evidently, which were not predicted in the base case calculation. As the result calculated by the PSI-updated version, the core heatups were a little higher than the base case calculation result. It was due to some modifications of heat transfer coefficients

in the subcooled or saturated transition film boiling regime included in the PSI updates [6].

At 49 inch elevation, the sensitivity calculation result shows a appreciable blowdown heatup and a rewet, which was not found in the base case one. The onset of CHF at this elevation was currently understood as a deficiency of Biasi's CHF correlation in the RELAP5/MOD2. A comparison of void fraction at the 5th volume in hot channel was presented in Fig. 29. In spite that the void fraction predicted by the PSI version was lower than that calculated by cycle 36.04 version until 1.5 sec approximately, as shown in Fig.29, a heatup was found in the calculat' n by the PSI version.

From these comparisons, it is concluded that the deficiency of the Biasi's CHF correlation was re-identified at high flow rate and that the modification of rewet criteria using PSI updates can predict the rewet phenomena during blowdown phase properly

6. Run Statistics

The main frame computer used in the present calculations was CDC 170-875 Series at KAERI, with NOS Version 2.6.1.

Fig.30 presents the plot of the required CPU time for the transient time in the base case calculation. And the time step size are also plotted in Fig.31. The user-specified maximum time step was 0.05 sec up to 20 second in real time and then reduced to 0.01 sec up to 100 second as recommended in reference[1]. The run statistics is summarized in Table 5 from the major edit and the grind time can be calculated as follows.

Computer time, CPU = 1795.36 - 3.121 = 1792.239 (sec)

Number of time step, DT = 9635 - 76 = 9559

Number of volume, C = 128

Transient real time, RT = 100 (sec)

Grind time = CPU x1000/ (C * DT) = 1.4647 CPU m sec/vol/step

7. Conclusions

RELAP5/MOD2 Cycle 36.04 code was assessed using LOFT L2-3 LBLOCE data. A base case calculation was carried out using the original version of the code. And one sensitivity calculation was conducted with an updated version by the PSI modification. The calculated thermal-hydraulic behaviors were compared with the experimental data to identify code capability. As a result of the present calculations, the following conclusions are obtained :

- 1) Using LOFT LOCE L2-3, a base case calculation and a sensitivity calculation were successfully executed from the point of view of specific objectives and requirements of ICAP assessment activity.
- 2) The loop flow behaviors were fairly well predicted by the frozen RELAP5/MOD2 Cycle 36.04 code. The secondary side behavior and ECCS performance were also well simulated by the base case calculation. Hydraulic behavior such as liquid levels in downcomer and core in the reactor vessel were reasonably predicted. The thermal response of fuel rods was calculated, and the calculated PCT was 950 K, a little higher than the measured PCT of 891 K.
- 3) From the base case calculation using the frozen RELAP5/MOD2, the cold leg break flow was underpredicted due to the deficiency of the critical flow model in the transition phase from subcooled flow to two-phase flow. This led a overprediction of coolant inventory. The early core heatup during the blowdown phase was not well-predicted due to a deficiency of CHF correlation at high flow rate of the frozen code. The rewet phenomena was also poorly predicted due to the severeness of the criteria.
- 4) As a result of the sensitivity calculation using the updated rewet criteria by PSI, blowdown quenching behavior was relatively well-predicted.

References

1. Ransom, V.H. and Wagner, R.J. RELAP5/MOD2 Code Manuals, NUREG/CR-4312, EGG-2396, EG&G Idaho Inc., Dec. 1985.
2. Prassinos, P.G., et al, Experimental Data Report for LOFT Power Ascension Experiment L2-3, NUREG/CR-0792, TREE-1326, July 1979.
3. Carbajo, J.J, "A Study on the Rewetting Temperature," Nuclear Engineering and Design, Vol 84, pp 21-52, 1985.
4. Aksan, S.N., "Investigation on Rapid Cladding Cooling and Quench During the Blowdown Phase of a LBLOCA Using RELAP5/MOD2," Presentation on the Fourth International Topical Meeting on Nuclear Reactor Thermal-Hydraulics(NURETH-4), Karlsruhe, FRG, Oct. 1989
5. Driskell W.E. et al, Summary of ICAP Assessment Results for RELAP5/MOD2, Draft of ICAP Annul Report for 1989, INEL.
6. Aksan, S.N., Analytis, G.Th., and Lubbesmeyer, D., Switzerland's Code Assessment Activities in Support of the ICAP the 16th Water Reactor Safety Meeting, Oct. 1988, Gaithersburg, USA
7. Reeder, P.L., LOFT System and Test Descriptions, NUREG/CR-0247, July 1978
8. Young Seok Bang, et al, Assessment of RELAP5/MOD2 Cycle 36.04 Using LOFT Large Break Experiment L2-5, NUREG/IA (to be published), KAERI, Korea, 1990.
9. Demmie, P.N., et al, Best Estimate Prediction for LOFT Nuclear Experiment L2-3, EGG-LOFT-5869, EG&G, INEL, May 1982.

Table 1 Summary of comparison of the initial conditions
between the measured and the calculated in base case

Parameter	Measured	Calculated
• Primary Coolant System		
Mass flow rate*, kg/s	199.0	199.01
Hot leg pressure*, MPa	15.06	15.07
Cold leg temperature*, K	560.7	560.39
Hot leg temperature, K	592.9	592.75
• Reactor Vessel		
Power level, MW	36.0	36.0
Maximum linear heat generation rate(MLHGR), kW/m	39.4	39.8
• Pressurizer		
Liquid temperature, K	615.3	613.8
Pressure, MPa	15.06	15.066
Liquid level*, m	1.19	1.1723
Water volume, m ³	0.67	0.627
• Steam Generator sec.side		
Saturation temperature, K	482.1	487.88
Pressure, MPa	6.18	6.1
Mass flow rate, kg/s	19.5	19.129
Level*, m	3.11	3.11

Note * : Setpoint in steady state controllers

Table 2 Summary of comparison of the sequence of events
between the measured and the calculated in base case

Event	Measured, sec	Calculated, sec
Experiment initiated	0.	0.
End of subcooled blowdown	0.05	**
Reactor scrammed *	0.103	0.103
First indication of DNB	0.96	0.4
End of subcooled break flow (cold leg)	3.0	3.05
Maximum cladding temperature attained	4.95	5.0
Earliest corewide rewet	8.0	7.8
HPSI initiated *	14.0	14.0
Pressureizer emptied	14.0	14.0
Accumulator injection initiated	16.0	15.66
LPSI initiated *	29.0	29.0
Lower plenum refilled	35.0	35.0
Saturated blowdown ended	40.0	**
Accumulator liquid flow ended	45.0	42.0
Core volume reflooded	55.0	43.0

Note * : specified by input , ** : not predicted

Table 3. Uncertainties of Measurements

item	type	range	uncertainty
Primary system pressure	M	0.1 - 20.8 MPa	0.22 MPa
Secondary system pressure	M	0.1 - 8.4 MPa	0.11 MPa
Coolant Temperature	M	311 - 977.4 K	5.1 K
Accumulator liquid level	M	0.0 - 3 m	0.02 m
Accumulator flow rate	M	0.0 - 126.2 l/s	3.5 l/s
HPSI flow rate	M	0.0 - 1.9 l/s	0.02 l/s
LPSI flow rate	M	0.0 - 25.2 l/s	Not available
Mass flow rate at broken loop cold leg	C		63.7 kg/s
broken loop hot leg	C		23.7 kg/s
Cladding Temperature	M	422 - 1533 K	6.5 K
Primary Coolant Pump Speed	C	0.0 - 4500 RPM	8.2 RPM
Reactor Power	M	0.0 - 100 %	3.0 %

Note. M : Measured data,

C : Computed variables from the measured data

Table 4. Summary of the important items in nodalization

items	Description
Core	
Number of flow channel	2
Channel area ratio (hot/total)	13.7 %
Number of volume per channel	6
Number of crossflow junction between channels	6
Loss coefficients at crossflow junctions	4.2
Number of heat structure component (hot:average)	1:2
Power ratio (hot/total)	20.5 %
Number of volume per heat structure	6
Gap conductance model	used
Reflood option	Pressure *
Number of mesh point in heat structure	10
Number of maximum fine mesh	8
Number of volume in core bypass component	3
Core Bypass flow ratio	5 %
Downcomer	
Number of flow channel	2
Area ratio (intact side channel/broken side channel)	1/1
Number of volume per flow channel	5
Number of crossflow junctions for downcomer bypass	5
Loss coefficients at crossflow junction	18.0 - 98.0 **

Note * : Pressure at core top less than 0.1 MPa

** : Loss coefficients varies with elevation

Table 5 . Run statistics data in base case

Transient time (sec)	CPU time (sec)	Attempted ADV	Repeated ADV	Last DT	Courant DT
0	3.121	0	0	0.05	0
10	122.678	669	12	0.0125	0.01546
20	265.146	1469	12	0.0125	0.01202
25	352.17	1969	12	0.01	0.00958
30	446.903	2469	12	0.01	0.01097
35	542.424	2969	12	0.01	0.00916
40	645.349	3497	12	0.01	0.02857
45	750.017	4020	21	0.01	0.01576
50	845.089	4520	21	0.01	0.02828
55	940.003	5020	21	0.01	0.02852
60	1035.32	5520	21	0.01	0.03126
65	1130.72	6028	25	0.01	0.02552
70	1223.29	6528	25	0.01	0.03884
75	1316.72	7028	25	0.01	0.0450
80	1410.51	7528	25	0.01	0.01604
85	1504.71	8050	35	0.01	0.03274
90	1594.56	8550	35	0.01	0.04819
95	1693.06	9083	50	0.01	0.05249
100	1795.36	9635	76	0.01	0.04379




Fig. 1 Axonometric configuration of LOFT L2-3 test




Fig.2 Notalization diagram for base case calculation of LST LZ-3 test

LOFT L2-3 Base Calculation




Fig. 3

Axial power distribution in base case calculation of L2-3 test

LOFT L2-3 Base Calculation




Fig. 4 Comparison of mass flow rate in broken loop cold leg between the base case calculation and the experiment

LOFT L2-3 Base Calculation




Fig. 5

Comparison of mass flow rate at broken loop hot leg between the base case calculation and the experiment

LOFT L2-3 Base Calculation
Mass flow in intact loop cold leg




Fig. 6 Comparison of mass flow rate at intact loop cold leg between the base case calculation and the experiment

Fig. 6




Fig. 7

Comparison of net mass flow rate into the core between the base case calculation and the experiment





Fig.8 Comparison of steam dome pressure at S/G secondary side between the base case calculation and the experiment

LOFT L2-3 Base Calculation



F. 9 Comparison of accumulator injection flow rate between the base case calculation and the experiment




Fig. 10 Comparison of accumulator liquid level between the base case calculation and the experiment




Fig.11 Comparison of HPIS flow rate
between the base case calculation and the experiment

L2-3 Base calculation




Fig. 12

Comparison of LPSI flow rate between the base case calculation and the experiment




Fig. 13 Comparison of primary system pressure between the base case calculation and the experiment

LOFT L2-3 Base Calculation

Lower Plenum Coolant Temperature




Fig. 14 Comparison of coolant temperature in lower plenum between the base case calculation and the experiment

LOFT L2-3 Base Calculation

Collapsed Water Level in Reactor Vessel




Fig.15 Collapsed liquid levels calculated in the base case calculation for the broken side downcomer, intact side downcomer, hot core channel and average core channel of the reactor vessel

LOFT L2-3 Base Calculation

Cladding Temperature at 5 inches




Fig. 16

Comparison of cladding temperature at 5 inches of hot fuel between the base case calculation and the experiment




Fig. 17 Comparison of cladding temperature at 16.5 inches of hot fuel between the base case calculation and the experiment

LOFT L2-3 Cladding Temperature

Hot Fuel 27.5 inch




Fig. 18 Comparison of cladding temperature at 27.5 inches of hot fuel between the base case calculation and the experiment




Fig.19 Comparison of cladding temperature at 39 inches of hot fuel between the base case calculation and the experiment

LOFT L2-3 Cladding Temperature

Hot Fuel 49 inches




Fig. 20 Comparison of cladding temperature at 49.5 inches of hot fuel between the base case calculation and the experiment




Fig. 21 Comparison of cladding temperature at 60 inches of hot fuel between the base case calculation and the experiment




Fig. 22 Wall heat transfer coefficients calculated in the base case calculation at volume 2 and 3 of hot fuel

L2-3 Base Calculation




Fig.23 Liquid fractions calculated in the base case calculation
at volume 2 and 3 of hot fuel

LOFT L2-3 Base Calculation

Flow Regime 'n' Hot Core Vol 2, 3




Fig.24 Flow regimes predicted in the base case calculation
at volume 2 and 3 cf hot core channel




Fig. 25

Comparison of cladding temperature at 16.5 inches of hot fuel between the base case calculation and the sensitivity calculation

LOFT L2-3 Cladding Temperature

Hot Fuel 27.5 inch




Fig. 26

Comparison of cladding temperature at 27.5 inches of hot fuel between the base case calculation and the sensitivity calculation




Fig.27 Comparison of cladding temperature at 39 inches of hot fuel between the base case calculation and the sensitivity calculation

LOFT L2-3 Cladding Temperature

Hot Fuel 49 inches




Fig. 28

Comparison of cladding temperature at 49.5 inches of hot fuel between the base case calculation and the sensitivity calculation




Fig. 29 Comparison of void fraction at volume 5 of hot core channel
between the base case calculation and the sensitivity calculation

LOFT L2-3 Base Calculation




Fig. 30 The required CPU time versus the advanced time in the base case calculation

LOFT L2-3 Base Calculation




Fig.31 Time step size of base case calculation

Appendix A. Update List for RELAP5/MOD2 Cycle 36.04

APPENDIX A Update list for RELAP5/MOD3 Cycle 36.04

```
/JOB  
RM3648,T200.  
/USER  
ATTACH,OLDPL=REL364S.  
PURGE,RE364BS/NA.  
PURGE,RE364BX/NA.  
PURGE,RE364BL/NA.  
* *****  
* IMPORTANT !!  
* THE UPDATE DIRECTIVE  
* SHOULD HAVE *COMPILE DEFINE  
* AS THE FIRST DIERECTIVE  
*****  
UPDATE,N=RE364BS,  
UPDATE,P=RE364BS,Q,L=R5SEG,  
REPLACE,R5SEG.  
RETURN,OLDPL.  
*DEFINE,RE364BS.  
RETURN,RE364BS.  
ATTACH,ENVRLX=ENVRL41X  
LIBRARY,ENVRLX.  
SELECTA,COMPILE,COMP.  
LIBRARY.  
RETURN,ENVRLX.  
REWIND,COMP.  
FTN5,I=COMP,DO,ET,STATIC,OPT=Z,ROUND,LO=M/A/B/S,L=0.  
RETURN,COMP.  
REWIND,LOO.  
ATTACH,RELAP5I=REL364L.  
GTR,RELAP5I,ADD,REL/*  
*DEFINE,RELAP50=RE364BL.  
LIBEDIT,P=RELAP50,I=0,B=ADD,LO=F,U,C.  
LIBFDIT,P=RELAP50,B=LGO,I=0,LO=F,U,C.  
RETURN,NULL,LGO,RELAP5I.  
RETURN,RLP5F1,RLP5F2.  
ATTACH,ENVRL=ENVRL41L.  
FILE,RSTIN,RT=S,SBF=NO,USE,F0=SQ.  
RFL,EC=200.  
DEFINE,RE364BX.  
SEGLOAD,I=R5SEG,B=RE364BX.  
LDSET,LIB=RELAP50/ENVRL.  
LDSET,PRESETA=NGINDEF,ERR=NONE,MAP=SB.  
LDSET,STAT=RSTIN.  
LIBLOAD,ENVRL,$HDR=$.  
LIBLOAD,FTN5LIB,$FERCAP.$,$RPVCAP.$,$FTNRP2.$,$Q2NTRY.$.  
NOGO.  
PERMIT,RE364BX,KA41202.  
RETURN,RELAP50,ENVRL,COMPILE.  
SKIP,KKK.  
EXIT.  
ENDIF,KKK.  
DAYFILE,KMRRDAY.  
REPLACE,KMRRDAY.  
/EOR  
*COMPILE DEFINE  
*ID CBD3604  
*D DMK3601.484
```

```

*D PLOTNO,24
 0/1 FORMAT ('OP' OTEL SCRATCH FILE GENERATED.')
*COMPILE DEFINE,SEGDIR
*COMPILE RELAPS
*D RJK3603,23
  DATA PTITLE "RELAPS/2/3", "6.04-NSC", "REACTOR LO", "SS OF COOL",
*/
*/
*ENDIF
*/* ID KWU01 ALREADY IMPLEMENTED IN RELAP5OLDPL3604C,
*/* WHICH IS USED AS BASIS
*/* +/- CORRECTIONS OF INDEX IN SUBROUTINE RACUM
*/* I RACUM,618
*/* IEIV=1
*/* #B DMK3602,581
*/* I=IEIV
*COMPILE DEFINE,SEGDIR,RACUM
*D KWU01
*I RACUM,618
IEIV=1
*B DMK3602,581
I=IEIV
*/ /* END OF KWU-UPDATES TO CYCLE 3604
*COMPILE DEFINE,SEGDIR
*I IDENT SK101
*/* THESE UPDATES ARE RECOMMENDED BY SK1 TO BE
*/* IMPLEMENTED IN RELAPS/MOD2-36.04
*/* SOURCE: LETTER FROM STUDSVIK (MR.SANDERVAG)
*/* TO KWU (MR.GRUBEK)
*/* 1987-06-25
*/
*/
*/* COMPILE RELAPS
*/
*/
*COMPILE INTCMP
*/
*/
*/* FIX AN INDEXING ERROR IN INTCMP
*/* ERROR CAUSED ROD PLENUM VOLUME FOR GAP-GAS PRESSURE CALCULATION
*/* TO BE INCORRECT. FOUND AND FIXED BY J.CARAKER 20MAY87
*/* FIX ONLY CDC-VERSION CODING
*D INTCMP,1041
L=(.NOT.MASK(43).AND.IHTPTR(1))+FILENDX(8)
*/
*/
*/* UPDATE ROUTINE IRFLHT TO ALLOW REFLOOD TO WORK
*/* HEAT STRUCTURE FILE GETS CHANGED ON RESTART (FOR
*/* EXAMBLE BY DELETING OR ALTERING SOME STRUCTURES)
*/* NOTE: HEAT STRS ASSOCIATED WITH REFLOOD CANNOT BE ALTERED
*/* ON RESTART AS IRFLHT IS NOW PROGRAMMED
*/
*/
*COMPILE IRFLHT
*I IRFLHT,330
C UPDATE THE GEOMETRY POINTER IN IGLRFL BITS 44-60 IN CASE P.E.
C HEAT STRUCTURE FILE CHANGED ON RESTART.
J=(.NOT.MASK(43).AND.IH3+IHT
J=(.NOT.MASK(43).AND.IHTPTR(J))+IHT
NCOSS=.NOT.MASK(43).AND.INXGOM(J)
IGLRFL(1)=(MASK(43).AND.IGLRFL(1)).OR.NCOSS
*/
*/
*/* END OF UPDATES SK101
*/
*/
/END
*COMPILE SEGDIR

```

Appendix B. A Base Case Input Deck for a Steady State Calculation

* PRESSURIZER CONNECTION TEE STEAM GENERATOR SIDE						
1100C00	"PZR T SGS"	BRANCH				
1100001	1	0				
1100101	0.0606063	0.9207292	0.0	0.0	0.0	0.0
1100102	4.0E-5	0.0	00			
1100200	0	15005300.	1410030.	2459800.	.00000000	
1101101	110010000	112000000	0.0	0.15	0.15	0000
1101201	5.1146000	5.1146000	0.0			
* HOT LEG PIPING						
1120000	"HOT LEG PP"	PIPE				
1120001	2					
1120101	0.0	2				
1120201	0.0	1				
1120301	1.38893	1				
1120302	0.707687	2				
1120401	0.0796973	1				
1120402	0.0579614	2				
1120501	0.0	2				
1120601	0.0	1				
1120602	90.0	2				
1120701	0.0	1				
1120702	0.246447	2				
1120801	4.0E-5	0.0	2			
1120901	0.20	0.20	1			
1121001	00	2				
1121101	0000	1				
1121201	0	15002900.	1410030.	2459870.	.00000000	0.0
1121202	0	15005500.	1410030.	2459770.	.00000000	0.0
1121300	0					
1121301	5.1146000	5.1146000	0.0	01		
* SG INLET PLENUM						
1140000	"SG IN PLNM"	BRANCH				
1140001	2	0				
1140101	0.0	0.629795	0.33532	0.0	90.0	0.512756
1140102	4.E-5	0.0102	00			
1140200	0	14987200.	1410020.	2460000.	.00000000	
1141101	112010000	114000000	0.0512	0.0	0.0	0100
1142101	114010000	115000000	0.0	0.0	0.0	0100
1141201	3.5832000	3.5832000	0.0			
1142201	1.9414000	1.9414000	0.0			
* SG U-TUBES						
1150000	"SG TUBES "	PIPE				
1150001	8					
1150101	0.0	8				
1150201	0.151171	7				
1150301	0.902	1				
1150302	0.6096	3				
1150303	0.462908	5				
1150304	0.6096	7				
1150305	0.902	5				
1150401	0.136356	1				
1150402	0.0921538	3				
1150403	0.0699783	5				

1150404	0.0921538	7					
1150405	0.136356	8					
1150501	0.0	8					
1150601	90.0	4					
1150602	-90.0	8					
1150701	0.902	1					
1150702	0.6096	3					
1150703	0.299572	4					
1150704	-0.299572	5					
1150705	-0.6096	7					
1150706	-0.902	8					
1150801	1.27-7	0.01022	8				
1150901	0.0	0.0	7				
1151001	00	8					
1151101	0000	7					
1151201	0	14979600.	1367230.	2460010.0	.00000000	0.0	01
1151202	0	14972800.	1333400.	2460020.0	.00000000	0.0	02
1151203	0	14967300.	1306120.	2460030.0	.00000000	0.0	03
1151204	0	14962900.	1288520.	2460040.0	.00000000	0.0	04
1151205	0	14962000.	1273520.	2460050.0	.00000000	0.0	05
1151206	0	14964300.	1257470.	2460042.0	.00000000	0.0	06
1151207	0	14967600.	1244800.	2460030.0	.00000000	0.0	07
1151208	0	14971800.	1233820.	2460020.0	.00000000	0.0	08
1151300	0						
1151301	1.8921000	1.8921000	0.0	01			
1151302	1.8565000	1.8565000	0.0	02			
1151303	1.8299000	1.8299000	0.0	03			
1151304	1.8134000	1.8134000	0.0	04			
1151305	1.7997000	1.7997000	0.0	05			
1151306	1.7856000	1.7856000	0.0	06			
1151307	1.7746000	1.7746000	0.0	07			
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
* SG OUTLET PLENUM							
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
1160000	"SG OUT PLN"		BRANCH				
1160001	2	0					
1160101	0.0	0.629795	0.33532	0.0	-90.0	-0.512756	
1160102	4.E-5	0.0102	00				
1160200	0	14976400.	1233810.	2460100.	.00000000		
1161101	115010000	116000000	0.0	0.0	0.0	0100	
1162101	116010000	118000000	0.0512	0.0	0.0	0100	
1161201	1.7656000	1.7656000	0.0				
1162201	3.2740000	3.2740000	0.0				
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
* PUMP SUCTION PIPING							
*-----	1-----	1-----	1-----	1-----	1-----	1-----	1-----
1180000	"PMP SUC PP"		PIPE				
1180001	3						
1180101	0.0	3					
1180201	0.0	2					
1180301	0.546638	1					
1180302	0.688596	2					
1180303	0.558577	3					
1180401	0.0445625	1					
1180402	0.0445137	2					
1180403	0.0354278	3					
1180501	0.0	3					
1180601	-90.0	3					
1180701	-0.498052	1					
1180702	-0.688596	2					
1180703	-0.355604	3					

1180801 4.E-5 0.0 3
 1180901 0.083 0.083 1
 1180902 0.104 0.104 2
 1181001 00 3
 1181101 0000 2
 1181201 0 14965800. 1233810. 2460030.0 .00000000 0.0 01
 1181202 0 14967700. 1233810. 2460033.0 .00000000 0.0 02
 1181203 0 14970500. 1233810. 2460035.0 .00000000 0.0 03
 1181300 0
 1181301 4.1288000 4.1288000 0.0 01
 1181302 4.2081000 4.2081000 0.0 02
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PUMP SUCTION TEE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 1200000 "PMP SCT T" BRANCH
 1200001 3 0
 1200101 0.0 0.759614 0.0487901 0.0 0.0 0.0
 1200102 4.0E-5 0.0 00
 1200200 0 14974000. 1233810. 2460020. .00000000
 1201101 118010000 120000000 0.063427 0.0 0.0 0000
 1202101 120010000 125000000 0.063427 1.075 1.25 0000
 1203101 120010000 155000000 0.063427 1.075 1.25 0000
 1201201 4.2080000 4.2080000 0.0
 1202201 1.9967000 1.9967000 0.0
 1203201 2.2113000 2.2113000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PUMP1 SUCTION TEE OUTLET
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 1250000 "PMP1 SCT T" BRANCH
 1250001 1 0
 1250101 0.0 1.00308 0.0640548 0.0 90.0 0.520704
 1250102 4.0E-5 0.0 00
 1250200 0 14974500. 1233810. 2460022. .00000000
 1251101 125010000 130000000 0.0 0.13 0.13 0000
 1251201 3.2631000 3.2631000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PUMP 1 INLET
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 1300000 "PMP1 INLET" SNGLVOL
 1300101 0.0 0.457201 0.0177444 0.0 90.0 0.457201
 1300102 4.0E-5 0.0 00
 1300200 0 14968300. 1233810. 2460030. .00000000
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRIMARY COOLANT PUMP 1
 *-----1-----1-----1-----1-----1-----1-----1-----
 1350000 "PCPUMP1" PUMP
 1350101 0.0 0.4572 0.0991 0.0 90.0 0.317900
 1350102 0
 1350103 130010000 0.0 0.017 0.017 0000
 1350109 140000000 0.0 0.05 0.05 0000
 1350200 0 15010900. 1233820. 2459500. .00000000
 1350201 0 3.2631000 3.2631000 0.0
 1350202 0 3.4591000 3.4591000 0.0
 1350301 0 0 0 -1 -1 0 0
 1350302 369.00000 .35501355 .31550000 96.000000 500.60000 1.4310000
 1350303 613.60000 .00000000 207.43300 .04440000 19.598700 .00000000
 1350310 0.0 0.0 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * PUMP 1 OUTLFT PUMP SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----
 1400000 "PMP1 OUT P" SNGLVOL

7000401 0.0 1
 7000501 0.0 1
 7000601 90.0 1
 7000801 3.81-6 0.172 1
 7001001 00 1
 7001201 0 15028400. 1233830. 2459250. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - UPPER TO LOWER INLET ANNULUS INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7010000 "INANMUINT" SNGLJUN
 7010101 730000000 700000000 0.129467 0.0000 0.0000 0100
 7010201 0 .34062000 .34062000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * INLET ANNULUS MIDDLE VOLUME INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7300000 "INANMIDINT" ANNULUS
 7300001 1
 7300101 0.1308530 1
 7300301 0.2851823 1
 7300401 0.0 1
 7300501 0.0 1
 7300601 -90.0 1
 7300801 3.81-6 0.172 1
 7301001 00 1
 7301201 0 15028400. 1233830. 2459250. 0.0 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - MIDDLE TO LOWER INLET ANNULUS INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7310000 "INANMLINT" SNGLJUN
 7310101 730010000 702000000 0.0709408 0.0 0.0 0100
 7310201 0 1.5959 1.5959 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * INLET ANNULUS LOWER VOLUME INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7020000 "INANLWRINT" ANNULUS
 7020001 1
 7020101 0.1464354 1
 7020301 0.2525361 1
 7020401 0.0 1
 7020501 0.0 1
 7020601 -90.0 1
 7020801 3.81-6 0.172 1
 7021001 00 1
 7021201 0 15030600. 1233830. 2459300. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - INLET ANNULUS TO DOWNCOMER INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7030000 "INAN2DCINT" SNGLJUN
 7030101 702010000 704000000 0.0709408 0.0000 0.0000 0100
 7030201 0 1.5959000 1.5359000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * DOWNCOMER UPPER VOLUME INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7040000 "DNCRUPRINT" ANNULUS
 7040001 1
 7040101 0.0 1
 7040301 1.5200561 1
 7040401 0.1581866 1
 7040501 0.0 1
 7040601 -90.0 1
 7040801 3.81-6 0.102 1

7041001 00 1
 7041201 0 15036100. 1233810. 2459350. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - UPPER TO MIDDLE DOWNCOMER INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7050000 "UPR2MIDINT" SNGLJUN
 7050101 704010000 706000000 0.0709408 0.0000 0.0000 0100
 7050201 0 1.5106000 1.5106000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * DOWNCOMER MIDDLE VOLUME INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7060000 "DNCRMIDINT" ANNULUS
 7060001 1
 7060101 0.0 1
 7060301 1.2616333 1
 7060401 0.1217000 1
 7060501 0.0 1
 7060601 -90.0 1
 7060801 3.81-6 0.102 1
 7061001 00 1
 7061201 0 15045800. 1233800. 2459500. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - MIDDLE TO LOWER DOWNCOMER INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7070000 "MID2LWRINT" SNGLJUN
 7070101 706010000 708000000 0.0709408 0.0000 0.0000 0100
 7070201 0 1.4821000 1.4821000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * DOWNCOMER LOWER VOLUME INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7080000 "DNCRLWRINT" ANNULUS
 7080001 1
 7080101 0.0 1
 7080301 1.0792591 1
 7080401 0.0986806 1
 7080501 0.0 1
 7080601 -90.0 1
 7080801 3.81-6 0.102 1
 7081001 00 1
 7081201 0 15054000. 1233790. 2458600. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - LOWER DOWNCOMER TO LOWER PLENUM INTACT SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7090000 "1PDC2LPINT" SNGLJUN
 7090101 706010000 215000000 0.0709408 0.0000 0.0000 0100
 7090201 0 1.4104000 1.4104000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * INLET ANNULUS UPPER VOLUME BROKEN SIDE
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 7100000 "JNANUPRBKN" ANNULUS
 7100001 1
 7100101 0.1308530 1
 7100301 0.1876129 1
 7100401 0.0 1
 7100501 0.0 1
 7100601 90.0 1
 7100801 3.81-6 0.172 1
 7101001 00 1
 7101201 0 15027200. 1233830. 2459250. .00000000 0.0 01
 *-----1-----1-----1-----1-----1-----1-----1-----1-----1-----1-----
 * JUNCTION - MIDDLE TO UPPER INLET ANNULUS BROKEN SIDE

7260201 0 10572000 10572000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * CROSSFLOW JUNCTION - LOWER DOWNCOMER
 *-----1-----1-----1-----1-----1-----1-----1-----
 7280000 "LWRDNCMRXP" SNGLJUN
 7280101 708000000 718000000 0.03 98.0 18.0 0003
 7280201 0 .07171910 .07171910 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * LOWER PLENUM TOP VOLUME
 *-----1-----1-----1-----1-----1-----1-----1-----
 2156000 "LWR PL TOP" BRANCH
 2150001 2 0
 2150101 0.0 0.3533183 0.2592277 0.0 -90.0 -0.3533183
 2150102 3.81-6 0.0 00
 2150200 0 15059400. 1233780. 2458550. .00000000
 2151101 215010000 220000000 0.0 0.005 0.005 0000
 2152101 215000000 225000000 0.1499 1.5 1.5 0000
 2151201 .571898-5 .571894-5 0.0
 2152201 1.7076000 1.7076000 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * LOWER PLENUM BOTTOM VOLUME
 *-----1-----1-----1-----1-----1-----1-----1-----
 2200000 "LWR PL BOT" SNGLVOL
 2200101 0.0 0.3741720 0.29656 0.0 -90.0 -0.3741720
 2200102 4.0E-5 0.0 00
 2200200 0 15062100. 1233780. 2458500. .00000000
 *-----1-----1-----1-----1-----1-----1-----1-----
 * LOWER CORE SUPPORT STRUCTURE
 *-----1-----1-----1-----1-----1-----1-----1-----
 2250000 "L CORE SUP" BRANCH
 *2250001 2 0
 2250001 3 0
 2250101 0.2832456 0.5709989 0.0 0.0 90.0 0.5709989
 2250102 3.81-6 0.095 00
 2250200 0 14970400. 1230690. 2460590. 0.0
 2251101 225010000 011000000 0.09790318 1.5 1.5 00100
 2252101 225010000 021000000 0.01549682 1.5 1.5 00100
 2253101 225010000 235000000 0.0 12.0 12.0 00100
 2251201 2.0569000 2.0569000 0.0
 2252201 2.0569000 2.0569000 0.0
 2253201 0.0602599 0.15501 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * PERIPHERAL CORE VOLUME 1
 *-----1-----1-----1-----1-----1-----1-----1-----
 0110000 "PERI#1" BRANCH
 0110001 2 0
 0110101 0.1582181 0.279404 0.0 0.0 90.0 0.279404
 0110102 1.27-7 0.0 00
 0110200 0 14965200. 1241610. 2460710. 0.0
 0111101 011010000 012000000 0. 0.0 0.0 00100
 0112101 011000000 021000000 0.239275 4.69 4.69 00003
 0111201 1.3752 1.3752 0.0
 0112201 0.0 0.0 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----
 * PERIPHERAL CORE VOLUME 2
 *-----1-----1-----1-----1-----1-----1-----1-----
 0120000 "PERI#1" BRANCH
 0120001 2 0
 0120101 0.1462431 0.279404 0.0 0.0 90.0 0.279404
 0120102 1.27-7 0.0 00
 0120200 0 14965200. 1241610. 2460710. 0.0

0121101	012010000	013000000	0.122946	0.66	0.66	00100
0122101	012000000	022000000	0.239275	4.69	4.69	00003
0121201	1.3752	1.3752	0.0			
0122201	0.0	0.0	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-
* PERIPHERAL CORE VOLUME 3						
*	-1-	-1-	-1-	-1-	-1-	-1-
0130000	"PERI#1"	BRANCH				
0130001	2	0				
0130101	0.1479421	0.279404	0.0	0.0	90.0	0.279404
0130102	1.27-7	0.0	00			
0130200	0	14965200.	1241610.	2460710.	0.0	
0131101	013010000	014000000	0.	0.0	0.0	00100
0132101	013000000	023000000	0.239275	4.69	4.69	00003
0131201	1.3752	1.3752	0.0			
0132201	0.0	0.0	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-
* PERIPHERAL CORE VOLUME 4						
*	-1-	-1-	-1-	-1-	-1-	-1-
0140000	"PERI#1"	BRANCH				
0140001	2	0				
0140101	0.1452617	0.279404	0.0	0.0	90.0	0.279404
0140102	1.27-7	0.0	00			
0140200	0	14965200.	1241610.	2460710.	0.0	
0141101	014010000	015000000	0.122946	0.66	0.66	00100
0142101	014000000	024000000	0.239275	4.69	4.69	00003
0141201	1.3752	1.3752	0.0			
0142201	0.0	0.0	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-
* PERIPHERAL CORE VOLUME 5						
*	-1-	-1-	-1-	-1-	-1-	-1-
0150000	"PERI#1"	BRANCH				
0150001	2	0				
0150101	0.1464111	0.279404	0.0	0.0	90.0	0.279404
0150102	1.27-7	0.0	00			
0150200	0	14965200.	1241610.	2460710.	0.0	
0151101	015010000	016000000	0.	0.0	0.0	00100
0152101	015000000	025000000	0.239275	4.69	4.69	00003
0151201	1.3752	1.3752	0.0			
0152201	0.0	0.0	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-
* PERIPHERAL CORE VOLUME 6						
*	-1-	-1-	-1-	-1-	-1-	-1-
0160000	"PERI#1"	BRANCH				
0160001	1	0				
0160101	0.1510117	0.279404	0.0	0.0	90.0	0.279404
0160102	1.27-7	0.0	00			
0160200	0	14965200.	1241610.	2460710.	0.0	
0161101	016000000	026000000	0.239275	4.69	4.69	00003
0161201	0.0	0.0	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-
* CENTRAL CORE VOLUME 1						
*	-1-	-1-	-1-	-1-	-1-	-1-
0210000	"CENT#1"	BRANCH				
0210001	1	0				
0210101	0.0250439	0.279404	0.0	0.0	90.0	0.279404
0210102	1.27-7	0.0	00			
0210200	0	14965200.	1241610.	2460710.	0.0	
0211101	021010000	022000000	0.0	0.0	0.0	00100
0211201	1.3752	1.3752	0.0			
*	-1-	-1-	-1-	-1-	-1-	-1-

2350801	3.81-6	0.003	3				
2350901	0.0	0.0	2				
2351001	00	3					
2351101	0000	2					
2351201	0	15048000.	1233790.	2459550.0	.00000000	0.0	01
2351202	0	15042400.	1233790.	2459550.0	.00000000	0.0	02
2351203	0	15036500.	1233790.	2459550.0	.00000000	0.0	03
2351300	0						
2351301	.71258000	.71258000	0.0	01			
2351302	.73579000	.73579000	0.0	02			
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* UPPER END BOXES AND SUPPORT STRUCTURE							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
2400000	"UPR END BX"		BRANCH				
2400001	2	0					
2400101	0.2423341	0.5867979	0.0	0.0	90.0	0.5867979	
2400102	3.81-6	0.145	00				
2400200	0	14946300.	1422480.	2461120.	1.37821-3		
2401101	016010000	240000000	0.122945736	1.5	1.5	00100	
2402101	235010000	240000000	0.0	12.	12.	00100	
2401201	.67053000	.87895000	0.0				
2402201	.67053000	.87895000	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* UPPER CORE SUPPORT STRUCTURE - CROSS FLOW REGION							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
2450000	"UPR CR SUP"		BRANCH				
2450001	2	0					
2450101	0.0	0.4933248	0.1280806	0.0	90.0	0.4933248	
2450102	3.81-6	0.145	00				
2450200	0	15025400.	1417510.	2459600.	.00000000		
2451101	240010000	245000000	0.0	0.0	0.0	0000	
2452101	245010000	251000000	0.0	0.0	0.0	0000	
2451201	1.1669000	1.1669000	0.0				
2452201	.439867-4	.439867-4	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* UPPER FLOW SKIRT REGION							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
2500000	"U FLW SKRT"		BRANCH				
2500001	1	0					
2500101	0.1547532	0.7850547	0.6	0.0	90.0	0.7850547	
2500102	3.81-6	0.131	00				
2500200	0	15020100.	1410020.	2459600.	.00000000		
2501101	245010000	250000000	0.0	0.0	0.0	0000	
2501201	1.8273000	1.8273000	0.0				
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* DEAD END OF FUEL MODULES							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
2510000	"DE FL MODS"		SNGLVOL				
2510101	0.0	0.7844123	0.1154214	0.0	90.0	0.7844123	
2510102	3.81-6	0.214	00				
2510200	0	15021500.	1424270.	2459600.	.00000000		
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
* UPPER HEAD							
*-----1-----1-----1-----1-----1-----1-----1-----1-----							
2520000	"UPR HEAD "		BRANCH				
2520001	2	0					
2520101	0.2622585	0.2869580	0.0	0.0	90.0	0.2869580	
2520102	3.81-6	0.0	00				
2520200	0	15019000.	1410020.	2459550.	.00000000		
2521101	250010000	252000000	0.0	0.006	0.006	0000	
2522101	730000000	252000000	0.0	0.90+4	0.90+4	0003	

3150000	"SG+PMP SIM"		PIPE				
3150001	8						
3150101	0.0	8					
3150201	8.3647-3	1					
3150202	1.12-2	2					
3150203	0.105626	3					
3150204	1.12-2	4					
3150205	8.3647-3	7					
3150301	0.919969	1					
3150302	1.987956	2					
3150303	0.849744	4					
3150304	1.987956	5					
3150305	1.371350	6					
3150306	1.365029	7					
3150307	1.674812	8					
3150401	7.75291-3	1					
3150402	0.1721108	2					
3150403	8.97552-2	4					
3150404	0.1721108	5					
3150405	1.82303-2	6					
3150406	5.46687-2	7					
3150407	1.82489-2	8					
3150601	90.0	3					
3150602	-90.0	7					
3150603	90.0	8					
3150701	0.679201	1					
3150702	1.987956	2					
3150703	0.457202	3					
3150704	0.457203	4					
3150705	-1.987956	5					
3150707	-1.371350	6					
3150708	-0.520701	7					
3150709	1.212851	8					
3150801	4.0E-5	0.0	8				
3150901	0.93596	0.93596	1				
3150902	2.0	2.0	2				
3150903	0.5	0.5	3				
3150904	2.0	2.0	4				
3150905	0.23025	0.23025	5				
3150906	2.534	2.534	6				
3150907	5.069	5.069	7				
3151001	00	8					
3151101	0000	7					
3151201	0	15015600.	1243880.	2459924.	.00000000	0.0	01
3151202	0	15005700.	1237630.	2459924.	.00000000	0.0	02
3151203	0	14996600.	1237670.	2459924.	.00000000	0.0	03
3151204	0	14996600.	1237680.	2459924.	.00000000	0.0	04
3151205	0	15005600.	1237680.	2459924.	.00000000	0.0	05
3151206	0	15018100.	1237680.	2459924.	.00000000	0.0	06
3151207	0	15025100.	1237680.	2459924.	.00000000	0.0	07
3151208	0	15022500.	1237680.	2459924.	.00000000	0.0	08
3151300	0						
3151301	.910345-3	.910345-3	0.0	01			
3151302	.487913-3	.487915-3	0.0	02			
3151303	.411825-4	.411825-4	0.0	03			
3151304	.289111-3	.289109-3	0.0	04			
3151305	.133199-3	.133198-3	0.0	05			
3151306	.106449-3	.106449-3	0.0	06			
3151307	.266103-4	.266103-4	0.0	07			

* HOT LEG BREAK VALVE

3170000	"HL_BREAK "	VALVE						
3170101	315010000	800000000	8.3647-3	0.94883	0.94883	0100		
3170102	0.93	0.84						
3170201	0	.00000000	.00000000	0.0				
3170300	TRPVLV							
3170301	501							

* REACTOR VESSEL NOZZLE BROKEN LOOP COLD LEG

3350000	"RVN_BLCL "	BRANCH						
3350001	2	0						
3350101	0.0	0.749305	0.047979	0.0	0.0	0.0		
3350102	4.0E-5	0.0	00					
3350200	0	15028400.	1233660.	2459250.	.00000000			
3351101	740000000	335000000	0.064130	1.455594	0.812933	0002		
3352101	335010000	340000000	0.063426	0.1005	0.1005	0000		
3351201	.06071680	.06071680	0.0					
3352201	.06138070	.06138070	0.0					

* COLD LEG PIPE TO REFLOOD ASSIST BYPASS TEE

3400000	"CLP-RABS_T"	BRANCH						
3400001	1	0						
3400101	0.0	0.698336	0.0443927	0.0	0.0	0.0		
3400102	4.0E-5	0.0	00					
3400200	0	15028400.	1233140.	2459250.	.00000000			
3401101	340010000	342000000	0.063426	0.1005	0.1005	0000		
3401201	.06137130	.06137130	0.0					

* BROKEN LOOP COLD LEG RABS TO DTT

3420600	"BLCL_2DTT "	BRANCH						
3420001	1	0						
3420101	0.0	0.5715069	0.0362484	0.0	0.0	0.0		
3420102	4.0E-5	0.0	00					
3420200	0	15028400.	1232540.	2459250.	.00000000			
3421101	342000000	370000000	0.0388	0.84	0.84	0000		
3421201	.10030000	.10030000	0.0					

* BROKEN LOOP COLD LEG DTT TO BREAK PLANE

3440000	"BLCL_2BRK "	BRANCH						
3440001	1	0						
3440101	0.0	0.9286231	0.0310679	0.0	0.0	0.0		
3440102	4.0E-5	0.0	00					
3440200	0	15028400.	1232300.	2459250.	.00000000			
3441101	342010000	344000000	0.0540157	0.545	14.05	0000		
3441201	.759199-5	.759199-5	0.0					

* COLD LEG BREAK VALVE

3470000	"CL_BREAK "	VALVE						
3470101	344010000	805000000	8.3647-3	0.415	0.415	0100		
3470102	0.93	0.84						
3470201	0	.00000000	.00000000	0.0				
3470300	TRPVLV							
3470301	501							

* REFLOOD ASSIST BYPASS PIPING - COLD LEG SIDE

3700000	"RABS C L "		PIPE			
3700001	3					
3700101	0.0388	2				
3700102	0.0776	3				
3700201	0.0388	2				
3700301	0.0	3				
3700401	0.0279	1				
3700402	0.070	2				
3700403	0.1165	3				
3700601	90.0	1				
3700602	0.0	3				
3700701	0.64	1				
3700702	0.0	3				
3700801	4.0-5	0.0	3			
3700901	0.28	0.28	1			
3700902	0.84	0.84	2			
3701001	00	3				
3701101	0000	2				
3701201	0	15026000.	1232040.	2459300.	.00000000	0.0
3701202	0	15023600.	1231420.	2459300.	.00000000	0.0
3701203	0	15023600.	1231430.	2459300.	.00000000	0.0
3701300	0					03
3701301	.10029000	.10029000	0.0	01		
3701302	.10027000	.10027000	0.0	02		
* REFLOOD ASSIST BYPASS VALVES						
3750000	"RABS VALVS"		SNGLJUN			
3750101	370010000	380000000	0.0	0.90+4	0.90+4	0000
3750201	0	.05011390	.05011390	0.0		
* REFLOOD ASSIST BYPASS PIPING - HOT LEG SIDE						
3800000	"RABS H L "		PIPE			
3800001	3					
3800101	0.0776	1				
3800102	0.0388	3				
3800201	0.0388	2				
3800301	0.0	3				
3800401	0.0915	1				
3800402	0.048	2				
3800403	0.0489	3				
3800601	0.0	1				
3800602	-90.0	2				
3800603	0.0	3				
3800701	0.0	1				
3800702	-0.64	2				
3800703	0.0	3				
3800801	4.0-5	0.0	3			
3800901	0.84	0.84	1			
3800902	0.28	0.28	2			
3801001	00	3				
3801101	0000	2				
3801201	0	15013400.	1231640.	2459400.	.00000000	0.0
3801202	0	15015700.	1231730.	2459400.	.00000000	0.0
3801203	0	15018100.	1231820.	2459400.	.00000000	0.0
3801300	0					03
3801301	.10020000	.10020000	0.0	01		
3801302	.10018000	.10018000	0.0	02		

\$

4150801	4.0E-5	0.0	6				
4151001	00	6					
4151101	0000	5					
4151201	0	15009100.	1586220.	2459600.	.00000000	0.0	01
4151202	0	15008000.	1586220.	2459600.	.00000000	0.0	02
4151203	0	15006300.	1585220.	2459600.	.00000000	0.0	03
4151204	0	15003800.	1586220.	2460000.	.03846070	0.0	04
4151205	0	15002300.	1586220.	2466560.	1.0000000	0.0	05
4151206	6	15002000.	1586220.	2468160.	1.0000000	0.0	06
4151300	0						
4151301	-.23340-3	-.23340-3	0.0	01			
4151302	-.15968-3	-.15968-3	0.0	02			
4151303	-.19217-3	.36250000	0.0	03			
4151304	-.4272500	-.48004-4	0.0	04			
4151305	-.23263-4	-.23263-4	0.0	05			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* PRESSURIZER VESSEL TO TOP HAT							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
4170000	"VSSL-TPHAT"	SNGLJUN					
4170101	415010000	420000000	0.0	0.0	0.0	0000	
4170201	0	-.21090-4	-.21090-4	0.0			
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* PRESSURIZER TOP HAT AND RELIEF CONNECTION							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
4200000	"PZR TOPHAT"	PIPE					
4200001	2						
4200101	0.0	2					
4200201	0.0	1					
4200301	0.1104915	2					
4200401	0.0139870	2					
4200601	90.0	2					
4200801	4.E-5	0.346066	2				
4201001	00	2					
4201101	6000	1					
4201201	0	15001900.	1509900.	2482590.	1.0000000	0.0	01
4201202	0	15001800.	1509900.	2484800.	1.0000900	0.0	02
4201300	0						
4201301	-.11442-4	-.11442-4	0.0	01			
\$							
*							
* STEAM GENERATOR SECONDARY SIDE							
*							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* PRIMARY SEPARATOR							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
5000000	"SEPARATOR "	SEPARATR					
5000001	3	0					
5000101	0.0	0.4445	0.2425	0.0	90.0	0.4445	
5000102	4.E-5	0.2840	00				
5000200	0	3828810.0	1145280.	2580000.	.49664000		
5001101	500010000	520000000	0.087745	0.0	0.0	0100	
5002101	500000000	505000000	0.087745	0.0	0.0	0100	
5003101	515010000	500000000	0.29187	0.4	0.4	0100	
5001201	.30829000	1.0170000	0.0				
5002201	1.1801000	.17265000	0.0				
5003201	2.4900000	2.4900000	0.0				
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
* SEPARATOR BYPASS							
*	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	
5030000	"SEPBYPASS "	BRANCH					
5030001	2	0					

*-----1-----1-----1-----1-----1-----1-----1-----1

* ACCUMULATOR VALVE
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6100000 "ACCUM VLV " VALVE
 6100101 615010000 605000000 5.9896-3 6.278 6.278 1000
 6100201 3 -.4902-15 .79206-11 0.0
 6100300 TRPVLV
 6100301 682
 *-----1-----1-----1-----1-----1-----1-----1-----1

* ACCUMULATOR PIPE
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6150000 "ACC PIPE " SNGLVAL
 6150101 0.0 25.997165 0.4074774 0.0 0.0 0.0
 6150102 4.0-5 0.0 00
 6150200 0 4.5E+6 112409. 2459920. 00000000
 *-----1-----1-----1-----1-----1-----1-----1-----1

* ACCUMULATOR VESSEL
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6200000 "ACCUMULATR" ACCUM
 6200101 0.0 1.8103 2.3422 0.0 -90.0 -1.8103
 6200102 4.0-5 0.0 00
 6200200 4.180+6 305.40
 6201101 615000000 8.2132-3 40.0 40.0 0
 6202200 0.0 1.0662 2.4509 1.6927 0.04445 0 0 0 0
 *-----1-----1-----1-----1-----1-----1-----1-----1

* BWST LPIS
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6250000 "BWST LPIS " TMDPVOL
 6250101 20.44 5.0 0.0 0.0 90.0 5.0
 6250102 4.0E-5 0.0 00
 6250200 3
 6250201 0.0 1.0+5 300.0
 *-----1-----1-----1-----1-----1-----1-----1-----1

* LOW PRESSURE INJECTION SYSTEM
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6300000 "LPIS " TMDPJUN
 6300101 625000000 605000000 5.9896-3
 6300200 1 504 P 605010000
 6300201 -1.0 0.0 0.0 0.0
 6300202 0.0 0.0 0.0 0.0
 6300203 8.483+4 7.045 0.0 0.0
 6300204 4.297+5 6.091 0.0 0.0
 6300205 7.745+5 5.045 0.0 0.0
 6300206 9.448+5 4.312 0.0 0.0
 6300207 1.119+6 3.454 0.0 0.0
 6300208 1.186+6 3.173 0.0 0.0
 6300209 1.257+6 2.673 0.0 0.0
 6300210 1.228+6 2.159 0.0 0.0
 6300211 1.395+6 1.536 0.0 0.0
 6300212 1.464+6 0.7182 0.0 0.0
 6300213 1.517+6 0.6 0.0 0.0
 *-----1-----1-----1-----1-----1-----1-----1-----1

* BWST HPIS
 *-----1-----1-----1-----1-----1-----1-----1-----1
 6350000 "BWST HPIS " TMDPVOL
 6350101 20.44 5.0 0.0 0.0 90.0 5.0
 6350102 4.0E-5 0.0 00
 6350200 3
 6350201 0.0 1.0+5 300.0
 *-----1-----1-----1-----1-----1-----1-----1-----1

* HIGH PRESSURE INJECTION SYSTEM

CONTAINMENT

REACTOR VESSEL HEAT STRUCTURES

positive score
SECTION 330 OF 363-34

HOT FUEL RODS HEAT STRUCTURE 11311

	1	1	1	1	1	1	1	1
12311000	6	10	2	1	0.0	555	1	8
12311001	7.869+6							
12311011	1.0E-6	2.0E-6	0.0	0.0	6			
12311100	0	1						
12311101	5	4.65564-3						
12311102	1	4.75106-3						
12311103	3	5.36806-3						
12311201	1	5						
12311202	-2	6						
12311203	-3	9						
12311301	1.0	5						
12311302	0.0	9						
12311401	560.0	10						
12311501	0	0	0	1	56.998416	06		
12311601	021010000	1000000	1	1	56.998416	06		
12311701	900	0.02306447	0.	0.	1			
12311702	900	0.051034	0.	0.	2			
12311703	900	0.05449747	0.	0.	3			
12311704	900	0.0414851	0.	0.	4			
12311705	900	0.02567737	0.	0.	5			
12311706	900	0.0090072	0.	0.	6			
12311901	0	0.013633	0.01504	1.6764	06			
	1	1	1	1	1	1	1	1

* AVERAGE FUEL RODS HEAT STRUCTURE :12301

	1	1	1	1	1	1	1	1
12301000	6	10	2	1	0.0	555	1	8
12301001	7.869+6							
12301011	1.0E-6	2.0E-6	0.0	0.0	6			
12301100	0	1						
12301101	5	4.65564-3						
12301102	1	4.75106-3						
12301103	3	5.36806-3						
12301201	1	5						
12301202	-2	6						
12301203	-3	9						
12301301	1.0	5						
12301302	0.0	9						
12301401	560.0	10						
12301501	0	0	0	1	159.819088	06		
12301601	011010000	1000000	1	1	159.819088	06		
12301701	900	0.036746	0.	0.	1			
12301702	900	0.0879275	0.	0.	2			
12301703	900	0.0990847	0.	0.	3			
12301704	900	0.5768387	0.	0.	4			
12301705	900	0.0491237	0.	0.	5			
12301706	900	0.0153074	0.	0.	6			
12301901	0	0.013633	0.01504	1.6764	6			
	1	1	1	1	1	1	1	1
	1	1	1	1	1	1	1	1

* INTERMEDIATE FUEL RODS HEAT STRUCTURE :12302

	1	1	1	1	1	1	1	1
12302000	6	10	2	1	0.0	555	1	8
12302001	7.869+6							
12302011	1.0E-6	2.0E-6	0.0	0.0	6			
12302100	0	1						

12302101	5	4.65564-3
12302102	1	4.75106-3
12302103	3	5.36805-3
12302201	1	5
12302202	-2	6
12302203	-3	9
12302301	1.0	5
12302302	0.0	9
12302401	560.0	20
12302501	0	0
12302601	011010000	10000000
12302701	900	0.0433049
12302702	900	0.103621287
12302703	900	0.116769857
12302704	900	0.09055324
12302705	900	0.05789154
12302706	900	0.01803428
12302901	0	0.013633
		0.01504
		1.0764

* STEAM GENERATOR HEAT STRUCTURES

* TUBING	1	1	1	1	1	1
10060200	1	1	1	1	1	1
10060100	8	8	2	1	0.0051054	
10060101	0	1				
10060101	7	0.0063403984				
10050201	6	7				
10060301	0.0	7				
10060401	560.9	8				
10060501	115010000	10000	1	1	1124.71	3
10060502	115040000	10000	1	1	849.063	5
10060503	115060000	10000	1	1	1124.71	8
10060601	515010000	10000	1	1	1124.71	3
10060602	515040000	0	1	1	849.063	4
10060603	515040000	0	1	1	849.063	5
10060604	515030000	-10000	1	1	1124.71	8
10060701	0	0	0	0	8	
10060801	0	0	0	0	8	
10060901	0	0	0	0	8	

HEAT STRUCTURE THERMAL PROPERTY DATA

0100100	TBL/FCTN	1	1	1	1	1	1
0100200	TBL/FCTN	3	1	*	U02		
0100300	TBL/FCTN	1	1	*	GAP		
0100400	TBL/FCTN	1	1	*	ZR		
				*	S-STEEL		

* ZIRCALOY-4 - VOLUMETRIC HEAT CAPACITY FROM MATPRO

20100351	300.0	1.841E6							
20100352	400.0	1.978E6							
20100353	640.0	2.168E6							
20100354	1090.0	2.456E6							
20100355	1093.0	3.288E6							
20100356	1113.0	3.865E6							
20100357	1133.0	4.028E6							
20100358	1153.0	4.709E6							
20100359	1173.0	5.345E6							
20100360	1193.0	5.044E6							
20100361	1213.0	4.054E6							
20100362	1233.0	3.072E6							
20100363	1243.0	2.332E6							
20100364	1477.0	2.332E6							
* S-STEEL - THERMAL CONDUCTIVITY									
20100401	273.15	12.98							
20100402	1199.82	25.1							
* S-STEEL - VOLUMETRIC HEAT CAPACITY									
20100451	273.15	3.83E6							
20100452	366.5	3.83E6							
20100453	477.59	4.190E6							
20100454	588.59	4.336E6							
20100455	699.82	4.504E6							
20100456	810.93	4.639E6							
20100457	922.04	4.773E6							
20100458	1144.26	5.076E6							
20100459	1366.5	5.376E6							
20100460	1477.59	5.546E6							
* INCONEL 600 - THERMAL CONDUCTIVITY									
20100601	366.5	13.85							
20100602	477.6	15.92							
20100603	588.7	18.17							
20100604	700.0	20.42							
20100605	810.9	22.50							
20100606	922.0	24.92							
20100607	1033.2	26.83							
20100608	1144.3	29.42							
20100609	1477.6	36.06							
* INCONEL 600 - VOLUMETRIC HEAT CAPACITY									
20100651	366.5	3.908E6							
20100652	477.6	4.084E6							
20100653	588.7	4.260E6							
20100654	700.0	4.436E6							
20100656	810.9	4.665E6							
20100657	922.0	4.929E6							
20100658	1033.2	5.105E6							
20100659	1477.6	5.727E6							

\$

* CONTROL VARIABLES

*

* 001-010 LEVEL CALCULATORS

* 001 STEAM GENERATOR LEVEL

	SGLVL	SUM	1.0	0.0	1
20500101	0.6	0.4445	VOIDF	503010000	
20500102		1.2131	VOIDF	505010000	
20500103		0.6096	VOIDF	508010000	
20500104		0.6096	VOIDF	510010000	
20500105		0.6096	VOIDF	510020000	
20500106		0.6096	VOIDF	510030000	

* 002 PRESSURIZER LEVEL

	PZRLVL	SUM	1.0	0.0	1
20500201	0.0	0.1815	VOIDF	415010000	
20500202		0.1524	VOIDF	415020000	
20500203		0.3967	VOIDF	415030000	
20500204		0.5289	VOIDF	415040000	
20500205		0.3967	VOIDF	415050000	
20500206		0.1943	VOIDF	415060000	
20500207		0.1029	VOIDF	420010000	
20500208		0.1029	VOIDF	420020000	

* 003 REACTOR VESSEL LEVEL

	RVLVL	SUM	1.0	0.0	1
20500301	0.0	0.84888	VOIDF	260010000	
20500302		0.24333	VOIDF	255010000	
20500303		0.9285337	VOIDF	250010000	
20500304		0.4933248	VOIDF	245010000	
20500305		0.4933248	VOIDF	240010000	
20500312		0.4269792	VOIDF	225010000	
20500313		0.3533183	VOIDF	215010000	
20500314		0.3741720	VOIDF	220010000	

* C04 ACCUMULATOR LEVEL

	ACCLVL	INTEGRAL	-6.3480-3	2.0447	0
--	--------	----------	-----------	--------	---

* 007 REACTOR VESSEL DOWNCOMER LEVEL INTACT SIDE

	RVDCLVLIN	SUM	1.0	0.0	1
20500700	0.0	0.3302040	VOIDF	700010000	
20500701		0.3951272	VOIDF	702010000	
20500702		1.5200561	VOIDF	704010009	
20500704		1.2616333	VOIDF	706010000	
20500705		1.0792591	VOIDF	708010000	
20500706		0.3533183	VOIDF	215010009	
20500707		0.3741720	VOIDF	220010000	

* 008 REACTOR VESSEL DOWNCOMER LEVEL BROKEN SIDE

	RVDCLVLBK	SUM	1.0	0.0	1
20500800	0.0	0.3302040	VOIDF	710010000	
20500802		0.3951272	VOIDF	712010000	
20500803		1.5200561	VOIDF	714010000	
20500804		1.2616333	VOIDF	716010000	
20500805		1.0792591	VOIDF	718010000	
20500806		0.3533183	VOIDF	215010000	
20500807		0.3741720	VOIDF	220010000	

* CORE LEVEL : HOT CHANNEL 009, AVERAGE 010

* HOT LEVEL

	HOTLVL	SUM	1.0	0.0	1
20500900	0.0	0.279404	VOIDF	021010000	
20500901		0.0279404	VOIDF	022010000	
20500902		0.0279404	VOIDF	023010000	
20500903		0.0279404	VOIDF	024010000	
20500904		0.0279404	VOIDF	024010000	

20506505		0.0986806	RHO	708010000	
20506506		0.0432082	RHO	710010000	
20506507		0.0578606	RHO	712010000	
20506508		0.1581866	RHO	714010000	
20506509		0.1217000	RHO	716010000	
20506510		0.0986806	RHO	718010000	
20506511		0.24520	RHO	215010000	
20506512		0.296	RHO	220010000	
* 067 CORE/UPPER PLENUM MASS					
20506700	CRJPNMASS	SUM	1.0	0.0	1
20506701	0.0	0.12094	RHO	225010000	
*20506702		0.0683340	RHO	821010000	
*20506703		0.0478582	RHO	822010000	
*20506704		0.0483329	RHO	823010000	
*20506705		0.0479138	RHO	824010000	
*20506706		0.0479052	RHO	825010000	
*20506707		0.0750459	RHO	826010000	
20506708		0.0091280	RHO	235010000	
20506709		0.0072325	RHO	235020000	
2050671		0.0088095	RHO	235030000	
20506711		0.1195494	RHO	240010000	
20506712		0.1280806	RHO	245010000	
20506713		0.1436936	RHO	250010000	
20506714		0.1154214	RHO	251010000	
20506715		0.083595	RHO	255010000	
20506716		0.310967	RHO	260010000	
* 068 BROKEN LOOP HOT LEG MASS					
20506800	BLHLMASS	SUM	1.0	0.0	1
20506801	0.0	5.75410-2	RHO	300010000	
20506802		4.42927-2	RHO	305010000	
20506803		5.78467-2	RHO	310010000	
20506804		7.75291-3	RHO	315010000	
20506805		1.72111-1	RHO	315020000	
20506806		8.97552-2	RHO	315030000	
20506807		8.97552-2	RHO	315040000	
20506808		1.72111-1	RHO	315050000	
20506809		1.82303-2	RHO	315060000	
20506810		5.46687-2	RHO	315070000	
20506811		1.82489-2	RHO	315080000	
20506812		9.15000-2	RHO	380015000	
20506813		4.80000-2	RHO	380020000	
20506814		4.89000-2	RHO	380030000	
* 069 BROKEN LOOP COLD LEG MASS					
20506900	BLCCLMASS	SUM	1.0	0.0	1
20506901	0.0	4.79790-2	RHO	335010000	
20506902		4.43927-2	RHO	340010000	
20506903		3.62484-2	RHO	342010000	
20506904		5.10679-2	RHO	344010000	
20506907		2.79000-2	RHO	370010000	
20506908		7.00000-2	RHO	370020000	
20506909		1.16500-1	RHO	370030000	
* 070 PRESSURIZER MASS					
20507000	PZRMASS	SUM	1.0	0.0	1
20507001	0.0	3.33500-3	RHO	409010000	
20507002		3.33500-3	RHO	405010000	
20507003		3.33500-3	RHO	405020000	
20507004		6.84000-2	RHO	415010000	
20507005		8.38000-2	RHO	415020000	
20507006		2.24255-1	RHO	415030000	
20507007		2.98957-1	RHO	415040000	
20507008		2.24255-1	RHO	415050000	

1351501	0.000000E+00	2.500000E-01
1351502	2.000000E-01	2.800000E-01
1351503	4.000000E-01	3.400000E-01
1351504	4.118000E-01	2.768000E-01
1351505	5.976300E-01	4.584000E-01
1351506	7.934670E-01	6.992000E-01
1351507	1.000000E+00	1.000000E+00
-----	-----	-----
* HEAD CURVE NO. 6		
-----	-----	-----
1351600	1	6
1351601	0.000000E+00	9.342790E-01
1351602	9.109900E-02	9.229000E-01
1351603	1.865090E-01	8.963000E-01
1351604	2.717620E-01	8.750000E-01
1351605	4.558720E-01	8.433000E-01
1351606	5.744060E-01	8.355000E-01
1351607	7.405760E-01	8.466000E-01
1351608	7.666190E-01	8.469000E-01
1351609	8.714710E-01	8.838000E-01
1351610	1.000000E+00	1.000000E+00
-----	-----	-----
* HEAD CURVE NO. 7		
-----	-----	-----
1351700	1	7
1351701	-1.000000E+00	-1.000000E+00
1351702	-8.000000E-01	-6.300000E-01
1351703	-6.000000E-01	-3.000000E-01
1351704	-4.000000E-01	-5.000000E-02
1351705	-2.000000E-01	1.500000E-01
1351706	0.000000E+00	2.500000E-01
-----	-----	-----
* HEAD CURVE NO. 8		
-----	-----	-----
1351800	1	8
1351801	-1.000000E+00	-1.000000E+00
1351802	-8.000000E-01	-9.700000E-01
1351803	-6.000000E-01	-9.500000E-01
1351804	-4.000000E-01	-8.800000E-01
1351805	-2.000000E-01	-8.000000E-01
1351806	0.000000E+00	-6.700000E-01
-----	-----	-----
* SINGLE PHASE TORQUE DATA		
-----	-----	-----
* TORQUE CURVE NO. 1		
-----	-----	-----
1351900	2	1
1351901	0.000000E+00	6.032000E-01
1351902	1.930000E-01	6.325000E-01
1351903	3.930000E-01	7.369000E-01
1351904	5.955200E-01	8.331000E-01
1351905	7.978200E-01	9.229000E-01
1351906	1.000000E+00	1.000000E+00
-----	-----	-----
* TORQUE CURVE NO. 2		
-----	-----	-----
1352000	2	2
1352001	0.000000E+00	-6.700000E-01
1352002	4.000000E-01	-2.500000E-01
1352003	5.000000E-01	1.500000E-01
1352004	7.372550E-01	5.265860E-01

1354308	-2.500000E-01	-1.690000E+00
1354309	-1.000000E-01	-5.000000E-01
1354310	0.000000E+00	0.000000E+00
*	-----1-----	-----1-----1-----1-----
* HEAD CURVE NO. 4		
*	-----1-----1-----1-----1-----1-----1-----	
1354400	1	4
1354401	-1.000000E+00	-1.160000E+00
1354402	-9.000000E-01	-7.800000E-01
1354403	-8.000000E-01	-5.000000E-01
1354404	-7.000000E-01	-3.100000E-01
1354405	-6.000000E-01	-1.700000E-01
1354406	-5.000000E-01	-8.000000E-02
1354407	-3.500000E-01	0.000000E+00
1354408	-2.000000E-01	5.000000E-02
1354409	-1.000000E-01	8.000000E-02
1354410	0.000000E+00	1.100000E-01
*	-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 5		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1354500	1	5
1354501	0.000000E+00	0.000000E+00
1354502	2.000000E-01	-3.400000E-01
1354503	4.000000E-01	-6.500000E-01
1354504	6.000000E-01	-9.300000E-01
1354505	8.000000E-01	-1.190000E+00
1354506	1.000000E+00	-1.470000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 6		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1354600	1	6
1354601	0.000000E+00	1.100000E-01
1354602	1.000000E-01	1.300000E-01
1354603	2.500000E-01	1.500000E-01
1354604	4.000000E-01	1.300000E-01
1354605	5.000000E-01	7.000000E-02
1354606	6.000000E-01	-4.000000E-02
1354607	7.000000E-01	-2.300000E-01
1354608	8.000000E-01	-5.100000E-01
1354609	9.000000E-01	-9.100000E-01
1354610	1.000000E+00	-1.470000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 7		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1354700	1	7
1354701	-1.000000E+00	0.000000E+00
1354702	0.000000E+00	0.000000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* HEAD CURVE NO. 8		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1354800	1	8
1354801	-1.000000E+00	0.000000E+00
1354802	0.000000E+00	0.000000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 1		
*	-----1-----1-----1-----1-----1-----1-----1-----	
1354900	2	1
1354901	0.000000E+00	1.000000E+00
1354906	1.000000E+00	1.000000E+00
*	-----1-----1-----1-----1-----1-----1-----1-----	
* TORQUE CURVE NO. 2		

	1	1	1	1	1	1	1
1355000	2	2					
1355001	0.000000E+00	1.000000E+00					
1355007	1.000000E+00	1.000000E+00					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 3							
	1	1	1	1	1	1	1
1355100	2	3					
1355101	-1.000000E+00	1.984300E+00					
1355102	-8.009600E-01	1.394000E+00					
1355103	-6.063800E-01	1.097500E+00					
1355104	-4.068600E-01	8.220000E-01					
1355105	-1.992800E-01	6.648000E-01					
1355106	0.000000E+00	6.032000E-01					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 4							
	1	1	1	1	1	1	1
1355200	2	4					
1355201	-1.000000E+00	1.984300E+00					
1355202	-8.223400E-01	1.830800E+00					
1355203	-6.337100E-01	1.682400E+00					
1355204	-4.585300E-01	1.557000E+00					
1355205	-2.670230E-01	1.436200E+00					
1355206	-1.761070E-01	1.387900E+00					
1355207	-8.931000E-02	1.348100E+00					
1355208	0.000000E+00	1.233610E+00					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 5							
	1	1	1	1	1	1	1
1355300	2	5					
1355301	0.000000E+00	-4.500000E-01					
1355302	4.000000E-01	-2.500000E-01					
1355303	5.000000E-01	0.000000E+00					
1355304	1.000000E+00	3.569000E-01					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 6							
	1	1	1	1	1	1	1
1355400	2	6					
1355401	0.000000E+00	1.233610E+00					
1355402	9.064300E-02	1.196500E+00					
1355403	1.885690E-01	1.109600E+00					
1355404	2.734700E-01	1.041600E+00					
1355405	4.586690E-01	8.958000E-01					
1355406	5.744800E-01	7.807000E-01					
1355407	7.381600E-01	6.134000E-01					
1355408	7.685200E-01	5.849000E-01					
1355409	8.700570E-01	4.877000E-01					
1355410	1.000000E+00	3.569000E-01					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 7							
	1	1	1	1	1	1	1
1355500	2	7					
1355501	-1.000000E+00	-1.000000E+00					
1355502	-3.000000E-01	-9.000000E-01					
1355503	-1.000000E-01	-5.000000E-01					
1355504	0.000000E+00	-4.500000E-01					
	1	1	1	1	1	1	1
* TORQUE CURVE NO. 8							
	1	1	1	1	1	1	1
1355600	2	8					
1355601	-1.000000E+00	-1.000000E+00					

* TORQUE CURVE NO. 3

	1	2	3
1652100	1	-1.000000E+00	1.984300E+00
1652101	2	-8.009600E-01	1.394000E+00
1652102		-6.063800E-01	1.097500E+00
1652103		-4.068600E-01	8.220000E-01
1652104		-1.992800E-01	6.648000E-01
1652105		0.000000E+00	6.032000E-01
1652106			

* TORQUE CURVE NO. 4

	1	2	4
1652200	1	-1.000000E+00	1.984300E+00
1652201	2	-8.223400E-01	1.830800E+00
1652202		-6.337100E-01	1.682400E+00
1652203		-4.585300E-01	1.557000E+00
1652204		-2.670230E-01	1.436200E+00
1652205		-1.761070E-01	1.387900E+00
1652206		-8.931000E-02	1.348100E+00
1652207		0.000000E+00	1.233610E+00
1652208			

* TORQUE CURVE NO. 5

	1	2	5
1652300	1	-1.000000E+00	-4.500000E-01
1652301	2	4.000000E-01	-2.500000E-01
1652302		5.000000E-01	0.000000E+00
1652303		1.000000E+00	3.569000E-01
1652304			

* TORQUE CURVE NO. 6

	1	2	6
1652400	1	-1.000000E+00	1.233610E+00
1652401	2	9.064300E-02	1.196500E+00
1652402		1.885690E-01	1.109600E+00
1652403		2.734700E-01	1.041600E+00
1652404		4.586690E-01	8.958000E-01
1652405		5.744800E-01	7.807000E-01
1652406		7.381600E-01	6.134000E-01
1652407		7.685290E-01	5.849000E-01
1652408		8.700570E-01	4.877000E-01
1652409		1.000000E+00	3.569000E-01
1652410			

* TORQUE CURVE NO. 7

	1	2	7
1652500	1	-1.000000E+00	-1.000000E+00
1652501	2	-3.000000E-01	-9.000000E-01
1652502		-1.000000E-01	-5.000000E-01
1652503		0.000000E+00	-4.500000E-01
1652504			

* TORQUE CURVE NO. 8

	1	2	8
1652600	1	-1.000000E+00	-1.000000E+00
1652601	2	-2.500000E-01	-9.000000E-01
1652602		-8.000000E-02	-8.000000E-01
1652603		0.300000E+00	-6.700000E-01
1652604			

* HEAD CURVE NO. 4

	1	1	1	1	1	1
1654400	1	4				
1654401	-1.000000E+00	-1.160000E+00				
1654402	-9.000000E-01	-7.800000E-01				
1654403	-8.000000E-01	-5.000000E-01				
1654404	-7.000000E-01	-3.100000E-01				
1654405	-6.000000E-01	-1.700000E-01				
1654406	-5.000000E-01	-8.000000E-02				
1654407	-3.500000E-01	0.000000E+00				
1654408	-2.000000E-01	5.000000E-02				
1654409	-1.000000E-01	8.000000E-02				
1654410	0.000000E+00	1.100000E-01				

* HEAD CURVE NO. 5

	1	1	1	1	1	1
1654500	1	5				
1654501	0.000000E+00	0.000000E+00				
1654502	2.000000E-01	-3.400000E-01				
1654503	4.000000E-01	-6.500000E-01				
1654504	6.000000E-01	-9.300000E-01				
1654505	8.000000E-01	-1.190000E+00				
1654506	1.000000E+00	-1.470000E+00				

* HEAD CURVE NO. 6

	1	1	1	1	1	1
1654600	1	6				
1654601	0.000000E+00	1.100000E-01				
1654602	1.000000E-01	1.300000E-01				
1654603	2.500000E-01	1.500000E-01				
1654604	4.000000E-01	1.300000E-01				
1654605	5.000000E-01	7.000000E-02				
1654606	6.000000E-01	-4.000000E-02				
1654607	7.000000E-01	-2.300000E-01				
1654608	8.000000E-01	-5.100000E-01				
1654609	9.000000E-01	-9.100000E-01				
1654610	1.000000E+00	-1.470000E+00				

* HEAD CURVE NO. 7

	1	1	1	1	1	1
1654700	1	7				
1654701	-1.000000E+00	0.000000E+00				
1654702	0.000000E+00	0.000000E+00				

* HEAD CURVE NO. 8

	1	1	1	1	1	1
1654800	1	8				
1654801	-1.000000E+00	0.000000E+00				
1654802	0.000000E+00	0.000000E+00				

* TORQUE CURVE NO. 1

	1	1	1	1	1	1
1654900	2	1				
1654901	0.000000E+00	1.000000E+00				
1654906	1.000000E+00	1.000000E+00				

* TORQUE CURVE NO. 2

	1	1	1	1	1	1
1655000	2	2				
1655001	0.000000E+00	1.000000E+00				


```

***** STEADY STATE CONTROL SYSTEM
*
* PRIMARY COOLANT PUMP SPEED CONTROLLERS
*
* CALCULATE MASS FLOW ERR.
*
* PUMP 1 SPEED
*
* PCP1 PUMP VELOCITY TABLE
*
* MODIFY PCP1 PUMP DATA
*
* PUMP 2 SPEED
*
* PCP2 PUMP VELOCITY TABLE
*
* MODIFY PCP2 PUMP DATA
*
* PRESSURIZER SPRAY VALVE CONTROLLER
*
* SPRAY LINE
*
* SPRAY VALVE
*

```

	MSSERR	SUM	1.0	0.0	1
20590100	199.00	-1.0		MFLOWJ	100010000

	PCP1SPD	INTEGRAL	0.34482	133.000	1
20590201	CNTRLVAR	901			

	1356100	510	CNTRLVAR	902
1356101	0.0	0.0		
1356102	369.0	369.0		

	1350301	0	0	-1	0	695	0
--	---------	---	---	----	---	-----	---

	20590300	PCP2SPD	INTEGRAL	0.34482	139.790	1
20590301	CNTRLVAR	901				

	1656100	510	CNTRLVAR	903
1656101	0.0	0.0		
1656102	369.0	369.0		

	1650301	0	0	-1	0	697	0
--	---------	---	---	----	---	-----	---

	4300000	"SPRAY"	BRANCH			
4300001	1	0				
4300101	0.0003363	6.322	0.0	0.0	90.0	2.9905
4300102	4.0-5	0.0	00			
4300200	0	15037900.	1238620.	2459550.	.00000000	
4301101	150000000	430000000	0.0	0.0	0.0	0000
4301201	.777018-4	.777018-4	0.0			

	4350000	"SPRVLV"	VALVE			
4350101	430010000	415010000	3.3451E-4	1.5432E01	1.5432E01	0100
4350201	0	.00000000	.00000000	0.0		
4350300	SRVVLV					

4350301 904 999
 *-----1-----1-----1-----1-----
 * SPRAY VALVE POSITION CALCULATOR
 *-----1-----1-----1-----1-----
 20590400 SPRAY SUM -1.0 0.0 1 * CONTIN
 + 3 0.0 1.0
 20590401 15.06+6 -1.0 P 420010000
 *-----1-----1-----1-----1-----
 * POSITION VS AREA TABLE
 *-----1-----1-----1-----1-----
 20299900 NORMAREA
 20299901 0.0 0.0
 20299902 0.0001 0.0
 20299903 1.0 1.0
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRESSURIZER HEATERS IN INITIALIZATION
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRESSURIZER HEATER TRIPS
 *-----1-----1-----1-----1-----
 * LT 693 CYCLING HEATERS CARD 20241700
 0000585 P 420010000 GT NULL 0 15.06+6 N
 0000586 P 420010000 LT NULL 0 15.0599+6 N
 0000666 586 OR 693 N
 0000667 -585 AND 666 N
 0000693 -503 AND 667 N
 *-----1-----1-----1-----1-----
 * LT 694 BACKUP HEATERS CARD 20241800
 0000587 P 420010000 GT NULL 0 15.01+6 N
 0000588 P 420010000 LT NULL 0 15.0099+6 N
 0000668 588 OR 694 N
 0000669 -587 AND 668 N
 0000694 -503 AND 669 N
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRESSURIZER HEATERS
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 14172000 2 9 2 1 0.0
 14172100 0 1
 14172101 8 8.3820E-3
 14172201 4 8
 14172301 1.0 8
 14172401 615.0 9
 14172501 0 0 0 1 5.4864 1
 14172502 0 0 0 1 1.8288 2
 14172601 415040000 0 1 1 5.4864 1
 14172602 415040000 0 1 1 1.8288 2
 14172701 417 1.0 0.0 0.0 1 * CYCLING
 14172702 418 1.0 0.0 0.0 2 * BACKUP
 14172901 0 1.6764E-2 1.6764E-2 5.4864 1
 14172902 0 1.6764E-2 1.6764E-2 1.8288 2
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRESSURIZER CYCLING HEATERS
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 20241700 POWER 693
 20241701 0.0 0.0
 20241702 1.0 3.6+4
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 * PRESSURIZER BACKUP HEATERS
 *-----1-----1-----1-----1-----1-----1-----1-----1-----
 20241800 POWER 694
 20241801 0.0 0.0
 20241802 1.0 1.2+4

* PRESSURIZER LEVEL CONTROL USING CHARGING AND LETDOWN COMPONENTS

* MODIFY PZR LEVEL CONTROL VARIABLE

20500206 0.1249 VOIDF 415060000
 20500 0.02477 VOIDF 420010000
 205002 0.02477 VOIDF 420020000

* CHARGING RESERVIOR

9800000 "CHRG RESRV" TMDPVOL
 9800101 1.0 1.0 0.0 0.0 0.0 0.0
 9800102 4.0-5 0.0 00
 9800200 3
 9800201 0.0 2.07+07 559.2

* CHARGING VALVE

9850000 "CHRG VALVE" VALVE
 9850101 980000000 185000000 3.8E-05 0.0 0.0 0100
 9850201 0 .608458-3 .608458-3 0.0
 9850300 SRVVLV
 9850301 905 999

* CHARGING VALVE POSITION CALCULATOR

20590500 CHARGE SUM 7.7 0.0 1 *CONTIN
 + 3 0.0 1.0
 20590501 1.18 -1.0 CNTRLVAR 2

* LETDOWN SINK

9900000 "LTDWN SINK" TMDPVOL
 9900101 1.0 1.0 0.0 0.0 0.0 0.0
 9900102 4.0-5 0.0 00
 9900200 3
 9900201 0.0 1.4+7 559.2

* LETDOWN VALVE

9950000 "LTDWN VLV" VALVE
 9950101 185000000 990000000 2.5-5 0.0 0.0 0100
 9950201 0 .00000000 .00000000 0.0
 9950300 SRVVLV
 9950301 906 999

* LETDOWN VALVE POSITION CALCULATOR

20590600 LETDOWN SUM -7.7 0.0 1 *CONTIN
 + 3 0.0 1.0
 20590601 1.1430 -1.0 CNTRLVAR 2

* STEAM VALVE CONTROLLER

* CHANGES TO STEAM VALVE

5400201 0 13.604000 13.604000 0.0
 5400300 SRVVLV
 5400301 910 540
 20254000 NORMAREA

```

20254001 0.0      0.0
20254002 0.0001   0.0
20254003 1.0      1.0
*-----1-----1-----1-----
* COMPUTE DELTA T ERROR
*-----1-----1-----1-----
20590700 "DELTA T" SUM      1.0      0.0      1
20590701 560.7    -1.      TEMPF    185010000
*-----1-----1-----1-----
* FILTER DELTA T THRU DEADBAND
*-----1-----1-----1-----
20590800 DEADBAND FUNCTION 1.0      0.0      1
20590801 CNTRLVAR 907      908
20290800 REAC-T
20290801 -100.     -100.
20290802 -0.1      -0.1
20290803 -0.1      0.0
20290804 0.1      0.0
20290805 0.1      0.1
20290806 100.     100.
*-----1-----1-----1-----
* INTEGRATE DELTA T ERROR
*-----1-----1-----1-----
20590900 "INT D T" INTEGRAL 1.0      0.0      1
20590901 CNTRLVAR 908
*-----1-----1-----1-----
* STEAM VALVE POSITION CALCULATOR
*-----1-----1-----1-----
20591000 TCONTROL SUM      1.0      0.44405  0      *CONTI
+      3      0.40      0.55
20591001 0.44405    -0.0564  CNTRLVAR 908
20591002      -0.0059  CNTRLVAR 909
*-----1-----1-----1-----1-----1-----1-----1-----
* SIMPLIFIED FEED SYSTEM CONTROLLER
*-----1-----1-----1-----1-----1-----1-----1-----
* SIMPLIFIED FEED LOGIC
*-----1-----1-----1-----
20591100 SGLVLERR SUM      1.0      0.0      1
20591101 3.11      -1.0      CNTRLVAR 001
20591200 FEEDFLOW SUM      1.0      0.0      1
20591201 0.0       1.0      MFLOWJ    540000000
20591202      48.4      CNTLVAR 911
*-----1-----1-----1-----
* REPLACE FEED JUNCTION TABLE
*-----1-----1-----1-----
5660200 1      0      CNTRLVAR 912
5660201 -100.0  19.15    0.0      0.0
5660202 -1.0     0.0      0.0      0.0
5660203 0.0      0.0      0.0      0.0
5660204 50.0     50.0     0.0      0.0
5660205
5660206
5660207
*-----1-----1-----1-----1-----1-----1-----1-----
* REPLACE REACTOR POWER TABLE
*-----1-----1-----1-----1-----1-----1-----1-----
RELAP5 END CARD

```

Appendix C. A Base Case Input Deck for a Transient Calculation

L23BTR2,T5000.

/USER

ATTACH,RSTIN=L23R2.

ATTACH,STH2XT,RE364BX.

DEFINE,RSTPLT=L23RSTT.

FILE,RSTIN,SBF=NO.

FILE,RSTPLT,SBF=NO.

*DEFINE,PLUTFL=L23RPL0.

RFL,CM=300000,FC=200.

REDUCE(-)

RE364BX,,*PL=50000.

/EOB

* LOFT L2-3 BASE TRANSIENT TO 100 SEC

0000100 RESTART TRANSNT

0000101 RUN

0000103 5237

0000105 5.0 10.0

*-----1-----1-----1-----1-----1-----1-----1-----1-----

0000201 20.0 1.0-6 0.05 3 2 200 1000

0000202 100.0 1.0-6 0.01 3 10 500 2500

* REMOVE PUMP SPEED CONTROLLERS

*-----1-----1-----1-----1-----1-----1-----1-----1-----

20590100 MSSERR DELETE 0.0 0.0 0.0 0.0 0.0 0.0

20590200 PCP1SPD DELETE 0.0 0.0 0.0 0.0 0.0 0.0

20590300 PCP2SPD DELETE 0.0 0.0 0.0 0.0 0.0 0.0

*-----1-----1-----1-----1-----1-----1-----1-----1-----

* RENORMALIZE PUMP1

*-----1-----1-----1-----1-----1-----1-----1-----1-----

1350000 "PCPUMP1" PUMP

1350101 0.0 0.4572 0.0991 0.0 90.0 0.317900

1350102 0

1350108 130010000 0.0 0.017 0.017 9000

1350109 140000000 0.0 0.05 0.05 9000

1350200 0 1.49288+7 1.23094+6 2.46151+6 0.

1350201 0 3.0790 3.0790 0.0

1350202 0 3.2641 3.2641 0.0

1350301 0 0 0 -1 -1 0 0

1350302 369.00000 .35501355 .31550000 96.000000 500.60000 1.4310000

1350303 513.60000 .00000000 207.43300 .04440000 19.598700 .00000000

1350310 0 0 0 0.0 0.0

*-----1-----1-----1-----1-----1-----1-----1-----1-----

*

* PUMP DATA

*

*-----1-----1-----1-----1-----1-----1-----1-----1-----

* SINGLE PHASE HEAD CURVES

*-----1-----1-----1-----1-----1-----1-----1-----1-----

* HEAD CURVE NO. 1

*-----1-----1-----1-----1-----1-----1-----1-----1-----

1351100 1 1

1351101 0.000000E+00 1.403600E+00

1351102 1.906100E-01 1.363600E+00

1351103 3.896300E-01 1.318600E+00

1351104 5.939600E-01 1.232800E+00

1351105 7.902030E-01 1.133600E+00

1351106 1.000000E+00 1.000000E+00

*-----1-----1-----1-----1-----1-----1-----1-----1-----

* HEAD CURVE NO. 2

*-----1-----1-----1-----1-----1-----1-----1-----1-----

1351200 1 2

1351201 0.000000E+00 -6.700000E-01

1351202 2.000000E-01 -5.000000E-01

* HEAD CURVE NO. 8
 *
 1351800 1 8
 1351801 -1.000000E+00 -1.000000E+00
 1351802 -8.000000E-01 -9.700000E-01
 1351803 -6.000000E-01 -9.500000E-01
 1351804 -4.000000E-01 -8.800000E-01
 1351805 -2.000000E-01 -8.000000E-01
 1351806 0.000000E+00 -6.700000E-01
 *
 * SINGLE PHASE TORQUE DATA
 *
 * TORQUE CURVE NO. 1
 *
 1351900 2 1
 1351901 0.000000E+00 6.002900E-01
 1351902 1.930000E-01 6.325000E-01
 1351903 3.900000E-01 7.369000E-01
 1351904 5.955200E-01 8.331000E-01
 1351905 7.978200E-01 9.229000E-01
 1351906 1.000000E+00 1.000000E+00
 *
 * TORQUE CURVE NO. 2
 *
 1352000 2 2
 1352001 0.000000E+00 -6.790000E-01
 1352002 4.000000E-01 -2.500000E-01
 1352003 5.000000E-01 1.500000E-01
 1352004 7.372550E-01 5.265860E-01
 1352005 7.680490E-01 6.065940E-01
 1352006 8.672300E-01 7.436600E-01
 1352007 1.000000E+00 1.000000E+00
 *
 * TORQUE CURVE NO. 3
 *
 1352100 2 3
 1352101 -1.900000E+00 1.984300E+00
 1352102 -8.009600E-01 1.394000E+00
 1352103 -6.063800E-01 1.097500E+00
 1352104 -4.068600E-01 8.220000E-01
 1352105 -1.992800E-01 6.648000E-01
 1352106 0.040300E+00 6.032000E-01
 *
 * TORQUE CURVE NO. 4
 *
 1352200 2 4
 1352201 -1.000000E+00 1.984300E+00
 1352202 -8.223400E-01 1.830870E+00
 1352203 -6.337100E-01 1.682400E+00
 1352204 -4.585300E-01 1.557010E+00
 1352205 -2.670230E-01 1.436210E+00
 1352206 -1.761070E-01 1.387900E+00
 1352207 -8.931000E-02 1.348100E+00
 1352208 0.000000E+00 1.237610E+00
 *
 * TORQUE CURVE NO. 5
 *
 1352300 2 5
 1352301 0.000000E+00 -4.500000E-01
 1352302 4.000000E-01 -2.500000E-01
 1352303 5.000000E-01 0.000000E+00
 1352304 1.000000E+00 3.569000E-01

	1.060000E+00	0.000000E+00
*	1	1
*	PUMP 2-PHASE DIFFERENCE DATA	
*	1	1
*	HEAD CURVE NO. 1	
*	1	1
1354100	1	1
1354101	0.000000E+00	1.000000E+00
1354102	1.000000E+00	1.000000E+00
*	1	1
*	HEAD CURVE NO. 2	
*	1	1
1354200	1	2
1354201	0.000000E+00	1.000000E+00
1354202	1.000000E+00	1.000000E+00
*	1	1
*	HEAD CURVE NO. 3	
*	1	1
1354300	1	3
1354301	-1.000000E+00	-1.160000E+00
1354302	-9.000000E-01	-1.240000E+00
1354303	-8.000000E-01	-1.770000E+00
1354304	-7.000000E-01	-2.360000E+00
1354305	-6.000000E-01	-2.790000E+00
1354306	-5.000000E-01	-2.910000E+00
1354307	-4.000000E-01	-2.670000E+00
1354308	-2.500000E-01	-1.690000E+00
1354309	-1.000000E-01	-5.000000E-01
1354310	0.000000E+00	0.000000E+00
*	1	1
*	HEAD CURVE NO. 4	
*	1	1
1354400	1	4
1354401	-1.000000E+00	-1.160000E+00
1354402	-9.000000E-01	-7.800000E-01
1354403	-8.000000E-01	-5.000000E-01
1354404	-7.000000E-01	-3.100000E-01
1354405	-6.000000E-01	-1.700000E-01
1354406	-5.000000E-01	-8.000000E-02
1354407	-3.500000E-01	0.000000E+00
1354408	-2.000000E-01	5.000000E-02
1354409	-1.000000E-01	8.000000E-02
1354410	0.000000E+00	1.100000E-01
*	1	1
*	HEAD CURVE NO. 5	
*	1	1
1354500	1	5
1354501	0.000000E+00	0.000000E+00
1354502	2.000000E-01	-3.400000E-01
1354503	4.000000E-01	-6.500000E-01
1354504	6.000000E-01	-9.300000E-01
1354505	8.000000E-01	-1.190000E+00
1354506	1.000000E+00	-1.470000E+00
*	1	1
*	HEAD CURVE NO. 6	
*	1	1
1354600	1	6
1354601	0.000000E+00	1.190000E-01
1354602	1.000000E-01	1.300000E-01
1354603	2.500000E-01	1.500000E-01
1354604	4.000000E-01	1.300000E-01
1354605	5.000000E-01	7.000000E-02
1354606	6.000000E-01	-4.000000E-02

1354608 8.00000E-01 -5.10000E-01
 1354609 9.00000E-01 -9.10000E-01
 1354610 1.00000E+00 -1.47000E+00
 * HEAD CURVE NO. 7
 *-----1-----1-----1-----1-----1-----1
 1354700 1 7
 1354701 -1.00000E+00 0.00000E+00
 1354702 0.00000E+00 0.00000E+00
 *-----1-----1-----1-----1-----1-----1
 * HEAD CURVE NO. 8
 *-----1-----1-----1-----1-----1-----1
 1354800 1 8
 1354801 -1.00000E+00 0.00000E+00
 1354802 0.00000E+00 0.00000E+00
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 1
 *-----1-----1-----1-----1-----1-----1
 1354900 2 1
 1354901 0.00000E+00 1.00000E+00
 1354906 1.00000E+00 1.00000E+00
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 2
 *-----1-----1-----1-----1-----1-----1
 1355000 2 2
 1355001 0.00000E+00 1.00000E+00
 1355007 1.00000E+00 1.00000E+00
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 3
 *-----1-----1-----1-----1-----1-----1
 1355100 2 3
 1355101 -1.00000E+00 1.984300E+00
 1355102 -8.063600E-01 1.394000E+00
 1355103 -6.063800E-01 1.097500E+00
 1355104 -4.068600E-01 8.22000E-01
 1355105 -1.992800E-01 6.648000E-01
 1355106 0.00000E+00 6.032000E-01
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 4
 *-----1-----1-----1-----1-----1-----1
 1355200 2 4
 1355201 -1.00000E+00 1.984300E+00
 1355202 -8.223400E-01 1.830800E+00
 1355203 -6.337100E-01 1.682400E+00
 1355204 -4.585300E-01 1.557000E+00
 1355205 -2.670230E-01 1.436200E+00
 1355206 -1.761070E-01 1.387900E+00
 1355207 -8.931000E-02 1.348100E+00
 1355208 0.00000E+00 1.233610E+00
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 5
 *-----1-----1-----1-----1-----1-----1
 1355300 2 5
 1355301 0.00000E+00 -4.50000E-01
 1355302 4.00000E-01 -2.50000E-01
 1355303 5.00000E-01 0.00000E+00
 1355304 1.00000E+00 3.569000E-01
 *-----1-----1-----1-----1-----1-----1
 * TORQUE CURVE NO. 6
 *-----1-----1-----1-----1-----1-----1
 1355400 2 6
 1355401 0.00000E+00 1.233610E+00

* INSTEAD OF REMOVING PRESSURIZER HEAT STRUCTURE COMPONENTS

20241700	POWER	693					
20241701	0.0	0.0					
20241702	1.0	0.0					
20241800	POWER	694					
20241801	0.0	0.0					
20241802	1.0	0.0					

* REMOVE PRESSURIZER LEVEL CONTROLLERS, CHARGING COMPONENT, AND
* LETDOWN COMPONENT

20500200	PZRLVL	SUM	1.0	0.0	1		
20500201	0.0	0.1815	VOIDF	415010000			
20500202		0.1524	VOIDF	415020000			
20500203		0.3967	VOIDF	415030000			
20500204		0.5289	VOIDF	415040000			
20500205		0.3967	V_IDF	415050000			
20500206		0.1943	VOIDF	415060000			
20500207		0.1029	VOIDF	420010000			
20500208		0.1029	VOIDF	420020000			
98000100	"CHRG R"	DELETE					
98500000	"CHRG V"	DELETE					
20590500	CHARGE	DELETE	0.0	0.0	0.0	0.0	0.0
99000000	"LTDWN S"	DELETE					
99500000	"LTDWN V"	DELETE					
20590600	LETDOWN	DELETE	0.0	0.0	0.0	0.0	0.0

* REMOVE STEAM VALVE CONTROLLER

54000000	"CV-P4-10 "	VALVE					
5400101	530010000	541000000	0.0047772	0.0		0.0	0100
5400201	0	14.541	13.536	0.0			
5400300	MTRVLV						
5400301	685	685	0.05	.416170	540		
20254000	NORMAREA						
20254001	0.0	0.0					
20254002	9.25-4	9.25-4					
20254003	1.0	1.0					
20590700	"DELTA T"	DELETE	0.0	0.0	0.0	0.0	0.0
20590800	DEADBAND	DELETE	0.0	0.0	0.0	0.0	0.0
20590900	"INT D T"	DELETE	0.0	0.0	0.0	0.0	0.0
20591000	TCONTROL	DELETE	0.0	0.0	0.0	0.0	0.0
20290800	DELETE						

* REMOVE FEED SYSTEM CONTROLLER

20591100	SGLVLERR	DELETE	0.0	0.0	0.0	0.0	0.0
20591200	FEEDFLOW	DELETE	0.0	0.0	0.0	0.0	0.0
56600000	"FEED "		TMDPJUN				
5660101	565000000	508000000	0.05				
5660200	1	502					
5660201	-100.0	19.150	0.0	0.0		*L2-5	
5660202	0.0	19.150	0.0	0.0		*L2-5	
5660203	0.5	10.0	0.0	0.0		*L2-5	
5660204	1.0	2.50	0.0	0.0		*L2-5	
5660205	1.5	1.00	0.0	0.0		*L2-5	
5660206	2.0	0.25	0.0	0.0		*L2-5	
5660207	2.5	0.00	0.0	0.0		*L2-5	

* REPLACE TRIPS FOR L2-3 TRANSIENT

--	--	--	--	--	--	--	--

0000501	TIME	0	GE	NULL	0	0.0	L	* BREAK OPEN
0000502	TIME	0	GE	NULL	0	0.103	L	* REACTOR SCRAM
0000503	TIME	0	GE	NULL	0	14.0	N	* HPIS STRAT
0000504	TIME	0	GE	NULL	0	29.0	N	* LPIS START
-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
* MINOR EDIT VARIABLES								
-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
0000301	P	250010000		*	PRIMARY PRESSURE PE-1UP-001			
0000302	P	530010000		*	SECONDARY PRESSURE			
0000303	TEMPF	250010000		*	UPPER PLENUM TEMP.			
0000304	TEMPF	215010000		*	LOWER PLENUM TEMP.			
0000305	MFLOWJ	340010000		*	BLCL MASS FLOW			
0000306	MFLOWJ	305010000		*	BLHL MASS FLOW			
0000307	RHO	100010000		*	ILHL DENSITY			
0000308	RHO	340010000		*	BLCL DENSITY			
0000309	RHO	305010000		*	BLHL DENSITY			
0000310	RHO	185010000		*	ILCL DENSITY			
0000311	RHO	180010000		*	PUMP EXIT DEN.			
0000312	MFLOWJ	630000000		*	LPSI MASS			
0000313	MFLOWJ	640000000		*	HPSI			
0000314	MFLOWJ	600000000		*	ECC MASS			
0000315	MFLOWJ	610000000		*	ACCUM MASS FLOW			
0000316	CNTRLVAR	4		*	ACCUMULATOR LEVEL			
0000317	PMPVEL	135		*	PUMP 1 SPEED			
0000318	P	100010000		*	ILHL PRESSURE			
0000319	VOIDGJ	317000000		*	HL BREAK JUNC VOID			
0000320	VOIDGJ	347000000		*	CL BREAK JUNC VOID			
0000321	CNTRLVAR	2		*	PZR LEVEL			
0000322	CNTRLVAR	1		*	S/G LEVEL			
0000323	CNTRLVAR	7		*	DC LEVEL (INTACT)			
0000324	CNTRLVAR	8		*	DC LEVEL (BROKEN)			
0000325	CNTRLVAR	9		*	HOT CORE LEVEL			
0000326	CNTRLVAR	10		*	AVER CORE LEVEL			
0000327	CNTRLVAR	12		*	TOTAL COLLAPSED LEVEL			
0000328	CNTRLVAR	59		*	AVERAGE CORE MASS			
0000329	CNTRLVAR	60		*	HOT CORE MASS			
0000330	CNTRLVAR	71		*	CORE MASS			
0000331	CNTRLVAR	72		*	PCS TOTAL MASS			
0000332	CNTRLVAR	75		*	TOTAL INJECTED MASS			
0000333	CNTRLVAR	77		*	TOTAL DISCHARGED MASS			
0000334	CNTRLVAR	81		*	TIME STEP SIZE			
0000335	CPUTIME	0						
0000336	MFLOWJ	180010000		*	PUMP DISCHARGE MASS			
0000337	MFLOWJ	185010000		*	ILCL MASS FLOW			
0000338	MFLOWJ	701000000		*	DC UPPER ANNULUS MASS			
0000339	MFLOWJ	731000000		*	DC DOWNWARD MASS			
0000340	MFLOWJ	722000000		*	CROSS FLOW 1			
0000341	MFLOWJ	724000000		*	CROSS FLOW 2			
0000342	MFLOWJ	726000000		*	CROSS FLOW 3			
0000343	MFLOWJ	728000000		*	CROSS FLOW 4			
0000344	MFLOWJ	719000000		*	BR. SIDE DC DOWNWARD MASS			
0000345	MFLOWJ	225010000		*	AVER CORE MASS FLOW			
0000346	MFLOWJ	225020000		*	HOT CORE MASS FLOW			
0000347	MFLOWJ	225030000		*	CORE BYPASS FLOW			
-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----	-----1-----
0000348	VOIDG	021010000		*	HOT CH 5 INCH VOID			
0000349	VOIDG	023010000		*	HOT CH 28 INCH VOID			
0000350	VOIDG	025010000		*	HOT CH 39 INCH VOID			
0000351	VOIDG	013010000		*	AVER CH 28 INCH VOID			
0000352	VOIDG	015010000		*	AVER CH 39 INCH VOID			
0000353	VOIDG	225010000		*	LOWER PLENUM VOID			
0000354	VOIDG	240010000		*	UPPER PLENUM VOID			

0000355	HTTEMP	231100110	* TE-5H5-002				
0000356	HTTEMP	231100210	* TE-5J9-005				
0000357	HTTEMP	231100310	* TE-5I8-008				
0000359	HTTEMP	231100410	* TE-5J7-011				
0000360	HTTEMP	231100510	* TE-5H5-015				
0000361	HTTEMP	231100610	*				
*							
0000362	HTTEMP	230100110					
0000363	HTTEMP	230100210	* TE-4E8-011				
0000364	HTTEMP	230100310	* TE-4F7-015				
0000365	HTTEMP	230100410	* TE-4G8-021				
0000366	HTTEMP	230100510	* TE-4F8-028				
0000367	HTTEMP	230100610	* TE-4F8-032				
0000368	TEMPF	712610000	* TE-1ST-001				
0000369	TEMPF	714010000					
0000370	TEMPF	716010000					
0000371	TEMPF	718010000					
0000372	TEMPF	225010000					
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	\$*						
*							
*	ACCUMULATOR, TRIPS, AND CONTROL VARIABLE						
*							
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ACCUMULATOR VALVE TRIPS						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
0000579	MFLOWJ	610000000	GE	NULL	0	0.0	N
0000580	CNTRLVAR	4	LT	NULL	0	1.0	L
0000682	579	AND	-580	N			
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ACCUMULATOR LEVEL CONTROL VARIABLE						
*	-1-	-	-1-	-1-	-1-	-1-	-1-
20500400	ACCMVL	NTEGRAL	-4.776E-3	2.04	0		
20500101	VELFJ	610000000					
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ECC CHECK VALVE						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
6000000	"ECC CHKVLV"	VALVE					
6000101	605010G00	185000000	0.0	1.3869	1.3869	0100	
6000201	0	0.0	0.0	0.0			
6000300	TRPVLV						
6000301	681						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ECCS HEADER TO PCS						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
6050000	"ECCS HEADR"	SNGLVOL					
6050101	5.989E-3	4.8247	0.0	0.0	90.0	2.2061	
6050102	1.0165E-5	0.0	10				
6050200	0	4.18E+6	125472.	2600290.	0.0		
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ACCUMULATOR VALVE						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
6100000	"ACCUM VLV "	VALVE					
6100101	615010000	605000000	0.0	8.1009	8.1009	0000	
6100201	0	0.0	0.0	0.0			
6100300	TRPVLV						
6100301	682						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
*	ACCUMULATOR PIPE						
*	-1-	-1-	-1-	-1-	-1-	-1-	-1-
6150000	"ACC PIPE "	SNGLVOL					

20301100	RHO	180010000	* DENSITI
20301200	MFLOWJ	630000000	* PUMP EXIT DEN.
20301300	MFLOWJ	640000000	* LPSI MASS
20301400	MFLOWJ	600000000	* HPSI
20301500	MFLOWJ	610000000	* ECC MASS
20301600	CNTRLVAR	4	* ACCUM MASS FLOW
20301700	PMPVEL	135	* ACCUMULATOR LEVEL
20301800	P	100010000	* PMP 1 SPEED
20301900	VOIDGJ	317000000	* HL BREAK JUNC VOID
20302000	VOIDGJ	347000000	* CL BREAK JUNC VOID
20302100	CNTRLVAR	2	* PZR LEVEL
20302200	CNTRLVAR	1	* S/G LEVEL
20302300	CNTRLVAR	7	* DC LEVEL (INTACT)
20302400	CNTRLVAR	8	* DC LEVEL (BROKEN)
20302500	CNTRLVAR	9	* HOT CORE LEVEL
20302600	CNTRLVAR	10	* AVER CORE LEVEL
20302700	CNTRLVAR	12	* TOTAL COLLAPSED LEVEL
20302800	CNTRLVAR	59	* AVERAGE CORE MASS
20302900	CNTRLVAR	60	* HOT CORE MASS
20303000	CNTRLVAR	71	* CORE MASS
20303100	CNTRLVAR	72	* PCS TOTAL MASS
20303200	CNTRLVAR	75	* TOTAL INJECTED MASS
20303300	CNTRLVAR	77	* TOTAL DISCHARGED MASS
20303400	CNTRLVAR	81	* TIME STEP SIZE
20303500	CPUTIME	0	
20303600	MFLOWJ	180010000	* PUMP DISCHAGE MASS
20303700	MFLOWJ	185010000	* ILCL MASS FLOW
20303800	MFLOWJ	701000000	* DC UPPER ANNULUS MASS
20303900	MFLOWJ	731000000	* DC DOWNWARD MASS
20304000	MFLOWJ	722000000	* CROSS FLOW 1
20304100	MFLOWJ	724000000	* CROSS FLOW 2
20304200	MFLOWJ	726000000	* CROSS FLOW 3
20304300	MFLOWJ	728000000	* CROSS FLOW 4
20304400	MFLOWJ	719000000	* BR.SIDE DC DOWNWARD MASS
20304500	MFLOWJ	225010000	* AVER CORE MASS FLOW
20304600	MFLOWJ	225020000	* HOT CORE MASS FLOW
20304700	MFLOWJ	225030000	* CORE BYPASS FLOW
*			
20304800	VOIDG	021010000	* HOT CH 11 INCH VOID
20304900	VOIDG	023010000	* HOT CH 21 INCH VOID
20305000	VOIDG	025010000	* HOT CH 45 INCH VOID
20305100	VOIDG	013010000	* AVER CH 21 INCH VOID
20305200	VOIDG	015010000	* AVER CH 45 INCH VOID
20305300	VOIDG	225010000	* LOWER PLENUM VOID
20305400	VOIDG	240010000	* UPPER PLENUM VOID
*			
20305500	HTTEMP	231100110	* TE-5H5-002
20305600	HTTEMP	231100210	* TE-5J9-005
20305700	HTTEMP	231100310	* TE-518-008
20305800	HTTEMP	231100410	* TE-5J7-011
20305900	HTTEMP	231100510	* TE-5H5-015
20306000	HTTEMP	231100610	*
*			
20306100	HTTEMP	230100110	
20306200	HTTEMP	230100210	* TE-4E8-011
20306300	HTTEMP	230100310	* TE-4F7-015
20306400	HTTEMP	230100410	* TE-4G8-021
20306500	HTTEMP	230100510	* TE-4F8-028
20306600	HTTEMP	230100610	* TE-4F8-032
20306700	TEMPF	712010000	* TE-1ST-001
20306800	TEMPF	714010000	
20306900	TEMPF	716010000	


```
20507700      BRMASS     INTEGRAL  1.0    0.0    1
20507701          CNTRLVAR   76
20507701          CNTRLVAR   76
*
*-----1-----1-----1-----1-----1-----1-----1-----
*      END OF INPUT
#EOR
#EOR
```

Appendix D. Updat List for PSI-EIR 83 based on RELAP5/MOD2 Cycle 36.04

APPENDIX D Update list for a updated RELAP5/MOD2 Cycle 36.04

```
/JOB  
RM364T,T200.  
/USER  
ATTACH,OLDPL=REL364S.  
PURGE,RE364TS/NA.  
PURGE,RE364TX/NA.  
PURGE,RE364TL/NA.  
*****  
* IMPORTANT !! *  
* THE UPDATE DIRECTIVE *  
* SHOULD HAVE *COMPILE DEFINE  
* AS THE FIRST DIERECTIVE  
*****  
UPDATE,N=RE364TS.  
UPDATE,P=RE364TS,Q,C=R5SEG.  
REPLACE,R5SEG.  
RETURN,OLDPL.  
*DEFINE,RE364TS.  
RETURN,RE364TS.  
ATTACH,ENVRLX=ENVR41X.  
LIBRARY,ENVRLX.  
SELECTA,COMPILE,COMP.  
LIBRARY.  
RETURN,ENVRLX.  
REWIND,COMP.  
FTN5,I=COMP,DO,ET,STATIC,OPT=2,ROUND,LO=M/A/R/S.  
RETURN,COMP.  
REWIND,LGO.  
ATTACH,RELAP5I=REL36IL.  
GTR,RELAP5I,ADD,REL/*  
*DEFINE,RELAP5O=RE364TL.  
LIBEDIT,P=RELAP5O,I=0,B=ADD,LO=F,U,C.  
LIBEDIT,P=RELAP5O,B=LGO,I=0,LO=F,U,C.  
RETURN,NULL,LGO,RELAP5I.  
RETURN,RLP5F1,RLP5F2.  
ATTACH,ENVRL=ENVR41L.  
FILE,RSTIN,RT=S,SBF=NO,USE,FO=SQ.  
RFL,EC=200.  
DEFINE,RE364TX.  
SEGLOAD,I=R5SEG,B=RE364TX.  
LDSET,LIB=RELAP5O/ENVRL.  
LDSET,PRESETA=NGINDEF,ERR=NONE,MAP=SB.  
LDSET,STAT=RSTIN.  
LIBLOAD,ENVRL,$HDR=$.  
LIBLOAD,FTN5LIB,$FERCAP.$,$RPVCAP.$,$FTNRP2.$,$Q2NTRY.$.  
NOGO.  
RETURN,RELAP5O,ENVRL,COMPILE.  
SKIP,KKK.  
EXIT.  
ENDIF,KKK.  
DAYFILE,KMRRDAY.  
REPLACE,KMRRDAY.  
/EOR  
*COMPILE DEFINE  
*ID CBD3604  
*D DMK3601.484  
*D PLOTMD.24
```

```

901 FORMAT ('OPLOTFL SCRACH FILE GENERATED.')
*COMPILE DEFINE,SEGDIR
*COMPILE RELAP5
*D RJW3603.23
    DATA PTITLE/"RELAP5/2/3","6.04-PSI","REACTOR LO","SS OF COOL",
*/
*/
ENDIF
*/
*ID KWU01 ALREADY IMPLEMENTED IN RELAPSOLDPL3604C,
*/
WHICH IS USED AS BASIS
*/
/* CORRECTIONS OF INDEX IN SUBRCUTINE RACUM
*/
*I RACUM.618
*/
IELV=1
*/
*B DMK3602.581
*/
I=IELV
*COMPILE DEFINE,SEGDIR,RACUM
*ID KWU01
*I RACUM.618
IELV=I
*B DMK3602.581
I=IELV
*/
/* END OF KWU-UPDATES TO CYCLE 3604
*COMPILE DEFINE,SEGDIR
*IDENT SKI01
*/
THESE UPDATES ARE RECOMMENDED BY SKI TO BE
IMPLEMENTED IN RELAPS/MOD2-36.04
*/
SOURCE: LETTER FROM STUDSVIK (MR.SANDERVAG)
TO KWU (MR.GRUBER)
*/
1987-06-25
*/
*/
COMPILE RELAP5
*/
*COMPILE IHTCMP
*/
FIX AN INDEXING ERROR IN IHTCMP
*/
ERROR CAUSED ROD PLENUM VOLUME FOR GAP-GAS PRESSURE CALCULATION
*/
TO BE INCORRECT. FOUND AND FIXED BY D.CARAHER 20MAY87
*/
FIX ONLY CDC-VERSION CODING
*D IHTCMP.1041
L=(.NOT.MASK(43).AND.IHTPTR(J))+FILNDX(8)
*/
*/
UPDATE ROUTINE IRFLHT TO ALLOW REFLOOD TO WORK
HEAT STRUCTURE FILE GETS CHANGED ON RESTART (FOR
EXAMPLE BY DELETING OR ALTERING SOME STRUCTURES)
*/
NOTE..HEAT STRS ASSOCIATED WITH REFLOOD CANNOT BE ALTERED
ON RESTART AS IRFLHT IS NOW PROGRAMMED
*/
*/
*COMPILE IRFLHT
*I IRFLHT.330
C UPDATE THE GEOMETRY POINTER IN IGLRFL BITS 44-60 IN CASE THE
C HEAT STRUCTURE FILE CHANGED ON RESTART.
J=(.NOT.MASK(43).AND.IH) + IHT
J=(.NOT.MASK(43).AND.IHTPTR(J)) + IHT
NCOLS=.NOT.MASK(43).AND.INXGOM(J)
IGLRFL(I)=(MASK(43).AND.IGLRFL(I)).OR.NCOLS
*/
*/
END OF UPDATES SKI01
*/
*/
START OF PSI UPDATE
*/

```

```

*ID MARTIN
*I PHAINT.9
    COMMON/IIFLG2/IFLAG2(1000)
    DIMENSION IFLAG1(1000)
*I PHAINT.151
    IIFLG1=(I-IV+IVSKP)/IVSKP
    IFLAG1(IIFLG1)=0
*I PHAINT.294
    TGSAT=TGSAT-40.*VOIDF(I)
*I PHAINT.370
    IF(FBUB.GT.0.0.OR.FSLUG.GT.0.0.AND.DIAMV(I).LT.0.018)
        I IFLAG1(IIFLG1)=1
*I PHAINT.390
    IF(DIAMV(I).LT.0.018) THEN
        FIC=65.0*VOIDG(I)*VOIDF(I)**3.0*RHOG(I)/DIAMV(I)
        ENDIF
*I PHAINT.421
    IF(DIAMV(I).LT.0.018) THEN
        FIC1=65.0*VOIDG(I)*VOIDF(I)**3.0*RHOG(I)/DIAMV(I)
        ENDIF
*I PHAINT.424
    IF(DIAMV(I).GE.0.018) THEN
*I PHAINT.425
        ENDIF
*I PHAINT.495
    IF(DIAMV(I).LT.0.018) FIC1=FIC1*0.5
*I PHAINT.633
    IF(DIAMV(I).LT.0.018) THEN
        FIC1=VOID*(FIC1*0.5+1.225*0.4*RHOG(I)*SLSLG*VOID**2.)
        ELSE
*I PHAINT.634
        ENDIF
*I PHAINT 5C5
    IF(DIAMV(I).LT.0.018) FIC=FIC*0.5
*I PHAINT.462
    IF(DIAMV(I).LT.0.018) FIC=FIC*0.5
*I PHAINT.855
    IIFLG2= (I-IJ+IJSKP)/IJSKP
    IFLAG2(IIFLG2)=0
*I PHAINT.919
    INDK=(K-IV+IVSKP)/IVSKP
    INDL=(L-IV+IVSKP)/IVSKP
    IF(IFLAG1(INDK).EQ.1.OR.IFLAG1(INDL).EQ.1) IFLAG2(IIFLG2)=1
*D QFHTRC.156
    HTV2(INDZ)=HCCHFA*EXP(-0.0175*TERM)+GTERM*EXP(-0.012*TERM)
*D QFHTRC.178
    FACBR = (1.+0.025*AMAX1(0.,SATT(IDX)-TEMPF(IDX)))
    HCBR=AMAX1(HTV2(INDZ),(CONVAP*TERM1*TERM2*((SATHG(IDX)-SATHG(IDX))
*D QFHTRC.179
    1./AMAX1(TMPBDY-SATT(IDX),0.01)+0.68*CSUBPG(IDX))*9.81/(2.*3.14159)
*D QFHTRC.180
    2    *SORT(9.81*TERM1/SIGMA(IDX))/VISCG(IDX))**0.25*0.62*FACBR)
    VELD=AMAX1(VELG(IDX)-VELF(IDX),0.001)
    DDROP=3.*SIGMA(IDX)/(RHOG(IDX)*VELD**2)
    IF(DDROP.LT.1.5E-4)DDROP=1.5E-4
    IF(DDROP.GT.3.0E-3)DDROP=3.0E-3
    TERM5=1./(1.+0.35*CSUBPG(IDX)*AMAX1(TMPBDY-SATT(IDX),0.0001)
    1    /AMAX1(SATHG(IDX)-SATHF(IDX),0.01))**3.
    HCFO=0.4*3.14159/4.*((6.*(1.-VOIDG(IDX))/3.14159)**0.6666667

```

```

1   *(9.81*RHOF(IDX)*RHOG(IDX)*AMAX1(SATHG(IDX)-SATHF(IDX),0.01)
2   *TERM5*CONVAP/(AMAX1(TMPBDY-TEMPF(IDX),0.0001)*VISCG(IDX)
3   *(3.14159/6.)**0.333333*DDROP))**0.25
    IF(VOIDG(IDX).LE.0.6)THEN
      HCFB=HCBR
    ELSE
      IF(VOIDG(IDX).GE.0.8) THEN
        HCFB=HCFO
      ELSE
        HCFB=(VOIDG(IDX)-0.6)/0.2*HCFO+(0.8-VOIDG(IDX))/0.2
      ENDIF
    ENDIF
*D QFHTRC.187,188
  TERM=TERM2+HCFB
*D QFHTRC.209
  1   *AMAX1(0.023*(REYN2)**0.4*DIAMV(IDX),TERM4)
*D QFHTRC.221,223
  VELD=AMAX1(VELG(IDX)-VELF(IDX),0.001)
  DDROP=3.*SIGMA(IDX)/(RHOG(IDX)*VELD**2)
  IF(DDROP.LT.1.5E-4) DDROP = 1.5E-4
  IF(DDROP.GT.3.0E-3) DDROP = 3.0E-3
  TERM5=1./(1.+0.35*CSUBPG(IDX)*AMAX1(TMPBDY-SATT(IDX),0.0001)
  1   /(SATHG(IDX)-SATHF(IDX)))**3.
  HCFO=0.4*3.14159/4.*((1.-VOIDG(IDX))/3.14159)**0.6666667
  1   *(9.81*RHOF(IDX)*RHOG(IDX)*(SATHG(IDX)-SATHF(IDX)))
  2   *TERM5*CONVAP/(AMAX1(TMPBDY-TEMPF(IDX),0.0001)*VISCG(IDX)
  3   *(3.14159/6.)**0.333333*DDROP))**0.25
    HCFB=HCFO
*I VEXPLT.9
  COMMON/IFLG2/IFLAG2(1000)
*I VEXPLT.322
  CO=1.0
  C1=1.0
  IIFL2=(I-IJ+IJSPK)/IJSPK
  IF(IFLAG2(IIFL2).EQ.1) THEN
    CO=1.2
    C1=(1.0-CO*VOIDGA)/AMAX1((1.-VOIDGA),1.0E-5)
    IF(C1.LT.0.7) C1=0.7
  ENDIF
*D VEXPLT.323
  FJFG=(FIJ(I)*DX*/ABS(C1*VELGJO(I)-CO*VELFJO(I))+0.01)
*D VEXPLT.507
  DIFF=SCRACH+(FRICFJ+CO*FJFG+VPGNX+HLOSSF)*DT
*D VEXPLT.508
  DIFG=-SCRACH-(FRICGJ+C1*FJFG+VPGNX+HLOSSG)*DT
*I VIMPLT.8
  COMMON/IFLG2/IFLAG2(1000)
*I VIMPLT.435
  CO=1.0
  C1=1.0
  IIFL2=(I-IJ+IJSPK)/IJSPK
  IF(IFLAG2(IIFL2).EQ.1) THEN
    CO=1.2
    C1=(1.0-CO*VOIDGA)/AMAX1((1.-VOIDGA),1.0E-5)
    IF(C1.LT.0.7) C1=0.7
  ENDIF
*D VIMPLT.436
  FJFG=(FIJ(I)*DX*/(ABS(C1*VELGJO(I)-CO*VELFJO(I))+0.01)

```

```

*D VIMPLT.591
    COEFV(IDG-1) = (FRICEJ+CO*FJFG+VPGNX+HLOSSF)*DT + SCRACH
*D VIMPLT.592
    COEFV(IDG)   =-(FF1CGJ+C1*FJFG+VPGNX+HLOSSG)*DT - SCRACH
*C DEFINE,PHAINT,QFHTRC,VEA,LT,VIMPLT
*/
*/
*/ END OF PSI UPDATE
*/
*/
*COMPILE ACCUM,PHAINT,DTSTEP
*/
*/ PROTECTS SIGMA (SURFACE TENSION) BY 1.OE-7 IN SUBROUTINE PHAINT
*/
*DELETE,PHAINT.200
    DSTAR(I) =DIAMV(I)*SQRT(9.8*RHOFG/AMAX1(SIGMA(I),1.OE-7))
*DELETE,PHAINT.326
    55 VCRIT=2.5*SQRT(SQRT(AMAX1(SIGMA(I),1.OE-7)*RHOFG)/RHOGL(I))
*/
*/ CORRECT ERROR IN SUBROUTINE DTSTEP INTRODUCED IN CYCLE 30 SO THAT
*/ STATE PROPERTIES ARE NOT RESET WHEN AT A MINIMUM TIMESTEP DUE TO
*/ MASS ERROR
*/
*DELETE,DTSTEP.161
    IF (NANY .EQ. 0) WRITE (OUTPT,2003)
*/
*/ REWET CRITERIA REDUCTION (89/5/23 AKSAN & ICAP)
*I HTRC1.60
    GGT = RHOF(IV)*VOIDF(IV)*VELF(IV)+  

    1      RHOGL(IV)*VOIDG(IV)*VELG(IV)
*I HTRC1.111
    IF(GGT.GT.-100.) GO TO 12
*D HTRC1.112
    IF(XE.GT.XEC.OR.TW.GT.(1250.-TSAT)) GO TO 2000
    GO TO 13
    12 IF(XE.GE.XEC) GO TO 2000
    13 CONTINUE
*I HTRC1.82
    IF(GGT.GT.-100.) GO TO 11
*D HTRC1.83
    IF(TW.GT.1250.-TSAT) GO TO 2000
    11 CONTINUE
*I PSTDNB.28
    GGT = RHOF(IV)*VOIDF(IV)*VELF(IV)+  

    1      RHOGL(IV)*VOIDG(IV)*VELG(IV)
*I PSTDNB.29
    IF(GGT.GT.-100.) GO TO 231
*D PSTDNB.30
    IF(XE.GT.XEC.OR.TW.GT.(1250.-TSAT)) GO TO 235
*I PSTDNB.31
    GO TO 232
    231 IF(XE.GT.XEC) GO TO 235
    232 CONTINUE
*I PSTDNB.124
    IF(GGT.GT.-100.) GO TO 401
*D PSTDNB.126
    1      (1250.-TSAT)) TRANS = .FALSE.
*I PSTDNB.141
    GO TO 499

```

```

401 IF(XE.GE.XEC)TRANS=.FALSE.
    IF(TRANS) THEN
        GO TO 402
    ELSE
        GO TO 403
    ENDIF
402 HTCF=AMAX1(HTBF,HFB)
    HTCG=AMAX1(HTBG,HV)
    QFFO=AMAX1(QTBF,BF)
    QFGO=AMAX1(QTBG,BG)
    GO TO 450
403 HTCF=HFB
    HTCG=HV
    QFFO=QFBF
    QFGO=QFBG
499 CONTINUE
*D PSTDNB.42
    IF(GGT.LT.-100) THEN
        FL=EXP(-5.0*THETA*AMIN1(ABS(TW-TWRTO),SQRT(DTSAT)))
    ELSE
        IF(GGT.GE.-100..AND.GGT.LE.0) THEN
            FL=((EXP(-2.0*THETA*AMIN1(ABS(TW-TWRTO),SQRT(DTSAT))))
1      -EXP(-5.0*THETA*AMIN1(ABS(TW-TWRTO),SQRT(DTSAT))))/100.)*GGT+
2      EXP(-2.0*THETA*AMIN1(ABS(TW-TWRTO),SQRT(DTSAT))))
        ELSE
            FL= EXP(-2.0*THETA*AMIN1(ABS(TW-TWRTO),SQRT(DTSAT)))
        ENDIF
        ENDIF
        FL = FL*AMIN1(1.,(((1.-ALPH)/0.05)**4))
*D PSTDNB.67
    HFB = 0.92163*(SQRT(HFB/SIGMA(IV)))
*I PSTDNB.69
    HCBR = HFB
    VAMA = AMAX1(VELG(IV)-VELF(IV),0.001)
    VFG2 = VAMA**2,
    XA= AMAX1(3.*SIGMA(IV),1.E-10)
    RDIAM =RHOG(IV)*VFG2/XA
    DDROP = 1./RDIAM
    IF(DDROP.LT.1.0E-4) DDROP=1.0E-4
    IF(DDROP.LT.3.0E-3) DDROP=3.0E-3
    TERM5=1./(1.+0.35*CSUBPG(IV))*AMAX1(TW-TSAT,0.001)
1      /AMAX1(SATHG(IV)-SATHF(IV),0.001))**3,
    HCFO=0.2*3.14159/4.*((5.*(1.-VOIDG(IV))/3.14159)**0.6666667
1      *(9.81*RHO(IV)*RHOG(IV)*AMAX1(SATHG(IV)-SATHF(IV),0.01)
2      *TERM5*THCONS**3/(AMAX1(TW-TEMPF(IV),0.01)*VISCS
3      *(3.14159/6.)**0.3333333*DDROP))**0.25
    HCFO = 0.001*HCFO
    IF(VOIDG(IV).LE.0.60) THEN
        HFB=HCBR
    ELSE
        IF(VOIDG(IV).GE.0.80) THEN
            HFB=HCFO
        ELSE
            HFB=(VOIDG(IV)-0.60)/0.2*HCFO+(0.80-VOIDG(IV))/0.2
        1 *HCBR
        ENDIF
        ENDIF
    IF(GGT.LT.0.) THEN
        HHHH=AMAX1(1.E-7,RHO(IV)-RHOG(IV))

```

```
HFB=1.09680*VOIDF(IV)*SQRT((1./1.)
1      *THCONS**3*RHOG(IV)*HHHH*(HFG+0.5*DTSAT*CSUBPG(IV))
2      /(VISCS*DTSAT))**.25
      ENDIF
*C HTRC1,PSTDNB,PREDNB
*/
*/ END OF AKSAN UPDATE
*/
/EOB
*COMPILE SEGDIR
```

NRC FORM 335
(2-89)
NRCM-1102,
3201, 3202

U.S. NUCLEAR REGULATORY COMMISSION

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

2. TITLE AND SUBTITLE

Assessment of RELAP5/MOD2 Cycle 36.04 with LOFT
Large Break LOCE L2-3

5. AUTHOR(S)

Y. S. Bang, H. J. Kim, Korea Institute of Nuclear Safety
S. H. Kim, Korea Atomic Energy Research Institute

8. PERFORMING ORGANIZATION – NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Korea Institute of Nuclear Safety
P.O. Box 16, Daeduk-Danji
Daejoni 300-31
Republic of Korea

9. SPONSORING ORGANIZATION – NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

The LOFT LOCE L2-3 was simulated using the RELAP5/MOD2 Cycle 36.04 code to assess its capability to predict the thermal-hydraulic phenomena in LBLOCA of the PWR. The reactor vessel was simulated with two core channels and split downcomer modelling for a base case calculation using the frozen code. From the results of the base case calculation, deficiencies of the critical flow model and the CHF correlation at high flow rate were identified, and the severeness of the rewetting criteria were also found. Additional calculation using an updated version of RELAP5/MOD2 Cycle 36.04 including modifications of the rewet criteria shows a substantial improvement in the core thermal response.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

RELAP5/MOD2, Assessment, RELAP5/MOD2 Cycle 36.04, LOFT Large Break
LOCE L2-3

1. REPORT NUMBER
(Assigned by NRC. Add Vol., Supp., Rev.
and Addendum Numbers, if any.)
NUREG/IA-0070

3. DATE REPORT PUBLISHED

MONTH	YEAR
April	1992

4. FIN OR GRANT NUMBER
A4682

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

120555139572
US NUREG-0ADM
DIV-FOT & PUBLICATIONS SVCS
TPS-PDP-NUREG
D-211
WASHINGTON
DC 20555

SPECIAL FOURTH-CLASS RATE
POSTAGE AND FEES PAID
USNRC
PERMIT NO. G-87