

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

VERMONT YANKEE NUCLEAR POWER CORPORATION

DOCKET NO. 50-271

VERMONT YANKEE NUCLEAR POWER STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 133 License No. DPR-28

- 1. The Nuclear Regulatory Commission (the fommission or the NRC) has found that:
 - A. The application for amendment filed by the Vermont Yankee Nuclear Power Corporation (the licensee) dated December 23, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as smended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security, or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-28 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.133, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Victor Nerses, Acting Director

Project Directorate I-3 Division of Reactor Projects 1/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 8. 1992

FACILITY OPERATING LICENSE NO. DPR-28 COCKET NO. 50-271

Replace the following page of the Appendix A Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Remove

Insert

54

54

VYNPS

TABLE 4.2.2

Minimum Test and Calibration Frequencies

Primary Containment Isolation Instrumentation

Trip Function	Functional Test(8)	Calibration(8)	Instrumen	t Check
Low-Low Reactor Vessel Water Level	(Note 1)	Once/Operating Cycle	Once Eac	nay .
High Steam Line Area Temperature	(Note 1)	Each Refueling Outage		
High Steam Line Flow	(Note 1)	Once/Operating Cycle	Once Eac	n Day
Low Main Steam Line Pressure	(Note 1)	Every Three Months		
Low Reactor Vessel Water Level	(Note 1)	Once/Operating Cycle		
High Main Steam Line Radiation	(Notes 1 and 7)	Each Refueling Outage	Once Eac	h Day
High Drywell Pressure	(Note 1)	Once/Operating Cycle	Once Eac	h Day
Condenser Low Vacuum	(Note 1)	Every Three Months		
Trip System Logic	Once/Operating Cycle (Note 2)	Once/Operating Cycle (Note 3)		