

ENCLOSURE 2

BEAVER VALLEY UNIT 2 IST PROGRAM

Issue 1, Revision 15

9601190106 951226
PDR ADOCK 05000412
P PDR

DUQUESNE LIGHT COMPANY



Beaver Valley Power Station

Unit 2

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

Issue 1

Revision 15

 9-13-95 Unit Operations Manager Review/Date	Pages Issued i - iv, 1 - 230	OSC Review Date BV-OSC-38-95 9/21/95	Effective Date 9/26/95
Approved by  Date 9/26/95			

List of Effective Pages

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
i	15	40	15
ii	15	41	15
iii	15	42	15
iv	15	43	15
1	15	44	15
2	15	45	15
3	15	46	15
4	15	47	15
5	15	48	15
6	15	49	15
7	15	50	15
8	15	51	15
9	15	52	15
10	15	53	15
11	15	54	15
12	15	55	15
13	15	56	15
14	15	57	15
15	15	58	15
16	15	59	15
17	15	60	15
18	15	61	15
19	15	62	15
20	15	63	15
21	15	64	15
22	15	65	15
23	15	66	15
24	15	67	15
25	15	68	15
26	15	69	15
27	15	70	15
28	15	71	15
29	15	72	15
30	15	73	15
31	15	74	15
32	15	75	15
33	15	76	15
34	15	77	15
35	15	78	15
36	15	79	15
37	15	80	15
38	15	81	15
39	15	82	15

List of Effective Pages (Continued)

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
83	15	126	15
84	15	127	15
85	15	128	15
86	15	129	15
87	15	130	15
88	15	131	15
89	15	132	15
90	15	133	15
91	15	134	15
92	15	135	15
93	15	136	15
94	15	137	15
95	15	138	15
96	15	139	15
97	15	140	15
98	15	141	15
99	15	142	15
100	15	143	15
101	15	144	15
102	15	145	15
103	15	146	15
104	15	147	15
105	15	148	15
106	15	149	15
107	15	150	15
108	15	151	15
109	15	152	15
110	15	153	15
111	15	154	15
112	15	155	15
113	15	156	15
114	15	157	15
115	15	158	15
116	15	159	15
117	15	160	15
118	15	161	15
119	15	162	15
120	15	163	15
121	15	164	15
122	15	165	15
123	15	166	15
124	15	167	15
125	15	168	15

List of Effective Pages (Continued)

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
169	15	212	15
170	15	213	15
171	15	214	15
172	15	215	15
173	15	216	15
174	15	217	15
175	15	218	15
176	15	219	15
177	15	220	15
178	15	221	15
179	15	222	15
180	15	223	15
181	15	224	15
182	15	225	15
183	15	226	15
184	15	227	15
185	15	228	15
186	15	229	15
187	15	230	15
188	15		
189	15		
190	15		
191	15		
192	15		
193	15		
194	15		
195	15		
196	15		
197	15		
198	15		
199	15		
200	15		
201	15		
202	15		
203	15		
204	15		
205	15		
206	15		
207	15		
208	15		
209	15		
210	15		
211	15		

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

Table of Contents

SECTION I:	PUMP TESTING REQUIREMENTS	1
SECTION II:	PUMP TESTING OUTLINES	6
SECTION III:	PUMP MINIMUM OPERATING POINT (MOP) CURVES	37
SECTION IV:	PUMP TESTING RELIEF REQUESTS	66
SECTION V:	VALVE TESTING REQUIREMENTS	77
SECTION VI:	VALVE TESTING OUTLINES	85
SECTION VII:	VALVE TESTING COLD SHUTDOWN JUSTIFICATIONS	155
SECTION VIII:	VALVE TESTING RELIEF REQUESTS	192

SECTION I: PUMP TESTING REQUIREMENTS

The Inservice Test (IST) Program for pumps at Beaver Valley Power Station (BVPS), Unit 2, is based on subsection IWP - Inservice Testing of Pumps of the ASME Boiler and Pressure Vessel Code, Section XI, 1983 edition through the summer 1983 addenda (the code) and Generic Letter 89-04, "Guidance on Developing Acceptable Inservice Testing Programs", including Supplement 1 (NUREG-1482, "Guidelines for Inservice Testing at Nuclear Power Plants"). The pumps included in this program are all ASME "class 1, 2, or 3 centrifugal or displacement type pumps that are required to perform a specific function in shutting down the reactor or in mitigating the consequences of an accident, and that are provided with an emergency power source" at BVPS, Unit 2.

The requirements of the code will be followed at all times unless specific relief has been granted by the NRC. An inservice test, run quarterly, to measure or observe the test quantities listed in Table IWP-3100-1, below, is required for all pumps in the IST Program by the code.

Table IWP-3100-1
INSERVICE TEST QUANTITIES

Quantity	Measure	Observe
Speed N (if variable speed)	✓	
Inlet pressure P_i	✓(1)	
Differential pressure ΔP	✓	
Flow rate Q	✓	
Vibration amplitude V	✓	
Proper lubricant level or pressure		✓
Bearing temperature T_b	✓	

NOTE:
(1) Measure before pump startup and during test.

Table IWP-3100-2 shows the allowable ranges for test results that will be used to determine if corrective action is required following performance of BVPS-2 Surveillance Tests. The test data will be compared to the ranges applied to the reference values for each test quantity. If these ranges cannot be met, reduced range limits that allow the pump to fulfill its function will be used as permitted by IWP-3210 and in accordance with IWP-3112, in lieu of the ranges given in Table IWP-3100-2.

Table IWP-3100-2
ALLOWABLE RANGES OF TEST QUANTITIES

Test Quantity	Acceptable Range	Alert Range (Note (1))		Required Action Range (Note (1))	
		Low Values	High Values	Low Values	High Values
P_i	(Note (2))	(Note (2))	(Note (2))	(Note (2))	(Note (2))
ΔP	0.93-1.02 ΔP_r	0.90-0.93 ΔP_r	1.02-1.03 ΔP_r	< 0.90 ΔP_r	> 1.03 ΔP_r
Q	0.94-1.02 Q_r	0.90-0.94 Q_r	1.02-1.03 Q_r	< 0.90 Q_r	> 1.03 Q_r
V when $0 \leq V_r \leq 0.5$ mils	0-1 mil	None	1-1.5 mils	None	> 1.5 mils
V when $0.5 \text{ mils} < V_r \leq 2.0$ mils	0-2V,mils	None	2V,-3V,mils	None	> 3V,mils
V when $2.0 \text{ mils} < V_r \leq 5.0$ mils	0-(2 + V _r) mils	None	(2 + V _r)-(6 + V _r) mils	None	> (4 + V _r)mils
V when $V_r > 5.0$ mils	0-1.4V,mils	None	1.4V,-1.8V,mils	None	> 1.8V,mils
T_b	(Note (3))	(Note (3))	(Note (3))	(Note (3))	(Note (3))

NOTES:
(1) See IWP-3230.
(2) P_i shall be within the limits specified by Owner in the record of tests (IWP-6000).
(3) T_b shall be within the limits specified by Owner in the record of tests (IWP-6000).

The limits for vibration readings are taken from ASME/ANSI OM-6 as permitted by relief and are measured in velocity units. These limits may not be reduced because OM-6 does not contain a paragraph similar to IWP-3210.

Corrective action shall be taken if necessary using the following:

1. If deviations fall within the "Alert Range" of Table IWP-3100-2, the frequency of testing shall be doubled until the cause of the deviation is determined and corrected.
2. If the deviations fall within the "Required Action Range" of Table IWP-3100-2, the pump shall be declared inoperative immediately and an evaluation of the pump's condition with respect to system operability and technical specifications shall be made as follows:
 - a. If the inoperable pump is specifically identified in the technical specifications, then the applicable technical specification action statements shall be followed.
 - b. If the inoperable pump is in a system covered by a technical specification, an assessment of its condition must be made to determine if it makes the system inoperable. If the condition of the pump renders the system inoperable, then the applicable system technical specification action statements shall be followed.
 - c. Corrective action shall be either replacement or repair per IWP-3111, or shall be an analysis to demonstrate that the condition does not impair pump operability and that the pump will still fulfill its function. A new set of reference values shall be established after such analysis.
 - d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supercede the requirements of any technical specification.
3. When tests show deviations greater than allowed (see Table IWP-C100-2), the instruments involved may be recalibrated and the test rerun. This is an alternative to replacement or repair, not an additional action that can be taken before declaring the pump inoperative.
4. The pump shall not be returned to service until the condition has been corrected. The corrective action shall be considered completed when a satisfactory inservice test has been conducted in accordance with IWP-3111.

Per IWP-3500 each pump shall run at least 5 minutes under conditions as stable as the system permits prior to measurement of the specified parameters.

Utilization of a pump curve in the BVPS-2 IST Program for performing testing and establishing acceptance criteria requires specific relief approved by the NRC prior to usage. The following guidance provided by the NRC relating to the use of a pump curve shall be followed:

1. A pump curve shall be developed, or manufacturer's pump curve validated, when the pump is known to be operating acceptably.
2. The reference points used to develop or validate a pump curve shall be measured using instruments at least as accurate (accuracy and range) as required by the ASME XI Code.

3. A pump curve shall be based on an adequate number of reference points, with a minimum of five (5).
4. Sufficient reference points shall be beyond the "flat" portion (low flow rates) of the pump curve in a range which includes or is as close as practical to the design basis flow rate.
5. Acceptance criteria based on a pump curve does not conflict with technical specifications or UFSAR operability criteria (minimum operating point/curve) for flow rate and differential pressure for the affected pump.
6. If vibration levels vary significantly over the range of pump conditions, a method of assigning appropriate vibration acceptance criteria should be developed for regions of the pump curve.
7. When the reference pump curve may have been affected by repair, replacement, or routine servicing, a new reference pump curve shall be determined or the previous pump curve revalidated by an inservice test.

Manufacturer supplied skid-mounted pumps which are integral sub-components of, and are required to support operation of a parent pump or other component, are often times not designed to be tested in accordance with the ASME XI Code, regardless of their ASME Code class. Although ASME Code class skid-mounted pumps are not included in the BVPS Unit 2 IST Program, they are tested in conjunction with the parent pump or other component for which they provide support, as documented in the IST Program Basis Document and applicable surveillance test. This ensures that the skid-mounted pumps operate acceptably commensurate with their safety functions provided satisfactory performance of the parent pump or other component is demonstrated. Because it has been recognized that the test of the parent pump or other component itself challenges the operability of the sub-components, relief from Code testing requirements and including ASME Code class manufacturer supplied skid-mounted pumps in the IST Program has been approved by the NRC.

Records of the results of inservice tests and corrective actions as required by subsection IWP-6000 are trended in tabular form. Pump performance characteristics will be examined for trends.

The following three sections of this document are the "Pump Testing Outlines", "Pump Minimum Operating Point (MOP) Curves" and "Pump Relief Requests" sections. The "Pump Testing Outlines" section is a listing of all the pumps in the IST Program, their testing requirements, and their specific relief request reference numbers. The pumps are arranged according to system and pump mark number. The following abbreviations and designations are used on the Pump Testing Outlines and throughout the IST Program for pumps:

1. Under Parameter column
 - a. (N) - Speed
 - b. (Pi) - Inlet Pressure
 - c. (ΔP) - Differential Pressure
 - d. (Q) - Flowrate
 - e. (V) - Vibration
-

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

- f. (Tb) - Bearing Temperature
 - g. (L) - Lubricant Level or Pressure
2. Under 2OST column
- a. (2BVT) - Unit 2 Beaver Valley Test
 - b. (2OST) - Unit 2 Operating Surveillance Test
 - c. (Q) - Quarterly Test Frequency
 - d. (A) - Annual Test Frequency
 - e. (CSD) - Cold Shutdown Frequency
 - f. (R) - Refueling Test Frequency
 - g. (NA) - Not Applicable
3. Under Req'd column
- a. (RR) - Relief Request
 - b. (X) - Meets or exceeds ASME requirements
 - c. (E) - Exempt
 - d. (NA) - Not Applicable

The "Pump Minimum Operating Point (MOP) Curves" section contains a graphical representation of the minimum allowable pump flow versus head, which is required to meet the applicable safety analysis, for each centrifugal pump in the Unit 2 IST Program.

The "Pump Relief Requests" section contains the detailed technical description of particular conditions and equipment installations prohibiting the testing of some of the characteristics of safety-related pumps. An alternate test method and the frequency of revised testing is also included to meet the intent of 10CFR50.55a. The relief request(s) for a specific pump is referenced by the number(s) listed on the pump's testing outline sheet.

SECTION II: PUMP TESTING OUTLINES

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Charging Pump		Pump Number: 2CHS*P21A	Code Class: 2	Dwg. OM No.: 7-1 Dwg. Coord.: D-8	System: 7 Chemical and Volume Control
Function: To provide normal RCS inventory makeup, Seal Injection and High Head Safety Injection		Type: Centrifugal		Remarks: Pump is tested quarterly on recirculation flow and at full flow during Refueling outages. Also see RR9.	
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	7.4 (Q)	X	Pump Suction Pressure Indicator [2CHS-PI151A], local.		
	11.14B (R)	X	Pump Suction Pressure Indicator [2CHS-PI151A], local.		
ΔP	7.4 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI151B] and Pump Suction Pressure, local.		
	11.14B (R)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI151B] and Pump Suction Pressure, local.		
Q	7.4 (Q)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A, 160], Control Room, and [2CHS-FI170], local.		
	11.14B (R)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A] and [2SIS-FI943], Control Room.		
V	7.4 (Q)	RR9	Portable monitoring equipment using velocity units.		
	11.14B (R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	7.4 (Q)	X	Sight glass on oil reservoir, local.		
	11.14B (R)	X	Sight glass on oil reservoir, local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Charging Pump	Pump Number: 2CHS*P21B	Code Class: 2	Dwg. OM No.: 7-1 Dwg. Coord.: D-9	System: 7 Chemical and Volume Control
-------------------------------------	-------------------------------	----------------------	--	--

Function: To provide normal RCS inventory makeup, Seal Injection and High Head Safety Injection
Type: Centrifugal
Remarks: Pump is tested quarterly on recirculation flow and at full flow during Refueling outages. Also see RR9.

Parameter	20ST (Frequency)	Req'd	Comments
N	NA	NA	Constant speed induction motor.
PI	7.5 (Q)	X	Pump Suction Pressure Indicator [2CHS-PI152A], local.
	11.14B (R)	X	Pump Suction Pressure Indicator [2CHS-PI152A], local.
ΔP	7.5 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI152B] and Pump Suction Pressure, local.
	11.14B (R)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI152B] and Pump Suction Pressure, local.
Q	7.5 (Q)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A, 160], Control Room, and [2CHS-FI170], local.
	11.14B (R)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A] and [2SIS-FI943], Control Room.
V	7.5 (Q)	RR9	Portable monitoring equipment using velocity units.
	11.14B (R)	RR9	Portable monitoring equipment using velocity units.
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.
L	7.5 (Q)	X	Sight glass on oil reservoir, local.
	11.14B (R)	X	Sight glass on oil reservoir, local.

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21C Charging Pump		Pump Number: 2CHS*P21C	Code Class: 2	Dwg. OM No.: 7-1 Dwg. Coord.: D-10	System: 7 Chemical and Volume Control
Function: To provide normal RCS inventory makeup, Seal Injection and High Head Safety Injection		Type: Centrifugal	Remarks: Pump is tested quarterly on recirculation flow and at full flow during Refueling outages. Also see RR9		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	7.6 (Q)	X	Pump Suction Pressure Indicator [2CHS-PI153A], local.		
	11.14B (R)	X	Pump Suction Pressure Indicator [2CHS-PI153A], local.		
ΔP	7.6 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI153B] and Pump Suction Pressure, local.		
	11.14B (R)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI153B] and Pump Suction Pressure, local.		
Q	7.6 (Q)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A, 160], Control Room, and [2CHS-FI170], local.		
	11.14B (R)	X	Summation of flow rates from Flow Indicators [2CHS-FI122A, 124A, 127A, 130A] and [2SIS-FI943], Control Room.		
V	7.6 (Q)	RR9	Portable monitoring equipment using velocity units.		
	11.14B (R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	7.6 (Q)	X	Sight glass on oil reservoir, local.		
	11.14B (R)	X	Sight glass on oil reservoir, local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 22B Boric Acid Transfer Pump		Pump Number: 2CHS*P22B	Code Class: 3	Dwg. OM No.: 7-2 Dwg. Coord.: F-3	System: 7 Chemical and Volume Control
Function: Chemical Shim and Emergency Boration Supply		Type: Centrifugal	Remarks: See RR9.		
Parameter	20ST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	7.2 (Q)	X	Pump Suction Pressure Indicator [2CHS-PI123B], local.		
ΔP	7.2 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2CHS-PI110] and Pump Suction Pressure, local.		
Q	7.2 (Q)	X	Flow Indicator [2CHS-FI123B], local.		
V	7.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	7.2 (Q)	X	Level indication provided at the constant level oiler (local) on bearing housing.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Residual Heat Removal Pump		Pump Number: 2RHS*P21A	Code Class: 2	Dwg. OM No.: 10-1 Dwg. Coord.: B-3	System: 10 Residual Heat Removal
Function: Long term decay heat removal		Type: Vertical	Remarks: See RR1. Pump is tested quarterly during Cold Shutdowns and Refueling outages. Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	10.1 (CSD,R)	X	Pump Suction Pressure Indicator [2RHS-PI603A], Control Room.		
ΔP	10.1 (CSD,R)	X	Calculated using Pump Discharge Pressure Indicator [2RHS-PI602A] and Pump Suction Pressure, Control Room.		
Q	10.1 (CSD,R)	X	Summation of flow rates from Recirculation Line flow Indicator [2RHS-FI607A], Return Line Flow Indicator to Cold Leg 22 [2RHS-FI605A], and Letdown Line Flow [2CHS-FI150], Control Room.		
V	10.1 (CSD,R)	RR9	Portable monitoring equipment using velocity units. (Pump bearings in the driver)		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	10.1 (CSD,R)	X	Motor bearings upper and lower - oil sight glass - local (pump and driver bearings integral in motor).		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Residual Heat Removal Pump		Pump Number: 2RHS*P21B	Code Class: 2	Dwg. OM No.: 10-1 Dwg. Coord.: E-3	System: 10 Residual Heat Removal
Function: Long term decay heat removal		Type: Vertical	Remarks: See RR1. Pump is tested quarterly during Cold Shutdowns and Refueling outages. Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	10.2 (CSD,R)	X	Pump Suction Pressure Indicator [2RHS-PI603B], Control Room.		
ΔP	10.2 (CSD,R)	X	Calculated using Pump Discharge Pressure Indicator [2RHS-PI602B] and Pump Suction Pressure, Control Room.		
Q	10.2 (CSD,R)	X	Summation of flow rates from Recirculation Line flow Indicator [2RHS-FI607B], Return Line Flow Indicator to Cold Leg 22 [2RHS-FI605B], and Letdown Line Flow [2CHS-FI150], Control Room.		
V	10.2 (CSD,R)	RR9	Portable monitoring equipment using velocity units. (Pump bearings in the driver)		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	10.2 (CSD,R)	X	Motor bearings upper and lower - oil sight glass - local (pump and driver bearings integral in motor).		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Low Head Safety Injection Pump		Pump Number: 2SIS*P21A	Code Class: 2	Dwg. OM No.: 11-1 Dwg. Coord.: E-2	System: 11 Safety Injection
Function: Low Pressure - High Volume Safety Injection		Type: Centrifugal	Remarks: Pump is tested quarterly on recirculation flow and at full flow during Refueling outages. Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	11.1 (Q)	X	Pump Suction Pressure Indicator [2SIS-PI938], local.		
	11.14A (R)	X	Pump Suction Pressure Indicator [2SIS-PI938], local.		
ΔP	11.1 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2SIS-PI943] and Pump Suction Pressure, local.		
	11.14A (R)	X	Calculated using Pump Discharge Pressure Indicator [2SIS-PI943] and Pump Suction Pressure, local.		
Q	11.1 (Q)	X	Flow indicator [2SIS-FIS970A], local.		
	11.14A (R)	X	Flow Indicator [2SIS-FI945], Control Room.		
V	11.1 (Q)	RR9	Portable monitoring equipment using velocity units		
	11.14A (R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	11.1 (Q)	X	Level indication provided at the constant level oiler (local) on each bearing housing.		
	11.14A (R)	X	Level indication provided at the constant level oiler (local) on each bearing housing.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Low Head Safety Injection Pump		Pump Number: 2SIS-P21B	Code Class: 2	Dwg. OM No.: 11-1 Dwg. Coord.: G-2	System: 11 Safety Injection
Function: Low Pressure - High Volume Safety Injection		Type: Centrifugal	Remarks: Pump is tested quarterly on recirculation flow and at full flow during Refueling outages. Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	11.2 (Q)	X	Pump Suction Pressure Indicator [2SIS-PI939], local.		
	11.14A (R)	X	Pump Suction Pressure Indicator [2SIS-PI939], local.		
ΔP	11.2 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2SIS-PI944] and Pump Suction Pressure, local.		
	11.14A (R)	X	Calculated using Pump Discharge Pressure Indicator [2SIS-PI944] and Pump Suction Pressure, local.		
Q	11.2 (Q)	X	Flow Indicator [2SIS-FIS970B], local.		
	11.14A (R)	X	Flow Indicator [2SIS-FI946], Control Room.		
V	11.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
	11.14A (R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	11.2 (Q)	X	Level indication provided at the constant level oiler (local) on each bearing housing.		
	11.14A (R)	X	Level indication provided at the constant level oiler (local) on each bearing housing.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Quench Spray Pump		Pump Number: 2QSS*P21A	Code Class: 2	Dwg. OM No.: 13-2 Dwg. Coord.: A-9	System: 13 Containment Depressurization
Function: To provide borated water from the RWST to the Containment Spray Header for containment depressurization following a DBA.		Type: Centrifugal	Remarks: See RR9.		
Parameter	20ST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	13.1 (Q)	X	Pump Suction Pressure Indicator [2QSS-PI102A], Control Room.		
ΔP	13.1 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2QSS-PI101A] and Pump Suction Pressure, Control Room.		
Q	13.1 (Q)	X	Flow Indicator [2QSS-FIS101A or 102A], local.		
V	13.1 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	13.1 (Q)	X	Level indication provided at the constant level oilers (local) on each bearing housing.		

BVPS-2 IST		PUMP TESTING OUTLINE	
Pump Name: 21B Quench Spray Pump	Pump Number: 2QSS-P21B	Code Class: 2	Dwg. OM No.: 13-2 Dwg. Coord.: G-9
Function: To provide borated water from the RWST to the Containment Spray Header for containment depressurization following a DBA.		Type: Centrifugal	System: 13 Containment Depressurization
Parameter	2OST (Frequency)	Req'd	Comments
N	NA	NA	Constant speed induction motor.
PI	13.2 (0)	X	Pump Suction Pressure Indicator [2QSS-PI102B], Control Room.
ΔP	13.2 (0)	X	Calculated using Pump Discharge Pressure Indicator [2QSS-PI101B] and Pump Suction Pressure, Control Room.
Q	13.2 (0)	X	Flow Indicator [2QSS-FIS101B or 102B], local.
V	13.2 (0)	RR9	Portable monitoring equipment using velocity units.
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.
L	13.2 (0)	X	Level indication provided at the constant level oilers (local) on each bearing housing.

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS-2 IST									
PUMP TESTING OUTLINE									
Pump Name: 24A Chemical Injection Pump		Pump Number: 20SS-P24A	Code Class: 2	Dwg. OM No.: 13-2	System: 13 Containment Depressurization				
Function: Chemical injection to the Quench Spray System during Containment depressurization.		Type: Positive Displacement	Remarks: See RR6 and RR9						
Parameter	20ST (Frequency)	Req'd	Comments						
N	NA	NA	Constant speed induction motor.						
PI	13.10A (O)	RR6	Positive displacement pump. Suction pressure not required.						
ΔP	13.10A (O)	RR6	Based on Pump Discharge Pressure Indicator [20SS-PI111A], local.						
Q	13.10A (O)	X	Flow Indicator [20SS-FIS105A], local.						
V	13.10A (O)	RR9	Portable monitoring equipment using velocity units.						
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units						
L	NA	NA	Pump bearing is grease lubricated via grease fitting - no observable lubrication level.						

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS-2 IST									
PUMP TESTING OUTLINE									
Pump Name: 24B Chemical Injection Pump		Pump Number: 2QSS-P24B		Code Class: 2		Dwg. OM No.: 13-2		System: 13 Containment Depressurization	
Function: Chemical injection to the Quench Spray System during Containment depressurization.		Type: Positive Displacement		Remarks: See RR6 and RR9.					
Parameter	20ST (Frequency)	Req'd	Comments						
N	NA	NA	Constant speed induction motor.						
PI	13.10B (Q)	RR6	Positive displacement pump. Suction pressure not required						
ΔP	13.10B (C)	RR6	Based on Pump Discharge Pressure Indicator [2QSS-PI111B], local						
Q	13.10B (Q)	X	Flow Indicator [2QSS-FIS105B], local						
V	13.10B (Q)	RR9	Portable monitoring equipment using velocity units.						
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.						
L	NA	NA	Pump bearing is grease lubricated via grease fitting - no observable lubrication level.						

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Recirculation Spray Pump	Pump Number: 2RSS-P21A	Code Class: 2	Dwg. OM No.: 13-1	System: 13 Containment Depressurization
			Dwg. Coord.: F-2	

Function: Circulate containment sump water for long term containment depressurization	Type: Vertical	Remarks: See RR2. Pump is normally tested dry in Modes 1 through 4, and with flow during Refueling outages only. Also see RR9.
--	-----------------------	---

Parameter	2OST (Frequency)	Req'd	Comments
N	NA	NA	Constant speed induction motor.
PI	13.3 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	No permanently installed suction pressure gauge. Test connection for local temporary test gauge.
ΔP	13.3 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Calculated using Pump Discharge Pressure Indicator [2RSS-PI156A], Control Room, and local pressure test gauge.
Q	13.3 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Flow Indicator [2RSS-FI157A], Control Room.
V	13.3 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	RR9	Portable monitoring equipment using velocity units.
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.
L	NA	NA	Motor bearings grease lubricated no observable level. Pump has self-lubricated bearing - internal pump fluid porting not observable.

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Recirculation Spray Pump	Pump Number: 2RSS-P21B	Code Class: 2	Dwg. OM No.: 13-1 Dwg. Coord.: E-8	System: 13 Containment Depressurization
--	-------------------------------	----------------------	---	--

Function: Circulate containment sump water for long term containment depressurization
Type: Vertical
Remarks: See RR2. Pump is normally tested dry in Modes 1 through 4, and with flow during Refueling outages only. Also see RR9

Parameter	2OST (Frequency)	Req'd	Comments
N	NA	NA	Constant speed induction motor.
Pi	13.4 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	No permanently installed suction pressure gauge. Test connection for local temporary test gauge.
ΔP	13.4 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Calculated using Pump Discharge Pressure Indicator [2RSS-PI156B], Control Room, and local pressure test gauge.
Q	13.4 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Flow Indicator [2RSS-FI157B], Control Room.
V	13.4 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	RR9	Portable monitoring equipment using velocity units.
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.
L	NA	NA	Motor bearings grease lubricated no observable level. Pump has self-lubricated bearing - internal pump fluid porting not observable.

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21C Recirculation Spray Pump	Pump Number: 2RSS*P21C	Code Class: 2	Dwg. OM No.: 13-1	System: 13 Containment Depressurization
			Dwg. Coord.: E-5	

Function: Circulate containment sump water for long term containment depressurization and long term core recirculation	Type: Vertical	Remarks: See RR2. Pump is normally tested dry in Modes 1 through 4, and with flow during Refueling outages only. Also see RR9.
---	-----------------------	---

Parameter	2OST (Frequency)	Req'd	Comments
N	NA	NA	Constant speed induction motor.
PI	13.5 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	No permanently installed suction pressure gauge. Test connection for local temporary test gauge.
ΔP	13.5 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Calculated using Pump Discharge Pressure Indicator [2RSS-P1156C], Control Room, and local pressure test gauge.
Q	13.5 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	X	Flow Indicator [2RSS-F1157C], Control Room.
V	13.5 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.
	2BVT 1.13.5 (R)	RR9	Portable monitoring equipment using velocity units.
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.
L	NA	NA	Motor bearings grease lubricated no observable level. Pump has self-lubricated bearing - internal pump fluid porting not observable.

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21D Recirculation Spray Pump		Pump Number: 2RSS-P21D	Code Class: 2	Dwg. OM No.: 13-1 Dwg. Coord.: E-6	System: 13 Containment Depressurization
Function: Circulate containment sump water for long term containment depressurization and long term core recirculation		Type: Vertical		Remarks: See RR2. Pump is normally tested dry in Modes 1 through 4, and with flow during Refueling outages only. Also see RR9.	
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	13.6 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.		
	2BVT 1.13.5 (R)	X	No permanently installed suction pressure gauge. Test connection for local temporary test gauge.		
ΔP	13.6 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.		
	2BVT 1.13.5 (R)	X	Calculated using Pump Discharge Pressure Indicator [2RSS-PI156D], Control Room, and local pressure test gauge.		
Q	13.6 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.		
	2BVT 1.13.5 (R)	X	Flow Indicator [2RSS-FI157D], Control Room.		
V	13.6 (Q)	RR2	Pump run dry and stopped as soon as pump start is verified, pump not run more than 60 seconds.		
	2BVT 1.13.5 (R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	NA	NA	Motor bearings grease lubricated no observable level. Pump has self-lubricated bearing - internal pump fluid porting not observable.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Component Cooling Water Pump		Pump Number: 2CCP-P21A	Code Class: 3	Dwg. DM No.: 15-1 Dwg. Coord.: B-4	System: 15 Primary Component Cooling Water
Function: Provide Cooling Water to Residual Heat Removal Heat Exchangers and Rx Plant Components		Type: Centrifugal	Remarks: See RR7 (Pump Curve). Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	15.1 (Q)	X	Suction Pressure Indicator [2CCP-PI150A], local.		
ΔP	15.1 (Q)	X	Calculated using Discharge Pressure Indicator [2CCP-PI145A], Control Room, and Pump Suction Pressure, local.		
Q	15.1 (Q)	X	Containment Cooling Water Supply Header Flow Indicator [2CCP-FI117A1], Control Room.		
V	15.1 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	15.1 (Q)	X	Level indication provided at the constant level oiler (local) on bearing housing.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Component Cooling Water Pump		Pump Number: 2CCP-P21B	Code Class: 3	Dwg. OM No.: 15-1 Dwg. Coord.: F-4	System: 15 Primary Component Cooling Water
Function: Provide Cooling Water to Residual Heat Removal Heat Exchangers and Rx Plant Components		Type: Centrifugal	Remarks: See RR7 (Pump Curve). Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	15.2 (Q)	X	Suction Pressure Indicator [2CCP-PI150B], local.		
ΔP	15.2 (Q)	X	Calculated using Discharge Pressure Indicator [2CCP-PI145B], Control Room, and Pump Suction Pressure, local.		
Q	15.2 (Q)	X	Summation of flow rates from Containment Cooling Water Supply Header Flow Indicator [2CCP-FI117B1], Control Room, Nonregenerative Heat Exchanger Branch Flow Indicator [2CCP-FI103] and Seal Water Heat Exchanger Branch Flow Indicator [2CCP-FI102], local.		
V	15.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	15.2 (Q)	X	Level indication provided at the constant level oiler (local) on bearing housing		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21C Component Cooling Water Pump		Pump Number: 2CCP-P21C	Code Class: 3	Dwg. OM No.: 15-1 Dwg. Coord.: D-4	System: 15 Primary Component Cooling Water
Function: Provide Cooling Water to Residual Heat Removal Heat Exchangers and Rx Plant Components		Type: Centrifugal	Remarks: See RR7 (Pump Curve). Also see RR9.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	15.3 (Q)	X	Suction Pressure Indicator [2CCP-PI150C], local.		
ΔP	15.3 (Q)	X	Calculated using Discharge Pressure Indicator [2CCP-PI145C], Control Room, and Pump Suction Pressure, local.		
Q	15.3 (Q)	X	Containment Cooling Water Supply Header Flow Indicator [2CCP-FI117A1], Control Room, OR summation of flow rates from Containment Cooling Water Supply Header Flow Indicator [2CCP-FI117B1], Control Room, Nonregenerative Heat Exchanger Branch Flow Indicator [2CCP-FI103] and Seal Water Heat Exchanger Branch Flow Indicator [2CCP-FI102], local.		
V	15.3 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	15.3 (Q)	X	Level indication provided at the constant level oiler (local) on bearing housing.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: Turbine Driven Auxiliary Feedwater Pump		Pump Number: 2FWE*P22	Code Class: 3	Dwg. OM No.: 24-3 Dwg. Coord.: E-4	System: 24 Auxiliary Feedwater
Function: Provide emergency makeup to Steam Generator during loss of normal feedwater		Type: Centrifugal	Remarks: Pump is tested monthly on recirculation flow and at full flow when in Mode 3 during startup from cold shutdowns and refueling outages. Also see RR9.		
Parameter	20ST (Frequency)	Req'd	Comments		
N	24.4 (Q)	X	Tachometer may be provided with steam turbine depending on governor installed, local, or use portable monitoring equipment - Stroboscope.		
	24.4 (CSD,R)	X	Tachometer may be provided with steam turbine depending on governor installed, local, or use portable monitoring equipment - Stroboscope.		
Pi	24.4 (Q)	X	Pump Suction Pressure Indicator [2FWE-Pi156], local.		
	24.4 (CSD,R)	X	Pump Suction Pressure Indicator [2FWE-Pi156], local.		
ΔP	24.4 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-Pi155] and Pump Suction Pressure, local.		
	24.4 (CSD,R)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-Pi155] and Pump Suction Pressure, local.		
Q	24.4 (Q)	X	Flow Indicator [2FWE-Fi155], local.		
	24.4 (CSD,R)	X	Summation of flow rates from SG Aux FW Line Flow Indicators [2FWE-Fi100A,B,C], Control Room.		
V	24.4 (Q)	RR9	Portable monitoring equipment using velocity units.		
	24.4 (CSD,R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	24.4 (Q)	X	Sight glass on oil reservoir, local.		
	24.4 (CSD,R)	X	Sight glass on oil reservoir, local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 23A Motor Driven Auxiliary Feedwater Pump		Pump Number: 2FWE*P23A	Code Class: 3	Dwg. OM No.: 24-3 Dwg. Coord.: F-4	System: 24 Auxiliary Feedwater
Function: Provide emergency makeup to Steam Generator during loss of normal feedwater		Type: Centrifugal	Remarks: Pump is tested monthly on recirculation flow and at full flow during cold shutdowns and refueling outages. Also see RR9		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	24.2 (Q)	X	Pump Suction Pressure Indicator [2FWE-PI156A], local.		
	24.6 (CSD,R)	X	Pump Suction Pressure Indicator [2FWE-PI156A], local.		
ΔP	24.2 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-PI155A] and Pump Suction Pressure, local.		
	24.6 (CSD,R)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-PI155A] and Pump Suction Pressure, local.		
Q	24.2 (Q)	X	Flow Indicator [2FWE-FI155A], local.		
	24.6 (CSD,R)	X	Summation of flow rates from SG Aux FW Line Flow Indicators [2FWE-FI100A,B,C], Control Room.		
V	24.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
	24.6 (CSD,R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	24.2 (Q)	X	Sight glass on oil reservoir, local.		
	24.6 (CSD,R)	X	Sight glass on oil reservoir, local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 23B Motor Driven Auxiliary Feedwater Pump		Pump Number: 2FWE-P23B	Code Class: 3	Dwg. OM No.: 24-3 Dwg. Coord.: G-4	System: 24 Auxiliary Feedwater
Function: Provide emergency makeup to Steam Generator during loss of normal feedwater		Type: Centrifugal	Remarks: Pump is tested monthly on recirculation flow and at full flow during cold shutdowns and refueling outages. Also see RR9.		
Parameter	20ST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
Pi	24.3 (Q)	X	Pump Suction Pressure Indicator [2FWE-PI156B], local.		
	24.6 (CSD,R)	X	Pump Suction Pressure Indicator [2FWE-PI156B], local.		
ΔP	24.3 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-PI155B] and Pump Suction Pressure, local.		
	24.6 (CSD,R)	X	Calculated using Pump Discharge Pressure Indicator [2FWE-PI155B] and Pump Suction Pressure, local.		
Q	24.3 (Q)	X	Flow Indicator [2FWE-FI155B], local.		
	24.6 (CSD,R)	X	Summation of flow rates from SG Aux FW Line Flow Indicators [2FWE-FI100A,B,C], Control Room.		
V	24.3 (Q)	RR9	Portable monitoring equipment using velocity units.		
	24.6 (CSD,R)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	24.3 (Q)	X	Sight glass on oil reservoir, local.		
	24.6 (CSD,R)	X	Sight glass on oil reservoir, local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Service Water Pump		Pump Number: 2SWS-P21A	Code Class: 3	Dwg. OM No.: 30-1 Dwg. Coord.: C-2	System: 30 Service Water
Function: Provide cooling water to Recirculation Spray Heat Exchangers and Reactor Plant components under normal and emergency conditions		Type: Vertical		Remarks: See RR3, RR8 (Pump Curve), and RR9	
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	30.2 (Q)	RR3	No installed instrumentation to measure suction pressure. Calculate Pi using Unit No. 1 Ohio River Intake Water Level Indicator [LR-1CW-101], local.		
ΔP	30.2 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2SWS-PI101A] local, and Intake Water Level.		
Q	30.2 (Q)	X	Portable Flow Indicator [2SWS-FIT100], local.		
V	30.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	30.2 (Q)	X	Upper motor bearing oil level sight glass, bottom motor bearing grease lubricated, bottom pump bearing grease lubricated and sealed at factory. Shaft bearing freshwater lubricated and can be observed with Supply Pressure Indicator [2SWS-PI105A], local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Service Water Pump		Pump Number: 2SWS*P21B	Code Class: 3	Dwg. OM No.: 30-1 Dwg. Coord.: D-2	System: 30 Service Water
Function: Provide cooling water to Recirculation Spray Heat Exchangers and Reactor Plant components under normal and emergency conditions		Type: Vertical	Remarks: See RR3, RR8 (Pump Curve), and RR9		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	30.3 (Q)	RR3	No installed instrumentation to measure suction pressure. Calculate Pi using Unit No. 1 Ohio River Intake Water Level Indicator [LR-1CW-101], local.		
ΔP	30.3 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2SWS-PI101B], local, and Intake Water Level.		
Q	30.3 (Q)	X	Portable Flow Indicator [2SWS-FIT100S], local.		
V	30.3 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	30.3 (Q)	X	Upper motor bearing oil level sight glass, bottom motor bearing grease lubricated, bottom pump bearing grease lubricated and sealed at factory. Shaft bearing freshwater lubricated and can be observed with Supply Pressure Indicator [2SWS-PI105B], local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21C Service Water Pump		Pump Number: 2SWS*P21C	Code Class: 3	Dwg. OM No.: 30-1 Dwg. Coord.: G-2	System: 30 Service Water
Function: Provide cooling water to Recirculation Spray Heat Exchangers and Reactor Plant components under normal and emergency conditions		Type: Vertical		Remarks: See RR3, RR8 (Pump Curve), and RR9.	
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	30.6 (Q)	RR3	No installed instrumentation to measure suction pressure. Calculate Pi using Unit No. 1 Ohio River Intake Water Level Indicator [LR-1CW-101], local.		
ΔP	30.6 (Q)	X	Calculated using Pump Discharge Pressure Indicator [2SWS-PI101C], local, and Intake Water Level.		
Q	30.6 (Q)	X	Portable Flow Indicator [2SWS-FIT100(S)], local.		
V	30.6 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	30.6 (Q)	X	Upper motor bearing oil level sight glass, bottom motor bearing grease lubricated, bottom pump bearing grease lubricated and sealed at factory. Shaft bearing freshwater lubricated and can be observed with Supply Pressure Indicator [2SWS-PI105C], local.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21A Fuel Oil Transfer Pump		Pump Number: 2EGF*P21A	Code Class: 3	Dwg. OM No.: 36-1 Dwg. Coord.: F-3	System: 36 Diesel Fuel Oil System
Function: Transfer Fuel from underground storage tank to the day tank		Type: Vertical	Remarks: See RR4, RR5 and RR9. Pump is normally tested bi-monthly.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	36.1 (Q)	RR5	No suction pressure indication provided. Suction pressure will remain almost constant.		
ΔP	36.1 (Q)	RR5	Based on pump Discharge Pressure Indicator [2EGF-PI201A], local.		
Q	36.1 (Q)	RR4	No instrumentation provided for flow - Level change over time in the day tank will be measured using Level Gauge [2EGF*LG201], local and converted to flowrate.		
V	36.1 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	NA	NA	Self-lubricated bearings, internal pumped fluid lubrication.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21B Fuel Oil Transfer Pump		Pump Number: 2EGF-P21B	Code Class: 3	Dwg. OM No.: 36-1 Dwg. Coord.: E-3	System: 36 Diesel Fuel Oil System
Function: Transfer Fuel from underground storage tank to the day tank		Type: Vertical	Remarks: See RR4, RR5 and RR9. Pump is normally tested bi-monthly.		
Parameter	20ST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	36.1 (Q)	RR5	No suction pressure indication provided. Suction pressure will remain almost constant.		
ΔP	36.1 (Q)	RR5	Based on pump Discharge Pressure Indicator [2EGF-PI201B], local.		
Q	36.1 (Q)	RR4	No instrumentation provided for flow - Level change over time in the day tank will be measured using Level Gauge [2EGF-LG201], local, and converted to flowrate.		
V	36.1 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	NA	NA	Self-lubricated bearings, internal pumped fluid lubrication.		

BVPS-2 IST

PUMP TESTING OUTLINE

Pump Name: 21C Fuel Oil Transfer Pump		Pump Number: 2EGF*P21C	Code Class: 3	Dwg. OM No.: 36-1 Dwg. Coord.: F-8	System: 36 Diesel Fuel Oil System
Function: Transfer Fuel from underground storage tank to the day tank			Type: Vertical	Remarks: See RR4, RR5 and RR9. Pump is normally tested bi-monthly.	
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	36.2 (Q)	RR5	No suction pressure indication provided. Suction pressure will remain almost constant.		
ΔP	36.2 (Q)	RR5	Based on pump Discharge Pressure Indicator [2EGF-PI201C], local.		
Q	36.2 (Q)	RR4	No instrumentation provided for flow - Level change over time in the day tank will be measured using Level Gauge [2EGF*LG202], local, and converted to flowrate.		
V	36.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	NA	NA	Self-lubricated bearings, internal pumped fluid lubrication.		

BVPS-2 IST

PUMP TESTING OUTLINE


Pump Name: 21D Fuel Oil Transfer Pump		Pump Number: 2EGF-P21D	Code Class: 3	Dwg. OM No.: 36-1 Dwg. Coord.: E-8	System: 36 Diesel Fuel Oil System
Function: Transfer Fuel from underground storage tank to the day tank		Type: Vertical	Remarks: See RR4, RR5 and RR9. Pump is normally tested bi-monthly.		
Parameter	2OST (Frequency)	Req'd	Comments		
N	NA	NA	Constant speed induction motor.		
PI	36.2 (Q)	RR5	No suction pressure indication provided. Suction pressure will remain almost constant.		
ΔP	36.2 (Q)	RR5	Based on pump Discharge Pressure Indicator [2EGF-PI201D], local.		
Q	36.2 (Q)	RR4	No instrumentation provided for flow - Level change over time in the day tank will be measured using Level Gauge [2EGF-LG202], local, and converted to flowrate.		
V	36.2 (Q)	RR9	Portable monitoring equipment using velocity units.		
Tb	NA	RR9	Annual pump bearing temperature measurement will not be taken since vibration is measured in velocity units.		
L	NA	NA	Self-lubricated bearings, internal pumped fluid lubrication.		

SECTION III: PUMP MINIMUM OPERATING POINT (MOP) CURVES

Pump Name: 21A Charging Pump

Pump Number: 2CHS*P21A

2CHS*P2 1A MOP CURVE



MOP CURVE
DATA POINTS:


FLOW (GPM)	HEAD (FT.)
0	5649
50	5629
100	5595
150	5538
200	5331
250	5021
300	4599
350	4098
400	3541
450	2902
500	2200
550	1260

SUPPLIED BY WESTINGHOUSE PER LETTER NO.
BV2-SET-024 (2/3/87), (REFERENCE: WESTINGHOUSE
CALCULATION NO. PS-C-104 (UPDATED 5/10/86)).

Pump Name: 21B Charging Pump

Pump Number: 2CHS-P21B

2CHS*P2 1B MOP CURVE




SUPPLIED BY WESTINGHOUSE PER LETTER NO.
BV2-SET-024 (2/3/87), (REFERENCE: WESTINGHOUSE
CALCULATION NO. PS-C-104 (UPDATED 6/10/93))

Pump Name: 21C Charging Pump

Pump Number: 2CHS*P21C

2CHS*P21C MOP CURVE



MOP CURVE
DATA POINTS:


FLOW (GPM)	HEAD (FT.)
0	5649
50	5629
100	5595
150	5538
200	5331
250	5021
300	4599
350	4098
400	3541
450	2902
500	2200
550	1260

SUPPLIED BY WESTINGHOUSE PER LETTER NO.
BV2-SET-024 (2/3/87), (REFERENCE: WESTINGHOUSE
CALCULATION NO. PS-C-104 (UPDATED 5/10/93)).

Pump Name: 22A Boric Acid Transfer Pump

Pump Number: 2CHS*P22A

**2CHS*P22A
MOP CURVE**




SUPPLIED BY WESTINGHOUSE PER
LETTER NO BV2-SET-024 (2/3/87)

Pump Name: 22B Boric Acid Transfer Pump

Pump Number: 2CHS*P22B

2CHS*P22B MOP CURVE




SUPPLIED BY WESTINGHOUSE PER
LETTER NO BV2-SET-024 (2/3/87).

Pump Name: 21A Residual Heat Removal Pump

Pump Number: 2RHS*P21A

2RHS*P21A MOP CURVE




SUPPLIED BY WESTINGHOUSE PER
LETTER NO. BV2-SET-024 (2/3/87).

Pump Name: 21B Residual Heat Removal Pump

Pump Number: 2RHS*P21B

2RHS*P21B MOP CURVE




SUPPLIED BY WESTINGHOUSE PER
LETTER NO. BV2-SET-024 (2/3/87).

Pump Name: 21A Low Head Safety Injection Pump

Pump Number: 2SIS-P21A

2SIS*P21A MOP CURVE




SUPPLIED BY WESTINGHOUSE PER LETTER NO.
DLW-90-582 (4/10/90), (REFERENCE: WESTINGHOUSE
CALCULATION NO. PS-C-104 (UPDATED 5/10/93)).

Pump Name: 21B Low Head Safety Injection Pump

Pump Number: 2SIS*P21B

**2SIS*P21B
MOP CURVE**



SUPPLIED BY WESTINGHOUSE PER LETTER NO
DLW-90-562 (4/10/90), (REFERENCE: WESTINGHOUSE
CALCULATION NO. PS-C-104 (UPDATED 5/10/93)).

Pump Name: 21A Quench Spray Pump

Pump Number: 2QSS*P21A

(IN DEVELOPMENT)

Pump Name: 21B Quench Spray Pump


Pump Number: 2QSS*P21B

(IN DEVELOPMENT)

Pump Name: 21A Recirculation Spray Pump

Pump Number: 2RSS*P21A

**2RSS*P2 1A
MOP CURVE**



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT.)
2025	320
2533	297
3002	278
3500	250
3940	214


THE MOP CURVE IS BASED ON THE SHAPE OF THE CURRENT PUMP PERFORMANCE CURVE AS A CONSTANT PERCENTAGE (97.88%) TO THE MOP POINT. (4/17/95)

MOP POINT IS AT 250 FT AT 3500 GPM & IS BASED ON
 * TUBES PLUGGED IN (2RSS*E2 1A) PER EM 110 133 AND
 CALC. 10080-N-724-0. (CURRENT * TUBES PLUGGED=20)

Pump Name: 21B Recirculation Spray Pump

Pump Number: 2RSS*P21B

2RSS*P21B MOP CURVE




MOP POINT IS AT 260 FT AT 3500 GPM AND IS DERIVED FROM SWEC CALC. 12241-US(B)-193-0 REFERENCE LETTER NO 2DLS-28716 (8/7/86).

SUPPLIED BY ENGINEERING PER EM 63835 (3/14/89).

Pump Name: 21C Recirculation Spray Pump

Pump Number: 2RSS-P21C

2RSS*P21C MOP CURVE




MOP POINT IS AT 260 FT AT 3500 GPM AND IS DERIVED FROM SWEC CALC. 12241-US(B)-193-0 REFERENCE LETTER NO. 2DLS-28716 (6/7/86)

SUPPLIED BY ENGINEERING PER EM 63835 (3/14/89)

Pump Name: 21D Recirculation Spray Pump

Pump Number: 2RSS*P21D

2RSS*P21D MOP CURVE



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT.)
3500	260
3550	257
3600	254.5
3650	252
3700	249
3750	246.3
3800	243
3850	240
3900	236


MOP POINT IS AT 260 FT AT 3500 GPM AND IS DERIVED FROM SWEC CALC. 12241-US(B)-193-0 REFERENCE LETTER NO. 2DLS-28716 (8/7/86)

SUPPLIED BY ENGINEERING PER EM 63835 (3/14/89).

Pump Name: 21A Component Cooling Water Pump

Pump Number: 2CCP*P21A

2CCP*P21A MOP CURVE



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT.)
3400	215.8
4004	213.3
4553	209.3
5047	204.3
5541	198.0
6090	189.5


DERIVED AS 88.33% OF PUMP PERFORMANCE CURVE
OBTAINED ON 8/25/95.

MOP POINT IS AT 191 FT AT 8000 GPM PER CALC.
12241-MT-250 (1/23/87) (REF: EM 106280, 8/3/93).

Pump Name: 21B Component Cooling Water Pump

Pump Number: 2CCP*P21B

2CCP*P21B MOP CURVE



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT)
3094	224.3
3522	222.5
3950	219.6
4378	215.6
4806	210.6
5234	204.6
5662	197.4
6000	191.0
6395	182.7


DERIVED AS 92.28% OF PUMP PERFORMANCE CURVE
AS APPROVED BY NED PER EM 106287 (9/8/93).

MOP POINT IS AT 191 FT AT 6000 GPM PER CALC
12241-MT-250 (1/23/87) (REF: EM 106280, 9/3/93)

Pump Name: 21C Component Cooling Water Pump

Pump Number: 2CCP*P21C

2CCP*P21C MOP CURVE



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT.)
3000	218.1
3471	217.6
4010	215.3
4549	211.2
5020	206.1
5559	198.5
6000	191.0
6300	185.2
6615	178.5


DERIVED AS 89.04% OF PUMP PERFORMANCE CURVE
PER METHOD IN MPUAP 8.4.3 (8/26/94).

MOP POINT IS AT 191 FT AT 6000 GPM PER CALC.
12241-MT-250 (1/23/87) (REF: EM 106280, 9/3/93).

Pump Name: Turbine Driven Auxiliary Feedwater Pump

Pump Number: 2FWE-P22

2FWE-P22 MOP CURVE



MOP CURVE DATA POINTS	
FLOW (GPM)	HEAD (FT)
255	3005
300	2988
400	2961
500	2911
600	2815
700	2673
800	2510


DERIVED AS 98.3% OF PUMP PERFORMANCE CURVE
AS APPROVED BY NED PER EM 103222 (6/7/92)

MOP POINT IS AT 2752 FT AT 647 GPM AND IS
DERIVED FROM SWEC CALC 12241 PH-198 AND 150
REFERENCE LETTER NO 2DLS-28716 (8/7/86)

Pump Name: 23A Motor Driven Auxiliary Feedwater Pump

Pump Number: 2FWE*P23A

**2FWE*P23A
MOP CURVE**




MOP POINT IS AT 2747 FT AT 323 GPM AND IS
DERIVED FROM SWEC CALC 12241 PH-96 AND 150
REFERENCE LETTER NO 20LS-28716 (8/7/86)

DERIVED AS 98.7% OF PUMP PERFORMANCE CURVE
AS APPROVED BY NED PER EM 103200 (5/2/82)

Pump Name: 23B Motor Driven Auxiliary Feedwater Pump

Pump Number: 2FWE*P23B

2FWE*P23B MOP CURVE



MOP CURVE
DATA POINTS:

FLOW (GPM)	HEAD (FT.)
0	2980
100	2978
200	2925
300	2797
400	2577
500	2256
600	1837


MOP POINT IS AT 2747 FT AT 323 GPM AND IS
DERIVED FROM SWEC CALC 12241-PH-96 AND 150
REFERENCE LETTER NO 2DLS-28716 (8/7/86)

SUPPLIED BY ENGINEERING PER EM 22783 (3/11/81)

Pump Name: 21A Service Water Pump

Pump Number: 2SWS*P21A

**2SWS*P21A
 MOP CURVE**



MOP CURVE
 DATA POINTS:

FLOW (GPM)	HEAD (FT.)
4050	265.2
6162	249.3
8040	241.2
10152	226.6
12029	207.2
13438	189.7
14846	164.5


DERIVED AS 84.89% OF THE PUMP PERFORMANCE CURVE.

MOP POINT IS AT 199 FT AT 12720 GPM PER
 CALCULATION # 10080-N-726-0 (7/25/95)

Pump Name: 21B Service Water Pump

Pump Number: 2SWS*P21B

**2SWS*P21B
MOP CURVE**




MOP POINT IS AT 199 FT AT 12720 GPM PER
CALCULATION # 10080-N-726-0 (7/25/95)

DERIVED AS 81.23% OF PUMP THE PERFORMANCE CURV

Pump Name: 21C Service Water Pump

Pump Number: 2SWS*P21C

2SWS*P21C MOP CURVE



MOP CURVE
DATA POINTS

FLOW (GPM)	HEAD (FT.)
4196	249.9
5917	240.1
7885	231.6
10097	220.6
12065	205.6
14033	182.8
14770	171.8

DERIVED AS 82 12% OF THE PUMP PERFORMANCE CURVE.

MOP POINT IS AT 199 FT AT 12720 GPM PER
CALCULATION # 10080-N-726-0 (7/25/95).

Pump Name: 21A Fuel Oil Transfer Pump

Pump Number: 2EGF*P21A

(IN DEVELOPMENT)

Pump Name: 21B Fuel Oil Transfer Pump

Pump Number: 2EGF*P21B

(IN DEVELOPMENT)

Pump Name: 21C Fuel Oil Transfer Pump

Pump Number: 2EGF*P21C

(IN DEVELOPMENT)

Pump Name: 21D Fuel Oil Transfer Pump

Pump Number: 2EGF*P21D

(IN DEVELOPMENT)

SECTION IV: PUMP TESTING RELIEF REQUESTS

RELIEF REQUEST 1**Pump Mark No(s):**

2RHS*P21A

2RHS*P21B

Code Test Requirement: Quarterly pump testing.

Basis for Relief: These pumps are not required to be run at power or fulfill any safety function to mitigate a design basis accident. Possible overheating of the pumps could occur during pump testing on recirculation only and could compromise the system integrity. The system has no associated surge tank and the only available expansion protection is the system relief valve. Test personnel would have to make a containment entry to properly monitor pump operation.

Alternate Test: These pumps will be tested quarterly during cold shutdowns and refueling outages per 2OST-10.1 and 10.2.

RELIEF REQUEST 2**Pump Mark No(s):**

2RSS*P21A
2RSS*P21C
2RSS*P21E
2RSS*P21D

Code Test Requirement: Quarterly pump tests.

Basis for Relief: The function of these pumps is to take suction on the containment sump and discharge to the spray rings on the containment ceiling during a DBA. In order to test these pumps, a temporary dike must be installed in the containment around the safeguards sump to ensure adequate NPSH for each pump. Quarterly testing at power in this manner is a safety concern since it would block off the sump from the containment in the event of an accident. Pump testing during cold shutdowns, while not involving the same safety concern, would increase personnel radiation exposure, create additional radioactive liquid waste, divert maintenance from higher priority items, and could extend the length of a plant shutdown due to the extensive preparatory work required to properly install the dike.

Alternate Test: Dry run quarterly per 2OST-13.3, 13.4, 13.5, and 13.6 for not more than 60 seconds and stopped as soon as pump start is verified. Also, run on test line recirculation per 2BVT 1.13.5 during Refueling Outages.

RELIEF REQUEST 3**Pump Mark No(s):**

2SWS*P21A
2SWS*P21B
2SWS*P21C

Code Test Requirement: Measurement of pump suction pressure before pump startup and during test.

Basis for Relief: No installed instrumentation exists to measure suction pressure for these pumps, therefore, relief is requested from this requirement.

Alternate Test: The static head of the Ohio River water level will be used to calculate suction pressure, once per test per 2OST-30.2, 30.3, and 30.6.

RELIEF REQUEST 4**Pump Mark No(s):**

2EGF*P21A
2EGF*P21B
2EGF*P21C
2EGF*P21D

Code Test Requirement: Flow rate shall be measured using a rate or quantity meter installed in the pump test circuit.

Basis for Relief: There is no installed instrumentation provided to measure flow rate for these pumps, therefore, relief is requested from this requirement.

Alternate Test: Flow rate will be calculated by measuring the level change over time of the diesel fuel oil day tank and converting this data to diesel fuel oil transfer pump flow rate per 2OST-2.36.1 and 36.2.

RELIEF REQUEST 5**Pump Mark No(s):**

2EGF*P21A
2EGF*P21B
2EGF*P21C
2EGF*P21D

Code Test Requirement: Measurement of pump suction pressure (before pump startup and during test) and delta-P.

Basis for Relief: There is no installed instrumentation provided to measure suction pressure for these pumps. Suction pressure is dependent on the level in the diesel generator fuel oil storage tank. Due to the minimum technical specification level permitted in the tank (91.2%), suction pressure will remain almost constant (within 1/2 psig). The pump performance is dependent on flowrate and delta-P. Since suction pressure will remain almost constant, any pump degradation due to changes in delta-P would solely be dependent on discharge pressure.

Alternate Test: Discharge pressure will be recorded and trended as an indication of pump performance in 2OST-36.1 and 36.2.

RELIEF REQUEST 6**Pump Mark No(s):**

2QSS*P24A
2QSS*P24B

Code Test Requirement: Measure pump suction pressure, ΔP and flow.

Basis for Relief: The function of these pumps is to provide a NaOH water solution to the suction of the quench spray pumps during an accident. Since these pumps are rotary positive displacement pumps, flow rate and differential pressure are independent variables. Unlike centrifugal style pumps, it is not necessary to measure both parameters to assess the hydraulic performance of these pumps.

Alternate Test: Pump discharge pressure (at greater than or equal to the pressure at which the pumps are required to perform their safety function) and flow rate will be utilized for evaluating pump performance in 2OST-13.10A and 2OST-13.10B.

RELIEF REQUEST 7**Pump Mark No(s):**

2CCP*P21A

2CCP*P21B

2CCP*P21C

Code Test Requirement:

The resistance of the system shall be varied until either the measured differential pressure or the measured flow rate equals the corresponding reference value. The other test quantities shown in Table IWP-3100-1 shall then be measured or observed and recorded.

Basis for Relief:

The amount of Primary Component Cooling Water (CCP) System flow is dependent on the Service Water System and on seasonal Ohio River water temperatures due to the design of the CCP temperature control system. During Primary Component Cooling Pump testing, additional flow is obtained by placing the Residual Heat Removal (RHR) System Heat Exchangers into service. The overall amount of flow may vary by several hundred gallons per minute between cool winter months and warm summer months.

In order to increase flow to a reference value during cold winter months, the manual valves at the discharge of the RHR Heat Exchangers would require throttling in the open direction. These valves are located in the reactor containment building which is maintained subatmospheric as required by technical specifications. The subatmospheric condition present a hazardous working environment for station personnel (i.e., requires self-contained breathing apparatus and entry via an airlock into an atmosphere of approximately 9 psia) and is considered inaccessible for surveillance testing. Surveillance testing that requires reactor containment entry is performed at cold shutdown and refueling.

RELIEF REQUEST 7**Basis for Relief:**

In order to throttle flow to a reference value during warm summer months, a manual valve at the discharge of the pumps needs to be used since the RHR Heat Exchanger throttle valves are located inside containment. Operating experience has shown that any throttling of the pump discharge valves results in a large reduction in cooling water flow to the Reactor Coolant Pump thermal barrier heat exchangers, bearing lube oil coolers and motor stator air coolers resulting in low flow alarms. This could result in heatup of the Reactor Coolant Pumps to near required manual pump trip setpoints which could ultimately result in a plant trip. In addition, the added thermal cycling of these coolers for pump testing could prematurely degrade these heat exchangers.

IWP-3112 provides for multiple sets of reference values. A pump curve is merely a graphical representation of the fixed response of the pump to an infinite number of flow conditions which are based on some finite number of reference values verified by measurement. Relief is, therefore, requested to use a pump curve, which should provide an equivalent level of quality and safety in trending pump performance and degradation. Flow will be permitted to vary as system conditions require. Delta-P will be calculated and converted to a developed head for which ASME ranges will be applied.

Alternate Test:

A pump curve (developed per the guidelines in Section I, "Pump Testing Requirements") will be used to compare flowrate with developed pump head at the flow conditions dictated by seasonal temperatures per 2OST-15.1, 2OST-15.2 and 2OST-15.3 each quarter. Since normal flow varies based on Component Cooling Water System requirements due to Service Water System and seasonal Ohio River water temperatures, the most limiting vibration acceptance criteria will be used over this range of flows based on baseline vibration data obtained at various flow points on the pump curve.

RELIEF REQUEST 8**Pump Mark No(s):**

2SWS*P21A

2SWS*P21B

2SWS*P21C

Code Test Requirement:

The resistance of the system shall be varied until either the measured differential pressure or the measured flow rate equals the corresponding reference value. The other test quantities shown in Table IWP-3100-1 shall then be measured or observed and recorded.

Basis for Relief:

Operating experience has shown that plant conditions due to heat loads requiring cooling by the Service Water System may preclude returning the Service Water Pumps to the exact flowrate or differential pressure during pump surveillance testing. The Service Water System is dependent on seasonal Ohio River water temperatures and flow may vary from approximately 6,000 gpm in the cool winter months to approximately 12,000 gpm in the warm summer months.

In order to increase flow to a reference value during cold winter months, idle heat exchangers would need to be placed into service or additional flow would be needed through heat exchangers already in service. Increased cooling flow through primary and secondary component cooling and chiller unit heat exchangers already in service could result in a thermal transient and a potential plant trip. Clean heat exchangers may require placement into service prematurely if additional flow is required to return to a reference value. Idle heat exchangers are normally held in reserve following cleaning to improve plant reliability and safety until one of the inservice heat exchangers becomes fouled.

In order to throttle flow to a reference value during warm summer months, any inservice primary and secondary component cooling and chiller unit heat exchangers would need flow reduced or isolated which could interrupt flow of cooling water to Train A or Train B cooling loads resulting in a thermal transient and potential plant trip. In addition, the added thermal cycling due to placement and/or removal of heat exchangers from service for pump testing could prematurely degrade the heat exchangers.

RELIEF REQUEST 8**Basis for Relief:**

The thermal transients created by increasing or throttling Service Water System flow to the turbine plant cooling loads raises operational concerns of stability problems. Changes in oil temperature from the turbine generator lube oil system create vibration problems. Changes in the Hydrogen gas cooler temperatures could imply problems or mask real problems with the generator. Chiller unit heat exchanger flow disturbances often result in a trip of the chiller unit causing reactor containment temperature risks of exceeding the technical specification limit.

IWP-3112 provides for multiple sets of reference values. A pump curve is merely a graphical representation of the fixed response of the pump to an infinite number of flow conditions which are based on some finite number of reference values verified by measurement. Relief is, therefore, requested to use a pump curve, which should provide an equivalent level of quality and safety in trending pump performance and degradation. Flow will be permitted to vary as system conditions require. Delta-P will be calculated and converted to a developed head for which ASME ranges will be applied.

Alternate Test:

A pump curve (developed per the guidelines in Section I, "Pump Testing Requirements") will be used to compare flowrate with developed pump head at the flow conditions dictated by Service Water System loads per 2OST-30.2, 2OST-30.3, and 2OST-30.6 each quarter. Since normal flow varies based on Service Water System requirements due to seasonal Ohio River water temperatures, the most limiting vibration acceptance criteria will be used over this range of flows based on baseline vibration data obtained at various flow points on the pump curve.

RELIEF REQUEST 9

Pump Mark No(s): All of the pumps in the IST Program

Code Test Requirement: Quarterly vibration amplitude measurements in mils and annual bearing temperature measurements.

Basis for Relief: The mechanical characteristics of a pump can be better determined by taking vibration measurements in velocity units than by taking the vibration measurements in displacement units and by bearing temperature measurements taken annually.

Vibration severity is a function of both displacement and frequency. Therefore, vibration in velocity units is the more accurate description of the vibration. In addition, velocity measurements are more sensitive to small changes that are indicative of developing mechanical problems and hence more meaningful than displacement measurements. Velocity measurements detect not only high amplitude vibrations that indicate a major mechanical problem, but also the equally harmful low amplitude high frequency vibrations due to misalignment, imbalance or bearing wear that usually go undetected by simple displacement measurements. Also, a bearing will be seriously degraded prior to the detection of increased heat at the bearing housing. Quarterly vibration velocity readings should achieve a much higher probability of detecting developing problems than the once a year reading of bearing temperatures.

Therefore, relief from measuring bearing temperatures annually and from measuring pump vibration in displacement units (mils) is permitted by 10CFR50.55a (footnote 6) and Regulatory Guide 1.147 which reference NRC approved ASME Code Case N-465 (permits use of ASME/ANSI OMa-1988, Part 6 (OM-6), as an alternative for pump testing in lieu of ASME subsection IWP).

Alternate Test: Obtain pump vibration measurements in accordance with the vibration measurement requirements and corrective actions of ASME/ANSI OM-6, and measure vibration in velocity units (in/sec) using the ranges listed in OM-6 as acceptance criteria. (See the attached table). Annual pump bearing temperature measurements will not be taken.

RELIEF REQUEST 9

TABLE

RANGES OF TEST PARAMETERS (1)

<u>PUMP TYPE</u>	<u>TEST PARAMETER</u>	<u>ACCEPTABLE RANGE</u>	<u>ALERT RANGE</u>	<u>REQUIRED ACTION RANGE</u>
Centrifugal (2) and Vertical Line Shaft (3)	Vv	$\leq 2.5 V_r$	> 2.5 Vr to 6 Vr but not > 0.325 in/sec	> 6 Vr but not > 0.70 in/sec
Reciprocating (4)	Vv	$\leq 2.5 V_r$	> 2.5 Vr to 6 Vr	> 6 Vr

Notes:

1. Vv represents the peak vibration velocity. Vr is vibration reference value in the selected units.
2. On centrifugal pumps, measurements shall be taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump bearing housing. Measurement also shall be taken in the axial direction on each accessible pump thrust bearing housing.
3. On vertical line shaft pumps, measurements shall be taken on the upper motor bearing housing in three orthogonal directions, one of which is the axial direction.
4. On reciprocating pumps, the location shall be on the bearing housing of the crankshaft, approximately perpendicular to both the crankshaft and the line of plunger travel.

SECTION V: VALVE TESTING REQUIREMENTS

The Inservice Test (IST) Program for valves at Beaver Valley Power Station (BVPS), Unit 2, is based on subsection IWV - Inservice Testing of Valves of the ASME Boiler and Pressure Vessel Code, Section XI, 1983 edition through the summer 1983 addenda (the code) and Generic Letter No. 89-04, "Guidance on Developing Acceptable Inservice Testing Programs", including Supplement 1 (NUREG-1482, "Guidelines for Inservice Testing at Nuclear Power Plants"). The valves included in this section are all ASME "Class 1, 2, or 3 valves (and their actuating and position indicating systems) which are required to perform a specific function in shutting down the reactor to cold shutdown or in mitigating the consequences of an accident" at BVPS, Unit 2.

The requirements of the code will be followed at all times unless specific relief has been granted by the NRC.

- A. Category A valves are valves for which seat leakage in the closed position is limited to a specific maximum amount for fulfillment of their function. Category B valves are valves for which seat leakage in the closed position is inconsequential for fulfillment of their function. Category A and B valves will be exercised at least once every three months to the position required to fulfill their function unless such operation is not practical during plant operation. If only limited operation is practical during plant operation, the valves will be part-stroke exercised at power and full-stroke exercised during cold shutdowns. In the case of frequent cold shutdowns, these valves need not be tested more often than once every three months. For a valve in a system declared inoperable or not required to be operable, the exercising test schedule need not be followed. Within 30 days prior to return of the system to operable status, the valves shall be exercised and the schedule resumed.

The time to full-stroke exercise each power-operated valve will also be measured and compared to a limiting stroke time. Full-stroke time is that time interval from initiation of the actuating signal to the end of the actuating stroke. The stroke time of all power-operated valves shall be measured to at least the nearest second, for stroke times 10 seconds or less, or 10% of the specified limiting stroke time for full-stroke times longer than 10 seconds, whenever such a valve is full-stroke tested. Position indication lights on the Control Board are used for valve stroke indication for all testing of power-operated valves with remote position indicators. In addition, per NUREG-1482 Paragraph 4.2.5, valves with remote position indicators will be observed at least once every 2 years (normally at refuelings) to verify that valve operation is accurately indicated.

Exception is taken to part-stroke timing motor-operated valves, unless specifically stated. This is necessary because the motor-operated valve circuitry prevents throttling of these valves. Under normal operation, the valves must travel to either the full open or shut position prior to reversing direction.

The necessary valve disk movement shall be determined by exercising the valve while observing an appropriate indicator, which signals the required change of disk position, or observing indirect evidence (such as changes in system pressure, flow rate, level, or temperature), which reflect stem or disk position.

All valves with fail-safe actuators (ie. Air-Operated Valves) that are applicable to this program are tested from the Control Room by the remote operating switch. By placing the control switch to the closed position, or de-energizing the control power, air is vented off of the valve actuator thus positioning the valve in the fail-safe position.

Corrective action shall be taken if necessary, using the following:

1. If the stroke time of a power-operated valve exceeds its previous stroke time by 25% for valves with full-stroke times greater than 10 seconds, or 50% for valves with full-stroke times less than or equal to 10 seconds, the test frequency will be increased to monthly. Stroke times of the valves will be examined for trends. During the trend review, it will be determined if corrective action is necessary for any valve based on its stroke time history. When either the corrective action is complete or the review determines it is unnecessary, the original test frequency will be resumed.
2. If a valve fails to exhibit the required change of valve stem or disk position or exceeds its specified ASME limiting value of full-stroke time, then the valve shall be declared inoperable immediately and an evaluation of the valve's condition with respect to system operability and technical specifications shall be made as follows:
 - a. If the inoperable valve is specifically identified in the technical specifications, then the applicable technical specification action statements must be followed.
 - b. If the inoperable valve is in a system covered by a technical specification, an assessment of its condition must be made to determine if it makes the system inoperable. If the condition of the valve renders the system inoperable, then the applicable system technical specification action statements must be followed.
 - c. Corrective action (ie., MWR) shall be initiated immediately for the valve's repair or replacement.
 - d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supercede the requirements of any technical specification.
3. When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters, which could be affected by the replacement, repair, or maintenance, are within acceptable limits. Examples of maintenance that could affect valve performance parameters are adjustment of stem packing, removal of the bonnet, stem assembly, or actuator, and disconnection of hydraulic or electrical lines.

The ASME limiting valve stroke time is based on the following criteria:

1. The Technical Specification value.
 2. ESF Response Time requirements.
 3. Establishing a two (2) second limit for valves with stroke times under one (1) second. (rapid-acting valves)
 4. The average of past stroke times plus 100% for valves with stroke times less than or equal to ten (10) seconds.
-

5. The average of past stroke times plus 50% for valves with stroke times greater than ten (10) seconds.
6. The design time listed in the UFSAR.

In addition, Category A valves shall be leak rate tested at least once every two years normally, but not necessarily, at refueling outages. The Category A valves that are tested in accordance with 10CFR50, Appendix J, Type C, per relief, are leak rate tested normally at refueling outages. If the leak rate exceeds the allowable limit, the valve will be repaired or replaced.

- B. Category C valves are valves which are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves). Category C valves are divided into two groups; safety or relief valves and check valves.

Safety and relief valves are setpoint tested in accordance with ASME PTC 25.3-1976 at least once every five (5) years, with a portion of the valves from each system included in the IST Program tested during each refueling outage. If any valves fail the setpoint test, additional valves from that system must be tested in accordance with Table IWV-3510-1. If a safety or relief valve fails to function properly during a test, it will be repaired or replaced.

Check valves will be exercised to the position required to fulfill their function every three months, unless such operation is not practical during plant operation. If only limited operation is practical during plant operation, the check valve will be part-stroke exercised at power and full-stroke exercised every cold shutdown, not to exceed more than once every three months. Check valves that are normally open during plant operation and whose function is to prevent reversed flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Check valves that are normally closed during plant operation and whose function is to open on reversal of pressure differential shall be tested by proving that the disk moves promptly away from the seat when the closing pressure differential is removed and flow through the valve is initiated, or when a mechanical opening force is applied to the disk. If the check valves cannot be tested mechanically or with flow, they will be disassembled and inspected per the requirements of Generic Letter No. 89-04. These valves will normally, but not necessarily be inspected during refueling outages.

If a check valve fails to exhibit the required change of disk position by this testing, then the check valve shall be declared inoperable immediately and an evaluation of the check valve's condition with respect to system operability and technical specifications shall be made as follows:

1. If the inoperable check valve is specifically identified in the technical specifications, then the applicable technical specification action statements must be followed.
2. If the inoperable check valve is in a system covered by a technical specification, an assessment of its condition must be made to determine if it makes the system inoperable. If the condition of the check valve renders the system inoperable, then the applicable system technical specification action statements must be followed.
3. Corrective action (ie., MWR) shall be initiated immediately for the check valve's repair or replacement.

4. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supercede the requirements of any technical specification.

Before returning the check valve to service after corrective action, a retest showing acceptable operation will be run.

- C. Category D valves are valves which are actuated by an energy source capable of only one operation, such as rupture disks or explosively actuated valves. There are no ASME Class 1, 2, or 3 Category D valves at Beaver Valley Power Station, Unit 2.

All the inservice testing requirements for each different category of valve in the IST Program are summarized in Table IWV-3700-1. This table lists the subarticles of the code that apply to each different type of valve.

**Table IWV-3700-1
INSERVICE TEST QUANTITIES (1)**

Category	Valve Function (IWV-2100)	Leak Test Procedure	Exercise Test Procedure	Special Test Procedure
A	Active	IWV-3420	IWV-3410	None
A	Passive	IWV-3420	None	None
B	Active	None	IWV-3410	None
C-Safety & Relief	Active	None	IWV-3510	None
C-Check	Active	None	IWV-3520	None
D	Active	None	None	IWV-3600

NOTE:

(1) No tests required for Category B, C and D passive valves.

Passive valves are valves which are not required to change position to accomplish a specific function. As stated in the table, passive valves are not required to be exercised. Therefore, relief is not required from exercising any passive valve and no testing requirement is listed in the outline section except where remote position verification is required.

Certain exemptions from the valve testing requirements of the ASME code defined by subsection IWV-1200 are listed below:

1. Valves used only for operating convenience (ie., manual vent, drain, instrument and test valves);
2. Valves used only for system control (ie., pressure, temperature or flow regulating valves);
3. Valves used only for maintenance; and
4. External control and protection systems responsible for sensing plant conditions and providing signals for valve operation.

Manufacturer supplied skid-mounted valves (i.e., check valves, SOV's, TCV's, relief valves) which are integral sub-components of, and are required to support the operation of a parent pump or other component, are often times not designed to be tested in accordance with the ASME XI Code, regardless of their ASME Code class. Although ASME Code class skid-mounted valves are not included in the BVPS Unit 2 IST Program, they are either tested in conjunction with the parent pump or other component for which they provide support, as documented in the IST Program Basis Document and applicable surveillance test, or are examined separately by a preventative maintenance activity. This ensure the skid-mounted valves operate acceptably commensurate with their safety functions provided satisfactory performance of the parent pump or other component is demonstrated. Because it has been recognized that the test of the parent pump or other component itself challenges the operability of the sub-components, relief from Code testing requirements and including AMSE Code class manufacturer supplied skid-mounted valves in the IST Program has been approved by the NRC.

Records of the results of inservice tests and corrective actions as required by subsection IWB-6000 are maintained in tabular form. Stroke times of valves will be reviewed for developing trends.

If a question on valve testability exists, the IST program should be the controlling document since each component is individually assessed for testability and inclusion in the IST Program. If a valve is specifically called out in the Tech. Specs. (ie., specific valve mark number or uniquely specified by valve nomenclature) to be tested at one frequency and the IST Program endorses another frequency, then the more restrictive test frequency would be applicable.

The following three sections of this document are the "Valve Testing Outlines", "Cold Shutdown Justifications" and "Valve Relief Requests" sections.

- A. The "Valve Testing Outlines" section is a listing of all the valves in the IST Program, their class, category, size, type, NSA, drawing number and coordinates, testing requirements, specific cold shutdown justification reference numbers, relief request reference numbers, and test procedure numbers and comments.
 1. The valve class will be 1, 2 or 3, corresponding to the safety classifications.

2. The category of the valve will be A, B, C or D in accordance with the guidelines of subsection IWV-2200. In addition, combinations of categories may be utilized. If the valve is not required to change position during an accident or bring the reactor to a cold shutdown condition, the fact that it is Passive (P) will also be indicated. For example, a containment isolation check valve that does not change position would be a category A/C/P valve. From the valve mark number given, the valve actuator can be determined from the list of abbreviations below:

AOV - Air Operated Valve
FCV - Flow Control Valve
HCV - Hand Control Valve
HYV - Hydraulic Valve
LCV - Level Control Valve
MOD - Motor Operated Damper
MOV - Motor Operated Valve
PCV - Pressure Control Valve
RV - Relief Valve
SOV - Solenoid Operated Valve
SV - Safety Valve
DMP - Damper (Manual)

3. The normal system arrangement will be listed using the abbreviations below:

NSA - Normal System Arrangement
O - Open
S - Shut
A - Automatic
T - Throttled
LO - Locked Open
LS - Locked Shut
SS - Sealed Shut

4. The drawing number and coordinates will be the ones used in the Operating Manual.

5. The test requirements will be listed using the abbreviations below:

QS - Quarterly Stroke
QST - Quarterly Stroke & Time
LT - Leak Rate Test
SPT - Set Point Test
LM - Leakage Monitoring
POS - Position Verification
NA - Not Applicable

6. The specific Cold Shutdown Justification (CSJ) reference number or the Relief Request (RR) reference number will be listed.

7. The specific test procedure number, frequency, type of testing, and any comments will be listed using the abbreviations below:

2OM - Operating Manual (Unit 2)
2BVT - Beaver Valley Test (Unit 2)
2OST - Operating Surveillance Test (Unit 2)
CMP - Corrective Maintenance Procedure
CSD - Cold Shutdown Frequency
R - Refueling Frequency
SA - Semiannually Frequency
Q - Quarterly Frequency
M - Monthly Frequency
FS - Full Stroke
PS - Partial Stroke
FD - Forward Direction
RD - Reverse Direction
RPV - Remote Position Verification normally at Refueling

- B. The "Cold Shutdown Justification" section contains the detailed technical description of conditions prohibiting the required testing of safety-related valves and an alternate test method to be performed during cold shutdowns. Per NUREG-1482 Paragraph 3.1.1.1, Cold Shutdown valve testing will commence within 48 hours of reaching cold shutdown conditions, but need not be completed more often than once every 92 days. Attempts will be made to complete testing prior to entering Mode 4. However, completion will not be a Mode 4 requirement. The testing will resume where left off when next entering Mode 5. For planned cold shutdowns, where ample time is available to complete testing on all valves identified for the cold shutdown test frequency, exceptions to the 48 hour requirement can be taken.

Beaver Valley Unit 2 reactor containment is maintained subatmospheric as required by technical specifications. The subatmospheric condition presents a hazardous working environment for station personnel and is considered inaccessible for surveillance testing. Surveillance testing that requires reactor containment entry will be performed at cold shutdown and refueling.

- C. The "Valve Relief Requests" section contains the detailed technical description of conditions prohibiting the required testing of safety-related valves, an alternate test method and frequency of revised testing.

SECTION VI:

VALVE TESTING OUTLINES



BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 6		
SYSTEM NAME: Reactor Coolant	Valve Mark Number		Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
								OM No.	Coord.			
	2RCS*68	2	A/C	2 1/4	Check			6-2	E-2	QS	CSJ1	2OST-1 10 FS RD by Mechanical Exerciser (CSD)
	2RCS*72	2	A/C	3	Check			6-2	F-2	OS	CSJ2	2OST-1 10 FS RD by Mechanical Exerciser (CSD)
	2RCS*RV100	2	A/C	1/4	Relief			6-2	G-2	SPT	RR1	2BVT 1 47 5 Leak Test (R)
	2RCS*AOV101	2	A	1/4	Globe	S		6-2	E-2	QST	RR1,RR28	2OST-47 3A(3B)-Stroke & Time Closed (O), (RPV)
	2RCS*SOV200A	1	B	1	Globe	S		6-2	E-6	QST	RR29,RR30	2BVT 1 47 5 Leak Test (R)
	2RCS*SOV200B	1	B	1	Globe	S		6-2	F-6	QST	RR29,RR30	2OST-6 9 Stroke & Time Open/Closed (R), (RPV)
	2RCS*SOV201A	1	B	1	Globe	S		6-2	E-6	QST	RR29,RR30	2OST-6 9 Stroke & Time Open/Closed (R), (RPV)
	2RCS*SOV201B	1	B	1	Globe	S		6-2	F-6	QST	RR29,RR30	2OST-6 9 Stroke & Time Open/Closed (R), (RPV)
	2RCS*HCV250A	2	B		Globe	S		6-2	G-6	Q3T	RR29	2OST-6 9 Stroke & Time Open/Closed (R), (RPV)
	2RCS*HCV250B	2	B	1	Globe	S		6-2	G-6	QST	RR29	2OST-6 9 Stroke & Time Open/Closed (R), (RPV)
	2RCS*PCV455C	1	B	3	Globe	A		6-1	F-1	QST	CSJ4,RR30	2OST-6 8 Stroke & Time Open (CSD), (RPV)
	2RCS*PCV455D	1	B	3	Globe	A		6-1	F-1	QST	CSJ4,RR30	2OST-6 8 Stroke & Time Open (CSD), (RPV)
	2RCS*PCV456	1	B	3	Globe	A		6-1	E-1	QST	CSJ4,RR30	2OST-6 8 Stroke & Time Open (CSD), (RPV)

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 6
SYSTEM NAME: Reactor Coolant										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	MSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2RCS*MOV519	2	A	3	Globe	S	6-2	F-1	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)
								LT	RR1,RR28	2BVT 1 47 5 Leak Test (R)
2RCS*MOV535	1	B	1	Gate	O	6-1	F-2	QST		2OST-6 6 Stroke & Time Open/Closed (Q), (RPV)
2RCS*MOV536	1	B	1	Gate	O	6-1	E-2	QST		2OST-6 6 Stroke & Time Open/Closed (Q), (RPV)
2RCS*MOV537	1	B	1	Gate	O	6-1	F-2	QST		2OST-6 6 Stroke & Time Open/Closed (Q), (RPV)
2RCS*RV551A	1	C	6x6	Relief		6-1	D-3	SPT		2BVT 1 60 5-(R)
2RCS*RV551B	1	C	6x6	Relief		6-1	D-3	SPT		2BVT 1 60 5-(R)
2RCS*RV551C	1	C	6x6	Relief		6-1	D-4	SPT		2BVT 1 60 5-(R)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 7
SYSTEM NAME: Chemical and Volume Control										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2CHS*22	2	C	3	Check		7-1	C-8	QS		20ST-7 4-PS,FD (Q)
								QS		20ST-7 5(6)-FS, RD (Q)
								QS	RR3	20ST-11 14B-FS, FD (R)
2CHS*23	2	C	3	Check		7-1	C-10	QS		20ST-7 5-PS, FD (Q)
								QS		20ST-7 4(6)-FS, RD (Q)
								QS	RR3	20ST-11 14B-FS, FD (R)
2CHS*24	2	C	3	Check		7-1	C-9	QS		20ST-7 6-PS, FD (Q)
								QS		20ST-7 4(5)-FS, RD (Q)
								QS	RR3	20ST-11 14B-FS, FD (R)
2CHS*31	2	A/C	3	Check		7-1	B-6	QS	CSJ5	20ST-1 10-FS, RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2CHS*75	3	C	2	Check		7-2	B-3	QS		20ST-7 1-FS, FD (Q)
2CHS*76	3	C	2	Check		7-2	F-3	QS		20ST-7 2-FS, FD (Q)
2CHS*84	3	C	2	Check		7-2	E-7	QS	CSJ7	20ST-7 13-FS, FD (CSD)
2CHS*FCV113A	3	B	2	Globe	A	7-2	E-7	QST		20ST-47 3A(3B) Stroke & Time Open (Q),(RPV)
2CHS*LCV115B	2	A	8	Gate	A	7-1	F-8	QST		20ST-47 3A(3B) Stroke & Time Open (Q),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)

BVPS 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 7
SYSTEM NAME: Chemical and Volume Control												
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2CHS*LCV115C	2	B	4	Gate	A	7-1	G-7	QST	CSJ6	2OST-1 10-Stroke & Time Closed (CSD), (RPV)		
2CHS*LCV115D	2	A	8	Gate	A	7-1	F-10	QST		2OST-47 3A(3B)-Stroke & Time Open (Q), (RPV)		
								LT		2BVT 1 47 11-Leak Test (R)		
2CHS*LCV115E	2	B	4	Gate	A	7-1	G-7	QST	CSJ6	2OST-1 10-Stroke & Time Closed (CSD), (RPV)		
2CHS*136	2	C	2	Check		7-2	E-8	QS	CSJ7	2OST-7 13-FS, FD (CSD)		
2CHS*141	2	C	2	Check		7-2	F-9	QS	CSJ7	2OST-7 13 FS, FD (CSD)		
2CHS*HCV142	2	A	2	Globe	S	7-1	F-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2CHS*152	2	C	2	Check		7-1	B-7	QS		2OST-7 4-FS, FD (Q)		
2CHS*153	2	C	2	Check		7-1	D-7	QS		2OST-7 5-FS, FD (Q)		
2CHS*154	2	C	2	Check		7-1	D-7	QS		2OST-7 6-FS, FD (Q)		
2CHS*FCV160	2	A/P	2	Globe	S	7-1	B-7	POS		2OST-47 3A(3B)-(RPV)		
								LT		2BVT 1 47 11-Leak Test (R)		
2CHS*RV160	2	C	1/4x1	Relief		7-1	A-7	SPT		2BVT 1 60 5-(R)		
2CHS*ADV200A	2	A	2	Globe	S	7-1	B-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)		
								LT	RR1, RR2, RR24	2BVT 1 47 5-Leak Test (R)		

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Chemical and Volume Control

SYSTEM NUMBER: 7

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2CHS*AOV200B	2	A	2	Globe	O	7-1	D-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
								LT	RR1,RR2,RR24	2BVT 1 47 5-Leak Test (R)
2CHS*AOV200C	2	A	2	Globe	S	7-1	E-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
								LT	RR1,RR2,RR24	2BVT 1 47 5-Leak Test (R)
2CHS*RV203	2	A/C	2x3	Relief		7-1	E-1	SPT		2BVT 1 60 5-(R)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2CHS*AOV204	2	A	2	Globe	O	7-1	G-2	QST	CSJ8	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2CHS*SOV206	2	B	1	Globe	S	7-2	E-8	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2OST-7 13-(RPV)
2CHS*RV260A	2	C	¼x1	Relief		7-3	B-4	SPT		2BVT 1 60 5-(R)
2CHS*RV260B	2	C	¼x1	Relief		7-3	E-3	SPT		2BVT 1 60 5-(R)
2CHS*RV260C	2	C	¼x1	Relief		7-3	G-4	SPT		2BVT 1 60 5-(R)
2CHS*MOV275A	2	B/P	2	Globe	O	7-1	F-6	POS		2OST-47 3B-(RPV)
2CHS*MOV275B	2	B/P	2	Globe	O	7-1	F-7	POS		2OST-47 3B-(RPV)
2CHS*MOV275C	2	B/P	2	Globe	O	7-1	F-7	POS		2OST-47 3B-(RPV)
2CHS*MOV289	2	A	3	Gate	O	7-1	B-6	QST	CSJ9	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)

SYSTEM NAME: Chemical and Volume Control										SYSTEM NUMBER: 7		
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2CHS*MOV308A	2	A	2	Gate	O	7-3	B-3	QST	CSJ10	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
								LT		2BVT 1 47 11-Leak Test (R)		
2CHS*MOV308B	2	A	2	Gate	O	7-3	D-3	QST	CSJ10	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
								LT		2BVT 1 47 11-Leak Test (R)		
2CHS*MOV308C	2	A	2	Gate	O	7-3	G-3	QST	CSJ10	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
								LT		2BVT 1 47 11-Leak Test (R)		
2CHS*MOV310	2	B	3	Gate	O	7-1	A-9	QST	CSJ11	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
2CHS*MOV350	2	B	2	Globe	S	7-2	F-8	QST		2OST-47 3A(3B) Stroke & Time Open (O), (RPV)		
2CHS*MOV378	2	A	3	Gate	O	7-3	E-8	QST	CSJ13	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
								LT	RR1,RR23	2BVT 1 47 5 Leak Test (R)		
2CHS*MOV381	2	A	3	Gate	O	7-3	F-8	QST	CSJ13	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
								LT		2BVT 1 47 5 Leak Test (R)		
2CHS*RV382A	2	C	2x3	Relief		7-3	C-8	SPT		2BVT 1 60 5 (R)		
2CHS*RV382B	2	C	2x3	Relief		7-3	E-10	SPT		2BVT 1 60 5 (R)		
2CHS*LCV460A	1	B	2	Globe	O	7-1	A-1	QST	CSJ14	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
2CHS*LCV460B	1	B	2	Globe	O	7-1	A-3	QST	CSJ14	2OST-1 10 Stroke & Time Closed (CSD), (RPV)		
2CHS*472	2	A/C/P	2 1/2	Check		7-1	B-7	LT		2BVT 1 47 11-Leak Test (R)		

**BVPS-2 1ST
VALVE TESTING OUTLINE**

SYSTEM NAME: Chemical and Volume Control

SYSTEM NUMBER: 7

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2CHS*473	2	A/C	2½	Check		7-3	E-8	QS	CSJ15	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT	RR1,RR23	2BVT 1 47 5-Leak Test (R)
2CHS*474	2	A/C	2½	Check		7-3	B-4	QS	CSJ16	2OST-1 10-FS,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2CHS*475	2	A/C	2½	Check		7-3	G-4	QS	CSJ16	2OST-1 10-FS,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2CHS*476	2	A/C	2½	Check		7-3	D-4	QS	CSJ16	2OST-1 10-FS,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2CHS*MOV8130A	2	B	8	Gate	LO	7-1	E-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8130B	2	B	8	Gate	LO	7-1	E-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8131A	2	B	8	Gate	LO	7-1	E-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8131B	2	B	8	Gate	LO	7-1	E-10	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8132A	2	B	4	Gate	LO	7-1	C-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8132B	2	B	4	Gate	LO	7-1	C-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8133A	2	B	4	Gate	LO	7-1	C-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*MOV8133B	2	B	4	Gate	LO	7-1	C-9	QST	CSJ17	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2CHS*RV8144	2	C	¼x1	Relief		7-1	A-5	SPT		2BVT 1 60 5-(R)

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 9
SYSTEM NAME: Reactor Plant Vents and Drains (Aerated Drains)										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2DAS-AOV100A	2	A	2	Globe	0	9-1	F-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (O), (RP-V)
2DAS-AOV100B	2	A	2	Globe	0	9-1	F-2	QST	RR1	2BVT 1 47 5-Leak Test (R)
2DAS-RV110	2	A/C	1 1/2x2 1/2	Relief		9-1	F-3	ST	RR1,RR28	2OST-47 3A(3B)-Stroke & Time Closed (O), (RPV)
								LT		2BVT 1 47 5-Leak Test (R)
								LT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Reactor Plant Vents and Drains (Hydrogenated Drains)

SYSTEM NUMBER: 9

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2DGS*AOV108A	2	A	2	Globe	O	9-1	F-10	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2DGS*AOV108B	2	A	2	Globe	O	9-1	E-10	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2DGS*RV115	2	A/C	1½x2	Relief		9-1	E-9	ST		2BVT 1 60 5 (R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 9
SYSTEM NAME: Reactor Plant Vents and Drains (Hydrogenated Gaseous Vents)										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2VRS*AOV109A1	2	A	1 1/2	Globe	0	9-1	C-9	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2VRS*AOV109A2	2	A	1 1/2	Globe	0	9-1	C-9	QST	RR1	20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
								LT	RR1	2BVT 1 47 5 Leak Test (R)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 10
SYSTEM NAME: Residual Heat Removal										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	
2RHS*3	2	C	10	Check		10-1	B-3	QS	CSJ18	20ST-10 3 FS RD (CSD)
2RHS*4	2	C	10	Check		10-1	E-3	QS	CSJ18	20ST-10 1 FS FD (CSD)
2RHS*15	2	A/P	6	Globe	LS	10-1	D-8	LT	RR1,RR2,RR28	20ST-10 4 FS RD (CSD)
2RHS*RV100	2	A/C	1/2x1	Relief		10-1	D-8	SPT		20ST-10 2 FS FD (CSD)
2RHS*107	2	A/P	6	Globe	LS	10-1	D-7	LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)
2RHS*FCV605A	2	B	8	Butterfly	T	10-1	B-5	QST	RR1,RR2	2BVT 1 60 5-(R)
2RHS*FCV605B	2	B	8	Butterfly	T	10-1	F-5	QST	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2RHS*MOV701A	1	A	12	Gate	S	10-1	C-1	QST	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2RHS*MOV701B	1	A	12	Gate	S	10-1	D-1	QST	CSJ19	20ST-10 3 Stroke, Time & Fail Closed (CSD), (RPV)
2RHS*MOV702A	1	A	12	Gate	S	10-1	C-1	QST	CSJ19	20ST-10 4 Stroke, Time & Fail Closed (CSD), (RPV)
								LT	CSJ20	20ST-10 3-Stroke & Time Closed (CSD), (RPV)
								LT		20ST-10 5-Leak Test (R)
								QST	CSJ20	20ST-10 4-Stroke & Time closed (CSD), (RPV)
								LT		20ST-10 5-Leak Test (R)
								QST	CSJ20	20ST-10 3-Stroke & Time Closed (CSD), (RPV)
								LT		20ST-10 5-Leak Test (R)

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Residual Heat Removal

SYSTEM NUMBER: 10

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2RHS*MOV702B	1	A	12	Gate	S	10-1	D-1	QST	CSJ20	2OST-10 4 Stroke & Time Closed (CSD), (RPV)
								LT		2OST-10 5 Leak Test (R)
2RHS*MOV720A	1	A	10	Gate	S	10-1	C-8	QST	CSJ20	2OST-10 3 Stroke & Time Closed (CSD), (RPV)
								LM		Continuously Monitored by 2OM 54 Station Log L5-120
2RHS*MOV720B	1	A	10	Gate	S	10-1	F-8	QST	CSJ20	2OST-10 4 Stroke & Time Closed (CSD), (RPV)
								LM		Continuously Monitored by 2OM 54 Station Log L5-120
2RHS*RV721A	2	C	3x4	Relief		10-1	C-1	SPT		2BVT 1 60 5-(R)
2RHS*RV721B	2	C	3x4	Relief		10-1	E-1	SPT		2BVT 1 60 5-(R)
2RHS*HCV758A	2	B	10	Butterfly	T	10-1	D-5	QST	CSJ21	2OST-10 3 Stroke, Time & Fail Open (CSD), (RPV)
2RHS*HCV753B	2	B	10	Butterfly	T	10-1	F-5	QST	CSJ21	2OST-10 4 Stroke, Time & Fail Open (CSD), (RPV)

BVPS 2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Safety Injection								SYSTEM NUMBER: 11		
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SIS*6	2	A/C	10	Check		11-1	E-4	QS		2OST-11 2-FS RD (Q)
								QS	RR4	2OST-11 14A-FS,FD (R)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*7	2	A/C	10	Check		11-1	G-4	QS		2OST-11 1-FS, RD (Q)
								QS	RR4	2OST-11 14A-FS,FD (R)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*27	2	A/C	8	Check		11-1	F-1	QS	RR5	2OST-1 10-PS,FD (CSD)
								QS	RR5	2OST-11 14B-FS,FD (R)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*41	2	A/P	1	Globe	S	11-2	C-2	LT	RR1,RR2B	2BVT 1 47 5-Leak Test (R)
2SIS*42	2	A/C	2½	Check		11-2	E-2	QS	CSJ22	2OST-1 10-FS, RD by Mechanical Exerciser (CSD)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SIS*46	2	C	10	Check		11-1	F-5	QS	CSJ53	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
2SIS*47	2	C	10	Check		11-1	D-5	QS	CSJ53	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
2SIS*83	2	A/C	3	Check		11-1	A-4	QS	CSJ23	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)

BVPS 2 IST
VALVE TESTING OUTLINE

SYSTEM NAME: Safety Injection						SYSTEM NUMBER: 11				
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SIS*84	2	A/C	3	Check		11-1	B-4	QS	CSJ23	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*84	2	A/C	3	Check		11-1	D-6	QS	CSJ23	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*85	2	A/C	3	Check		11-1	C-6	QS	CSJ23	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*107	1	A/C	6	Check		11-1	G-9	QS	RR6	2OST-11 14A-FS,FD (R)
								LT		2OST-11 16-Leak Test (R)
2SIS*108	1	A/C	6	Check		11-1	E-9	QS	RR6	2OST-11 14A-FS,FD (R)
								LT		2OST-11 16-Leak Test (R)
2SIS*109	1	A/C	6	Check		11-1	F-9	QS	RR6	2OST-11 14A-FS,FD (R)
								LT		2OST-11 16-Leak Test (R)
2SIS*122	1	C	2	Check		11-1	A-7	QS	RR7	2OST-11 14B-FS,FD (R)
2SIS*123	1	C	2	Check		11-1	A-7	QS	RR7	2OST-11 14B-FS,FD (R)
2SIS*124	1	C	2	Check		11-1	A-7	QS	RR7	2OST-11 14B-FS,FD (R)
2SIS*125	1	C	2	Check		11-1	B-7	QS	RR7	2OST-11 14B-FS,FD (R)
2SIS*126	1	C	2	Check		11-1	B-7	QS	RR7	2OST-11 14B-FS,FD (R)

SYSTEM NAME: Safety Injection										SYSTEM NUMBER: 11		
BVPs-2 IST VALVE TESTING OUTLINE												
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2SIS*127	1	C	2	Check		11-1	B-7	QS	RR7	2OST-11 14B-FS,FD (R)		
2SIS*128	1	A/C	6	Check		11-1	B-8	QS	RR8	2OST-11 14A-FS,FD (R)		
2SIS*129	1	A/C	6	Check		11-1	B-10	LT		2OST-11 16-Leak Test (R)		
2SIS*130	2	A/C	10	Check		11-1	F-9	QS	CSJ24	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
2SIS*RV130	2	A/C	1/2x1	Relief		11-2	D-2	SPT		2BVT 1 47 11-Leak Test (R)		
2SIS*132	2	A/C	10	Check		11-1	F-9	LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)		
2SIS*133	2	A/C	10	Check		11-1	E-9	QS	CSJ24	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
2SIS*134	1	C	2	Check		11-1	C-9	LT		2OST-11 16-Leak Test (R)		
2SIS*135	1	C	2	Check		11-1	D-9	QS	RR9	2OST-11 14B-FS,FD (R)		
2SIS*136	1	C	2	Check		11-1	D-9	QS	RR9	2OST-11 14B-FS,FD (R)		
2SIS*137	1	C	2	Check		11-1	C-9	QS	RR9	2OST-11 14B-FS,FD (R)		

BVPS 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 11
SYSTEM NAME: Safety Injection												
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2SIS*138	1	C	2	Check		11-1	C-9	QS	RR9	2OST-11 14B-FS,FD (R)		
2SIS*139	1	C	2	Check		11-1	C-9	QS	RR9	2OST-11 14B-FS,FD (R)		
2SIS*141	1	A/C	12	Check		6-1	E-6	QS	RR10	2BVT 1 11 3-FS,FD (R)		
								LT		2OST-11 4-Leak Test (R)		
2SIS*142	1	A/C	12	Check		11-2	F-9	QS	RR10	2BVT 1 11 3-FS,FD (R)		
2SIS*145	1	A/C	12	Check		6-1	D-6	QS	RR10	2BVT 1 11 3-FS,FD (R)		
								LT		2OST-11 4-Leak Test (R)		
2SIS*147	1	A/C	12	Check		11-2	F-7	QS	RR10	2BVT 1 11 3-FS,FD (R)		
								LT		2OST-11 5-Leak Test (R)		
2SIS*148	1	A/C	12	Check		11-2	F-4	QS	RR10	2BVT 1 11 3-FS,FD (R)		
								LT		2OST-11 5-Leak Test (R)		
2SIS*151	1	A/C	12	Check		6-1	D-5	QS	RR10	2BVT 1 11 3-FS,FD (R)		
								LT		2OST-11 4-Leak Test (R)		
2SIS*RV175	2	A/C	3/4x1	Relief		11-2	F-1	SPT		2BVT 1 60 5 (R)		
								LT		2BVT 1 47 5-Leak Test (R)		
2SIS*545	1	C	6	Check		11-1	A-9	QS	RR11	2OST-11 14A-FS,FD (R)		

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 11
SYSTEM NAME: Safety Injection										
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	OM No.	Drawing Coord.	Test Requirement	CSJ or Relief Requests	Comments
2SIS*546	1	C	6	Check		11-1	A-9	QS	RR11	2OST-11 14A-FS,FD (R)
2SIS*547	1	C	6	Check		11-1	A-9	QS	RR11	2OST-11 14B-FS,FD (R)
2SIS*548	1	C	6	Check		11-1	A-10	QS	RR12	2OST-11 14A-FS,FD (R)
2SIS*550	1	C	6	Check		11-1	A-10	QS	RR12	2OST-11 14A-FS,FD (R)
2SIS*552	1	C	6	Check		11-1	A-10	QS	RR12	2OST-11 14A-FS,FD (R)
2SIS*MOV836	2	A	3	Gate	S	11-1	D-5	QST	CSJ25	2OST-1 10-Stroke & Time Open/Closed (CSD),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*MOV840	2	A	1	Globe	S	11-1	C-5	QST		2OST-47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
								LT		BVT 1 47 11-Leak Test (R)
2SIS*MOV841	2	B	3	Gate	O	11-1	B-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SIS*MOV842	2	A	2	Globe	S	11-2	F-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SIS*RV858A	2	C	1x2	Relief		11-2	D-4	SPT		2BVT 1 60 5-(R)
2SIS*RV858B	2	C	1x2	Relief		11-2	D-7	SPT		2BVT 1 60 5-(R)
2SIS*RV859C	2	C	1x2	Relief		11-2	D-10	SPT		2BVT 1 60 5-(R)
2SIS*MOV863A	2	B	8	Gate	S	11-1	D-7	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2SIS*MOV863B	2	B	8	Gate	S	11-1	F-6	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)

BVP5-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 11
SYSTEM NAME: Safety Injection										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	
2SIS*MOV/865A	2	B/P	12	Gate	O	11-2	F-4	POS		20M-54 Log L5-35 Position Verified 2BVT 1 11 3-(RPV)
2SIS*MOV/865B	2	B/P	12	Gate	O	11-2	F-6	POS		20M-54 Log L5-35 Position Verified 2BVT 1 11 3-(RPV)
2SIS*MOV/865C	2	B/P	12	Gate	O	11-2	F-8	POS		20M-54 Log L5-35 Position Verified 2BVT 1 11 3-(RPV)
2SIS*MOV/867A	2	B	3	Gate	S	11-1	B-2	QST		20ST-47 3A(3B) Stroke & Time Open (Q), (RPV)
2SIS*MOV/867B	2	B	3	Gate	S	11-1	C-2	QST		20ST-47 3A(3B) Stroke & Time Open (Q), (RPV)
2SIS*MOV/867C	2	A	3	Gate	S	11-1	C-6	QST		20ST-47 3A(3B) Stroke & Time Open/Closed (Q), (RPV)
2SIS*MOV/867D	2	A	3	Gate	S	11-1	C-5	QST	RR33	2BVT 1 47 11-Leak Test (R)
2SIS*HCV/868A	2	B	1	Globe	S	11-1	D-5	QST		20ST-47 3A(3B) Stroke & Time Open/Closed (Q) 20ST-1 10-(RPV)
2SIS*HCV/868B	2	B	1	Globe	S	11-1	B-3	QST		20ST-47 3A(3B) Stroke & Time Open/Closed (Q) 20ST-1 10-(RPV)
2SIS*MOV/868A	2	A	3	Gate	S	11-1	A-3	QST	CSJ26	20ST-1 10-Stroke & Time Open/Closed (CSD), (RPV)
2SIS*MOV/868B	2	A	3	Gate	S	11-1	B-3	QST		2BVT 1 47 11-Leak Test (R)
2SIS*AOV/889	2	A	3/4	Globe	S	11-2	F-1	QST	RR1,RR28	20ST-47 3A(3B) Stroke & Time Closed (Q), (RPV) 2BVT 1 47 5-Leak Test (R)

SYSTEM NAME: Safety Injection										SYSTEM NUMBER: 11	
BVPS 2 IST VALVE TESTING OUTLINE											
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	MSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments	
						OM No.	Coord.				
2SIS-894	2	C	4	Check		11-1	E-3	QS		2OST-11 1-FS-FD (Q)	
2SIS-895	2	C	4	Check		11-1	F-4	QS		2OST-11 2-FS-RD (Q)	
2SIS*MOV8809A	2	A	14	Gate	O	11-1	E-1	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)	
2SIS*MOV8809B	2	A	14	Gate	O	11-1	G-1	LT		2BVT 1 47 11-Leak Test (R)	
2SIS*MOV8811A	2	B	10	Gate	S	11-1	E-5	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)	
2SIS*MOV8811B	2	B	10	Gate	S	11-1	F-5	QST		2OST-47 3A(3B) Stroke & Time Open (Q), (RPV)	
2SIS-RV8864A	2	C	1/4x1	Relief		11-1	F-7	SPT		2BVT 1 60 5-(R)	
2SIS-RV8864B	2	C	1/4x1	Relief		11-1	G-6	SPT		2BVT 1 60 5-(R)	
2SIS-RV8865	2	C	1/4x1	Relief		11-1	F-7	SPT		2BVT 1 60 5-(R)	
2SIS*MOV8867A	2	B	10	Gate	O	11-1	F-7	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)	
2SIS*MOV8867B	2	B	10	Gate	O	11-1	E-8	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)	
2SIS*MOV8868A	2	A	10	Gate	O	11-1	E-8	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)	
								LT		2BVT 1 47 11-Leak Test (R)	

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Safety Injection							SYSTEM NUMBER: 11			
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SIS*MOV8888B	2	A	10	Gate	O	11-1	G-8	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*MOV8889	2	A	10	Gate	S	11-1	F-8	QST	CSJ27	2OST-1 10-Stroke & Time Open/Closed (CSD),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*MOV8890A	2	A	4	Gate	S	11-1	F-4	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)
2SIS*MOV8890B	2	A	4	Gate	S	11-1	F-4	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
								LT		2BVT 1 47 11-Leak Test (R)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 11
SYSTEM NAME: Safety Injection (Gaseous Nitrogen)										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2GNS-AOV101-1	2	A	1	Globe	O	11-2	C-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q) 2BVT 1 11 3-(RPV) 2BVT 1 47 5-Leak Test (R)
2GNS-AOV101-2	2	A	1	Globe	O	11-2	C-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853A	2	B	1	Globe	S	11-2	D-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853B	2	B	1	Globe	S	11-2	C-6	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853C	2	B	1	Globe	S	11-2	C-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853D	2	B	1	Globe	S	11-2	C-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853E	2	B	1	Globe	S	11-2	C-6	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV853F	2	B	1	Globe	S	11-2	D-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV854A	2	B	1	Globe	S	11-2	C-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)
2GNS-SOV854B	2	B	1	Globe	S	11-2	D-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open (Q) 2BVT 1 11 3-(RPV)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 12
SYSTEM NAME: Containment Vacuum										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2CVS-93	2	A/C	1	Check		12-1	E-2	QS	RR13	2BVT 1 47 5-FS RD by Leak Test (R)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2CVS-SOV102	2	A	1	Globe	O	12-1	E-3	QST	CSJ52,RR30	2OST-1 10-Stroke & Time Open/Closed (CSD)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2CVS-151	2	A/P	B	Butterfly	LS	12-1	A-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2CVS-151-1	2	A/P	B	Butterfly	LS	12-1	A-3	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2CVS-SOV151A	2	A	2	Globe	O	12-1	C-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2CVS-SOV151B	2	A	2	Globe	O	12-1	D-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2CVS-SOV152A	2	A	2	Globe	O	12-1	C-5	QST	RR30	2OST-47 3A(3B)-Stroke & Time Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2CVS-SOV152B	2	A	2	Globe	O	12-1	D-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2CVS-SOV153A	2	A	1	Globe	O	12-1	F-3	QST	CSJ52,RR30	2OST-1 10-Stroke & Time Closed (CSD)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 12
SYSTEM NAME: Containment Vacuum										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
2CVS-SOV153B	2	A	1	Globe	0	OM No.	Coord.	OST	CSJ52,RR30	20ST-1 10-Stroke & Time Closed (CSD)
						12-1	F-2	LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)

**BVPS-2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Leakage Monitoring

SYSTEM NUMBER: 12

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2LMS*51	2	A/P	½	Gate	SS	12-2	E-6	LT	RR1	2BVT 1 47 5-Leak Test (R)
2LMS*52	2	A/P	½	Gate	SS	12-2	E-6	LT	RR1	2BVT 1 47 5-Leak Test (R)
2LMS*SOV850	2	B	½	Globe	O	12-1	F-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OM-51 4 D or 2OM-12 4 A-(RPV)
2LMS*SOV851	2	B	½	Globe	O	12-1	E-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OM-51 4 D or 2OM-12 4 A-(RPV)
2LMS*SOV852	2	B	½	Globe	O	12-1	C-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OM-51 4 D or 2OM-12 4 A-(RPV)
2LMS*SOV853	2	B	½	Globe	O	12-1	B-9	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OM-51 4 D or 2OM-12 4 A-(RPV)

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Containment Depressurization (Quench Spray)						SYSTEM NUMBER: 13				
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2QSS*3	2	A/C	10	Check		13-2	E-10	QS	CSJ28	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2QSS*4	2	A/C	10	Check		13-2	C-9	QS	CSJ28	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)
								LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2QSS*MOV100A	2	B	12	Gate	O	13-2	A-8	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2QSS*MOV100B	2	B	12	Gate	O	13-2	G-8	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2QSS*SOV100A	2	A	2	Globe	S	13-2	D-7	QST	CSJ29,RR30	2OST-1 10-Stroke & Time Open/Closed (CSD)
								LT	RR1,RR27	2BVT 1 47 5-Leak Test (R),(RPV)
2QSS*SOV100B	2	A	2	Globe	S	13-2	E-7	QST	CSJ29,RR30	2OST-1 10 Stroke & Time Open/Closed (CSD)
								LT	RR1,RR27	2BVT 1 47 5-Leak Test (R),(RPV)
2QSS*MOV101A	2	A	10	Gate	O	13-2	C-9	QST		2OST-47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
								LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)
2QSS*MOV101B	2	A	10	Gate	O	13-2	D-9	QST		2OST-47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
								LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)
2QSS*RV101A	2	A/C	1/4x1	Relief		13-2	C-9	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Containment Depressurization (Quench Spray)								SYSTEM NUMBER: 13		
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2QSS*RV101B	2	A/C	¼x1	Relief		13-2	E-9	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR2, RR2B	2BVT 1 47 5-Leak Test (R)
2QSS*SOV101A	2	B	2	Globe	O	13-2	D-7	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OST-13 10A-(RPV-Open) 2BVT 1 47 5-(RPV-Closed)
2QSS*SOV101B	2	B	2	Globe	O	13-2	E-7	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OST-13 10B-(RPV-Open) 2BVT 1 47 5-(RPV-Closed)
2QSS*MOV102A	2	B	6	Gate	S	13-2	B-5	QST	CSJ57	2OST-1 10-Stroke & Time Open (CSD),(RPV)
2QSS*MOV102B	2	B	6	Gate	S	13-2	E-5	QST	CSJ57	2OST-1 10-Stroke & Time Open (CSD),(RPV)
2QSS*RV102A	2	C	1½x2	Relief		13-2	C-6	SPT		2BVT 1 60 5-(R)
2QSS*RV102B	2	C	1½x2	Relief		13-2	E-6	SPT		2BVT 1 60 5-(R)
2QSS*SOV102A	2	B	2	Globe	O	13-2	D-7	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OST-13 10A-(RPV-Open) 2BVT 1 47 5-(RPV-Closed)
2QSS*SOV102B	2	B	2	Globe	O	13-2	E-7	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OST-13 10B-(RPV-Open) 2BVT 1 47 5-(RPV-Closed)
2QSS*AOV120A	2	B	6	Globe	O	13-2	D-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2QSS*AOV120B	2	B	6	Globe	O	13-2	D-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2QSS*227	2	C	2	Check		13-2	C-6	QS		2OST-13 10A-FS,FD (Q)
								QS		2OST-13 10B-FS,RD (Q)
2QSS*228	2	C	2	Check		13-2	D-6	QS		2OST-13 10B-FS,FD (Q)
								QS		2OST-13 10A-FS,RD (Q)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 13
SYSTEM NAME: Containment Depressurization (Quench Spray)										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2QSS-287	2	A/C	2 1/2	Check		13-2	C-9	QS	CSJ30	20ST-1 10-FS, FD, RD by Mechanical Exerciser (CSD)
2QSS-303	2	C	2	Check		13-2	A-8	QS	RR1	2BVT 1 47 5-Leak Test (R)
2QSS-304	2	C	2	Check		13-2	F-8	QS	CSJ34	20ST-13 10A-FS, FD (Q)
								QS		20ST-1 10-FS, RD (CSD)
								QS		20ST-13 10B-FS, FD (Q)
								QS	CSJ34	20ST-1 10-FS, RD (CSD)

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Containment Depressurization (Recirculation Spray)							SYSTEM NUMBER: 13			
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2RSS*3	2	A/P	4	Gate	LS	13-1	B-3	LT		2BVT 1 13 6-Leak Test (R)
2RSS*4	2	A/P	4	Gate	LS	13-1	B-8	LT		2BVT 1 13 6-Leak Test (R)
2RSS*5	2	A/P	4	Gate	LS	13-1	E-1	LT		2BVT 1 13 6-Leak Test (R)
2RSS*6	2	A/P	4	Gate	LS	13-1	E-10	LT		2BVT 1 13 6-Leak Test (R)
2RSS*9	2	A/P	1½	Gate	S	13-1	F-2	LT		2BVT 1 13 6-Leak Test (R)
2RSS*10	2	A/P	1½	Gate	S	13-1	E-9	LT		2BVT 1 13 6-Leak Test (R)
2RSS*11	2	A/P	1½	Gate	S	13-1	E-4	LT		2BVT 1 13 6-Leak Test (R)
2RSS*12	2	A/P	1½	Gate	S	13-1	E-7	LT		2BVT 1 13 6-Leak Test (R)
2RSS*27	2	A/P	4	Gate	LS	13-1	C-2	LT		2BVT 1 13 5-Leak Test (R)
2RSS*28	2	A/P	4	Gate	LS	13-1	C-9	LT		2BVT 1 13 5-Leak Test (R)
2RSS*29	2	C	12	Check		13-1	B-2	QS	CSJ31	2OST-1 10-FS,FD by Mechanical Exerciser (CSD)
2RSS*30	2	C	12	Check		13-1	B-8	QS	CSJ31	2OST-1 10-FS,FD by Mechanical Exerciser (CSD)
2RSS*31	2	C	12	Check		13-1	B-4	QS	CSJ31	2OST-1 10-FS,FD by Mechanical Exerciser (CSD)
2RSS*32	2	C	12	Check		13-1	B-7	QS	CSJ31	2OST-1 10-FS,FD by Mechanical Exerciser (CSD)
2RSS*RV101C	2	C	¼x1	Relief		13-1	C-4	SPT		2BVT 1 60 5-(R)
2RSS*RV101D	2	C	¼x1	Relief		13-1	C-7	SPT		2BVT 1 60 5-(R)
2RSS*MOV154C	2	B	3	Gate	S	13-1	C-4	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q)

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Containment Depressurization (Recirculation Spray)							SYSTEM NUMBER: 13			
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2RSS*MOV154D	2	B	3	Gate	S	13-1	C-7	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q)
2RSS*MOV155A	2	B	12	Butterfly	O	13-1	G-4	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV155B	2	B	12	Butterfly	O	13-1	G-7	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV155C	2	B	12	Butterfly	O	13-1	F-5	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV155D	2	B	12	Butterfly	O	13-1	F-6	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV156A	2	B	12	Gate	O	13-1	B-2	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV156B	2	B	12	Gate	O	13-1	B-9	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV156C	2	B	12	Gate	O	13-1	B-4	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*MOV156D	2	B	12	Gate	O	13-1	B-7	QST		2OST 47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
2RSS*RV156A	2	C	¼x1	Relief		13-1	B-2	SPT		2BVT 1 60 5-(R)
2RSS*RV156B	2	C	¼x1	Relief		13-1	B-8	SPT		2BVT 1 60 5-(R)
2RSS*RV156C	2	C	¼x1	Relief		13-1	B-4	SPT		2BVT 1 60 5-(R)
2RSS*RV156D	2	C	¼x1	Relief		13-1	B-7	SPT		2BVT 1 60 5-(R)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 14A
SYSTEM NAME: Reactor Plant Sample										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2SSR*AOV100A1	2	A	3/4	Globe	O	14A-1	C-8	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SSR*AOV100A2	2	A	3/4	Globe	O	14A-1	D-9	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR*AOV102A1	2	A	3/4	Globe	O	14A-2	C-1	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SSR*AOV102A2	2	A	3/4	Globe	O	14A-2	D-1	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR*AOV109A1	2	A	3/4	Globe	O	14A-1	C-7	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SSR*AOV108A2	2	A	3/4	Globe	O	14A-1	D-7	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR*AOV112A1	2	A	3/4	Globe	O	14A-1	C-8	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2SSR*AOV112A2	2	A	3/4	Globe	O	14A-1	D-8	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR*AOV117A	2	B	3/4	Globe	O	14A-1	B-2	QST		2OST-47 3A(3B) Stroke & Time Closed (Q) (RPV)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 14A
SYSTEM NAME: Reactor Plant Sample										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	OM Nc.	Coord.	Test Requirement	CSJ or Relief Requests	
2SSR-AOV117B	2	B	1/4	Globe	O	14A-1	B-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (O), (RPV)
2SSR-AOV117C	2	B	1/4	Globe	O	14A-1	B-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (O), (RPV)
2SSR-RV117	2	A/C	1/4 x 1	Relief		14A-1	D-7	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-RV118	2	A/C	1/4 x 1	Relief		14A-2	C-1	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-RV119	2	A/C	1/4 x 1	Relief		14A-1	D-9	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-RV120	2	A/C	1/4 x 1	Relief		14A-2	C-2	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-RV121	2	A/C	1/4 x 1	Relief		14A-1	D-8	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-RV122	2	A/C	1/4 x 1	Relief		14A-2	C-3	SPT		2BVT 1 60 5-(R)
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R)
2SSR-SOV128A1	2	A	1/4	Globe	O	14A-2	B-3	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (O)
								LT	RR1	2BVT 1 47 5-Leak Test (R), (RPV)

BVPS-2 IST VALVE TESTING OUTLINE											
SYSTEM NUMBER: 14A											
SYSTEM NAME: Reactor Plant Sample											
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments	
						OM No.	Coord.				
25SR-SOV129A2	2	A	½	Globe	O	14A-2	D-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)	
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R),(RPV)	
25SR-SOV129A1	2	A	½	Globe	O	14A-2	B-4	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)	
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)	
25SR-SOV129A2	2	A	½	Globe	O	14A-2	D-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)	
								LT	RR1,RR28	2BVT 1 47 5-Leak Test (R),(RPV)	
25SR-SOV130A1	2	A	½	Globe	O	14A-2	B-10	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)	
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)	
25SR-SOV130A2	2	A	½	Globe	O	14A-2	C-10	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)	
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)	

BVPS 2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Post-Accident Sample						SYSTEM NUMBER: 14C				
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2PAS-SOV105A1	2	A	1/2	Globe	S	14C-2	A-2	QST	RR30	20ST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2PAS-SOV105A2	2	A	1/2	Globe	S	14C-2	A-3	QST	RR30	20ST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 15
SYSTEM NAME: Primary Component Cooling Water										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	OM No.	Drawing Coord.	Test Requirement	CSJ or Relief Requests	
2CCP-4	3	C	20	Check		15-1	B-5	QS		20ST-15.1-PS,FD & FS,RD (Q)
2CCP-5	3	C	20	Check		15-1	F-5	QS	CSJ58	20ST-15.1-FS,FD (CSD)
2CCP-6	3	C	20	Check		15-1	D-5	QS	CSJ58	20ST-15.2-PS,FD & FS,RD (Q)
2CCP-27A	3	B	20	Butterfly	O	15-1	C-6	QS	CSJ54	20ST-15.3-PS,FD & FS,RD (Q)
2CCP-27B	3	B	20	Butterfly	O	15-1	E-6	QS	CSJ54	20ST-15.3-FS,FD (CSD)
2CCP-RV102	2	A/C	1/2x1	Relief		15-2	D-4	SPT		20ST-1.10-Stroke Only Closed (CSD)
2CCP-RV103	2	A/C	1/2x1	Relief		15-2	D-5	SPT	RR1,RR2,RR28	20ST-1.10-Stroke Only Closed (CSD)
2CCP-RV104	2	A/C	1/2x1	Relief		15-2	D-4	SPT		2BVT 1.60.5-(R)
2CCP-RV105	2	A/C	1/2x1	Relief		15-2	E-4	SPT	RR1,RR2,RR28	2BVT 1.47.5-Leak Test (R)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 15
SYSTEM NAME: Primary Component Cooling Water										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	
2CCP-ADV107A	3	A	2	Globe	O	15-3	C-5	QST	CSJ32	2OST-1 10-Stroke, Time & Fail Closed (CSD), (RPV)
								LT		2BVT 1 60 6-Leak Test (R)
2CCP-ADV107B	3	A	2	Globe	O	15-3	F-5	QST	CSJ32	2OST-1 10-Stroke, Time & Fail Closed (CSD), (RPV)
								LT		2BVT 1 60 6-Leak Test (R)
2CCP-ADV107C	3	A	2	Globe	O	15-3	F-10	QST	CSJ32	2OST-1 10-Stroke, Time & Fail Closed (CSD), (RPV)
								LT		2BVT 1 60 6-Leak Test (R)
2CCP-MOV112A	3	B	18	Butterfly	S	15-2	D-8	QST		2OST-15 1(3)-Stroke & Time Open (Q), (RPV)
2CCP-MOV112B	3	B	18	Butterfly	S	15-2	F-9	QST		2OST-15 2(3)-Stroke & Time Open (Q), (RPV)
2CCP-RV116A	3	C	1/4x1	Relief		15-3	C-2	SPT		2BVT 1 60 5-(R)
2CCP-RV116B	3	C	1/4x1	Relief		15-3	F-1	SPT		2BVT 1 60 5-(R)
2CCP-RV116C	3	C	1/4x1	Relief		15-3	F-6	SPT		2BVT 1 60 5-(R)
2CCP-MOV118	3	B	2	Ball	O	15-2	C-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2CCP-MOV119	3	B	2	Ball	O	15-2	C-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2CCP-MOV120	3	B	2	Ball	O	15-2	A-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2CCP-RV120A	3	C	1/4x1	Relief		15-2	C-2	SPT		2BVT 1 60 5-(R)
2CCP-RV140	3	C	1/4x1	Relief		15-2	E-7	SPT		2BVT 1 60 5-(R)
2CCP-RV141	3	C	1/4x1	Relief		15-2	B-7	SPT		2BVT 1 60 5-(R)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 15
SYSTEM NAME: Primary Component Cooling Water										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2CCP-MOV150-1	2	A	18	Butterfly	O	15-2	D-4	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV150-2	2	A	18	Butterfly	O	15-2	D-5	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV151-1	2	A	18	Butterfly	O	15-2	E-4	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV151-2	2	A	18	Butterfly	O	15-2	E-5	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV156-1	2	A	18	Butterfly	O	15-2	D-3	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV156-2	2	A	18	Butterfly	O	15-2	D-4	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV157-1	2	A	18	Butterfly	O	15-2	E-3	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-MOV157-2	2	A	18	Butterfly	O	15-2	E-4	QST	CSJ33	2OST-1 10-Stroke & Time Closed (CSD), (RPV)
								LT	RR1,RR2, RR28	2BVT 1 47 5-Leak Test (R)
2CCP-AOV171	3	B	3	Globe	O	15-2	E-7	QST	RR1,RR2, RR28	2OST-47.3A(3B) Stroke & Time Closed (CSD), (RPV)

**BVPS-2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Primary Component Cooling Water

SYSTEM NUMBER: 15

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2CCP*AOV172	3	B	3	Globe	O	15-2	D-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*AOV173	3	B	3	Globe	O	15-2	B-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*AOV174	3	B	3	Globe	O	15-2	B-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV175-1	3	B	10	Butterfly	O	15-5	B-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV175-2	3	B	10	Butterfly	O	15-5	B-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV176-1	3	B	10	Butterfly	O	15-5	A-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV176-2	3	B	10	Butterfly	O	15-5	A-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV177-1	3	B	10	Butterfly	O	15-5	G-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV177-2	3	B	10	Butterfly	O	15-5	G-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV178-1	3	B	10	Butterfly	O	15-5	G-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*MOV178-2	3	B	10	Butterfly	O	15-5	G-5	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q).(RPV)
2CCP*289	3	A/C	2	Check		15-3	C-1	QS	RR14	2BVT 1 60 6-FS.RD By Leak Test (R)
								LT		2BVT 1 60 6-Leak Test (R)
2CCP*290	3	A/C	2	Check		15-3	F-1	QS	RR14	2BVT 1 60 6-FS.RD By Leak Test (R)
								LT		2BVT 1 60 6-Leak Test (R)
2CCP*291	3	A/C	2	Check		15-3	F-6	QS	RR14	2BVT 1 60 6-FS.RD By Leak Test (R)
								LT		2BVT 1 60 6-Leak Test (R)

SYSTEM NAME: Primary Component Cooling Water										SYSTEM NUMBER: 15		
BVPS 2 IST VALVE TESTING OUTLINE												
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	MSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2CCP-321	3	B	2	Butterfly	O	15-1	B-3	QS		20ST-15 1-Stroke Only Closed (Q)		
2CCP-322	3	B	2	Butterfly	O	15-1	F-3	QS		20ST-15 2-Stroke Only Closed (Q)		
2CCP-323	3	B	2	Gate	O	15-1	C-3	QS		20ST-15 1-Stroke Only Closed (Q)		
2CCP-324	3	B	20	Butterfly	O	15-1	E-3	QS		20ST-15 2-Stroke Only Closed (Q)		
2CCP-325	3	B	20	Butterfly	O	15-1	C-3	QS		20ST-15 1-Stroke Only Closed (Q)		
2CCP-326	3	B	2	Butterfly	O	15-1	E-3	QS		20ST-15 2-Stroke Only Closed (Q)		
2CCP-352	3	C	2	Check		15-2	A-2	QS	RR15	2BVT 1 69 6-FS, RD By Leak Test (R)		
2CCP-354	3	B	20	Butterfly	O	15-1	E-8	QS	CSJ54	20ST-1 10-Stroke Only Closed (CSD)		
2CCP-355	3	B	20	Butterfly	O	15-1	D-9	QS	CSJ54	20ST-1 10-Stroke Only Closed (CSD)		

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Fuel Pool Cooling & Purification										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2FNC-9	2	A/P	6	Ball	LS	20-1	E-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2FNC-38	2	A/P	6	Ball	LS	20-1	E-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2FNC-121	2	A/P	6	Ball	LS	20-1	D-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)
2FNC-122	2	A/P	6	Ball	LS	20-1	F-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)

SYSTEM NUMBER: 20

**BVPS-2 1ST
VALVE TESTING OUTLINE**

SYSTEM NAME: Main Steam

SYSTEM NUMBER: 21

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2MSS*18	3	C	3	Check		21-2	A-3	QS	RR16	2BVT 1 60 6-FS RD By Leak Test (R)
								QS		2OST-24 4-PS FD (Q)
								QS	CSJ12	2OST-24 4-FS FD (CSD)
2MSS*19	3	C	3	Check		21-2	C-2	QS	RR16	2BVT 1 60 6-FS RD By Leak Test (R)
								QS		2OST-24 4-PS FD (Q)
								QS	CSJ12	2OST-24 4-FS FD (CSD)
2MSS*20	3	C	3	Check		21-2	D-2	QS	RR16	2BVT 1 60 6-FS RD By Leak Test (R)
								QS		2OST-24 4-PS FD (Q)
								QS	CSJ12	2OST-24 4-FS FD (CSD)
2MSS*AOV101A	2	B	32	Globe	O	21-1	G-8	QS		2OST-21 1 Partial Stroked Closed Only (Q)
								QST	CSJ35	2OST-21 7-Stroke & Time Closed (CSD),(RPV)
2MSS*AOV101B	2	B	32	Globe	O	21-1	D-8	QS		2OST-21 2-Partial Stroked Closed Only (Q)
								QST	CSJ35	2OST-21 7-Stroke & Time Closed (CSD),(RPV)
2MSS*AOV101C	2	B	32	Globe	O	21-1	B-9	QS		2OST-21 3-Partial Stroked Closed Only (Q)
								QST	CSJ35	2OST-21 7-Stroke & Time Closed (CSD),(RPV)
2MSS*SV101A	2	C	6x10	Relief		21-1	F-5	SPT		2BVT 1 21 2-(R)
2MSS*SV101B	2	C	6x10	Relief		21-1	C-5	SPT		2BVT 1 21 2-(R)

**EVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Main Steam

SYSTEM NUMBER: 21

Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2MSS*SV101C	2	C	6x10	Relief		21-1	A-5	SPT		2BVT 1 21 2-(R)
2MSS*AOV102A	2	B	2	Globe	S	21-1	G-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2MSS*AOV102B	2	B	2	Globe	S	21-1	E-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q) (RPV)
2MSS*AOV102C	2	B	2	Globe	S	21-1	C-7	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2MSS*SV102A	2	C	6x10	Relief		21-1	F-5	SPT		2BVT 1 21 2-(R)
2MSS*SV102B	2	C	6x10	Relief		21-1	C-4	SPT		2BVT 1 21 2-(R)
2MSS*SV102C	2	C	6x10	Relief		21-1	A-5	SPT		2BVT 1 21 2-(R)
2MSS*SV103A	2	C	6x10	Relief		21-1	F-4	SPT		2BVT 1 21 2-(R)
2MSS*SV103B	2	C	6x10	Relief		21-1	C-4	SPT		2BVT 1 21 2-(R)
2MSS*SV103C	2	C	6x10	Relief		21-1	A-4	SPT		2BVT 1 21 2-(R)
2MSS*SV104A	2	C	6x10	Relief		21-1	F-4	SPT		2BVT 1 21 2-(R)
2MSS*SV104B	2	C	6x10	Relief		21-1	C-4	SPT		2BVT 1 21 2-(R)
2MSS*SV104C	2	C	6x10	Relief		21-1	A-4	SPT		2BVT 1 21 2-(R)
2MSS*SOV105A	2	B	3	Globe	S	21-2	D-1	QST		2OST-24 4 Stroke & Time Open/Closed (Q),(RPV)
2MSS*SOV105B	2	B	3	Globe	S	21-2	C-2	QST	RR30	2OST-24 4-Stroke & Time Open/Closed (Q),(RPV)
2MSS*SOV105C	2	B	3	Globe	S	21-2	A-1	QST	RR30	2OST-24 4-Stroke & Time Open/Closed (Q),(RPV)
2MSS*SOV105D	2	B	3	Globe	S	21-2	D-2	QST		2OST-24 4-Stroke & Time Open (Q),(RPV)

**BVPS-2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Main Steam

SYSTEM NUMBER: 21

Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2MSS*SOV105E	2	B	3	Globe	S	21-2	C-2	QST	RR30	2OST-24 4-Stroke & Time Open (Q) (RPV)
2MSS*SOV105F	2	B	3	Globe	S	21-2	A-2	QST	RR30	2OST-24 4-Stroke & Time Open (Q) (RPV)
2MSS*SV105A	2	C	6x10	Relief		21-1	F-3	SPT		2BVT 1 21 2-(R)
2MSS*SV105B	2	C	6x10	Relief		21-1	C-3	SPT		2BVT 1 21 2-(R)
2MSS*SV105C	2	C	6x10	Relief		21-1	A-3	SPT		2BVT 1 21 2-(R)
2MSS*SOV120	2	B	1/2	Globe	S	21-2	G-5	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q) 2OST-47 3A-(RPV)
2MSS*196	3	C	3	Check		21-2	D-3	QS	RR16	2BVT 1 60 6-PS,RD By Leak Test (R)
								QS		2OST-24 4-PS,FD (Q)
								QS	CSJ12	2OST-24 4-FS,FD (CSD)
2MSS*199	3	C	3	Check		21-2	C-3	QS	RR16	2BVT 1 60 6-FS,RD By Leak Test (R)
								QS		2OST-24 4-PS,FD (Q)
								QS	CSJ12	2OST-24 4-FS,FD (CSD)
2MSS*352	3	C	3	Check		21-2	A-2	QS	RR16	2BVT 1 60 6-FS,RD By Leak Test (R)
								QS		2OST-24 4-PS,FD (Q)
								QS	CSJ12	2OST-24 4-FS,FD (CSD)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 21
SYSTEM NAME: Main Steam (Drains)										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2SDS*AOV111A1	2	B	1 1/2	Globe	0	21-3	B-4	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2SDS*AOV111A2	2	B	1 1/2	Globe	0	21-3	B-4	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (P/V)
2SDS*AOV111B1	2	B	1 1/2	Globe	0	21-3	B-6	QST		20ST-47 3A(3B)-Stroke & Time Closed (C), (RPV)
2SDS*AOV111B2	2	B	1 1/2	Globe	0	21-3	B-6	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2SDS*AOV111C1	2	B	1 1/2	Globe	0	21-3	B-8	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2SDS*AOV111C2	2	B	1 1/2	Globe	0	21-3	B-8	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2SDS*AOV129A	2	B	1	Globe	0	21-3	C-1	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2SDS*AOV129B	2	B	1	Globe	0	21-3	B-1	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)

BVP-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 21
SYSTEM NAME: Main Steam (Vents)										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SVS*80	2	C	6	Check		21-2	F-8	QS	RR17	2BVT 1 60 6 FS.RD By Leak Test (R)
								QS	CSJ36	2OM-51 4C-FS-FD (CSD)
2SVS*81	2	C	6	Check		21-2	F-9	QS	RR17	2BVT 1 60 6-FS.RD By Leak Test (R)
								QS	CSJ36	2OM-51 4C-FS-FD (CSD)
2SVS*82	2	C	6	Check		21-2	F-10	QS	RR17	2BVT 1 60 6 FS.RD By Leak Test (R)
								QS	CSJ36	2OM-51 4C-FS-FD (CSD)
2SVS*PCV101A	2	B	10	Globe	S	21-1	F-4	QST	CSJ37	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
								QST	CSJ37	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
2SVS*PCV101B	2	B	10	Globe	S	21-1	D-4	QST	CSJ37	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
								QST	CSJ37	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
2SVS*PCV101C	2	B	10	Globe	S	21-1	B-4	QST	CSJ37	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
								QST	CSJ38	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
2SVS*HCV104	2	B	10	Globe	S	21-2	F-7	QST	CSJ38	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)
								QST	CSJ38	2OST-1 10-Stroke & Time Open/Closed & Fail Closed (CSD), (RPV)

BVPS-2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 24
SYSTEM NAME: Main Feedwater												Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Retief Requests	Comments	SYSTEM NUMBER: 24	
						OM No.	Coord.					
2FWS*28	2	C	16	Check		24-2A	F-7	QS	RR18	20ST-24 B FS RD By Leak Test (R)		
2FWS*29	2	C	16	Check		24-2A	D-7	QS	RR18	20ST-24 B FS RD By Leak Test (R)		
2FWS*31	2	C	16	Check		24-2A	B-7	QS	RR18	20ST-24 B FS RD By Leak Test (R)		
2FWS*HYV157A	2	B	16	Gate	O	24-2A	F-6	QST	CSJ39	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*HYV157B	2	B	16	Gate	O	24-2A	D-6	QST	CSJ39	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*HYV157C	2	B	16	Gate	O	24-2A	B-6	QST	CSJ39	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV478	2	B	16	Globe	T	24-2A	F-3	QST	CSJ55	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV479	2	B	6	Globe	T	24-2A	E-3	QST	CSJ56	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV488	2	B	16	Globe	T	24-2A	D-3	QST	CSJ55	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV489	2	B	6	Globe	T	24-2A	C-3	QST	CSJ56	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV496	2	B	16	Globe	T	24-2A	B-3	QST	CSJ55	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		
2FWS*FCV499	2	B	6	Globe	T	24-2A	A-3	QST	CSJ56	20ST-1 10-Stroke & Time Closed (CSD), (RPV)		

BVP5 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 24
SYSTEM NAME: Auxiliary Feedwater												Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	Comments	SYSTEM NUMBER: 24	
2FWE*42A	2	C	4	Check		24-3	A-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*42B	2	C	4	Check		24-3	B-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*43A	2	C	4	Check		24-3	C-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*43B	2	C	4	Check		24-3	C-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*44A	2	C	4	Check		24-3	D-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*44B	2	C	4	Check		24-3	E-8	QS	CSJ40	20ST-24 6 FS,FD,RD (CSD)		
2FWE*90	3	B	6	Butterfly	LS	24-3	D-2	QS		20ST-24 1-Stroke Only Open (M)		
2FWE*91	3	B	4	Butterfly	LS	24-3	E-2	QS		20ST-24 1-Stroke Only Open (M)		
2FWE*92	3	B	4	Butterfly	LS	24-3	F-2	QS		20ST-24 1-Stroke Only Open (M)		
2FWE*99	2	C	4	Check		24-3	B-10	QS	RR19	20ST-24 8A,FS,RD By Leak Test (R)		
2FWE*100	2	C	4	Check		24-3	C-10	QS	RR19	20ST-24 8A,FS,RD By Leak Test (R)		
2FWE*HCV100A	2	B	3	Globe	O	24-3	D-7	QST	CSJ41	20ST-24 6 FS,FD (CSD)		
2FWE*HCV100B	2	B	3	Globe	O	24-3	E-7	QST		20ST-47 3A(3B)-Stroke & Time Open/Closed (Q) (RPV)		
2FWE*HCV100C	2	B	3	Globe	O	24-3	C-7	QST		20ST-47 3A(3B)-Stroke & Time Open/Closed (Q) (RPV)		
2FWE*HCV100D	2	B	3	Globe	O	24-3	C-7	QST		20ST-47 3A(3B)-Stroke & Time Open/Closed (Q) (RPV)		

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 24
SYSTEM NAME: Auxiliary Feedwater										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	
2FWE-HCV100E	2	B	3	Globe	O	24-3	A-7	QST		20ST-47 3A(3B)-Stroke & Time Open/Closed (Q).(RPV)
2FWE-HCV100F	2	B	3	Globe	O	24-3	B-7	QST		20ST-47 3A(3B)-Stroke & Time Open/Closed (Q).(RPV)
2FWE-SOV100A	3	B/P	2	Globe	S	24-3	D-2	POS		20ST-47 3B (RPV)
2FWE-SOV100B	3	B/P	2	Globe	S	24-3	D-2	POS		20ST-47 3B (RPV)
2FWE*101	2	C	4	Check		24-3	E-10	QS	RR19	20ST-24 8A-FS, RD By Leak Test (R)
2FWE-RV101	3	C	3x4	Relief		24-3	D-5	SPT	CSJ41	20ST-24 6-FS, FD (CSD)
2FWE-FCV122	3	B	6	(NOTE 1)		24-3	E-5	QS		2BVT 1 60 5-(R)
								QS	CSJ42	20ST-24 4 Stroke Only Open (M)
								QS	CSJ42	20ST-24 4 Stroke Only Closed (CSD)
								QS	CSJ42	20ST-24 4-FS, FD (CSD)
								QS	CSJ42	20ST-24 6-FS, RD (CSD)
2FWE-FCV123A	3	B	4	(NOTE 1)		24-3	F-6	QS		20ST-24 2 Stroke Only Open (M)
								QS	CSJ42	20ST-24 6 Stroke Only Closed (CSD)
								QS	CSJ42	20ST-24 6-FS, FD (CSD)
								QS	CSJ42	20ST-24 6-FS, RD (CSD)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 24
SYSTEM NAME: Auxiliary Feedwater										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	MSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2PWE-FCV123B	3	B	4	(NOTE 1)		24-3	G-6	QS		20ST-24 3 Stroke Only Open (M)
								QS	CSJ42	20ST-24 6 Stroke Only Closed (CSD)
	3	C	4	Check		24-3	G-6	QS	CSJ42	20ST-24 6 FS, FD (CSD)
								QS	CSJ42	20ST-24 6 FS, RD (CSD)

NOTE 1: Yarway automatic recirculation control valve acts as both a flow control valve and check valve

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Steam Generator Blowdown

SYSTEM NUMBER: 25

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2BDG*AOV100A1	2	B	3	Globe	O	25-1	G-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV100B1	2	B	3	Globe	O	25-1	E-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV100C1	2	B	3	Globe	O	25-1	B-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101A1	2	B	3	Globe	O	25-1	G-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101A2	2	B	3	Globe	O	25-1	G-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101B1	2	B	3	Globe	O	25-1	E-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101B2	2	B	3	Globe	O	25-1	E-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101C1	2	B	3	Globe	O	25-1	B-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2BDG*AOV101C2	2	B	3	Globe	O	25-1	C-3	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 27
SYSTEM NAME: Auxiliary Steam										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	
						OM No.	Coord.			
2ASS-ACV130A	3	B	8	Globe	O	27A-1	F-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2ASS-ACV130B	3	B	8	Globe	O	27A-1	F-4	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)

SYSTEM NAME: Service Water										SYSTEM NUMBER: 30	
BVPS-2 IST VALVE TESTING OUTLINE											
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments	
						OM No.	Coord.				
2SWS-57	3	C	30	Check		30-1	C-3	QS		2OST-30 2-PS-FD (Q)	
								QS	CSJ3	2OST-30 2-FS-FD (CSD) 2OST-30 13A-FS-FD (R)	
								QS	CSJ43	2OST-30 6-FS-RD (Q or CSD)	
2SWS-58	3	C	30	Check		30-1	D-4	QS		2OST-30 3-PS-FD (Q)	
								QS	CSJ3	2OST-30 3-FS-FD (CSD) 2OST-30 13B-FS-FD (R)	
								QS	CSJ43	2OST-30 6-FS-RD (Q or CSD)	
2SWS-59	3	C	30	Check		30-1	G-3	QS		2OST-30 6-PS-FD (Q)	
								QS	CSJ3	2OST-30 6-FS-FD (CSD) 2OST-30 13A(B)-FS-FD (R)	
								QS	CSJ43	2OST-30 6-FS-RD (Q or CSD)	
2SWS-99	3	B	3	Globe	S	30-2	B-3	QS		2OST-47 3A(3B) Stroke Only Closed (Q)	
2SWS-100	3	B	3	Globe	S	30-2	E-3	QS		2OST-47 3A(3B) Stroke Only Closed (Q)	
2SWS-MOV102A	3	B	30	Butterfly	O	30-1	C-4	QST	CSJ44	2OST-30 6 Stroke & Time Open (Q or CSD) (RPV)	
2SWS-MOV102B	3	B	30	Butterfly	O	30-1	D-4	QST	CSJ44	2OST-30 6 Stroke & Time Open (Q or CSD) (RPV)	
2SWS-MOV102C1	3	B	30	Butterfly	S	30-1	G-4	QST	CSJ44	2OST-30 6 Stroke & Time Open (Q or CSD) (RPV)	
2SWS-MOV102C2	3	B	30	Butterfly	S	30-1	G-4	QST	CSJ44	2OST-30 6 Stroke & Time Open (Q or CSD) (RPV)	
2SWS-MOV103A	3	B	24	Butterfly	S	30-1	C-7	QST	RR20	2OST-30 13A Stroke & Time Open (R) (RPV)	
2SWS-MOV103B	3	B	24	Butterfly	S	30-1	C-6	QST	RR20	2OST-30 13B Stroke & Time Open (R) (RPV)	

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 30
SYSTEM NAME: Service Water										Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	OM No.	Drawing Coord.	Test Requirement	CSJ or Relief Requests	
2SWS*MOV104A	3	B	16	Gate	O	30-3	A-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV104B	3	B	16	Gate	O	30-3	E-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV104C	3	B	16	Gate	O	30-3	C-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV104D	3	B	16	Gate	O	30-3	D-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV105A	3	B	16	Gate	O	30-3	A-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV105B	3	B	16	Gate	O	30-3	E-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV105C	3	B	16	Gate	O	30-3	C-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*MOV105D	3	B	16	Gate	O	30-3	D-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)
2SWS*106	3	C	30	Check		30-1	A-6	QS		2OST-30 2(e)-PS,FD (Q)
								QS	CSJ3	2OST-30 2(f)-FS,FD (CSD) 2OST-30 13A-FS,FD (R)
								QS	CSJ45	2OST-30 8A or 8B-FS,FD (CSD)
2SWS*MOV106A	3	B	30	Butterfly	O	30-1	C-7	QST		2OST-1 10-Stroke & Time Closed (CSD),(RPV) 2OST-30 13A-Stroke & Time Closed (R),(RPV)
2SWS*MOV106B	3	B	30	Butterfly	O	30-1	C-6	QST		2OST-1 10-Stroke & Time Closed (CSD),(RPV) 2OST-30 13B-Stroke & Time Closed (R),(RPV)
2SWS*107	3	C	30	Check		30-1	A-7	QS		2OST-30 3(e)-PS,FD (Q)
								QS	CSJ3	2OST-30 3(e)-FS,FD (CSD) 2OST-30 13B-FS,FD (R)
								QS	CSJ45	2OST-30 8A or 8B-FS,FD (CSD)
2SWS*MOV107A	3	B	24	Butterfly	O	30-1	F-7	QST		2OST-1 10-Stroke & Time Closed (CSD),(RPV)

**BVPS-2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: Service Water

SYSTEM NUMBER: 30

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SWS*MOV107B	3	B	24	Butterfly	O	30-1	F-7	QST	CSJ47	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2SWS*MOV107C	3	B	24	Butterfly	O	30-1	F-6	QST	CSJ47	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2SWS*MOV107D	3	B	24	Butterfly	O	30-1	F-6	QST	CSJ47	2OST-1 10-Stroke & Time Closed (CSD),(RPV)
2SWS*110	3	C/P	6	Check		30-2	C-8	NA		*(Internal Inspection per CMP (5 years))
2SWS*111	3	C	6	Check		30-2	C-8	QS		2OST-36 1-FS,FD (M) *(Internal Inspection per CMP (5 years))
2SWS*112	3	C	6	Check		30-2	E-8	QS		2OST-36 2-FS,FD (M) *(Internal Inspection per CMP (5 years))
2SWS*113	3	C/P	6	Check		30-2	E-8	NA		*(Internal Inspection per CMP (5 years))
2SWS*MOV113A	3	B	6	Gate	S	30-2	C-8	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2SWS*MOV113B	3	B/P	6	Gate	S	30-2	E-8	POS		2OST-47 3A(3B)-(RPV)
2SWS*MOV113C	3	B/P	6	Gate	S	30-2	C-8	POS		2OST-47 3A(3B)-(RPV)
2SWS*MOV113D	3	B	6	Gate	S	30-2	E-8	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2SWS*115A	3	B	1 1/2	Ball	S	30-1	B-2	QS		2OST-30 17A-Stroke to Open Throttled Position (Q)
2SWS*115B	3	B	1 1/2	Ball	S	30-1	F-2	QS		2OST-30 17B-Stroke to Open Throttled Position (Q)
2SWS*AOV118A	3	B	2	Globe	O	30-1	B-1	QST		2OST-30 17A-Stroke & Time Closed (Q),(RPV)
2SWS*AOV118B	3	B	2	Globe	O	30-1	E-1	QST		2OST-30 17B-Stroke & Time Closed (Q),(RPV)
2SWS*SOV130A	3	B	2	Globe	A	30-1	A-4	QST		2OST-30 17A-Stroke & Time Open (Q)

*Not required by ASME Performed by 1/2CMP-75-WAFER CHECK-1M to verify valve integrity per IE Bulletin 83-03

BVPS 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 30
SYSTEM NAME: Service Water												
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2SWS-SOV130B	3	B	2	Globe	A	30-1	E-4	QST		2OST-30 17B-Stroke & Time Open (Q)		
2SWS-142	3	B	3	Gate	S	30-2	A-1	QS		2OST-47 3A(3B)-Stroke Only Open (Q)		
2SWS-143	3	B	3	Gate	S	30-2	F-1	QS		2OST-47 3A(3B)-Stroke Only Open (Q)		
2SWS-152	3	B	3	Gate	O	30-2	C-3	QS		2OST-47 3A(3B)-Stroke Only Closed (Q)		
2SWS-RV152	2	A/C	1/2x1	Relief		29-4	A-2	SPT		2BVT 1 60 5-(R)		
2SWS-MOV152-1	2	A	8	Butterfly	O	29-4	A-2	QST	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS-MOV152-2	2	A	8	Butterfly	O	29-4	A-2	QST	RR1,RR2,RR28	2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)		
2SWS-153	3	B	3	Gate	O	30-2	E-3	QS		2BVT 1 47 5-Leak Test (R)		
2SWS-RV153	2	A/C	1/2x1	Relief		29-4	C-2	SPT		2OST-47 3A(3B)-Stroke Only Closed (Q)		
2SWS-MOV153-1	2	A/P	8	Butterfly	LS	29-4	C-2	LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS-MOV153-2	2	A/P	8	Butterfly	LS	29-4	C-2	LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS-RV154	2	A/C	1/2x1	Relief		29-4	D-2	SPT		2BVT 1 60 5-(R)		
								LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		

BVPS 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 30
SYSTEM NAME: Service Water												Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	OM No.	Coord.	Test Requirement	CSJ or Relief Requests	Drawing		
2SWS*MOV154-1	2	A/P	8	Butterfly	LS	29-4	D-2	LT	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS*MOV154-2	2	A/P	8	Butterfly	LS	29-4	D-2	LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)		
2SWS*RV155	2	A/C	1/2x1	Relief		29-4	G-2	SPT		2BVT 1 60 5-(R)		
2SWS*MOV155-1	2	A	8	Butterfly	O	29-4	G-2	QST	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS*MOV155-2	2	A	8	Butterfly	O	29-4	G-2	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q),(RPV)		
2SWS*486	3	C	3	Check		30-1	C-3	QS	RR1,RR2,RR28	2BVT 1 47 5-Leak Test (R)		
2SWS*487	3	C	3	Check		30-1	D-3	QS		2OST-30 2-FS, RD (Q or CSD)		
2SWS*488	3	C	3	Check		30-1	G-3	QS	CSJ48	2OST-30 2(6)-FS, FD (Q or CSD)		
2SWS*1103	3	C	4	Check		30-2	A-4	QS	CSJ48	2OST-30 3-FS, RD (Q or CSD)		
2SWS*1104	3	C	4	Check		30-2	G-4	QS	CSJ48	2OST-30 3(6)-FS, FD (Q or CSD)		
2SWS*1166	3	C	2	Check		30-1	B-5	QS	RR21	2BVT 1 60 6 FS, RD By Leak Test (R)		
2SWS*1167	3	C	2	Check		30-1	B-7	QS	RR21	2BVT 1 60 6 FS, RD By Leak Test (R)		

BVPS-2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 30
SYSTEM NAME: Service Water (Chlorine Injection)										
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CS: or Relief Requests	Comments
						OM No.	Coord.			
2SWM-MOV562	3	B	3	Plug	O	30-1	B-7	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)
2SWM-MOV563	3	B	3	Plug	O	30-1	B-6	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)
2SWM-MOV564	3	B	3	Plug	O	30-1	A-6	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)
2SWM-MOV565	3	B	3	Plug	O	30-1	B-7	QST		2OST-47 3A(3B) Stroke & Time Closed (Q), (RPV)

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 30
SYSTEM NAME: Standby Service Water										
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SWE*MOV116A	3	B	30	Butterfly	S	30-1	A-7	QST		20ST-30 1A Stroke & Time Open (Q), (RPV)
2SWE*MOV116B	3	B	30	Butterfly	S	30-1	A-6	QST		20ST-30 1B Stroke & Time Open (Q), (RPV)

BVPS 2 IST VALVE TESTING OUTLINE												SYSTEM NUMBER: 33
SYSTEM NAME: Fire Protection												
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2FPW-AOV204	2	A	2	Globe	S	33-1D	C-4	QST		2OST-47 3A(3B), Stroke & Time Closed (Q), (RPV)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-AOV205	2	A	4	Globe	S	33-1D	F-4	QST		2OST-47 3A(3B), Stroke & Time Closed (Q), (RPV)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-AOV206	2	A	6	Globe	S	33-1D	D-4	QST		2OST-47 3A(3B), Stroke & Time Closed (Q), (RPV)		
								LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)		
2FPW-AOV221	2	A	2	Globe	S	33-1D	A-4	QST		2OST-47 3A(3B), Stroke & Time Closed (Q), (RPV)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-382	2	A/C	2 1/2	Check		33-1D	C-4	QS	CSJ49	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-388	2	A/C	2 1/2	Check		33-1D	A-4	QS	CSJ49	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-753	2	A/C	4	Check		33-1D	F-4	QS	CSJ49	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
								LT	RR1	2BVT 1 47 5-Leak Test (R)		
2FPW-781	2	A/C	6	Check		33-1D	D-5	QS	CSJ49	2OST-1 10-FS,FD,RD by Mechanical Exerciser (CSD)		
								LT	RR1,RR2	2BVT 1 47 5-Leak Test (R)		

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Compressed Air (Containment Instrument Air)								SYSTEM NUMBER: 34		
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2IAC-22	2	A/C	3	Check		34-3	C-10	QS	CSJ50	2OST-1 10-FS, RD by Mechanical Exerciser (CSD)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2IAC*MOV130	2	A	3	Plug	O	34-3	C-10	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2IAC*MOV133	2	A	4	Plug	O	34-3	C-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2IAC*MOV134	2	A	4	Plug	O	34-3	C-1	QST		2OST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)

BVPS 2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Compressed Air (Station Air)						SYSTEM NUMBER: 34				
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2SAS*14	2	A/P	2	Globe	LS	34-1B	C-6	LT	RR1	2BVT 1 47 5-Leak Test (R)
2SAS*15	2	A/P	2	Globe	LS	34-1B	C-6	LT	RR1	2BVT 1 47 5-Leak Test (R)

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: 4KV Station Service (Diesel Air Start)

SYSTEM NUMBER: 36

Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2EGA*100	3	C	¼	Check		36-3	E-4	QS		2OST-47 3A(3B)-FS,RD (Q)
2EGA*101	3	C	¼	Check		36-3	F-4	QS		2OST-47 3A(3B)-FS,RD (Q)
2EGA*118	3	C	¼	Check (Excess Flow)		36-3	E-4	QS		2OST-47 3A(3B)-Closure Test (Q)
2EGA*119	3	C	¼	Check (Excess Flow)		36-3	F-4	QS		2OST-47 3A(3B)-Closure Test (Q)
2EGA*130	3	C	¼	Check		36-3	E-9	QS		2OST-47 3A(3B)-FS,RD (Q)
2EGA*131	3	C	¼	Check		36-3	F-9	QS		2OST-47 3A(3B)-FS,RD (Q)
2EGA*155	3	C	¼	Check (Excess Flow)		36-3	E-9	QS		2OST-47 3A(3B)-Closure Test (Q)
2EGA*156	3	C	¼	Check (Excess Flow)		36-3	F-9	QS		2OST-47 3A(3B)-Closure Test (Q)
2EGA*SOV202-1	3	B	2	Three-way		36-3	A-5	QST	RR22	2OST-36 1-Stroke & Time Open (Q)
2EGA*SOV202-2	3	B	2	Three-way		36-3	B-5	QST	RR22	2OST-36 1-Stroke & Time Open (Q)
2EGA*SOV203-1	3	B	2	Three-way		36-3	A-10	QST	RR22	2OST-36 2-Stroke & Time Open (Q)
2EGA*SOV203-2	3	B	2	Three-way		36-3	B-10	QST	RR22	2OST-36 2-Stroke & Time Open (Q)
2EGA*RV205	3	C	¼	Relief		36-3	E-4	SPT		2BVT 1 60 5-(R)
2EGA*RV206	3	C	¼	Relief		36-3	E-9	SPT		2BVT 1 60 5-(R)
2EGA*RV207	3	C	¼	Relief		36-3	F-4	SPT		2BVT 1 60 5-(R)
2EGA*RV208	3	C	¼	Relief		36-3	F-9	SPT		2BVT 1 60 5-(R)

BVPS 2 IST VALVE TESTING OUTLINE											SYSTEM NUMBER: 36
SYSTEM NAME: 4KV Station Service (Diesel Fuel Oil)											Comments
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments	
						OM No.	Coord.				
2EGP-7	3	C	3	Check		36-1	F-1	QS		20ST-36 1-FS,FD, RD (bi-monthly)	
2EGP-8	3	C	3	Check		36-1	E-6	QS		20ST-36 2-FS,FD, RD (bi-monthly)	
2EGP-9	3	C	3	Check		36-1	E-1	QS		20ST-36 1-FS,FD, RD (bi-monthly)	
2EGP-10	3	C	3	Check		36-1	E-7	QS		20ST-36 2-FS,FD, RD (bi-monthly)	

**BVPS 2 IST
VALVE TESTING OUTLINE**

SYSTEM NAME: 4KV Station Service (Diesel Lube Oil)						SYSTEM NUMBER: 36				
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2EGO*106	3	B	4	Gate	LO	36-5B	F-8	QS		2OST-47 3A-Stroke Only Closed (Q) 2OST-36 4-Stroke Only Closed (R)
2EGO*107	3	B	4	Gate	LO	36-5A	F-8	QS		2OST-47 3A-Stroke Only Closed (Q) 2OST-36 3-Stroke Only Closed (R)
2EGO*108	3	B	4	Gate	LO	36-5B	E-8	QS		2OST-47 3A-Stroke Only Closed (Q) 2OST-36 4-Stroke Only Closed (R)
2EGO*109	3	B	4	Gate	LO	36-5A	E-8	QS		2OST-47 3A-Stroke Only Closed (Q) 2OST-36 3-Stroke Only Closed (R)
2EGO*114	3	B	4	Gate	S	36-5B	F-7	QS		2OST-47 3A-Stroke Only Open (Q) 2OST-36 4-Stroke Only Open (R)
2EGO*115	3	B	4	Gate	S	36-5A	F-7	QS		2OST-47 3A-Stroke Only Open (Q) 2OST-36 3-Stroke Only Open (R)
2EGO*116	3	B	4	Gate	S	36-5B	E-7	QS		2OST-47 3A-Stroke Only Open (Q) 2OST-36 4-Stroke Only Open (R)
2EGO*117	3	B	4	Gate	S	36-5A	E-7	QS		2OST-47 3A-Stroke Only Open (Q) 2OST-36 3-Stroke Only Open (R)

INSERVICE TESTING (IST) PROGRAM FOR PUMPS AND VALVES

BVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NUMBER: 44A										
SYSTEM NAME: Control Area: Ventilation										
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2HVC-MOD201A	3	B	36	Butterfly	O	44A-2	D-2	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2HVC-MOD201B	3	B	36	Butterfly	O	44A-2	D-2	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2HVC-MOD201C	3	B	36	Butterfly	S	44A-2	C-2	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2HVC-MOD201D	3	B	36	Butterfly	S	44A-2	C-2	QST		20ST-47 3A(3B)-Stroke & Time Closed (Q), (RPV)
2HVC-MOD204A	3	B	8	Butterfly	S	44A-2	F-2	QST		20ST-47 3A(3B)-Stroke & Time Open (Q), (RPV)
2HVC-MOD204B	3	B	8	Butterfly	S	44A-2	G-2	QST		20ST-47 3A(3B)-Stroke & Time Open (Q), (RPV)

BVP-2 IST VALVE TESTING OUTLINE											
SYSTEM NAME: Containment Area Ventilation											SYSTEM NUMBER: 44C
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments	
						OM No.	Coord.				
2HVR-MOD23A	2	A	42	Butterfly	LS	44C-2	B-5	QST	CSJ51	20ST-1 10-Stroke & Time Closed (CSD),(RPV) 20ST-44C 1-Stroke & Time Closed (R),(RPV)	
								LT	RR1,RR2,RR25	2BVT 1 47 5-Leak Test (R)	
2HVR-MOD23B	2	A	42	Butterfly	LS	44C-2	B-7	QST	CSJ51	20ST-1 10-Stroke & Time Closed (CSD),(RPV) 20ST-44C 1-Stroke & Time Closed (R),(RPV)	
								LT	RR1,RR2,RR25	2BVT 1 47 5-Leak Test (R)	
2HVR-MOD25A	2	A	42	Butterfly	LS	44C-2	C-5	QST	CSJ51	20ST-1 10-Stroke & Time Closed (CSD),(RPV) 20ST-44C 1-Stroke & Time Closed (R),(RPV)	
								LT	RR1,RR2,RR26	2BVT 1 47 5-Leak Test (R)	
2HVR-MOD25B	2	A	42	Butterfly	LS	44C-2	C-7	QST	CSJ51	20ST-1 10-Stroke & Time Closed (CSD),(RPV) 20ST-44C 1-Stroke & Time Closed (R),(RPV)	
								LT	RR1,RR2,RR26	2BVT 1 47 5-Leak Test (R)	
2HVR-DMP206	2	A/P	8	Butterfly	LS	44C-2	D-6	LT	RR1,RR2,RR26	2BVT 1 47 5-Leak Test (R),(RPV)	

BVPS 2 IST VALVE TESTING OUTLINE										SYSTEM NUMBER: 46
SYSTEM NAME: Post DBA Hydrogen Control										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2HCS*110	2	A	2	Ball	LS	46-1	D-2	QS		2OST-47 3A(3B)-Stroke Only Open (Q),(RPV) 2BVT 1 47 5-Leak Test (R)
2HCS*111	2	A	2	Ball	LS	46-1	G-2	QS	RR1	2OST-47 3A(3B)-Stroke Only Open (Q),(RPV) 2BVT 1 47 5-Leak Test (R)
2HCS*MOV112A	2	B	2	Ball	S	46-1	C-6	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2HCS*MOV112B	2	B	2	Ball	S	46-1	F-6	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2HCS*SOV114A	2	A	2	Globe	S	46-1	B-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
2HCS*SOV114B	2	A	2	Globe	S	46-1	F-2	QST	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV115A	2	A	2	Globe	S	46-1	G-2	QST	RR1	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
2HCS*SOV115B	2	A	2	Globe	S	46-1	F-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
2HCS*MOV116	2	A	2	Ball	S	46-1	D-1	QST	RR1	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV) 2BVT 1 47 5-Leak Test (R)

**BVPS-2 IST
VALVE TESTING OUTLINE**


SYSTEM NAME: Post DBA Hydrogen Control						SYSTEM NUMBER: 46				
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2HCS*MOV117	2	A	2	Ball	S	46-1	G-1	QST		2OST-47 3A(3B)-Stroke & Time Open/Closed (Q),(RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R)
2HCS*MOV120A	2	B	2	Plug	S	46-1	D-7	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2HCS*MOV120B	2	B	2	Plug	S	46-1	G-6	QST		2OST-47 3A(3B)-Stroke & Time Open (Q),(RPV)
2HCS*SOV133A	2	A	¼	Globe	S	46-1	A-1	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV133B	2	A	¼	Globe	S	46-1	E-1	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV134A	2	A	¼	Globe	S	46-1	A-3	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV134B	2	A	¼	Globe	S	46-1	D-3	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV135A	2	A	¼	Globe	S	46-1	E-1	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)
2HCS*SOV135B	2	A	¼	Globe	S	46-1	E-2	QST	RR30	2OST-47 3A(3B)-Stroke & Time Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R),(RPV)

SVPS-2 IST VALVE TESTING OUTLINE										
SYSTEM NAME: Post DBA Hydrogen Control										
SYSTEM NUMBER: 46										
Valve Mark Number	Valve Class	Valve Category	Valve Size (in.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments
						OM No.	Coord.			
2HCS-SOV136A	2	A	1/4	Globe	S	46-1	B-1	QST	RR30	2OST-47 3A(3B) Stroke & Trime Open/Closed (Q)
2HCS-SOV136B	2	A	1/4	Globe	S	46-1	B-3	QST	RR30	2OST-47 3A(3B) Stroke & Trime Open/Closed (Q)
								LT	RR1	2BVT 1 47 5-Leak Test (R), (RPV)
								LT	RR1	2BVT 1 47 5-Leak Test (R), (RPV)

SYSTEM NAME: Containment										SYSTEM NUMBER: 47		
BVP5-2 IST VALVE TESTING OUTLINE												
Valve Mark Number	Valve Class	Valve Category	Valve Size (In.)	Valve Type	NSA	Drawing		Test Requirement	CSJ or Relief Requests	Comments		
						OM No.	Coord.					
2PHS*100	2	A/P	1 1/2	Gate	S	47-1	F-4	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*101	2	A/P	1 1/2	Gate	S	47-1	F-2	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*110	2	A/P	1 1/2	Ball	S	47-1	E-4	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*111	2	A/P	1 1/2	Ball	S	47-1	E-4	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*112	2	A/P	1 1/2	Ball	S	47-1	E-2	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*113	2	A/P	1 1/2	Ball	S	47-1	E-2	LT	RR31	2BVT 1 47 8-Type B Leak Test (SA)		
2PHS*201	2	A/P	2	Gate	S	47-1	B-9	LT	RR32	2BVT 1 47 10-Type B Leak Test (SA)		
2PHS*202	2	A/P	2	Gate	S	47-1	B-6	LT	RR32	2BVT 1 47 10-Type B Leak Test (SA)		

SECTION VII:

VALVE TESTING COLD SHUTDOWN JUSTIFICATIONS



COLD SHUTDOWN JUSTIFICATION 1**Valve No.:**

2RCS*68

Category A/C**Class** 2**Function:**

Inside containment isolation check valve on the nitrogen supply to the Pressurizer Relief Tank [2RCS-TK22].

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valve is normally closed and is opened during nitrogen makeup to the Pressurizer Relief Tank. Safety position is closed for containment isolation. Full stroking can only be verified by cycling the weight loaded arm or by leak testing. Because this valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 2**Valve No.:**

2RCS*72

Category A/C**Class** 2**Function:**

Inside containment isolation check valve on the primary grade water supply to the Pressurizer Relief Tank [2RCS-TK22]

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valve is normally closed and is opened during primary grade water makeup to the Pressurizer Relief Tank. Safety position is closed for containment isolation. Full stroking can only be verified by cycling the weight loaded arm or by leak testing. Because this valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 3**Valve No.:**

2SWS*57
2SWS*58
2SWS*59
2SWS*106
2SWS*107

Category C**Class** 3**Function:**

Service water pumps discharge and header check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These valves are open during normal plant operation, but full stroke exercising them in the forward direction cannot always be performed because normal plant operating loads do not always support enough service water system flow to develop the required accident flowrate needed to full stroke exercise the check valves in the open direction. Full stroking of these check valves may be possible during warm summer months when additional flowpaths and heat exchangers are in service, but can normally only be accomplished by aligning the service water system through additional flowpaths which are only used for accident conditions and through additional heat exchangers not normally in service. The additional flowpaths and heat exchangers are maintained isolated for biota control to prevent fouling. Placing flow through these additional flowpaths and heat exchangers unnecessarily during quarterly testing could increase the potential for fouling thereby degrading this part of the service water system and reducing its reliability in meeting the required flowrates during an accident.

Alternate Test:

Partial stroke exercised open quarterly per 2OST-30.2(3)(6). Full stroke exercised open during warm summer months when additional flowpaths and heat exchangers are normally in service or at least at cold shutdown per 2OST-30.2(3)(6). If cold shutdown coincides with refueling, then some of the valves may also be full stroke exercised at refueling per 2OST-30.13A(B).

COLD SHUTDOWN JUSTIFICATION 4**Valve No.:**

2RCS*PCV455C
2RCS*PCV455D
2RCS*PCV456

Category B**Class** 1**Function:**

Pressurizer Power Operated Relief Valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally closed. The safety function is to provide overpressure protection for the Reactor Coolant System. Since these valves have shown a high probability of failing open, cycling during normal operation is not practical. In addition, safety grade over pressure protection at power is provided by the pressurizer code safety valves.

Alternate Test:

Full stroke exercised and timed open at cold shutdown per 2OST-6.8.

COLD SHUTDOWN JUSTIFICATION 5**Valve No.:**

2CHS*31

Category A/C**Class** 2**Function:**

Charging header inside containment isolation check valve

Test Requirement:

Quarterly full stroke

Basis for CSJ:

This valve is normally open, but is required to be closed for containment isolation. Full stroking can only be verified by cycling the weight loaded arm. Since the valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 6 **Valve No.:**

2CHS*LCV115C

2CHS*LCV115E

Category B **Class** 2 **Function:**

Volume Control Tank [2CHS*TK22] outlet isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These valves are normally open during power operation. Safety function is to isolate the VCT from the High Head Safety Injection System. Closing this valve during normal operation would isolate the suction of the charging pumps, causing pump damage and loss of pressurizer level control.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 7 **Valve No.:**

2CHS*84

2CHS*136

2CHS*141

Category C **Class** 2,3 **Function:**

Emergency and alternate boration line check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These valves are normally closed during power operation, and are required to open for emergency and alternate emergency boration. Exercising these valves during normal operation would result in concentrated Boric Acid being injected into the RCS, causing an undesired negative reactivity addition resulting in a reduction in plant power.

Alternate Test:

Full stroke exercised open during cold shutdown per 2OST-7.13.

COLD SHUTDOWN JUSTIFICATION 8**Valve No.:**

2CHS*AOV204

Category A**Class** 2**Function:**

Letdown isolation outside containment isolation valve

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valve is normally open. Safety function is to close for containment isolation on a receipt of a CIA signal. Stroking this valve at power will result in a thermal shock to the Regenerative Heat Exchanger and associated component piping resulting in an increased probability of system and component failure. In addition, failure of this valve in the closed position will cause loss of pressurizer level control which will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 9**Valve No.:**

2CHS*MOV289

Category A**Class** 2**Function:**

Normal charging system makeup outside containment isolation valve

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valve is normally open. Safety function is to close on receipt of an SI signal. Stroking this valve at power will result in a thermal shock to the Regenerative Heat Exchanger and associated component piping resulting in an increased probability of system and component failure. In addition, failure of this valve in the closed position will cause loss of pressurizer level control which will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 10**Valve No.:**

2CHS*MOV308A

2CHS*MOV308B

2CHS*MOV308C

Category A**Class** 2**Function:**

Reactor Coolant Pumps seal water supply outside containment isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These valves are open during normal plant operation, but are required to be closed for containment penetration isolation. Exercising these valves at power would secure RCP seal injection and cause seal damage. Failure in the closed position during testing will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 11**Valve No.:**

2CHS*MOV310

Category B**Class** 2**Function:**

Regenerative Heat Exchanger outlet isolation valve

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valve is normally open. Safety function is to close on receipt of an SI signal. Stroking this valve during normal operation will result in a thermal shock to the Regenerative Heat Exchanger and associated piping resulting in an increased probability of system and component failure. In addition, failure of this valve in the closed position will cause loss of pressurizer level control which will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 12**Valve No.:**

2MSS*18
2MSS*19
2MSS*20
2MSS*196
2MSS*199
2MSS*352

Category C**Class** 3**Function:**

Main Steam to Auxiliary Feed Pump Check Valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These check valves are normally closed and open to allow steam flow to run the Turbine Driven Auxiliary Feedwater Pump (TDAFP) during an accident. A full stroke to the opened position can only be verified by a full flow test of the TDAFP. Full stroking these valves cannot be performed during normal operation because this would require injecting relatively cold auxiliary feedwater to the steam generators by the TDAFP at its design flowrate. This would result in a thermal shock to the auxiliary feedwater and main feedwater piping interface which could lead to premature failure. The monthly pump test which operates the TDAFP on recirculation flow only does not require full steam flow.

Alternate Test:

Partial stroke exercised open quarterly and full stroke exercised open during cold shutdown per 2OST-24.4.

COLD SHUTDOWN JUSTIFICATION 13**Valve No.:**

2CHS*MOV378

2CHS*MOV381

Category A**Class** 2**Function:**

Reactor Coolant Pumps seal water return inside and outside containment isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open. Safety function is to close for containment isolation on receipt of a CIA signal. Exercising these valves at power would secure RCP seal return which could cause seal damage. Failure of these valves in the closed position will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 14**Valve No.:**

2CHS*LCV460A

2CHS*LCV460B

Category B**Class** 1**Function:**

Letdown inside containment isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open. Stroking these valves during normal operation will result in a thermal shock to the Regenerative Heat Exchanger and associated piping resulting in an increased probability of system and component failure. In addition, failure of these valves in the closed position will cause loss of pressurizer level control which will result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 15**Valve No.:**

2CHS*473

Category A/C**Class** 2**Function:**

Seal water return containment penetration X-19 thermal relief check valve (Bypasses 2CHS*MOV378)

Test Requirement:

Quarterly full stroke

Basis for CSJ:

This valve is closed during normal plant operation and is to remain closed for containment isolation. However, it will momentarily open if required to relieve pressure due to thermal expansion. Full stroke testing can only be performed by manually cycling the weight loaded arm. Since this valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 16**Valve No.:**

2CHS*474

2CHS*475

2CHS*476

Category A/C**Class** 2**Function:**

Reactor Coolant Pumps seal water supply inside containment isolation check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These valves are open during normal plant operation, but are required to be closed for containment isolation. Exercising these weight loaded arm check valves in the closed direction at power would secure RCP seal injection which would result in seal damage.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 17**Valve No.:**

2CHS*MOV8130A
2CHS*MOV8130B
2CHS*MOV8131A
2CHS*MOV8131B
2CHS*MOV8132A
2CHS*MOV8132B
2CHS*MOV8133A
2CHS*MOV8133B

Category B**Class** 2**Function:**

Charging pumps suction and discharge cross connect valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

The function of these valves is for Safety Injection train separation during cold leg recirculation. One valve in suction and discharge is required to close for train separation. Full stroking of the discharge cross connects cannot be performed during normal operation because these valves are required to be open and de-energized by technical specifications. Failure in the closed position under certain pump operating configurations would render the HHSI system inoperable. In addition, BV-2 has committed to de-energizing the power supply to the charging pump suction cross connects to prevent loss of charging pump suction in certain fire scenarios. The potential risk in damage to a HHSI pump does not justify the gain in cycling these valves during normal operation.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 18**Valve No.:**

2RHS*3

2RHS*4

Category C**Class** 2**Function:**

Residual Heat Removal Pumps check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valves open for Residual Heat Removal system operation and close to prevent reverse flow through the standby pump. During normal power operation, RHS is isolated from the RCS and Residual Heat Removal pumps are not required for operation. Verification of forward and reverse stroking requires pump operation and non-rotation of the idle pump respectively. Checking reverse stroke requires local observation. Since these valves are in containment they are inaccessible during normal operation.

Alternate Test:

Full stroke exercised open during cold shutdown per 2OST-10.1(2) Full stroke exercised closed during cold shutdown per 2OST-10.3(4)

COLD SHUTDOWN JUSTIFICATION 19**Valve No.:**

2RHS*FCV605A

2RHS*FCV605B

Category B**Class** 2**Function:**

Residual Heat Removal Heat Exchangers bypass flow control valves

Test Requirement:

Quarterly full stroke, time, and fail safe

Basis for CSJ:

The safety related function of these valves is to fail closed on loss of power. Local observation is required to determine valve stroking. Valves are located inside reactor containment and are inaccessible during power operation.

Alternate Test:

Full stroke exercised, timed and failed closed at cold shutdown per 2OST-10.3(4)

COLD SHUTDOWN JUSTIFICATION 20**Valve No.:**

2RHS*MOV701A
 2RHS*MOV701B
 2RHS*MOV702A
 2RHS*MOV702B
 2RHS*MOV720A
 2RHS*MOV720B

Category A**Class** 1**Function:**

Reactor Coolant System to Residual Heat Removal System
 isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These valves are normally closed. The safety function is to open for initiation of the RHR system to attain cold shutdown and closed to isolate the RCS from the RHR system during normal operation. Full stroking these valves during normal operation cannot be performed because they are interlocked closed during normal operation to prevent overpressurization of RHR system piping.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-10.3(4).

COLD SHUTDOWN JUSTIFICATION 21**Valve No.:**

2RHS*HCV758A
 2RHS*HCV758B

Category B**Class** 2**Function:**

Residual Heat Removal Heat Exchangers flow control valves

Test Requirement:

Quarterly full stroke, time , and fail safe

Basis for CSJ:

The safety related function of these valves is to fail open on loss of power. Local observation is required to determine valve stroking. Valves are located inside reactor containment and are inaccessible during power operation.

Alternate Test:

Full stroke exercised, timed and failed open at cold shutdown per 2OST-10.3(4).

COLD SHUTDOWN JUSTIFICATION 22**Valve No.:**

2SIS*42

Category A/C**Class** 2**Function:**

Safety Injection Accumulator fill inside containment isolation check valve

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valve is normally closed during power operation. Safety function is to be closed for containment isolation. Valve is opened during accumulator fill operation. Full stroke testing is verified by observing weight loaded arm movement. Since this valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 23**Valve No.:**

2SIS*83

2SIS*84

2SIS*94

2SIS*95

Category A/C**Class** 2**Function:**

HHSI to hot and cold legs inside containment isolation check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Normal position for these valves is closed. These valves are to remain closed for containment isolation and are opened for hot leg recirculation. Full stroking requires use of the weighted arm on the valves. Since these valves are located inside the containment they are not accessible during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 24**Valve No.:**

2SIS*130

2SIS*132

2SIS*133

Category A/C**Class** 2**Function:**

LHSI to hot and cold legs inside containment isolation valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Normal position is closed. These valves are to remain closed for containment isolation and reactor coolant pressure boundary isolation, and open for LHSI. Valves cannot be cycled during power operation because the LHSI pump can not develop enough head to overcome reactor coolant system pressure. In addition, cycling using the weighted arms is not possible since these valves are located inside containment and are not accessible during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 25**Valve No.:**

2SIS*MOV836

Category A**Class** 2**Function:**

HHSI to cold leg header isolation valve

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valve is normally closed and is opened by the operator to achieve a redundant flowpath to the cold legs during the recirculation mode. Full stroking during normal operation would inject relatively cold water into the RCS cold leg resulting in thermal shock to system piping and components which can lead to their premature failure.

Alternate Test:

Full stroke exercised and timed open and closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 26**Valve No.:**

2SIS*MOV869A

2SIS*MOV869B

Category A**Class** 2**Function:**

HHSI to hot leg header isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally closed and are opened by the operator for hot leg recirculation. Full stroking these valves during normal operation would inject relatively cold water into the RCS hot legs resulting in thermal shock to system piping and components which can lead to their premature failure.

Alternate Test:

Full stroke exercised and timed open and closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 27**Valve No.:**

2SIS*MOV8889

Category A**Class** 2**Function:**

LHSI to RCS hot leg outside containment isolation valve

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valve is normally closed. Valve is required to be opened during hot leg recirculation mode. This valve is required to be closed and deenergized during normal operation in accordance with technical specifications. Full stroking during normal operation could result in overpressurization of the low pressure portion of LHSI piping if simultaneous check valve failure occurred.

Alternate Test:

Full stroke exercised and timed open and closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 28**Valve No.:**

2QSS*3

2QSS*4

Category A/C**Class** 2**Function:**

Quench spray header inside containment isolation check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valves are normally closed. Safety position is open for QSS flow and closed for containment isolation. Exercising can only be performed by manually cycling the weight loaded arm on the check valve. Since these valves are located inside reactor containment, they are not accessible during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 29**Valve No.:**

2QSS*SOV100A

2QSS*SOV100B

Category A**Class** 2**Function:**

Chemical injection to containment sump outside containment isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Failure of these valves in the open position would cause loss of NaOH injection for the Quench Spray System. Also since these valves are located at the containment penetration, failure in the open position would require closing both chemical injection pump discharge valves to comply with technical specifications rendering chemical injection inoperable. This would require plant shutdown.

Alternate Test:

Full stroke exercised and timed open and closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 30**Valve No.:**

2QSS*267

Category A/C**Class** 2**Function:**

QSS chemical injection inside containment isolation check valve

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valve is normally closed. Safety function is open during chemical injection to containment sump and closed for containment isolation. Exercising can only be performed by cycling weight loaded arm. Since the valve is located inside the reactor containment, exercising cannot be performed during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 31**Valve No.:**

2RSS*29

2RSS*30

2RSS*31

2RSS*32

Category C**Class** 2**Function:**

RSS discharge headers to spray nozzle inside containment isolation valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valves are normally closed. Safety function is open for RSS operation. Because RSS is normally maintained dry cycling can only be done using the weighted arm on the valve. These valves are located in the containment and are inaccessible during normal operation.

Alternate Test:

Full stroke exercised open by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 32**Valve No.:**

2CCP*AOV107A

2CCP*AOV107B

2CCP*AOV107C

Category B**Class** 3**Function:**

Reactor Coolant Pump Thermal Barrier Heat Exchanger CCP outlet isolation valves

Test Requirement:

Quarterly full stroke, time, and fail safe.

Basis for CSJ:

Valves are normally open, and are required to close in the event of a primary loop to CCP leak in the reactor coolant pump seal thermal barrier. Closing the valves during normal operation would interrupt flow of cooling water to the reactor coolant pump seals. This could result in damage to the reactor coolant pump seals. Failure in the closed position would result in plant shutdown.

Alternate Test:

Full stroke exercised, timed and failed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 33**Valve No.:**

2CCP*MOV150-1
2CCP*MOV150-2
2CCP*MOV151-1
2CCP*MOV151-2
2CCP*MOV156-1
2CCP*MOV156-2
2CCP*MOV157-1
2CCP*MOV157-2

Category A**Class** 2**Function:**

CCP supply and return headers to reactor containment outside and inside isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open; Safety position is closed for containment isolation. Closing the valves during normal operation would interrupt flow of cooling water to the reactor coolant pump seals. This could result in damage to the reactor coolant pump seals. Failure in the closed position would result in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 34**Valve No.:**

2QSS*303

2QSS*304

Category A**Class** 2**Function:**

Chemical Injection Pump Discharge Header Check Valves to the Quench Spray Pumps

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These check valves are normally closed. Their safety functions are to open to provide 23% NaOH from the Chemical Injection System to the Quench Spray System upon a CIB signal and to close during the Recirculation Phase. Check valve closure can be verified by opening an upstream vent and collecting a timed leak rate sample, but only after draining the discharge header first. If tested quarterly or at cold shutdown, the amount of radioactive water (borated RWST water used for testing) drained from the system would create additional liquid waste for disposal. An alternate method would require opening Chemical Injection Pump Discharge to Containment Sump Valves [2QSS*SOV100A or B] which can only be opened during Cold Shutdown (Reference: CSJ No. 29). Backleakage through the check valves would open Chemical Injection Pump Discharge to Quench Spray Pump Target Rock SOV's [2QSS*SOV101A(B)] or [2QSS*SOV102A(B)] due to a delta-p created by RWST head to the containment sump when [2QSS*SOV100A or B] is opened.

Alternate Test:

Full stroke exercised in the open direction quarterly per 2OST-13.10A(B). Full stroke exercised in the closed direction during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 35**Valve No.:**

2MSS*AOV101A
2MSS*AOV101B
2MSS*AOV101C

Category B**Class** 2**Function:**

Main Steam isolation valves for Steam Generators

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open; safety position is closed for High Energy Line Break isolation. Closure of these valves during normal operation would result in plant shutdown.

Alternate Test:

Partizl stroke exercised closed quarterly per 2OST-21.1(2)(3). Full stroke exercised and timed closed per 2OST-21.7 at shutdown with TAVG \geq 515F.

COLD SHUTDOWN JUSTIFICATION 36**Valve No.:**

2SVS*80
2SVS*81
2SVS*82

Category C**Class** 2**Function:**

Steam Generators residual heat release check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Full stroking open these valves during normal operation cannot be performed because a reduction in plant power would be required in order to prevent exceeding full power limitations.

Alternate Test:

Full stroke exercised open during unit shutdown per 2OM-51.4.C.

COLD SHUTDOWN JUSTIFICATION 37**Valve No.:**

2SVS*PCV101A
2SVS*PCV101B
2SVS*PCV101C

Category B**Class** 2**Function:**

Steam Generators atmospheric dump valves

Test Requirement:

Quarterly full stroke, time, and fail safe

Basis for CSJ:

These valves are normally closed. The safety function is to open to control S/G pressure after a reactor trip. Full or partial stroking open these valves during normal operation cannot be performed because a reduction in plant power would be required in order to prevent exceeding full power limitations. Closing the manual isolation valves so that these valves can be cycled presents an unacceptable risk to plant personnel due to their location in the plant.

Alternate Test:

Full stroke exercised and timed open and closed and failed closed per 2OST-1.10 at cold shutdown.

COLD SHUTDOWN JUSTIFICATION 38**Valve No.:**

2SVS*HCV104

Category B**Class** 2**Function:**

Combined Main Steam atmospheric dump valve

Test Requirement:

Quarterly full stroke, time, and fail safe

Basis for CSJ:

Valve is normally closed. Opened as necessary by operator during cooldown from the control room or Emergency Shutdown Panel. Full or partial stroking open this valve during normal operation cannot be performed because a reduction in plant power would be required in order to prevent exceeding full power limitations. Closing the manual isolation valve so that this valve can be cycled presents an unacceptable risk to plant personnel due to its location in plant.

Alternate Test:

Full stroke exercised and timed open and closed and failed closed per 2OST-1.10 at cold shutdown.

COLD SHUTDOWN JUSTIFICATION 39**Valve No.:**

2FWS*HYV157A

2FWS*HYV157B

2FWS*HYV157C

Category B**Class** 2**Function:**Main Feedwater Headers Isolation Valves to Steam
Generators**Test Requirement:**

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open. Safety position is closed for Feedwater isolation in the event of a high energy line break or Safety Injection System actuation. Full stroking closed during normal operation cannot be performed since this would stop feedwater flow to the steam generators resulting in plant shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 40**Valve No.:**

2FWE*42A

2FWE*42B

2FWE*43A

2FWE*43B

2FWE*44A

2FWE*44B

Category C**Class** 2**Function:**

Auxiliary Feedwater headers check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Valves are normally closed. Safety position is opened for Auxiliary Feed System injection and closed to provide header separation in the event of a line break. Full stroking these valves during normal operation cannot be performed because the test method requires design flow to the steam generator for both forward and reverse stroking. Injection of relatively cold auxiliary feedwater would result in a thermal shock to the auxiliary feedwater piping which could lead to premature failure.

Alternate Test:

Full stroke exercised in both directions during cold shutdown per 2OST-24.6.

COLD SHUTDOWN JUSTIFICATION 41**Valve No.:**

2FWE*99
 2FWE*100
 2FWE*101

Category C**Class** 2**Function:**

Auxiliary Feedwater header check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Full stroking these valves open during normal operation cannot be performed because the test method requires design flow to the steam generator. Injection of relatively cold auxiliary feedwater would result in a thermal shock to the auxiliary feedwater piping which could lead to premature failure.

Alternate Test:

Full stroke exercised open during cold shutdown per 2OST-24.6.

COLD SHUTDOWN JUSTIFICATION 42**Valve No.:**

2FWE*FCV122
 2FWE*FCV123A
 2FWE*FCV123B

Category B/C**Class** 3**Function:**

Auxiliary Feed Pumps discharge flow control/check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These valves function as a pump discharge check valve (normally closed) and as an Auxiliary feed pump mini-flow control valve (normally open). Exercising of the check valves in the open position (and the mini-flow control valve closed) requires design flow to the steam generators, that would result in a thermal shock to the auxiliary feedwater piping which could lead to premature failure.

Alternate Test:

Full stroke exercised open and closed at cold shutdown per 2OST-24.4 and 24.6.

COLD SHUTDOWN JUSTIFICATION 43**Valve No.:**

2SWS*57
 2SWS*58
 2SWS*59

Category C**Class** 3**Function:**

Service water pumps discharge check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Due to system design flow requirements at power, exercising of these valves in the closed direction requires use of the idle SWS pump. Relief is requested in the event the idle SWS pump is out of service for maintenance. Exercising can be accomplished upon return of the idle SWS pump to service.

Alternate Test:

Full stroke exercised closed per 2OST-30.6 quarterly or when the idle SWS pump is returned to service or at least at cold shutdown.

COLD SHUTDOWN JUSTIFICATION 44**Valve No.:**

2SWS*MOV102A
 2SWS*MOV102B
 2SWS*MOV102C1
 2SWS*MOV102C2

Category B**Class** 3**Function:**

Service water pumps discharge valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Due to system design flow requirements at power, exercising of these valves requires use of the idle SWS pump. Relief is requested in the event the idle SWS pump is out of service for maintenance. Exercising can be accomplished upon return of the idle SWS pump to service.

Alternate Test:

Full stroke exercised and timed open per 2OST-30.6 quarterly or when the idle SWS pump is returned to service or at least at cold shutdown.

COLD SHUTDOWN JUSTIFICATION NO. 45**Valve No.:**

2SWS*106

2SWS*107

Category C**Class 3****Function:**

Service water header check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Full stroking these valves in the reverse direction is accomplished using a standby service water pump and cannot be performed during normal operation. Testing requires all SW pumps to be shutdown and the headers cross connected at the pumps in order to provide an upstream vent path of sufficient capacity to identify valve deterioration.

Alternate Test:

Full stroke exercised closed during cold shutdown per 2OST-30.8A(B).

COLD SHUTDOWN JUSTIFICATION 46**Valve No.:**

2SWS*MOV106A

2SWS*MOV106B

Category B**Class 3****Function:**

Service Water headers isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These valves are normally open. The safety function is to close to ensure sufficient SWS supply to the RSS Heat exchangers. Closing these valves during normal operation would reduce service water supply to Turbine Building and CCP heat exchangers below acceptable limits for full power operation. Failure of the valves to reopen after closure could lead to equipment damage and plant shutdown.

Alternate Test:

Full stroke exercised and timed closed per 2OST-1.10 at cold shutdown and per 2OST-30.13A(B) at refueling.

COLD SHUTDOWN JUSTIFICATION 47**Valve No.:**

2SWS*MOV107A
2SWS*MOV107B
2SWS*MOV107C
2SWS*MOV107D

Category B**Class** 3**Function:**

CCS HX from service water headers isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These valves are normally open. The safety function is to close to isolate the NNS portion of the service water system. Stroking of these valves closed during normal operation could result in a thermal transient and potential plant trip. The thermal transients created by isolating Service Water System flow to the turbine plant cooling loads raises operational concerns of stability problems. Changes in oil temperature from the turbine generator lube oil system create vibration problems. Changes in the Hydrogen gas cooler temperatures could imply problems or mask real problems with the generator. Chiller unit heat exchanger flow disturbances often result in a trip of the chiller unit causing reactor containment temperature risks of exceeding the technical specification limit.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 48**Valve No.:**

2SWS*486

2SWS*487

2SWS*488

Category C**Class** 3**Function:**

Service water pumps vacuum breaker check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

Due to system design flow requirements at power, exercising of these valves requires use of the idle SWS pump. Relief is requested in the event the idle SWS pump is out of service for maintenance. Exercising can be accomplished upon return of the idle SWS pump to service.

Alternate Test:

Full stroke exercised open and closed per 2OST-30.2(3)(6) quarterly or when the idle SWS pump is returned to service or at least cold shutdown.

COLD SHUTDOWN JUSTIFICATION 49**Valve No.:**

2FPW*382

2FPW*388

2FPW*753

2FPW*761

Category A/C**Class** 2**Function:**

Fire protection headers inside containment isolation check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These valves are normally closed. They would be opened in the event of a fire in containment. The safety position is closed for containment isolation. Full stroke testing can only be performed by cycling the weight loaded arm or leak testing. Since these valves are located inside containment, they are not accessible during normal operation.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 50**Valve No.:**

2IAC*22

Category A/C**Class** 2**Function:**

Instrument Air header inside containment isolation check valve

Test Requirement:

Quarterly full stroke

Basis for CSJ:

This valve is normally closed and is opened as required to supply instrument air to the containment. The safety position is closed for containment isolation. Full stroke testing can only be performed by cycling the weight loaded arm or leak testing. Since this valve is located inside containment, it is not accessible during normal operation.

Alternate Test:

Full stroke exercised closed by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 51**Valve No.:**

2HVR*MOD23A

2HVR*MOD23B

2HVR*MOD25A

2HVR*MOD25B

Category A**Class** 2**Function:**

Containment purge discharge and supply outside and inside isolation dampers

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

These dampers are closed during power operation and opened for refueling operation. Safety functions are during power operation to remain closed for containment isolation and during refueling to close in the event of a refueling accident. These dampers cannot be cycled during normal operation because Technical Specifications require the dampers to be locked shut during normal operations.

Alternate Test:

Full stroke exercised and timed closed per 2OST-1.10 at cold shutdown and per 2OST-44C.1 at refueling.

COLD SHUTDOWN JUSTIFICATION 52**Valve No.:**

2CVS*SOV102
2CVS*SOV153A
2CVS*SOV153B

Category A**Class** 2**Function:**

Containment Airborne Activity Radiation Monitor
[2RMR*RQ303] containment isolation valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

In order to stroke and time these valves, the Containment Airborne Activity Radiation Monitor [2RMR*RQ303] must be shutdown. When this occurs, both the containment gaseous and particulate airborne activity monitors are temporarily inoperable and places the plant in a twelve hour action per Tech. Spec. 3.4.6.1 with additional requirements to verify the containment sump discharge flow measurement system operable and to perform a RCS water inventory balance in four hours. Without these additional provisions a forced shutdown is required in six hours.

Alternate Test:

Each valve is full stroke exercised and timed closed at cold shutdown per 2OST-1.10. [2CVS*SOV102] is also full stroke exercised and timed open at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 53**Valve No.:**

2SIS*46

2SIS*47

Category C**Class** 2**Function:**

Recirculation Spray Pump discharge to LHSI Pump discharge weighted arm check valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These check valves are normally closed. Their safety function is to open during the Recirculation Phase. Full stroke testing can only be done by cycling the weight loaded arm of each check valve. Exercising these weighted arm check valves in the open direction during normal operation requires excessive forces due to the head of water from the Refueling Water Storage Tank (RWST) against the check valve disk. Engineering does not recommend applying the excessive forces required to cycle the check valves open. The pressure created by the head of water from the RWST could be bled off by isolating one LHSI System train at a time and draining radioactive water from a drain valve into a sump. However, isolating one train of an Emergency Core Cooling System during plant operation would place the plant into a Technical Specification Action Statement. If tested quarterly, the amount of radioactive water drained from the system to bleed off pressure would create additional liquid waste for disposal.

Alternate Test:

Full stroke exercised in both directions by mechanical exerciser during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 54**Valve No.:**

2CCP*27A

2CCP*27B

2CCP*354

2CCP*355

Category B**Class** 3**Function:**

Component Cooling discharge header cross-connect manual isolation valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

The Component Cooling System operates in a cross-connected condition with all the above manual valves open and any two of three Component Cooling Pumps supplying any two of three Component Cooling Heat Exchangers through a Train A or Train B flow path. With one of the heat exchangers out of service for cleaning, closure of these manual valves during normal operation would interrupt flow of cooling water to Train A or Train B cooling loads resulting in a thermal transient and potential plant trip. In addition, the idle heat exchanger is normally held in reserve following cleaning to improve plant reliability until one of the inservice heat exchangers becomes fouled. Exercising of these valves in conjunction with the quarterly pump tests with the "C" Heat Exchanger in service would require placing the clean heat exchanger into service prematurely in order to prevent isolation of the Train A or Train B cooling loads.

Alternate Test:

Full stroke exercised closed during cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 55**Valve No.:**

2FWS*FCV478
2FWS*FCV488
2FWS*FCV498

Category B**Class** 2**Function:**

Steam generator main feedwater regulating valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally open during power operation. Their safety position is closed for feedwater isolation in the event of a high energy line break or Safety Injection System actuation. Full stroking closed during normal operation cannot be performed since this would isolate feedwater flow to the steam generators resulting in a plant trip and shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 56**Valve No.:**

2FWS*FCV479
2FWS*FCV489
2FWS*FCV499

Category B**Class** 2**Function:**

Steam generator bypass feedwater control valves

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Valves are normally set at approximately 10% open during power operation. Their safety position is closed for feedwater isolation in the event of a high energy line break or Safety Injection System actuation. Full stroking closed may cause an unnecessary challenge to the plant during normal operation since this will cause the main feed regulating valves to reposition to compensate for the loss of flow. The resulting transient on the steam generators may result in a plant trip and shutdown.

Alternate Test:

Full stroke exercised and timed closed at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 57**Valve No.:**

2QSS*MOV102A

2QSS*MOV102B

Category B**Class** 2**Function:**

Quench Spray Chemical Addition Tank discharge isolation valves to Chemical Injection Pumps

Test Requirement:

Quarterly full stroke and time

Basis for CSJ:

Stroking these valves introduces 23% NaOH from the Chemical Addition Tank into the piping downstream of these valves. Attempts to purge the downstream piping using a backflush of RWST water to the Safeguards sump after valve stroking has proven ineffective. Subsequent testing of the Chemical Injection Pumps on recirculation with the RWST results in sodium contamination of the RWST. During refueling outages the RCS, fuel pool and RWST are all in direct communication, therefore any sodium intrusion into the RWST will eventually spread to the RCS, a highly undesirable situation.

Removal of sodium from the RWST is a difficult process which involves recirculation of the RWST through the Fuel Pool Ion Exchangers. This process can degrade RWST cooling (RWST temperature is limited by Technical Specifications), and can take months to reduce the concentration to the desired level. In order to prevent any sodium introduction into the RWST, a more effective flush after valve stroking could be performed, but it involves a much longer period of system inoperability. Performance at Cold Shutdown would allow a more thorough backflush while in a Mode where the system is not required by Technical Specifications.

Alternate Test:

Full stroke exercised and timed open at cold shutdown per 2OST-1.10.

COLD SHUTDOWN JUSTIFICATION 58**Valve No.:**

2CCP*4

2CCP*5

2CCP*6

Category C**Class** 3**Function:**

Component Cooling Water Pump Discharge Check Valves

Test Requirement:

Quarterly full stroke

Basis for CSJ:

These check valves open for Component Cooling Water (CCP) System operation and close to prevent reverse flow through the standby Component Cooling Water Pump(s). Normal CCP flow is less than the maximum required accident flowrate necessary to verify full stroke open of these check valves. In order to increase flow above the maximum required accident flowrate, the manual throttle valves at the discharge of the Residual Heat Removal (RHR) Heat Exchangers would require throttling in the open direction. Since these manual throttle valves are located in subatmospheric containment, they are inaccessible during normal operation.

Alternate Test:

Partial stroke exercised open and full stroke exercised closed quarterly per 2OST-15.1(2)(3). Full stroke exercised open at cold shutdown per 2OST-15.1(2)(3).

SECTION VIII: VALVE TESTING RELIEF REQUESTS

RELIEF REQUEST 1 **Valve No.:**

See next page

Category A and A/C **Class** 2 **Function:**

Containment Isolation

Test Requirement:

Leak tested per IWV-3420 at least once every 2 years.

Basis for Relief:

These containment isolation valves are leak tested in accordance with 10CFR50, Appendix J, Type C. Since the acceptance criteria for Appendix J, Type C testing is more limiting than ASME Section XI, additional leak testing in accordance with ASME Section XI would be redundant.

Alternate Test:

Leak test at refueling in accordance with 10CFR50, Appendix J, IWV-3426, and IWV-3427(a) per 2BVT 1.47.5. As a special test, after maintenance has been performed on any Type C relief valves, 2BVT 2.47.2 may be performed to leak test the applicable relief valves in lieu of 2BVT 1.47.5.

RELIEF REQUEST 1CONTAINMENT ISOLATION VALVES

2RCS*68	2CVS*151-1	2SSR*SOV129A2	2FPW*AOV205
2RCS*72	2CVS*SOV151A	2SSR*SOV130A1	2FPW*AOV206
2RCS*RV100	2CVS*SOV151B	2SSR*SOV130A2	2FPW*AOV221
2RCS*AOV101	2CVS*SOV152A	2PAS*SOV105A1	2FPW*382
2RCS*AOV519	2CVS*SOV152B	2PAS*SOV105A2	2FPW*388
2CHS*HCV142	2CVS*SOV153A	2CCP*RV102	2FPW*753
2CHS*AOV200A	2CVS*SOV153B	2CCP*RV103	2FPW*761
2CHS*AOV200B	2LMS*51	2CCP*RV104	2SAS*14
2CHS*AOV200C	2LMS*52	2CCP*RV105	2SAS*15
2CHS*RV203	2QSS*3	2CCP*MOV150-1	2IAC*22
2CHS*AOV204	2QSS*4	2CCP*MOV150-2	2IAC*MOV130
2CHS*MOV378	2QSS*SOV100A	2CCP*MOV151-1	2IAC*MOV133
2CHS*MOV381	2QSS*SOV100B	2CCP*MOV151-2	2IAC*MOV134
2CHS*473	2QSS*MOV101A	2CCP*MOV156-1	2HVR*MOD23A
2DAS*AOV100A	2QSS*MOV101B	2CCP*MOV156-2	2HVR*MOD23B
2DAS*AOV100B	2QSS*RV101A	2CCP*MOV157-1	2HVR*MOD25A
2DAS*RV110	2QSS*RV101B	2CCP*MOV157-2	2HVR*MOD25B
2DGS*AOV108A	2QSS*267	2FNC*9	2HVR*DMP206
2DGS*AOV108B	2SSR*AOV100A1	2FNC*38	2HCS*110
2DGS*RV115	2SSR*AOV100A2	2FNC*121	2HCS*111
2VRS*AOV109A1	2SSR*AOV102A1	2FNC*122	2HCS*SOV114A
2VRS*AOV109A2	2SSR*AOV102A2	2SWS*RV152	2HCS*SOV114B
2RHS*15	2SSR*AOV109A1	2SWS*MOV152-1	2HCS*SOV115A
2RHS*RV100	2SSR*AOV109A2	2SWS*MOV152-2	2HCS*SOV115B
2RHS*107	2SSR*AOV112A1	2SWS*RV153	2HCS*MOV116
2SIS*41	2SSR*AOV112A2	2SWS*MOV153-1	2HCS*MOV117
2SIS*42	2SSR*RV117	2SWS*MOV153-2	2HCS*SOV133A
2SIS*RV130	2SSR*RV118	2SWS*RV154	2HCS*SOV133B
2SIS*RV175	2SSR*RV119	2SWS*MOV154-1	2HCS*SOV134A
2SIS*MOV842	2SSR*RV120	2SWS*MOV154-2	2HCS*SOV134B
2SIS*AOV889	2SSR*RV121	2SWS*RV155	2HCS*SOV135A
2GNS*AOV101-1	2SSR*RV122	2SWS*MOV155-1	2HCS*SOV135B
2GNS*AOV101-2	2SSR*SOV128A1	2SWS*MOV155-2	2HCS*SOV136A
2CVS*93	2SSR*SOV128A2	2FPW*AOV204	2HCS*SOV136B
2CVS*SOV102	2SSR*SOV129A1		
2CVS*151			

RELIEF REQUEST 2 **Valve No.:**

See below

Category A and A/C **Class** 2 **Function:**

Containment Isolation

Test Requirement:

Corrective action following leak testing per IWV-3427(b)

Basis for Relief:

IWV-3427(b) specifies additional requirements on increased test frequencies for valve sizes of six inches and larger and repairs or replacement over the requirements of IWV-3427(a). The usefulness of IWV-3427(b) does not justify the burden of complying with this requirement. Unnecessary repair or replacement of a valve or additional leak testing, if attempted at cold shutdown, could delay plant startup. Per 10CFR50.55a(a)(3)(ii), compliance with the specified requirements of IWV-3427(b) would result in hardship or unusual difficulties without a compensating increase in the level of quality and safety.

Alternate Test:

For valves (6 inch diameter or larger) in 2BVT 1.47.5, if the measured leak rate exceeds the rate determined, the valve shall be replaced or repaired.

CONTAINMENT ISOLATION VALVES

2CHS*AOV200A	2QSS*MOV101A	2CCP*MOV151-1	2FNC*122	2SWS*MOV154-2
2CHS*AOV200B	2QSS*MOV101B	2CCP*MOV151-2	2SWS*RV152	2SWS*RV155
2CHS*AOV200C	2QSS*RV101A	2CCP*MOV156-1	2SWS*MOV152-1	2SWS*MOV155-1
2RHS*15	2QSS*RV101B	2CCP*MOV156-2	2SWS*MOV152-2	2SWS*MOV155-2
2RHS*RV100	2CCP*RV102	2CCP*MOV157-1	2SWS*RV153	2FPW*AOV206
2RHS*107	2CCP*RV103	2CCP*MOV157-2	2SWS*MOV153-1	2FPW*761
2CVS*151	2CCP*RV104	2FNC*9	2SWS*MOV153-2	2HVR*MOD23A
2CVS*151-1	2CCP*RV105	2FNC*38	2SWS*RV154	2HVR*MOD23B
2QSS*3	2CCP*MOV150-1	2FNC*121	2SWS*MOV154-1	2HVR*MOD25A
2QSS*4	2CCP*MOV150-2			2HVR*MOD25B
				2HVR*DMP206

RELIEF REQUEST 3 **Valve No.:**

2CHS*22

2CHS*23

2CHS*24

Category C **Class** 2 **Function:**

Charging pumps discharge check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

When the RCS is at normal operating pressure, full stroking the discharge check valves cannot be performed because the charging pump will not develop the required flow. In addition, injection of relatively cold water will cause a thermal cycle or shock resulting in an increased probability of system failure. At cold shutdown full stroking cannot be performed because full flow testing could result in low-temperature overpressurization of the RCS.

Alternate Test:

Partial stroke exercised open quarterly per 2OST-7.4(5)(6). Full stroke exercised open at refueling per 2OST-11.14B.

RELIEF REQUEST 4 **Valve No.:**

2SIS*6

2SIS*7

Category C **Class** 2 **Function:**

LHSI pumps discharge check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for LHSI. When the RCS is at normal operating pressure, full stroking the discharge check valves cannot be performed because the LHSI pump will not develop the required flow to open the valve. At cold shutdown full stroking cannot be performed because testing would require full flow injection to the RCS where there is not sufficient volume to receive the additional inventory.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14A.

RELIEF REQUEST 5**Valve No.:**

2SIS*27

Category C**Class** 2**Function:**

RWST to HHSI pump suction check valve

Test Requirement:

Quarterly full stroke

Basis for Relief:

When the RCS is at normal operating pressure, full stroking the suction check valve cannot be performed because the charging pump will not develop the required flow. In addition, partial stroking cannot be performed because injection of relatively cold water will cause a thermal cycle or shock resulting in an increased probability of system failure. At cold shutdown full stroking cannot be performed because full flow testing could result in low-temperature overpressurization of the RCS.

Alternate Test:

Part-stroke exercised open at cold shutdown per 2OST-1.10.
Full stroke exercised open at refueling per 2OST-11.14B.

RELIEF REQUEST 6**Valve No.:**

2SIS*107

2SIS*108

2SIS*109

Category A/C**Class** 1**Function:**

LHSI header check valves to RCS cold legs

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for LHSI and closed to isolate the LHSI system piping from the RCS during normal operation. When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the LHSI pump will not develop the required flow to open the valve. At cold shutdown full stroking cannot be performed because testing would require full flow injection to the RCS where there is not sufficient volume to receive the additional inventory.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14A.

RELIEF REQUEST 7**Valve No.:**

2SIS*122

2SIS*123

2SIS*124

2SIS*125

2SIS*126

2SIS*127

Category C**Class** 1**Function:**

HHSI header check valves to RCS hot legs

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for HHSI. When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the charging pump will not develop the required flow. In addition, injection of relatively cold water will cause a thermal cycle or shock resulting in an increased probability of system failure. At cold shutdown full stroking cannot be performed because full flow testing could result in low-temperature overpressurization of the RCS.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14B.

RELIEF REQUEST 8**Valve No.:**

2SIS*128

2SIS*129

Category A/C**Class** 1**Function:**

LHSI header check valves to RCS hot legs

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for LHSI and closed to isolate the LHSI system piping from the RCS during normal operation. When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the LHSI pump will not develop the required flow to open the valve. At cold shutdown full stroking cannot be performed because testing would require full flow injection to the RCS where there is not sufficient volume to receive the additional inventory.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14A.

RELIEF REQUEST 9 **Valve No.:**

2SIS*134

2SIS*135

2SIS*136

2SIS*137

2SIS*138

2SIS*139

Category C **Class** 1 **Function:**

HHSI header check valves to RCS cold legs

Test Requirement:

Quarterly full stroke

Basis for Relief:

When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the charging pump will not develop the required flow. In addition injection of relatively cold water will cause a thermal cycle or shock resulting in an increased probability of system failure. At cold shutdown full stroking cannot be performed because full flow testing could result in low-temperature overpressurization of the RCS.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14B.

RELIEF REQUEST 10**Valve No.:**

2SIS*141

2SIS*142

2SIS*145

2SIS*147

2SIS*148

2SIS*151

Category A/C**Class** 1**Function:**

Safety Injection Accumulators discharge check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for passive low pressure injection to the RCS. When the RCS is at normal operating pressure, full stroking accumulator discharge check valves cannot be performed because the RCS is at a higher pressure than the accumulators. Full stroking may not be performed during cold shutdown because the reduced pressure which is required to perform this test may not be obtainable. In addition, stroke testing if attempted at cold shutdown could extend the length of a plant shutdown due to extensive preparatory work in establishing the proper reactor coolant system conditions.

Alternate Test:

Full stroke exercised open at refueling per 2BVT 1.11.3. As a special test, after maintenance has been performed on any of these valves, 2OST-11.15 may be performed to partial stroke exercise the applicable check valve.

RELIEF REQUEST 11**Valve No.:**

2SIS*545

2SIS*546

2SIS*547

Category C**Class** 1**Function:**

HHSI/LHSI header to RCS hot legs check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the charging pump will not develop the required flow. In addition, injection of relatively cold water will cause a thermal cycle or shock resulting in an increased probability of system failure. At cold shutdown full stroking cannot be performed for [2SIS*547] because full flow testing could result in low-temperature overpressurization of the RCS. Additionally, full stroking of [2SIS*545 and 546] cannot be performed because testing would require full flow injection from LHSI to the RCS where there is not sufficient volume to receive the additional inventory.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14A(B).

RELIEF REQUEST 12**Valve No.:**

2SIS*548

2SIS*550

2SIS*552

Category C**Class** 1**Function:**

HHSI/LHSI header to RCS cold legs check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Normal position is closed. Safety function is to open for HHSI/LHSI. When the RCS is at normal operating pressure, full stroking the header check valves cannot be performed because the LHSI pumps will not develop the required flow. At cold shutdown full stroking cannot be performed because testing would require full flow injection to the RCS where there is not sufficient volume to receive the additional inventory.

Alternate Test:

Full stroke exercised open at refueling per 2OST-11.14A.

RELIEF REQUEST 13**Valve No.:**

2CVS*93

Category A/C**Class** 2**Function:**

Containment Vacuum Radiation Monitor Pump discharge header inside containment isolation check valve

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valve is normally open. Safety function is closed for containment isolation. Full stroking closed cannot be performed during normal operation because this valve is located inside containment and is inaccessible. In addition, leak testing is required to verify closure of this valve, and if attempted at cold shutdown could delay plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.47.5.

RELIEF REQUEST 14**Valve No.:**

2CCP*289

2CCP*290

2CCP*291

Category A/C**Class** 3**Function:**

CCP to Reactor Coolant Pump Thermal Barrier Heat Exchanger supply check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valves are normally open. Safety function is to close to isolate CCP from reactor coolant if a leak develops in the RCP thermal barrier heat exchanger. Valves cannot be full stroked during normal operation because the valves are located inside the containment and leak testing is required to verify closure. In addition, leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.60.6.

RELIEF REQUEST 15**Valve No.:**

2CCP*352

Category C**Class** 3**Function:**

SC-3 to NNS boundary isolation valve

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valve is normally open. Safety function is closed to isolate NNS from SC-3 component cooling piping. Testing during normal operation cannot be performed because leak testing is required to verify valve closure, which would cause extended interruption of cooling water to the instrument air compressors. In addition, leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.60.6.

RELIEF REQUEST 16**Valve No.:**

2MSS*18

2MSS*19

2MSS*20

2MSS*196

2MSS*199

2MSS*352

Category C**Class** 3**Function:**

Main Steam to Auxiliary Feed Pumps check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valves are normally closed. Safety function is to open for operation of the steam driven auxiliary feed pump and closed to prevent steam generator cross-connection during a high energy line break. Full stroking closed for these valves cannot be performed during normal operation because leak testing is required to verify full closure. In addition, leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.60.6.

RELIEF REQUEST 17**Valve No.:**

2SVS*80

2SVS*81

2SVS*82

Category C**Class** 2**Function:**

Steam Generators residual heat release reverse flow check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valves are normally closed. Safety position is closed to prevent cross-connection of steam generators during a high energy line break. Full stroking closed for these valves cannot be performed during normal operation because leak testing is required to verify full closure. In addition, leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.60.6.

RELIEF REQUEST 18**Valve No.:**

2FWS*28

2FWS*29

2FWS*30

Category C**Class** 2**Function:**

Main Feedwater header isolation check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valves are normally open. Safety position is closed for Feedwater isolation in the event of a high energy line break. Exercising during power operation is not possible since this would require stopping feedwater flow to the Steam Generators, resulting in a plant shutdown. Leak testing to be performed with steam generator level $\geq 85\%$ is required to verify the valves are full closed because they have no position indication or weighted arms. Leak testing if attempted at cold shutdown could result in delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2OST-24.8.

RELIEF REQUEST 19**Valve No.:**

2FWE*99
2FWE*100
2FWE*101

Category C**Class** 2**Function:**

Auxiliary Feedwater heater to Steam Generators check valves

Test Requirement:

Quarterly full stroke

Basis for Relief:

Valves are normally closed. Safety function is to open during Auxiliary Feed System operation. Verification of full stroke closed is not possible during power operation because this involves a leak test to be performed with steam generator level $\geq 85\%$. Leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2OST-24.8A.

RELIEF REQUEST 20**Valve No.:**

2SWS*MOV103A
2SWS*MOV103B

Category B**Class** 3**Function:**

RSS heat exchangers service water supply isolation valves.

Test Requirement:

Quarterly full stroke and time

Basis for Relief:

Valves are normally closed. Safety function is to open to supply cooling water to the RSS heat exchangers. Valve is not cycled during plant operation as failure of the valve in the open position would require plant shutdown. Failure of the valve in the open position at cold shutdown would delay plant startup. (The Service Water System cannot simultaneously support normal plant operation and the RSS heat exchangers)

Alternate Test:

Full stroke exercised and timed open at refueling per 2OST-30.13A(B).

RELIEF REQUEST 21**Valve No.:**

2SWS*1103

2SWS*1104

Category C**Class** 3**Function:**Service water to main steam valve house cooling headers
check valves**Test Requirement:**

Quarterly full stroke

Basis for Relief:

Safety position is closed to prevent draining the inlet lines to the MSVH cooling coils during a service water pump trip on a loss of power. Full stroking in the closed position cannot be performed during normal operation because isolation of the service water supply header in conjunction with a leak test is required to verify full closure. Isolation of the header is not acceptable because both SW headers are normally in service. In addition, leak testing if attempted at cold shutdown could result in a delayed plant startup.

Alternate Test:

Valve closure is verified by a leak test at refueling per 2BVT 1.60.6.

RELIEF REQUEST 22**Valve No.:**

2EGF*SOV202-1

2EGF*SOV202-2

2EGF*SOV203-1

2EGF*SOV203-2

Category B**Class** 3**Function:**

Emergency Diesel Generator Air Starting Solenoid Valves

Test Requirement:

Quarterly stroke and time/verify remote position indication bi-annually.

Basis for Relief:

These valves are quick acting and do not have position indication. Operation of these valves will be monitored by timing the starting time to rated speed for each EDG. Individual valves will be tested by isolating one bank of air prior to starting on an alternating frequency. This will insure each bank is capable of starting the EDG in the required time and that the air starting solenoids are not degrading.

Alternate Test:

Stroked and indirectly timed on an alternating frequency in conjunction with monthly diesel generator 2OST-36.1 and 36.2 to ensure compliance with ASME XI requirement for stroke testing on a quarterly frequency. Assign a limiting stroke time based on EDG starting requirements for ESF response time. (EDG ready to accept load \leq 10 sec.).

RELIEF REQUEST 23**Valve No.:**

2CHS*MOV378

2CHS*473

Category A and A/C**Class** 2**Function:**

RCP seal water return line inside containment isolation valves

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #19, the configuration of this containment penetration (i.e., two inside containment isolation valves in parallel) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 23



RELIEF REQUEST 24**Valve No.:**

2CHS*AOV200A
2CHS*AOV200B
2CHS*AOV200C

Category A**Class** 2**Function:**

Reactor coolant letdown orifice inside containment isolation valves

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #28, the configuration of this containment penetration (i.e., three inside containment isolation valves in parallel) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 24



RELIEF REQUEST 25**Valve No.:**

2HVR*MOD23A

2HVR*MOD23B

Category A**Class** 2**Function:**

Containment purge exhaust fan containment isolation dampers

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #90, the configuration of this containment penetration (i.e., a single test connection located between two containment isolation dampers in series) is such that individual leakage rates for each specific damper cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each damper would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 25



RELIEF REQUEST 26**Valve No.:**

2HVR*MOD25A

2HVR*MOD25B

2HVR*DMP206

Category A**Class** 2**Function:**

Containment purge supply fan containment isolation dampers

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #91, the configuration of this containment penetration (i.e., a single test connection located between the three penetration isolation dampers) is such that individual leakage rates for each specific damper cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each damper would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 26



RELIEF REQUEST 27**Valve No.:**

2QSS*SOV100A

2QSS*SOV100B

Category A**Class** 2**Function:**

Chemical Injection Pump discharge to containment sump isolation valves

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #118, the configuration of this containment penetration (i.e., two outside containment isolation valves in parallel) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 27



RELIEF REQUEST 28**Valve No.:**

See next page

Category A and A/C**Class** 2**Function:**

Containment Isolation

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for the penetrations listed on the next page, the configuration of these containment penetrations (i.e. two outside or two inside containment isolation valves in parallel, one valve being a relief valve) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Assign a maximum permissible leakage rate for the entire barrier to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 28



Penetration No. 1	Valves 2CCP*MOV157-1	& 2CCP*RV105
Penetration No. 2	Valves 2CCP*MOV150-1	& 2CCP*RV102
Penetration No. 4	Valves 2CCP*MOV151-1	& 2CCP*RV103
Penetration No. 5	Valves 2CCP*MOV156-1	& 2CCP*RV104
Penetration No. 14	Valves 2SWS*MOV153-1	& 2SWS*RV153
Penetration No. 20	Valves 2SIS*41	& 2SIS*RV130
Penetration No. 21	Valves 2SWS*MOV155-1	& 2SWS*RV155
Penetration No. 24	Valves 2RHS*15	& 2RHS*RV100
Penetration No. 25	Valves 2SWS*MOV154-1	& 2SWS*RV154
Penetration No. 27	Valves 2SWS*MOV152-1	& 2SWS*RV152
Penetration No. 29	Valves 2DGS*AOV108B	& 2DGS*RV115
Penetration No. 38	Valves 2DAS*AOV100B	& 2DAS*RV110
Penetration No. 45	Valves 2RCS*AOV519	& 2RCS*RV100
Penetration No. 55-1	Valves 2SSR*AOV109A2	& 2SSR*RV117
Penetration No. 56-1	Valves 2SSR*AOV102A2	& 2SSR*RV118
Penetration No. 56-2	Valves 2SSR*AOV128A2	& 2SSR*RV120
Penetration No. 56-3	Valves 2SSR*AOV100A2	& 2SSR*RV119
Penetration No. 57-1	Valves 2SSR*AOV112A2	& 2SSR*RV121
Penetration No. 63	Valves 2QSS*MOV101A	& 2QSS*RV101A
Penetration No. 64	Valves 2QSS*MOV101B	& 2QSS*RV101B
Penetration No. 97-1	Valves 2SSR*SOV129A2	& 2SSR*RV122
Penetration No. 106	Valves 2SIS*AOV889	& 2SIS*RV175

RELIEF REQUEST 29**Valve No.:**

2RCS*SOV200A
2RCS*SOV200B
2RCS*SOV201A
2RCS*SOV201B
2RCS*HCV250A
2RCS*HCV250B

Category B**Class** 1,2**Function:**

Reactor Vessel Head Vent Valves

Test Requirement:

Quarterly full stroke and time

Basis for Relief:

Valves are normally closed and are only required to be opened during accident conditions to provide reactor vessel venting and reactor coolant system (RCS) letdown. Westinghouse (the valve manufacturer) does not recommend these valves be "tested" at temperatures above 200F or pressures exceeding 300 psia or "operated" to vent the reactor vessel following startup from a refueling outage at pressures exceeding 415 psig. (References: PSE-SSA-4743, dated February 8, 1985 and DLW-89-667, dated June 14, 1989). Degradation of the system can result from repeated strokes at greater than these temperatures/pressures. In addition, Westinghouse does not recommend stroking the HCV's while isolated from the RCS by the SOV's (SOV's are required to remain closed to prevent RCS leakage) unless the trapped pressure between the HCV's and SOV's is first relieved by very slowly opening the HCV's. This goes against INPO's good practice of not pre-exercising power operated valves prior to stroking and timing them. In addition, if the SOV's are leaking, there is the potential for exceeding the design pressure limit of the Pressure Relief Tank because there is no pressure indication in this piping. Also, full stroke testing may not be performed during cold shutdown because the reduced pressure which is required to perform this test may not be obtainable. In addition, stroke testing, if attempted at cold shutdown, could extend the length of a plant shutdown due to extensive preparatory work in establishing the proper reactor coolant system conditions.

Alternate Test:

Full stroke exercised and timed open and closed at refueling per 2OST-6.9.

RELIEF REQUEST 30**Valve No.:**

See below

Category A,B**Class** 1,2,3**Function:**

Various

Test Requirement:

Stroke time trending, IWV-3417(a)

Basis for Relief:

Stroke times for rapid acting valves are affected by variations in the response time of personnel performing the test. Therefore, trending stroke times for rapid acting valves is not practical and relief from trending these valves is permitted by Generic Letter No. 89-04, Attachment 1, Item 6.

Alternate Test:

Assign a limiting stroke time of 2 seconds to these valves and delete trending requirements.

RAPID ACTING VALVES

2RCS*SOV200A	2CVS*SOV152B	2PAS*SOV105A1
2RCS*SOV200B	2CVS*SOV153A	2PAS*SOV105A2
2RCS*SOV201A	2CVS*SOV153B	<input type="checkbox"/> <input type="checkbox"/> 2MSS*SOV105B
2RCS*SOV201B	2LMS*SOV950	<input type="checkbox"/> <input type="checkbox"/> 2MSS*SOV105C
2RCS*PCV455C	2LMS*SOV951	2MSS*SOV105E
2RCS*PCV455D	2LMS*SOV952	2MSS*SOV105F
2RCS*PCV456	2LMS*SOV953	2MSS*SOV120
2CHS*SOV206	<input type="checkbox"/> 2QSS*SOV100A	2HCS*SOV114A
2GNS*SOV853A	<input type="checkbox"/> 2QSS*SOV100B	2HCS*SOV114B
2GNS*SOV853B	<input type="checkbox"/> 2QSS*SOV101A	2HCS*SOV115A
2GNS*SOV853C	<input type="checkbox"/> 2QSS*SOV101B	2HCS*SOV115B
2GNS*SOV853D	<input type="checkbox"/> 2QSS*SOV102A	2HCS*SOV133A
2GNS*SOV853E	<input type="checkbox"/> 2QSS*SOV102B	2HCS*SOV133B
2GNS*SOV853F	2SSR*AOV112A2	2HCS*SOV134A
2GNS*SOV854A	2SSR*SOV128A1	2HCS*SOV134B
2GNS*SOV854B	2SSR*SOV128A2	2HCS*SOV135A
2CVS*SOV102	2SSR*SOV129A1	2HCS*SOV135B
2CVS*SOV151A	2SSR*SOV129A2	2HCS*SOV136A
2CVS*SOV151B	2SSR*SOV130A1	2HCS*SOV136B
2CVS*SOV152A	2SSR*SOV130A2	

Stroked in both directions, but rapid-acting in open direction only.

Stroked in both directions, but rapid-acting in closed direction only.

RELIEF REQUEST 31**Valve No.:**

2PHS*100
2PHS*101
2PHS*110
2PHS*111
2PHS*112
2PHS*113

Category A**Class** 2**Function:**

Containment Isolation (Personnel Air Lock)

Test Requirement:

Leak tested per IWV-3420. In addition, IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.

Basis for Relief:

These containment isolation valves are leak tested in accordance with 10CFR50, Appendix J, Type B. Since the acceptance criteria for Appendix J, Type B testing is more limiting than ASME Section XI, additional leak testing in accordance with ASME Section XI would be redundant. In addition, as shown on the attached figure for the Personnel Air Lock, the configuration of this containment penetration (ie., a single test connection located in the airlock between six airlock equalization valves) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Leak test semi-annually in accordance with Technical Specification 4.6.1.3.b.1, 10CFR50, Appendix J and IWV-3426 per 2BVT 1.47.8. In addition, assign a maximum permissible leakage rate for the entire airlock to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 32**Valve No.:**

2PHS*201

2PHS*202

Category A**Class** 2**Function:**

Containment Isolation (Emergency Air Lock)

Test Requirement:

Leak tested per IWV-3420. In addition, IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

These containment isolation valves are leak tested in accordance with 10CFR50, Appendix J, Type B. Since the acceptance criteria for Appendix J, Type B testing is more limiting than ASME Section XI, additional leak testing in accordance with ASME Section XI would be redundant. In addition, as shown on the attached figure for the Emergency Air Lock, the configuration of this containment penetration (ie., a single test connection located in the airlock between two airlock equalization valves) is such that individual leakage rates for each specific valve cannot be determined using the test method of 10CFR50, Appendix J. In this case, assigning maximum permissible leakage rates for each valve would not be practical.

Alternate Test:

Leak test semi-annually in accordance with Technical Specification 4.6.1.3.b.1, 10CFR50, Appendix J and IWV-3426 per 2BVT 1.47.10. In addition, assign a maximum permissible leakage rate for the entire airlock to then be used as the criteria for initiating corrective action in accordance with IWV-3427(a).

RELIEF REQUEST 32



EMERGENCY AIR LOCK

RELIEF REQUEST 33**Valve No.:**

2SIS*MOV867C

2SIS*MOV867D

Category A**Class** 2**Function:**

HHSI Pump Isolation to Cold Leg Injection.

Test Requirement:

IWV-3426 and 3427(a) require Owner specified maximum permissible leakage rates for specific valves as a function of valve size and type, and provide the corrective action to be followed when these limits are exceeded.


Basis for Relief:

As shown on the attached figure for Penetration #113, the configuration of this containment penetration (i.e. two outside containment isolation valves in parallel) is such that individual leakage rates for each specific valve cannot be determined using the test method of IWV-3424. In this case, assigning maximum permissible leakage rates for each valve would not be practical. Therefore, relief from meeting Code requirements is permitted by following the guidelines in ASME/ANSI OMa-1988, Part 10 (OM-10), Paragraph 4.2.2.3 in accordance with 10CFR50.55a (f) (4) (iv) as approved by the NRC.

Alternate Test:

Assign a maximum permissible leakage rate for both 3 inch valves as a unit to then be used as the criteria for initiating corrective actions in accordance with IWV-3427(a).

RELIEF REQUEST 33



SYSTEM DESIGNATION

(2SIS)

PENETRATION #113