

DCP

MAY 8 1992

Docket No. 50-440

Centerior Service Company
ATTN: Mr. Michael D. Lyster
Vice President
Nuclear - Perry
c/o The Cleveland Electric
Illuminating Company
10 Center Road
Perry, OH 44081

Dear Mr. Lyster:

This refers to the routine safety inspection conducted by Mr. S. K. Orsh of this office on April 20 - 24, 1992, of activities at the Perry Nuclear Power Plant, authorized by NRC Operating License No. NPF-58, and to the discussion of our findings with Messrs. R. Stratman, B. Beyer, E. Riley, and others of your staff on April 24, 1992.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No violations of NRC requirements were identified during the course of the inspection.

This inspection identified an unresolved item concerning the operability of the ventilation systems in the Emergency Operations Facility and Technical Support Center. During the inspection, your staff did not have the necessary information to explain deviations from the testing procedures described in Section 3.b of the enclosed inspection report No. 50-440/92008(DRSS). We request a written response within 30 days describing the reasons for the deviations.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

9205180032 920508
PDR ADOCK 05000440
PDR

150005

IC 35
/

Centerior Service Company

2 MAY 8 1992

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original signed by Cynthia D. Pederson"

Cynthia D. Pederson, Chief
Reactor Programs Branch

Enclosure: Inspection Report
No. 50-440/92008(DRSS)

cc w/enclosure:

- F. R. St. Clair, Director, Nuclear Support Department
- R. H. Stratman, General Manager, Perry Nuclear Power Plant
- Kevin P. Donovan, Manager, Licensing and Compliance Section
- S. F. Kensicki, Director, Perry Nuclear Engineering Dept.
- H. Ray Caldwell, General Superintendent Nuclear Operations DCD/DCB (RIDS) Licensing Fee & Debt Collection Branch
- Resident Inspector, RIII
- Terry J. Lodge, Esq.
- James R. Williams, State of Ohio
- Robert E. Owen, Ohio Department of Health
- A. Grandjean, State of Ohio, Public Utilities Commission
- Clinton SRI
- D. Bement, FEM, Region V

Yes
RIII
Orth/jp
5/6/92

Yes file
RIII
McCormick-Barger
5/6/92

RIII
Lanckbury
5/6/92

RIII
Pederson
5/8/92