



101 California Street, Suite 1000, San Francisco, CA 94111-5894

415/397-5600

August 31, 1984  
84056.031

50-445

Mr. J. B. George  
Project General Manager  
Texas Utilities Generating Company  
Comanche Peak Steam Electric Station  
Highway FM 201  
Glen Rose, Texas 76043

Subject: Cable Tray Support Review Questions  
Comanche Peak Steam Electric Station  
Independent Assessment Program - Phase 4  
Job No. 84056

Dear Mr. George:

Attachment A contains additional cable tray support review questions. If there are any questions while preparing responses, please call.

Very truly yours,

*NH Williams*

N. H. Williams  
Project Manager

NHW:jm

cc: Mr. S. Burwell (USNRC)  
Mr. S. Treby (USNRC)  
Mr. D. Wade (TUGCO)  
Ms. J. Van Amerongen (EBASCO/TUGCO)  
Mrs. J. Ellis (CASE)  
Mr. R. Ballard (G&H)

San Francisco Boston Chicago Richland

8409060262 840831  
PDR ADDCK 05000445  
A PDR

2222  
11  
USE ATTACHED DIST. LIST

ZZZZ - USE FOR CYGNA LTRS. # 84042.029

# 84056 . 030

# 84056 . 031

LTR      ENCL.

LB#1: DL - SB. BURWELL	3	3
MEB : DE - D. TERA U	1	1
SGEB : DE - F. RINALDI	1	1
QUAB : I+E - J. SPRAUL	1	1
EGCB: I+E - J. FAIR	1	1
REGION IV - D. HUNNICATT	1	1
REG FILE	1	1
PDR	1	1
LPDR	1	1
NTIS	1	1
ASIC	1	1
REGION IV FILE	<u>1</u>	<u>1</u>
	<u>14</u>	<u>14</u>

DIST: per SB. Burwell

ATTACHMENT A

CABLE TRAY SUPPORT REVIEW QUESTIONS

1. Support Number 202, Type A<sub>4</sub>

References: 1. Gibbs & Hill, Inc. Drawing 2323-E1-0700-01-S  
2. Brown & Root, Inc. Drawing FSE-00174

The referenced support is the only support located on a straight segment of cable tray. The support does not provide longitudinal restraint.

Please provide Cygna with justification and documentation to show that:

- The affected cable tray segments are adequately supported to prevent overstressing of the trays, and,
- Support 202 is capable of resisting all applied forces.

2. Eccentric Loads and Connections

2.1 Cable trays are attached to supports by friction type or heavy-duty tray clamps. The former type resists transverse and vertical loads while the latter resists transverse, vertical and longitudinal loads. The connection details for these clamps require that they be bolted or welded to the top of the cable tray support beam. A typical connection is shown in Figure 2A. Such connections provide a load transfer which is eccentric to the major axis and to the shear center of the channel sections typically used in the cable tray support designs. As a result, several effects are not considered in the design of the supports.

2.1.1 Major and Minor Axes Flexure

As noted in Figure 2B, the location of the transverse load,  $P_h$ , is eccentric to the major axis by a distance  $d/2$ , where  $d$  is the channel depth. The effect of this eccentricity is an increase in major axis bending. Minor axis bending will occur because  $P_h$  is eccentric to the minor axis by a distance of  $(g-x)$  where  $g$  is the gage distance and  $x$  is the location of the neutral axis relative to the back of the channel web.

2.1.2 Torsion due to Vertical Loads

As shown in Figure 2C, vertical cable tray loads are applied eccentrically to the shear center of the channel section which induces torsional moments into the beam. Cygna has

ATTACHMENT A

CABLE TRAY SUPPORT REVIEW QUESTIONS

noted that only beam members for Regular Case cable tray supports Details A<sub>j</sub>, B<sub>j</sub> and C<sub>j</sub> and Detail SP-7 with brace have been analyzed for the effects of eccentrically applied vertical loads. Cygna is currently reviewing these calculations. No other cable tray supports have been analyzed for the effects of torsion due to vertical loads.

2.1.3 Torsion Due to Longitudinal Loads

As shown in Figure 2C, longitudinal cable tray loads are applied eccentrically to the major axis (X-X) of the channel section which induces torsional moments into the beam member. Cygna has noted that only Detail SP-7 with brace has been analyzed for the effects of eccentrically applied loads.

2.2 Eccentric Connections

The cable tray supports are primarily constructed of channel sections for the hanger and beam members and angles for bracing members. (For Cygna's concerns regarding angles, reference Cygna's letter 84056.027, question 2.) Figure 2D shows the eccentricity between the neutral axis of a typical beam and hanger connection. Cygna has noted that the effect of this joint eccentricity has not been considered in the design calculations.

Please provide Cygna with documentation showing the cable tray supports are capable of resisting the applied loads when the effects of the eccentricities described above are considered.

3. Load Combinations

Reference: 1. Cygna Technical File 83090.11.2.1.50.

Gibbs & Hill performs the load combination for support member forces by combining the dead load component with the vertical seismic component before the seismic components are combined by the square root of the sum of the squares (SRSS) method. This is Gibbs & Hill's simplified method. Cygna had previously noted that the above method was incorrect because the dead load component was to be added to the SRSS of the vertical and horizontal seismic components. Gibbs & Hill terms this combination the exact method.

To satisfy Cygna's concerns, Gibbs & Hill performed an evaluation to compare the results of the exact combination to the simplified

ATTACHMENT A

CABLE TRAY SUPPORT REVIEW QUESTIONS

combination (Reference 1). This evaluation showed that the simplified method underestimated the resultant member stresses and anchor bolt loads by no more than 5% when compared with results from the exact method.

In general, the combinations used by Gibbs & Hill to qualify the acceptability of their simplified method is incorrect because it combines the seismic and dead load accelerations without considering the individual component's effect on the forces in the support members. The configuration of the support was not considered in the qualification calculations. Cygna performed an evaluation of the frames shown in Figures 3A, 3B and 3C for various aspect ratios ( $H/L$  for two-way frames  $H/L$  and  $H/d$  for three-way frames and  $L/B$  for cantilevers). The results are shown in Tables 1 through 3 for the Auxiliary, Safeguards, Electrical and Fuel Buildings.

The tables show that when the generic accelerations are used in the support design the simplified combination method is acceptable for all elevations of the four buildings except elevation 899'-6" in the auxiliary building, which is acceptable since supports on this elevation were designed specifically for higher accelerations. When the elevation-specific accelerations are employed, the simplified combination method results in reactions which are 4 to 16 percent smaller than the exact combination.

Cygna is not requesting a response to this discussion. However, Cygna believes this information should be considered in the preparation of future responses to Cygna's questions where the cumulative effect of design discrepancies is evaluated.

Project TEXAS UTILITIES - CPS&S PHASE 4 Prepared By J.P.P. Date 29 AUG. 88  
Subject ECCENTRIC LOADING OF CHANNELS Checked By \_\_\_\_\_ Date \_\_\_\_\_  
System REVIEW QUESTION 2 Job No. 84056 File No. \_\_\_\_\_  
Analysis No. \_\_\_\_\_ Rev. No. 0 Sheet No. \_\_\_\_\_




FIGURE 2A - TYPICAL TRAY CLAMP  
(NOT TO SCALE)

NOTES : 1. TRAY CLAMP IS AN ANGLE SECTION WHEN LONGITUDINAL LOADS ARE TO BE RESISTED. INDICATED BOLT IS FOR ILLUSTRATION OF LONGITUDINAL SUPPORT.

Calculation  
Sheet

Project TEXAS UTILITIES - CPSSES IAP Prepared By J.P.R. Date 29 AUG 84  
Subject ECCENTRIC LOADING OF CHANNELS Checked By \_\_\_\_\_ Date \_\_\_\_\_  
System REVIEW QUESTION 2 Job No 84056 File No \_\_\_\_\_  
Analysis No. Rev. No. Sheet No. \_\_\_\_\_





FIGURE 2B - ECCENTRICITY OF TRANSVERSE  
LOAD  $P_h$  FROM MAJOR AND  
MINOR AXIS OF A CHANNEL  
(NOT TO SCALE)

Project	TEXAS UTILITIES - CPS&S IAP	Prepared By	J.P.R.	Date
Subject	ECCENTRIC LOADING OF CHANNEL	Checked By		29 AUG '84
System	REVIEW QUESTION 2	Job No	84056	File No
Analysis No	Rev No	Sheet No	0	



$P_V$  = VERTICAL TRAY LOAD  
 $P_L$  = LONGITUDINAL TRAY LOAD

FIGURE 2C - ECCENTRICITIES OF VERTICAL  
AND LONGITUDINAL LOADS  
(NOT TO SCALE)

NOTES: 1. DISTANCES SHOWN GIVEN IN NOMENCLATURE  
OF THE AISC MANUAL OF STEEL CONSTRUCTION,  
7<sup>TH</sup> EDITION.

Project TEXAS UTILITIES - CPSES IAP PHASE 4 Prepared By J.P.R. Date 29 AUG '04  
Subject ECCENTRIC MEMBER CONNECTIONS Checked By \_\_\_\_\_ Date \_\_\_\_\_  
System REVIEW QUESTION 2 Job No 84056 File No \_\_\_\_\_  
Analysis No \_\_\_\_\_ Rev. No. 0 Sheet No. \_\_\_\_\_




FIGURE 2D - ECCENTRIC MEMBER CONNECTION


(NOT TO SCALE)

NOTES: 1. DISTANCES  $\bar{x}$  PER NOMENCLATURE OF  
AISC MANUAL OF STEEL CONSTRUCTION,  
7<sup>TH</sup> EDITION

Project TEXAS UTILITIES - CPSSES IAP Prepared By B HORNMAN Date 8/21/84  
 Subject SEISMIC LOAD COMBINATIONS Checked By \_\_\_\_\_ Date \_\_\_\_\_  
 System REVIEW QUESTION NO. 3 Job No 84056 File No \_\_\_\_\_  
 Analysis No Rev. No Sheet No \_\_\_\_\_

FIGURE 3A Two-WAY FRAME

SUPPORT CASES A<sub>1</sub>-A<sub>4</sub>



PRESENCE OF BRACES  
DEPEND ON SPECIFIC  
CASE, BUT ARE NOT  
RELEVANT IN THIS  
STUDY

DEFN:  $M$  = MASS OF TRAY width =  $w$ ,  $\text{SPT} = S$ ,  $\bar{m} = w^2 \cdot S^{1/2}$   
let  $M = 1.0$  for transverse loading:


$G_H$  = PEAK HORIZONTAL SPECTRAL ACCEL.  
 $G_V$  = PEAK VERTICAL SPECTRAL ACCEL.

$$\begin{aligned} H_s &= \text{HORIZ. SEISMIC LOAD} = M \times G_H = G_H \\ V_s &= \text{VERT. SEISMIC LOAD} = M \times G_V = G_V \\ V_d &= \text{VERTICAL DEAD LOAD} = M \times g = 1 \end{aligned}$$

$$\begin{aligned} R_{Ahs} &= \text{TENSILE REACTION AT A due to } H_s = H_s \times h/l \\ R_{Avs} &= \text{TENSILE REACTION AT A due to } V_s = V_s / 2 \\ R_{Avd} &= \text{TENSILE REACTION AT A due to } V_d = V_d / 2 \end{aligned}$$

Project: TEXAS UTILITIES - CPSSES IAP      Prepared By: BHorsman Date: 5/23/84  
 Subject: SEISMIC LOAD COMBINATIONS      Checked By: \_\_\_\_\_ Date: \_\_\_\_\_  
 System: REVIEW QUESTION No. 3      Job No: 84056 File No: \_\_\_\_\_  
 Analysis No.      Rev. No.      Sheet No. \_\_\_\_\_

FIGURE 3B THREE-WAY FRAME



DEFN:  $M$  = MASS OF TRAY per span (between vertical supports)  
 assumed 8'-0" O.C., assume  $M = 1.0$

$$H_s = \text{Horiz. Seismic Load} = M \times G_H = G_H$$

$$V_s = \text{Vert. Seismic Load} = M \times G_V = G_V$$


$$L_s = \text{Longit. Seismic Load} = 5 \times M \times G_H = 5G_H$$

(SINCE Longit. Span = 40' = 5 x Vert. Span)

$$V_D = \text{Vert. Dead load} = M \times g = 1.0$$

Project TEXAS UTILITIES - CPSES - IAP Prepared By B. Horwitz Date 8/23/81  
 Subject SEISMIC LOAD COMBINATIONS Checked By \_\_\_\_\_ Date \_\_\_\_\_  
 System REVIEW QUESTION No. 3 Job No. 84056 File No. \_\_\_\_\_  
 Analysis No. \_\_\_\_\_ Rev No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

FIGURE 3C CANTILEVERED RESTRAINT



DEFINITIONS

$L$  = distance from wall to tray center of gravity

$B$  = SPACING OF ANCHOR BOLTS

$H_S$  = HORIZONTAL SEISMIC LOAD =  $M \times G_H = G_H$

$V_S$  = VERTICAL SEISMIC LOAD =  $M \times G_V = G_V$

$V_D$  = VERTICAL DEAD LOAD =  $I_g \times M = 1.0$

$R_{AHS}$  = REACTION AT A due to  $H_S$  =  $H_S/2 = \dots$

$R_{AVS}$  = REACTION AT A due to  $V_S$  =  $V_S \left(\frac{2}{B}\right) = \dots$

$R_{AVD}$  = REACTION AT A due to  $V_D$  =  $V_D \left(\frac{2}{B}\right) = \dots$

TABLE 1  
**COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES Ai  
SAFEGUARDS BUILDING ACCELERATIONS**

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
896.50	2.2830	1.5000	0.2000	1.3781	1.3308	1.0355	0.9584
			0.5000	1.8658	1.6928	1.1022	0.9883
			1.0000	2.9030	2.6028	1.1153	0.9725
			2.0000	5.1272	4.7340	1.0831	0.9315
			4.0000	9.6627	9.2172	1.0483	0.8978
873.50	2.0790	1.6370	0.2000	1.4181	1.3825	1.0257	0.9862
			0.5000	1.8231	1.6790	1.0858	0.9656
			1.0000	2.7343	2.4618	1.1107	0.9160
			2.0000	4.7378	4.3620	1.0861	0.8607
			4.0000	8.8562	8.4199	1.0518	0.8228
852.50	1.6050	1.4580	0.2000	1.2965	1.2702	1.0207	0.9017
			0.5000	1.5842	1.4678	1.0793	0.8391
			1.0000	2.2628	2.0215	1.1194	0.7580
			2.0000	3.7917	3.4372	1.1031	0.6889
			4.0000	6.9613	6.5366	1.0650	0.6468
831.50	1.1410	1.3000	0.2000	1.1889	1.1724	1.0140	0.8269
			0.5000	1.3649	1.2837	1.0632	0.7229
			1.0000	1.8132	1.6200	1.1192	0.6074
			2.0000	2.8728	2.5554	1.1242	0.5219
			4.0000	5.1101	4.7067	1.0857	0.4748
810.50	0.7010	1.2600	0.2000	1.1454	1.1387	1.0059	0.7966
			0.5000	1.2209	1.1831	1.0320	0.6467
			1.0000	1.4425	1.3298	1.0848	0.4832
			2.0000	2.0370	1.8007	1.1313	0.3701
			4.0000	3.3739	3.0231	1.1160	0.3135
790.50	0.4290	1.0490	0.2000	1.0315	1.0281	1.0033	0.7174
			0.5000	1.0667	1.0467	1.0191	0.5650
			1.0000	1.1776	1.1107	1.0602	0.3945
			2.0000	1.5056	1.3363	1.1267	0.2735
			4.0000	2.2944	1.9986	1.1480	0.2132
785.50	0.3920	1.0170	0.2000	1.0145	1.0115	1.0029	0.7056
			0.5000	1.0450	1.0274	1.0171	0.5535
			1.0000	1.1421	1.0820	1.0555	0.3826
			2.0000	1.4345	1.2774	1.1230	0.2606
			4.0000	2.1484	1.8643	1.1524	0.1996
773.50	0.3270	0.9490	0.2000	0.9790	0.9767	1.0023	0.6809
			0.5000	1.0019	0.9881	1.0139	0.5307
			1.0000	1.0763	1.0279	1.0470	0.3605
			2.0000	1.3080	1.1736	1.1145	0.2376
			4.0000	1.8914	1.6311	1.1596	0.1757

TABLE 1  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES Ai  
ELECTRICAL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
873.33	1.7900	1.3200	0.2000	1.2508	1.2140	1.0304	0.8699
			0.5000	1.6120	1.4651	1.1003	0.8538
			1.0000	2.4078	2.1330	1.1288	0.8066
			2.0000	4.1403	3.7632	1.1002	0.7522
			4.0000	7.6904	7.2534	1.0602	0.7145
854.33	1.5700	1.3100	0.2000	1.2264	1.1969	1.0246	0.8529
			0.5000	1.5224	1.3965	1.0901	0.8064
			1.0000	2.2012	1.9491	1.1293	0.7374
			2.0000	3.7076	3.3457	1.1082	0.6736
			4.0000	6.8141	6.3853	1.0671	0.6331
830.00	1.1100	1.2200	0.2000	1.1491	1.1320	1.0152	0.7992
			0.5000	1.3247	1.2410	1.0674	0.7016
			1.0000	1.7666	1.798	1.1254	0.5918
			2.0000	2.8023	2.20	1.1290	0.5091
			4.0000	4.9817	4.5766	1.0885	0.4628
807.00	0.7200	1.2600	0.2000	1.1462	1.1391	1.0062	0.7972
			0.5000	1.2256	1.1860	1.0334	0.6492
			1.0000	1.4567	1.3399	1.0872	0.4880
			2.0000	2.0718	1.8304	1.1319	0.3764
			4.0000	3.4481	3.0938	1.1145	0.3204
778.00	0.5100	1.2600	0.2000	1.1382	1.1346	1.0032	0.7916
			0.5000	1.1797	1.1584	1.0183	0.6248
			1.0000	1.3106	1.2398	1.0571	0.4390
			2.0000	1.6989	1.5223	1.1160	0.3086
			4.0000	2.6351	2.3321	1.1299	0.2448

TABLE 1  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES Ai  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
899.50	2.6600	1.7100	0.2000	1.5070	1.4557	1.0352	1.0481
			0.5000	2.0811	1.8987	1.0961	1.1023
			1.0000	3.2940	2.9852	1.1034	1.1035
			2.0000	5.8883	5.4898	1.0726	1.0697
			4.0000	11.1743	10.7259	1.0418	1.0382
886.50	2.3200	1.6300	0.2000	1.4378	1.3945	1.0311	1.0000
			0.5000	1.9177	1.7535	1.0936	1.0157
			1.0000	2.9590	2.6668	1.1096	0.9912
			2.0000	5.2110	4.8227	1.0805	0.9467
			4.0000	9.8157	9.3727	1.0473	0.9120
873.50	1.9800	1.6600	0.2000	1.4196	1.3877	1.0230	0.9873
			0.5000	1.7919	1.6580	1.0808	0.9491
			1.0000	2.6469	2.3852	1.1097	0.8867
			2.0000	4.5460	4.1774	1.0883	0.8259
			4.0000	8.4634	8.0309	1.0539	0.7863
852.50	1.6600	1.6400	0.2000	1.3847	1.3611	1.0173	0.9630
			0.5000	1.6667	1.5593	1.0689	0.8828
			1.0000	2.3515	2.1208	1.1087	0.7877
			2.0000	3.9198	3.5728	1.0971	0.7121
			4.0000	7.1904	6.7699	1.0621	0.6681
831.50	1.2200	1.5800	0.2000	1.3268	1.3129	1.0106	0.9228
			0.5000	1.4981	1.4270	1.0499	0.7935
			1.0000	1.9534	1.7755	1.1002	0.6544
			2.0000	3.0647	2.7600	1.1104	0.5568
			4.0000	5.4435	5.0476	1.0784	0.5058
810.50	0.7100	1.4800	0.2000	1.2535	1.2481	1.0043	0.8718
			0.5000	1.3207	1.2898	1.0240	0.6996
			1.0000	1.5255	1.4289	1.0676	0.5110
			2.0000	2.1012	1.8852	1.1146	0.3817
			4.0000	3.4348	3.0989	1.1061	0.3191
790.50	0.5300	1.3400	0.2000	1.1783	1.1748	1.0030	0.8195
			0.5000	1.2205	1.1996	1.0174	0.6465
			1.0000	1.3543	1.2844	1.0544	0.4537
			2.0000	1.7540	1.5788	1.1110	0.3187
			4.0000	2.7234	2.4214	1.1247	0.2530

TABLE 1  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES Ai  
FUEL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
918.00	2.3000	0.9800	0.2000	1.1721	1.0917	1.0737	0.8152
			0.5000	1.7500	1.5174	1.1533	0.9269
			1.0000	2.8516	2.5040	1.1388	0.9553
			2.0000	5.1260	4.7053	1.0894	0.9313
			4.0000	9.7130	9.2531	1.0497	0.9024
899.50	2.0200	1.0200	0.2000	1.1506	1.0878	1.0578	0.8002
			0.5000	1.6315	1.4284	1.1422	0.8641
			1.0000	2.5834	2.2584	1.1439	0.8654
			2.0000	4.5721	4.1643	1.0979	0.8306
			4.0000	8.5961	8.1429	1.0557	0.7987
860.00	1.1400	0.9400	0.2000	1.0224	0.9964	1.0260	0.7111
			0.5000	1.2398	1.1251	1.1011	0.6561
			1.0000	1.7331	1.4968	1.1578	0.5806
			2.0000	2.8279	2.4778	1.1413	0.5138
			4.0000	5.0842	4.6620	1.0905	0.4724
841.00	0.9700	0.8800	0.2000	0.9809	0.9598	1.0219	0.6822
			0.5000	1.1548	1.0577	1.0918	0.6117
			1.0000	1.5651	1.3507	1.1587	0.5243
			2.0000	2.4893	2.1557	1.1547	0.4522
			4.0000	4.4049	3.9922	1.1034	0.4093
825.00	0.8400	0.8400	0.2000	0.9524	0.9352	1.0183	0.6624
			0.5000	1.0940	1.0113	1.0817	0.5794
			1.0000	1.4391	1.2458	1.1552	0.4821
			2.0000	2.2317	1.9154	1.1651	0.4054
			4.0000	3.8861	3.4837	1.1155	0.3611
810.50	0.7200	0.7600	0.2000	0.9064	0.8917	1.0164	0.6304
			0.5000	1.0234	0.9508	1.0764	0.5421
			1.0000	1.3141	1.1370	1.1558	0.4402
			2.0000	1.9893	1.6876	1.1788	0.3614
			4.0000	3.4050	3.0114	1.1307	0.3164

TABLE 1  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES Ai

NOTES:

1. ACCEL(HOR.): Peak horizontal spectral acceleration
2. ACCEL(VER.): Peak vertical spectral acceleration
3. ASPECT(H/L): Ratio of frame height to width
4. RAE(EXACT): Reaction for a unit load using the 'EXACT' Method of Seismic Load Combination
5. RAS(SIMP.): Reaction for a unit load using the 'SIMPLIFIED' Method of Seismic Load Combination
6. RATIO(RAE/RAS): Ratio of reactions from 'EXACT' and 'SIMPLIFIED' Methods
7. RAD: Reaction for a unit load using the 'SIMPLIFIED' Method with the design acceleration values of 2.67g horizontal and 1.67g vertical
8. RATIO(RAE/RAD): Ratio of reaction of 'EXACT' Method to the design reactions

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A<sub>i</sub>  
SAFEQUARDS BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
896.50	2.2830	1.5000	0.212	1.0000	11.9499	11.4934	1.0397	0.8899
				1.2500	14.7966	14.3316	1.0325	0.8834
				1.5000	17.6458	17.1749	1.0274	0.8789
			0.500	1.0000	11.9964	11.5398	1.0396	0.8898
				1.2500	14.8340	14.3688	1.0324	0.8833
				1.5000	17.6769	17.2060	1.0274	0.8788
			1.000	1.0000	12.1652	11.7080	1.0391	0.8893
				1.2500	14.9697	14.5042	1.0321	0.8830
				1.5000	17.7903	17.3192	1.0272	0.8787
			1.500	1.0000	12.4412	11.9830	1.0382	0.8886
				1.2500	15.1931	14.7271	1.0316	0.8826
				1.5000	17.9777	17.5063	1.0269	0.8785
			2.389	1.0000	13.1733	12.7127	1.0362	0.8867
				1.2500	15.7940	15.3267	1.0305	0.8816
				1.5000	18.4858	18.0136	1.0262	0.8779
873.50	2.0790	1.6370	0.212	1.0000	10.9365	10.4876	1.0428	0.8144
				1.2500	13.5270	13.0679	1.0351	0.8076
				1.5000	16.1202	15.6544	1.0298	0.8029
			0.500	1.0000	10.9789	10.5297	1.0427	0.8143
				1.2500	13.5609	13.1018	1.0350	0.8075
				1.5000	16.1485	15.6826	1.0297	0.8029
			1.000	1.0000	11.1324	10.6825	1.0421	0.8138
				1.2500	13.6844	13.2249	1.0347	0.8072
				1.5000	16.2518	15.7856	1.0295	0.8027
			1.500	1.0000	11.3835	10.9325	1.0413	0.8130
				1.2500	13.8878	13.4276	1.0343	0.8068
				1.5000	16.4223	15.9559	1.0292	0.8025
			2.389	1.0000	12.0496	11.5958	1.0391	0.8111
				1.2500	14.4347	13.9730	1.0330	0.8057
				1.5000	16.8849	16.4175	1.0265	0.8018
852.50	1.6050	1.4580	0.212	1.0000	8.5652	8.1257	1.0541	0.6378
				1.2500	10.5635	10.1120	1.0446	0.6306
				1.5000	12.5644	12.1049	1.0380	0.6258
			0.500	1.0000	8.5979	8.1581	1.0539	0.6377
				1.2500	10.5897	10.1381	1.0445	0.6306
				1.5000	12.5862	12.1267	1.0379	0.6258
			1.000	1.0000	8.7163	8.2757	1.0532	0.6372
				1.2500	10.6850	10.2329	1.0442	0.6303
				1.5000	12.6659	12.2061	1.0377	0.6256
			1.500	1.0000	8.9100	8.4680	1.0522	0.6364
				1.2500	10.8418	10.3891	1.0436	0.6299
				1.5000	12.7975	12.3373	1.0373	0.6253
			2.389	1.0000	9.4238	8.9785	1.0496	0.6344
				1.2500	11.2638	10.8092	1.0421	0.6287
				1.5000	13.1544	12.6931	1.0363	0.6247

**TABLE 2**  
**COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION**  
**FOR HANGER CASES L-Ai**  
**SAFEQUARDS BUILDING ACCELERATIONS**

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
831.50	1.1410	1.3000	0.212	1.0000	6.2470	5.8248	1.0725	0.4652
				1.2500	7.6649	7.2274	1.0605	0.4576
				1.5000	9.0856	8.6378	1.0518	0.4525
			0.500	1.0000	6.2702	5.8476	1.0723	0.4650
				1.2500	7.6835	7.2459	1.0604	0.4575
				1.5000	9.1011	8.6533	1.0518	0.4525
			1.000	1.0000	6.3542	5.9305	1.0714	0.4645
				1.2500	7.7511	7.3129	1.0599	0.4572
				1.5000	9.1577	8.7095	1.0515	0.4523
			1.500	1.0000	6.4916	6.0662	1.0701	0.4636
				1.2500	7.8625	7.4234	1.0592	0.4568
				1.5000	9.2511	8.8024	1.0510	0.4520
			2.389	1.0000	6.8561	6.4265	1.0668	0.4615
				1.2500	8.1621	7.7206	1.0572	0.4556
				1.5000	9.5046	9.0545	1.0497	0.4513
810.50	0.7010	1.2600	0.212	1.0000	4.0643	3.6857	1.1027	0.3027
				1.2500	4.9288	4.5271	1.0887	0.2943
				1.5000	5.7972	5.3796	1.0776	0.2887
			0.500	1.0000	4.0784	3.6993	1.1025	0.3025
				1.2500	4.9402	4.5382	1.0886	0.2942
				1.5000	5.8067	5.3890	1.0775	0.2887
			1.000	1.0000	4.1295	3.7488	1.1016	0.3019
				1.2500	4.9815	4.5786	1.0880	0.2939
				1.5000	5.8413	5.4231	1.0771	0.2885
			1.500	1.0000	4.2132	3.8298	1.1001	0.3009
				1.2500	5.0495	4.6452	1.0870	0.2933
				1.5000	5.8985	5.4794	1.0765	0.2882
			2.389	1.0000	4.4353	4.0456	1.0963	0.2986
				1.2500	5.2325	4.8246	1.0846	0.2921
				1.5000	6.0536	5.6323	1.0748	0.2875
790.50	0.4290	1.0490	0.212	1.0000	2.7101	2.3788	1.1392	0.2018
				1.2500	3.2336	2.8718	1.1260	0.1930
				1.5000	3.7612	3.3779	1.1135	0.1873
			0.500	1.0000	2.7186	2.3868	1.1390	0.2016
				1.2500	3.2405	2.8783	1.1258	0.1930
				1.5000	3.7670	3.3835	1.1134	0.1873
			1.000	1.0000	2.7495	2.4155	1.1383	0.2010
				1.2500	3.2655	2.9022	1.1252	0.1926
				1.5000	3.7881	3.4038	1.1129	0.1871
			1.500	1.0000	2.8000	2.4627	1.1370	0.2000
				1.2500	3.3068	2.9416	1.1242	0.1921
				1.5000	3.8229	3.4374	1.1121	0.1868
			2.389	1.0000	2.9344	2.5886	1.1336	0.1975
				1.2500	3.4180	3.0478	1.1215	0.1908
				1.5000	3.9173	3.5288	1.1101	0.1860

**TABLE 2**  
**COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION**  
**FOR HANGER CASES L-Ai**  
**SAFEQUARDS BUILDING ACCELERATIONS**

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
785.50	0.3920	1.0170	0.212	1.0000	2.5266	2.2058	1.1454	0.1882
				1.2500	3.0036	2.6508	1.1331	0.1793
				1.5000	3.4848	3.1093	1.1208	0.1736
			0.500	1.0000	2.5344	2.2129	1.1452	0.1880
				1.2500	3.0099	2.6567	1.1329	0.1792
				1.5000	3.4901	3.1143	1.1207	0.1735
			1.000	1.0000	2.5625	2.2388	1.1446	0.1873
				1.2500	3.0327	2.6783	1.1323	0.1789
				1.5000	3.5093	3.1328	1.1202	0.1733
			1.500	1.0000	2.6085	2.2813	1.1434	0.1863
				1.2500	3.0704	2.7139	1.1313	0.1784
				1.5000	3.5410	3.1633	1.1194	0.1730
			2.389	1.0000	2.7310	2.3949	1.1403	0.1838
				1.2500	3.1717	2.8101	1.1287	0.1770
				1.5000	3.6272	3.2462	1.1174	0.1722
773.50	0.3270	0.9490	0.212	1.0000	2.2039	1.9046	1.1571	0.1641
				1.2500	2.5993	2.2653	1.1474	0.1552
				1.5000	2.9989	2.6399	1.1360	0.1494
			0.500	1.0000	2.2103	1.9104	1.1570	0.1639
				1.2500	2.6045	2.2701	1.1473	0.1551
				1.5000	3.0033	2.6441	1.1359	0.1493
			1.000	1.0000	2.2336	1.9313	1.1565	0.1633
				1.2500	2.6234	2.2877	1.1468	0.1548
				1.5000	3.0193	2.6592	1.1354	0.1491
			1.500	1.0000	2.2717	1.9656	1.1558	0.1622
				1.2500	2.6547	2.3167	1.1459	0.1542
				1.5000	3.0457	2.6842	1.1347	0.1488
			2.389	1.0000	2.3731	2.0575	1.1534	0.1597
				1.2500	2.7388	2.3952	1.1435	0.1529
				1.5000	3.1173	2.7522	1.1326	0.1480

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A<sub>i</sub>  
ELECTRICAL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
873.33	1.7900	1.3200	0.212	1.0000	9.4823	9.0328	1.0498	0.7061
				1.2500	11.7134	11.2539	1.0408	0.6993
				1.5000	13.9466	13.4804	1.0346	0.6946
			0.500	1.0000	9.5188	9.0691	1.0496	0.7060
				1.2500	11.7426	11.2830	1.0407	0.6992
				1.5000	13.9710	13.5047	1.0345	0.6946
			1.000	1.0000	9.6511	9.2007	1.0490	0.7055
				1.2500	11.8490	11.3890	1.0404	0.6990
				1.5000	14.0599	13.5934	1.0343	0.6944
			1.500	1.0000	9.8674	9.4158	1.0480	0.7047
				1.2500	12.0241	11.5635	1.0398	0.6985
				1.5000	14.2068	13.7399	1.0340	0.6942
			2.389	1.0000	10.4411	9.9867	1.0455	0.7028
				1.2500	12.4951	12.0330	1.0384	0.6975
				1.5000	14.6051	14.1373	1.0331	0.6935
854.33	1.5700	1.3100	0.212	1.0000	8.3843	7.9415	1.0558	0.6244
				1.2500	10.3400	9.8859	1.0459	0.6173
				1.5000	12.2979	11.8362	1.0390	0.6125
			0.500	1.0000	8.4163	7.9733	1.0556	0.6242
				1.2500	10.3656	9.9114	1.0458	0.6172
				1.5000	12.3193	11.8575	1.0389	0.6125
			1.000	1.0000	8.5322	8.0884	1.0549	0.6237
				1.2500	10.4589	10.0042	1.0454	0.6170
				1.5000	12.3972	11.9352	1.0387	0.6123
			1.500	1.0000	8.7218	8.2766	1.0538	0.6229
				1.2500	10.6124	10.1570	1.0448	0.6165
				1.5000	12.5260	12.0636	1.0383	0.6121
			2.389	1.0000	9.2246	8.7764	1.0511	0.6210
				1.2500	11.0253	10.5682	1.0433	0.6154
				1.5000	12.8753	12.4118	1.0373	0.6114
830.00	1.1100	1.2200	0.212	1.0000	6.0884	5.6648	1.0748	0.4534
				1.2500	7.4682	7.0297	1.0624	0.4459
				1.5000	8.8506	8.4020	1.0534	0.4408
			0.500	1.0000	6.1109	5.6871	1.0745	0.4532
				1.2500	7.4863	7.0476	1.0623	0.4458
				1.5000	8.8657	8.4170	1.0533	0.4408
			1.000	1.0000	6.1927	5.7677	1.0737	0.4527
				1.2500	7.5522	7.1129	1.0618	0.4455
				1.5000	8.9208	8.4717	1.0530	0.4406
			1.500	1.0000	6.3264	5.8997	1.0723	0.4518
				1.2500	7.6605	7.2203	1.0610	0.4450
				1.5000	9.0118	8.5621	1.0525	0.4403
			2.389	1.0000	6.6811	6.2503	1.0689	0.4497
				1.2500	7.9520	7.5095	1.0589	0.4439
				1.5000	9.2584	8.8074	1.0512	0.4396

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A1  
ELECTRICAL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
807.00	0.7200	1.2600	0.212	1.0000	4.1579	3.7763	1.1011	0.3096
				1.2500	5.0465	4.6422	1.0871	0.3013
				1.5000	5.9388	5.5191	1.0760	0.2958
			0.500	1.0000	4.1724	3.7903	1.1008	0.3095
				1.2500	5.0581	4.6537	1.0869	0.3012
				1.5000	5.9485	5.5287	1.0759	0.2957
			1.000	1.0000	4.2250	3.8413	1.0999	0.3088
				1.2500	5.1006	4.6452	1.0863	0.3009
				1.5000	5.9841	5.5637	1.0756	0.2956
			1.500	1.0000	4.3109	3.9247	1.0984	0.3079
				1.2500	5.1705	4.7637	1.0854	0.3004
				1.5000	6.0429	5.6217	1.0749	0.2953
			2.389	1.0000	4.5393	4.1468	1.0947	0.3056
				1.2500	5.3586	4.9483	1.0829	0.2991
				1.5000	6.2022	5.7789	1.0733	0.2945
778.00	0.5100	1.2600	0.212	1.0000	3.1289	2.7913	1.1210	0.2330
				1.2500	3.7510	3.3836	1.1086	0.2239
				1.5000	4.3780	3.9899	1.0973	0.2181
			0.500	1.0000	3.1390	2.8009	1.1208	0.2328
				1.2500	3.7592	3.3915	1.1084	0.2238
				1.5000	4.3849	3.9966	1.0972	0.2180
			1.000	1.0000	3.1757	2.8354	1.1200	0.2321
				1.2500	3.7889	3.4201	1.1078	0.2235
				1.5000	4.4099	4.0209	1.0968	0.2178
			1.500	1.0000	3.2358	2.8922	1.1188	0.2311
				1.2500	3.8380	3.4673	1.1069	0.2230
				1.5000	4.4513	4.0611	1.0961	0.2175
			2.389	1.0000	3.3955	3.0437	1.1156	0.2286
				1.2500	3.9701	3.5947	1.1044	0.2216
				1.5000	4.5635	4.1704	1.0943	0.2167

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A1  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
899.50	2.6600	1.7100	0.212	1.0000	13.8394	13.3807	1.0343	1.0306
				1.2500	17.1565	16.6897	1.0280	1.0242
				1.5000	20.4763	20.0039	1.0236	1.0199
			0.500	1.0000	13.8937	13.4348	1.0342	1.0305
				1.2500	17.2000	16.7331	1.0279	1.0242
				1.5000	20.5126	20.0401	1.0236	1.0198
			1.000	1.0000	14.0903	13.6309	1.0337	1.0300
				1.2500	17.3582	16.8909	1.0277	1.0239
				1.5000	20.644	20.1721	1.0234	1.0197
			1.500	1.0000	14.4119	13.9516	1.0330	1.0293
				1.2500	17.6185	17.1507	1.0273	1.0235
				1.5000	20.8630	20.3902	1.0232	1.0194
			2.389	1.0000	15.2649	14.8023	1.0313	1.0275
				1.2500	18.3186	17.8496	1.0263	1.0225
				1.5000	21.4551	20.9814	1.0226	1.0188
886.50	2.3200	1.6300	0.212	1.0000	12.1390	11.6847	1.0389	0.9040
				1.2500	15.0312	14.5678	1.0318	0.8974
				1.5000	17.9260	17.4566	1.0269	0.8928
			0.500	1.0000	12.1863	11.7318	1.0387	0.9038
				1.2500	15.0691	14.6056	1.0317	0.8973
				1.5000	17.9577	17.4881	1.0268	0.8928
			1.000	1.0000	12.3578	11.9026	1.0382	0.9034
				1.2500	15.2070	14.7432	1.0315	0.8970
				1.5000	18.0729	17.6032	1.0267	0.8927
			1.500	1.0000	12.6381	12.1819	1.0374	0.9026
				1.2500	15.4340	14.9696	1.0310	0.8966
				1.5000	18.2633	17.7932	1.0264	0.8924
			2.389	1.0000	13.3819	12.9232	1.0355	0.9008
				1.2500	16.0446	15.5788	1.0299	0.8956
				1.5000	18.7796	18.3087	1.0257	0.8918
873.50	1.9800	1.6600	0.212	1.0000	10.4436	9.9978	1.0446	0.7777
				1.2500	12.9099	12.4533	1.0367	0.7707
				1.5000	15.3791	14.9154	1.0311	0.7660
			0.500	1.0000	10.4839	10.0379	1.0444	0.7776
				1.2500	12.9423	12.4856	1.0366	0.7706
				1.5000	15.4061	14.9423	1.0310	0.7659
			1.000	1.0000	10.6301	10.1833	1.0439	0.7771
				1.2500	13.0599	12.6028	1.0363	0.7704
				1.5000	15.3044	15.0403	1.0309	0.7658
			1.500	1.0000	10.8692	10.4211	1.0430	0.7763
				1.2500	13.2534	12.7957	1.0358	0.7700
				1.5000	15.6668	15.2024	1.0306	0.7655
			2.389	1.0000	11.5034	11.0523	1.0408	0.7743
				1.2500	13.7742	13.3148	1.0345	0.7689
				1.5000	16.1073	15.6418	1.0298	0.7649

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A<sub>i</sub>  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
852.50	1.6600	1.6400	0.212	1.0000	8.8478	8.4117	1.0519	0.6589
				1.2500	10.9133	10.4646	1.0429	0.6515
				1.5000	12.9819	12.5247	1.0365	0.6466
			0.500	1.0000	8.8816	8.4452	1.0517	0.6587
				1.2500	10.9404	10.4915	1.0428	0.6514
				1.5000	13.0046	12.5473	1.0364	0.6465
			1.000	1.0000	9.0040	8.5667	1.0510	0.6582
				1.2500	11.0389	10.5896	1.0424	0.6512
				1.5000	13.0869	12.6293	1.0362	0.6464
			1.500	1.0000	9.2042	8.7654	1.0501	0.6574
				1.2500	11.2011	10.7510	1.0419	0.6507
				1.5000	13.2230	12.7650	1.0359	0.6461
			2.389	1.0000	9.7352	9.2930	1.0476	0.6553
				1.2500	11.6373	11.1853	1.0404	0.6496
				1.5000	13.5921	13.1329	1.0350	0.6454
831.50	1.2200	1.5800	0.212	1.0000	6.6564	6.2403	1.0667	0.4957
				1.2500	8.1702	7.7377	1.0559	0.4878
				1.5000	9.6877	9.2441	1.0480	0.4825
			0.500	1.0000	6.6811	6.2647	1.0665	0.4955
				1.2500	8.1900	7.7574	1.0558	0.4877
				1.5000	9.7043	9.2606	1.0479	0.4825
			1.000	1.0000	6.7708	6.3531	1.0657	0.4950
				1.2500	8.2623	7.8290	1.0553	0.4874
				1.5000	9.7647	9.3207	1.0476	0.4823
			1.500	1.0000	6.9174	6.4979	1.0646	0.4940
				1.2500	8.3812	7.9469	1.0546	0.4869
				1.5000	9.8646	9.4200	1.0472	0.4820
			2.389	1.0000	7.3065	6.8825	1.0616	0.4918
				1.2500	8.7012	8.2644	1.0529	0.4857
				1.5000	10.1354	9.6892	1.0460	0.4813
810.50	0.7100	1.4800	0.212	1.0000	4.1294	3.7633	1.0973	0.3075
				1.2500	5.0013	4.6100	1.0849	0.2986
				1.5000	5.8783	5.4695	1.0747	0.2928
			0.500	1.0000	4.1436	3.7771	1.0971	0.3073
				1.2500	5.0128	4.6212	1.0847	0.2985
				1.5000	5.8879	5.4790	1.0746	0.2927
			1.000	1.0000	4.1952	3.8268	1.0963	0.3067
				1.2500	5.0545	4.6619	1.0842	0.2982
				1.5000	5.9229	5.5134	1.0743	0.2925
			1.500	1.0000	4.2795	3.9082	1.0950	0.3056
				1.2500	5.1231	4.7290	1.0833	0.2976
				1.5000	5.9006	5.5702	1.0737	0.2922
			2.389	1.0000	4.3034	4.1252	1.0917	0.3031
				1.2500	5.3079	4.9098	1.0811	0.2963
				1.5000	6.1374	5.7245	1.0721	0.2914

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A<sub>i</sub>  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
790.50	0.5300	1.3400	0.212	1.0000	3.2357	2.8990	1.1162	0.2410
				1.2500	3.8814	3.5149	1.1043	0.2317
				1.5000	4.5326	4.1451	1.0935	0.2258
	0.500	1.000	1.500	1.0000	3.2462	2.9089	1.1160	0.2408
				1.2500	3.8900	3.5230	1.1041	0.2316
				1.5000	4.5398	4.1521	1.0934	0.2257
	1.000	2.389	1.000	1.0000	3.2843	2.9449	1.1153	0.2401
				1.2500	3.9209	3.5528	1.1036	0.2313
				1.5000	4.5658	4.1774	1.0930	0.2255
	1.500	2.389	1.500	1.0000	3.3467	3.0039	1.1141	0.2390
				1.2500	3.9718	3.6019	1.1027	0.2307
				1.5000	4.6087	4.2192	1.0923	0.2252
	2.389	2.389	2.389	1.0000	3.5124	3.1614	1.1110	0.2364
				1.2500	4.1090	3.7343	1.1003	0.2294
				1.5000	4.7252	4.3327	1.0906	0.2244

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-A1  
FUEL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
918.00	2.3000	0.9800	0.212	1.0000	12.0208	11.5528	1.0405	0.8952
				1.2500	14.8916	14.4173	1.0329	0.8890
				1.5000	17.7639	17.2853	1.0277	0.8848
			0.500	1.0000	12.0677	11.5997	1.0404	0.8950
				1.2500	14.9292	14.4549	1.0328	0.8890
				1.5000	17.7952	17.3166	1.0276	0.8847
			1.000	1.0000	12.2380	11.7695	1.0398	0.8946
				1.2500	15.0661	14.5915	1.0325	0.8887
				1.5000	17.9096	17.4308	1.0275	0.8846
			1.500	1.0000	12.5163	12.0471	1.0390	0.8939
				1.2500	15.2913	14.8163	1.0321	0.8883
				1.5000	18.0984	17.6195	1.0272	0.8844
			2.389	1.0000	13.2547	12.7837	1.0368	0.8922
				1.2500	15.8972	15.4212	1.0309	0.8874
				1.5000	18.6106	18.1310	1.0265	0.8837
899.50	2.0200	1.0200	0.212	1.0000	10.6219	10.1594	1.0455	0.7910
				1.2500	13.1426	12.6726	1.0371	0.7846
				1.5000	15.6646	15.1897	1.0313	0.7802
			0.500	1.0000	10.6632	10.2005	1.0454	0.7909
				1.2500	13.1756	12.7055	1.0370	0.7845
				1.5000	15.6922	15.2172	1.0312	0.7802
			1.000	1.0000	10.8126	10.3494	1.0448	0.7904
				1.2500	13.2957	12.8254	1.0367	0.7843
				1.5000	15.7926	15.3174	1.0310	0.7800
			1.500	1.0000	11.0570	10.5930	1.0438	0.7897
				1.2500	13.4935	13.0227	1.0362	0.7839
				1.5000	15.9584	15.4830	1.0307	0.7798
			2.389	1.0000	11.7053	11.2391	1.0415	0.7879
				1.2500	14.0255	13.5536	1.0348	0.7829
				1.5000	16.4082	15.9321	1.0299	0.7792
860.00	1.1400	0.9400	0.212	1.0000	6.2245	5.7870	1.0756	0.4635
				1.2500	7.6446	7.1948	1.0625	0.4564
				1.5000	9.0663	8.6082	1.0532	0.4516
			0.500	1.0000	6.2477	5.8100	1.0753	0.4634
				1.2500	7.6632	7.2133	1.0624	0.4563
				1.5000	9.0819	8.6237	1.0531	0.4515
			1.000	1.0000	6.3319	5.8933	1.0744	0.4629
				1.2500	7.7309	7.2805	1.0619	0.4560
				1.5000	9.1385	8.6800	1.0528	0.4514
			1.500	1.0000	6.4695	6.0295	1.0730	0.4621
				1.2500	7.8424	7.3913	1.0610	0.4556
				1.5000	9.2320	8.7731	1.0523	0.4511
			2.389	1.0000	6.8347	6.3913	1.0694	0.4601
				1.2500	8.1422	7.6892	1.0589	0.4545
				1.5000	9.4856	9.0256	1.0510	0.4504

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-Ai  
FUEL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (H/L)	ASPECT (H/D)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
841.00	0.9700	0.8800	0.212	1.0000	5.3743	4.9445	1.0869	0.4002
				1.2500	6.5819	6.1384	1.0723	0.3929
				1.5000	7.7912	7.3384	1.0617	0.3881
			0.500	1.0000	5.3940	4.9640	1.0866	0.4001
				1.2500	6.5978	6.1541	1.0721	0.3929
				1.5000	7.8044	7.3515	1.0616	0.3880
			1.000	1.0000	5.4656	5.0346	1.0856	0.3995
				1.2500	6.6554	6.2112	1.0715	0.3926
				1.5000	7.8526	7.3993	1.0613	0.3879
			1.500	1.0000	5.5826	5.1501	1.0840	0.3987
				1.2500	6.7502	6.3051	1.0706	0.3921
				1.5000	7.9321	7.4784	1.0607	0.3876
			2.389	1.0000	5.8932	5.4567	1.0800	0.3967
				1.2500	7.0052	6.5580	1.0682	0.3910
				1.5000	8.1478	7.6928	1.0591	0.3869
825.00	0.8400	0.8400	0.212	1.0000	4.7247	4.3033	1.0979	0.3518
				1.2500	5.7698	5.3330	1.0819	0.3445
				1.5000	6.8165	6.3693	1.0702	0.3395
			0.500	1.0000	4.7418	4.3200	1.0976	0.3517
				1.2500	5.7835	5.3465	1.0817	0.3444
				1.5000	6.8279	6.3807	1.0701	0.3395
			1.000	1.0000	4.8037	4.3809	1.0965	0.3512
				1.2500	5.8333	5.3958	1.0811	0.3441
				1.5000	6.8696	6.4220	1.0697	0.3393
			1.500	1.0000	4.9050	4.4804	1.0948	0.3503
				1.2500	5.9154	5.4769	1.0801	0.3437
				1.5000	6.9385	6.4903	1.0691	0.3390
			2.389	1.0000	5.1737	4.7448	1.0904	0.3483
				1.2500	6.1361	5.6953	1.0774	0.3425
				1.5000	7.1252	6.6756	1.0674	0.3383
810.50	0.7200	0.7600	0.212	1.0000	4.1232	3.7091	1.1116	0.3070
				1.2500	5.0186	4.5878	1.0939	0.2996
				1.5000	5.9155	5.4734	1.0808	0.2946
			0.500	1.0000	4.1379	3.7234	1.1113	0.3069
				1.2500	5.0303	4.5993	1.0937	0.2995
				1.5000	5.9253	5.4831	1.0807	0.2946
			1.000	1.0000	4.1909	3.7753	1.1101	0.3064
				1.2500	5.0731	4.6414	1.0930	0.2993
				1.5000	5.9610	5.5184	1.0802	0.2944
			1.500	1.0000	4.2777	3.8602	1.1082	0.3055
				1.2500	5.1434	4.7107	1.0918	0.2988
				1.5000	6.0200	5.5768	1.0795	0.2942
			2.389	1.0000	4.5079	4.0857	1.1033	0.3034
				1.2500	5.3325	4.8973	1.0889	0.2977
				1.5000	6.1801	5.7352	1.0776	0.2935

TABLE 2  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASES L-Ai

NOTES:

1. ACCEL(HOR.): Peak horizontal spectral acceleration
2. ACCEL(VER.): Peak vertical spectral acceleration
3. ASPECT(H/L): Ratio of frame height to width
4. ASPECT(H/D): Slope of longitudinal brace
5. RAE(EXACT): Reaction for a unit load using the 'EXACT' Method of Seismic Load Combination
6. RAS(SIMP.): Reaction for a unit load using the 'SIMPLIFIED' Method of Seismic Load Combination
7. RATIO(RAE/RAS): Ratio of reactions from 'EXACT' and 'SIMPLIFIED' Methods
8. RAD: Reaction for a unit load using the 'SIMPLIFIED' Method with the design acceleration values of 2.67g horizontal and 1.67g vertical
9. RATIO(RAE/RAD): Ratio of reaction of 'EXACT' Method to the deisgn reactions

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
SAFEQUARDS BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
896.50	2.2830	1.5000	0.4000	1.6896	1.5176	1.1133	0.9883
			0.8000	2.4562	2.3028	1.0666	0.9751
			1.0000	2.8849	2.7483	1.0497	0.9664
			2.0000	5.2098	5.1286	1.0158	0.9465
			3.0000	7.6425	7.5864	1.0074	0.9411
			4.0000	10.1076	10.0649	1.0042	0.9391
873.50	2.0790	1.6370	5.2500	13.2073	13.1745	1.0025	0.9380
			0.4000	1.6285	1.4809	1.0997	0.9526
			0.8000	2.4720	2.3518	1.0511	0.9814
			1.0000	2.9392	2.8345	1.0369	0.9846
			2.0000	5.4351	5.3755	1.0111	0.9874
			3.0000	8.0198	7.9790	1.0051	0.9876
852.50	1.6050	1.4580	4.0000	10.6300	10.5991	1.0029	0.9876
			5.2500	13.9069	13.8832	1.0017	0.9876
			0.4000	1.3920	1.2691	1.0968	0.8142
			0.8000	2.2158	2.1238	1.0433	0.8797
			1.0000	2.6643	2.5857	1.0304	0.8925
			2.0000	5.0244	4.9811	1.0087	0.9128
831.50	1.1410	1.3000	3.0000	7.4470	7.4175	1.0040	0.9171
			4.0000	9.8870	9.8647	1.0023	0.9186
			5.2500	12.9465	12.9294	1.0013	0.9194
			0.4000	1.1719	1.0825	1.0826	0.6855
			0.8000	1.9862	1.9264	1.0310	0.7885
			1.0000	2.4197	2.3697	1.0211	0.8106
810.50	0.7010	1.2600	2.0000	4.6619	4.6352	1.0057	0.8469
			3.0000	6.9415	6.9235	1.0026	0.8548
			4.0000	9.2312	9.2177	1.0015	0.8577
			5.2500	12.0988	12.0885	1.0009	0.8592
			0.4000	1.0139	0.9696	1.0457	0.5930
			0.8000	1.8672	1.8417	1.0139	0.7413
790.50	0.4290	1.0490	1.0000	2.3078	2.2870	1.0091	0.7731
			2.0000	4.5443	4.5336	1.0024	0.8256
			3.0000	6.7962	6.7891	1.0011	0.8369
			4.0000	9.0522	9.0468	1.0006	0.8410
			5.2500	11.8743	11.8702	1.0003	0.8433
			0.4000	0.8712	0.8472	1.0284	0.5096
			0.8000	1.6662	1.6532	1.0079	0.6615
			1.0000	2.0707	2.0602	1.0051	0.6937
			2.0000	4.1089	4.1036	1.0013	0.7465
			3.0000	6.1543	6.1507	1.0006	0.7579
			4.0000	8.2015	8.1988	1.0003	0.7620
			5.2500	10.7614	10.7594	1.0002	0.7643

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
SAFEQUARDS BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
785.50	0.3920	1.0170	0.4000	0.8516	0.8303	1.0256	0.4981
			0.8000	1.6369	1.6255	1.0070	0.6498
			1.0000	2.0357	2.0265	1.0045	0.6819
			2.0000	4.0434	4.0388	1.0012	0.7346
			3.0000	6.0573	6.0542	1.0005	0.7459
			4.0000	8.0727	8.0704	1.0003	0.7500
			5.2500	10.5928	10.5911	1.0002	0.7523
773.50	0.3270	0.9490	0.4000	0.8133	0.7966	1.0210	0.4757
			0.8000	1.5766	1.5677	1.0056	0.6259
			1.0000	1.9630	1.9558	1.0036	0.6576
			2.0000	3.9050	3.9014	1.0009	0.7094
			3.0000	5.8517	5.8493	1.0004	0.7206
			4.0000	7.7995	7.7977	1.0002	0.7247
			5.2500	10.2349	10.2336	1.0001	0.7269

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
ELECTRICAL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
873.33	1.7900	1.3200	0.4000	1.4391	1.2893	1.1162	0.8418
			0.8000	2.1843	2.0605	1.0600	0.8672
			1.0000	2.5948	2.4866	1.0435	0.8692
			2.0000	4.7876	4.7255	1.0131	0.8698
			3.0000	7.0599	7.0173	1.0061	0.8694
			4.0000	9.3553	9.3231	1.0035	0.8692
854.33	1.5700	1.3100	0.4000	1.3438	1.2124	1.1084	0.7860
			0.8000	2.1094	2.0078	1.0506	0.8374
			1.0000	2.5272	2.4397	1.0358	0.8466
			2.0000	4.7351	4.6862	1.0104	0.8602
			3.0000	7.0076	6.9743	1.0048	0.8630
			4.0000	9.2985	9.2733	1.0027	0.8639
830.00	1.1100	1.2200	0.4000	1.1390	1.0472	1.0877	0.6662
			0.8000	1.9228	1.8607	1.0334	0.7633
			1.0000	2.3403	2.2883	1.0227	0.7840
			2.0000	4.5023	4.4746	1.0062	0.8180
			3.0000	6.7018	6.6831	1.0028	0.8253
			4.0000	8.9115	8.8973	1.0016	0.8280
807.00	0.7200	1.2600	0.4000	1.0194	0.9730	1.0476	0.5962
			0.8000	1.8704	1.8435	1.0146	0.7425
			1.0000	2.3104	2.2885	1.0096	0.7740
			2.0000	4.5456	4.5343	1.0025	0.8258
			3.0000	6.7971	6.7895	1.0011	0.8370
			4.0000	9.0528	9.0472	1.0006	0.8411
778.00	0.5100	1.2600	0.4000	0.9648	0.9393	1.0272	0.5644
			0.8000	1.8398	1.8259	1.0076	0.7304
			1.0000	2.2855	2.2743	1.0049	0.7656
			2.0000	4.5329	4.5272	1.0013	0.8235
			3.0000	6.7886	6.7848	1.0006	0.8360
			4.0000	9.0464	9.0436	1.0003	0.8405
			5.2500	11.8699	11.8677	1.0002	0.8430

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
899.50	2.6600	1.7100	0.4000	1.8956	1.7158	1.1048	1.1088
			0.8000	2.7080	2.5434	1.0647	1.0751
			1.0000	3.1663	3.0188	1.0489	1.0607
			2.0000	5.6695	5.5808	1.0159	1.0300
			3.0000	8.2996	8.2381	1.0075	1.0221
			4.0000	10.9681	10.9213	1.0043	1.0190
			5.2500	14.3255	14.2895	1.0025	1.0174
886.50	2.3200	1.6300	0.4000	1.7307	1.5660	1.1052	1.0123
			0.8000	2.5453	2.4026	1.0594	1.0105
			1.0000	3.0006	2.8745	1.0439	1.0052
			2.0000	5.4602	5.3864	1.0137	0.9920
			3.0000	8.0257	7.9748	1.0064	0.9883
			4.0000	10.6224	10.5838	1.0036	0.9869
			5.2500	13.8858	13.8561	1.0021	0.9861
873.50	1.9800	1.6600	0.4000	1.5921	1.4533	1.0954	0.9312
			0.8000	2.4564	2.3470	1.0466	0.9752
			1.0000	2.9328	2.8383	1.0333	0.9825
			2.0000	5.4645	5.4113	1.0098	0.9928
			3.0000	8.0774	8.0412	1.0045	0.9947
			4.0000	10.7134	10.6860	1.0026	0.9954
			5.2500	14.0210	14.0000	1.0015	0.9957
852.50	1.6600	1.6400	0.4000	1.4579	1.3431	1.0855	0.8528
			0.8000	2.3525	2.2692	1.0367	0.9339
			1.0000	2.8381	2.7674	1.0255	0.9507
			2.0000	5.3834	5.3448	1.0072	0.9780
			3.0000	7.9895	7.9634	1.0033	0.9839
			4.0000	10.6123	10.5926	1.0019	0.9860
			5.2500	13.8999	13.8848	1.0011	0.9871
831.50	1.2200	1.5800	0.4000	1.2784	1.1988	1.0664	0.7477
			0.8000	2.2035	2.1523	1.0238	0.8748
			1.0000	2.6937	2.6511	1.0160	0.9024
			2.0000	5.2183	5.1959	1.0043	0.9480
			3.0000	7.7791	7.7640	1.0019	0.9580
			4.0000	10.3494	10.3380	1.0011	0.9616
			5.2500	13.5674	13.5587	1.0006	0.9635
810.50	0.7100	1.4800	0.4000	1.0903	1.0536	1.0348	0.6377
			0.8000	2.0361	2.0155	1.0102	0.8083
			1.0000	2.5220	2.5053	1.0067	0.8448
			2.0000	4.9812	4.9727	1.0017	0.9050
			3.0000	7.4542	7.4485	1.0008	0.9179
			4.0000	9.9306	9.9263	1.0004	0.9227
			5.2500	13.0281	13.0248	1.0003	0.9252

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
AUXILIARY BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
790.50	0.5300	1.3400	0.4000	0.9979	0.9728	1.0258	0.5837
			0.8000	1.9043	1.8907	1.0072	0.7560
			1.0000	2.3660	2.3550	1.0047	0.7926
			2.0000	4.6931	4.6875	1.0012	0.8526
			3.0000	7.0287	7.0250	1.0005	0.8656
			4.0000	9.3565	9.3638	1.0003	0.8702
			5.2500	12.2900	12.2879	1.0002	0.8728

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7  
FUEL BUILDING ACCELERATIONS

ELEV. (FT.)	ACCEL. (HOR.)	ACCEL. (VER.)	ASPECT (L/B)	RAE (EXACT)	RAS (SIMP.)	RATIO (RAE/RAS)	RATIO (RAE/RAD)
918.00	2.3000	0.9800	0.4000	1.6150	1.3963	1.1566	0.9446
			0.8000	2.1918	1.9574	1.1197	0.8702
			1.0000	2.5109	2.2897	1.0966	0.8411
			2.0000	4.2725	4.1236	1.0361	0.7762
			3.0000	6.1569	6.0503	1.0176	0.7582
			4.0000	8.0852	8.0031	1.0103	0.7512
899.50	2.0200	1.0200	0.4000	1.4893	1.2934	1.1514	0.8711
			0.8000	2.0984	1.9057	1.1012	0.8331
			1.0000	2.4354	2.2584	1.0784	0.8157
			2.0000	4.2763	4.1643	1.0269	0.7769
			3.0000	6.2224	6.1436	1.0128	0.7663
			4.0000	8.2032	8.1429	1.0074	0.7622
860.00	1.1400	0.9400	0.4000	1.0828	0.9628	1.1246	0.6334
			0.8000	1.7436	1.6534	1.0546	0.6922
			1.0000	2.0993	2.0220	1.0382	0.7033
			2.0000	3.9645	3.9216	1.0109	0.7203
			3.0000	5.8770	5.8478	1.0050	0.7237
			4.0000	7.8030	7.7809	1.0028	0.7250
841.00	0.9700	0.8800	0.4000	0.7993	0.8948	1.1167	0.5845
			0.8000	1.6549	1.5803	1.0472	0.6570
			1.0000	2.0048	1.9416	1.0326	0.6716
			2.0000	3.8256	3.7912	1.0091	0.6950
			3.0000	5.6842	5.6608	1.0041	0.7000
			4.0000	7.5533	7.5356	1.0023	0.7018
825.00	0.8400	0.8400	0.4000	0.9379	0.8474	1.1067	0.5486
			0.8000	1.5925	1.5307	1.0403	0.6322
			1.0000	1.9391	1.8873	1.0275	0.6496
			2.0000	3.7317	3.7039	1.0075	0.6780
			3.0000	5.5548	5.5360	1.0034	0.6840
			4.0000	7.3861	7.3720	1.0019	0.6862
810.50	0.7200	0.7600	0.4000	0.8712	0.7907	1.1018	0.5096
			0.8000	1.5066	1.4533	1.0367	0.5981
			1.0000	1.8410	1.7964	1.0248	0.6167
			2.0000	3.5620	3.5384	1.0067	0.6471
			3.0000	5.3082	5.2923	1.0030	0.6537
			4.0000	7.0612	7.0492	1.0017	0.6561
			5.2500	9.2562	9.2470	1.0010	0.6574

TABLE 3  
COMPARISON OF SIMPLIFIED AND EXACT METHODS OF SEISMIC LOAD COMBINATION  
FOR HANGER CASE SP-7

NOTES:

1. ACCEL(HOR.): Peak horizontal spectral acceleration
2. ACCEL(VER.): Peak vertical spectral acceleration
3. ASPECT(H/L): Ratio of frame height to width
4. RAE(EXACT): Reaction for a unit load using the 'EXACT' Method of Seismic Load Combination
5. RAS(SIMP.): Reaction for a unit load using the 'SIMPLIFIED' Method of Seismic Load Combination
6. RATIO(RAE/RAS): Ratio of reactions from 'EXACT' and 'SIMPLIFIED' Methods
7. RAD: Reaction for a unit load using the 'SIMPLIFIED' Method with the design acceleration values of 2.67g horizontal and 1.67g vertical
8. RATIO(RAE/RAD): Ratio of reaction of 'EXACT' Method to the design reactions