



State of New Jersey
Department of Environmental Protection and Energy
Division of Environmental Safety, Health and Analytical Programs
CN 415
Trenton, NJ 08625-0415

Scott A. Weiner
Commissioner

May 7, 1992

Gerald P. Nicholls, Ph.D.
Director

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Technical Specification Change Request No. 207
Standby Liquid Control System Surveillance Change

On March 27, 1992, GPU Nuclear Corporation, licensee of the Oyster Creek Nuclear Generating Station, submitted the subject amendment to the Nuclear Regulatory Commission (NRC). This Technical Specification Change Request (TSCR) proposes to change the surveillance interval of the Standby Liquid Control System to once every 24 months.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) reviewed the above amendment in accordance with the requirements of 10CFR50.91(b). Based on this review, the BNE does not have any comments on the proposed license change request.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Chris Dell at (609)-987-2086.

Sincerely,

Kent W. Tosch
Kent Tosch, Chief
Bureau of Nuclear Engineering

c: Jill Lipoti
Assistant Director, Radiation Protection Programs
N.J. DEP&E

A. Dromerick
Sr. Project Manager
U.S. NRC

J. Knuble, GPU Nuclear Corporation

ADOCK 1/0