

**CAROLINA POWER & LIGHT COMPANY  
NUCLEAR ENGINEERING & LICENSING  
DEPARTMENT**

**REPORT**

**AUXILIARY ELECTRICAL  
DISTRIBUTION SYSTEM STUDY  
FOR  
BRUNSWICK STEAM ELECTRIC PLANT  
UNITS NO. 1 & 2**

8409060335 840830  
PDR ADOCK 05000324  
P PDR

CAROLINA POWER & LIGHT COMPANY  
P. O. BOX 1551  
RALEIGH, North Carolina 27602

ANALYSIS  
FOR  
4160V AND 480V  
AUXILIARY ELECTRICAL DISTRIBUTION SYSTEM  
For  
BRUNSWICK STEAM ELECTRIC PLANT  
UNITS 1 and 2

SAFETY CLASSIFICATION: NUCLEAR SAFETY RELATED  
SEISMIC CLASSIFICATION: N/A

Rev.	Prepared By/ Date	Verified By/ Date	Project Eng/ Date	Princ Eng./ Date	Pages Affected
0	A. Benge 5/25/84	J. A. Kowalechuk 6/4/84	W. K. Russell 6/4/84	William W. Prich 6/5/84	ALL

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
i	0
ii	0
iii	0
1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0
17	0
18	0
19	0
20	0
21	0
A1	0
A2	0
A3	0
A4	0
B1	0
B2	0
B3	0
C1	0
C2	0
C3	0
D1	0
D2	0
D3	0

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
E1	0
E2	0
E3	0
E4	0
E5	0
E6	0
E7	0
E8	0
E9	0
E10	0
E11	0
E12	0
E13	0
E14	0
E15	0
E16	0
E17	0
E18	0
E19	0
E20	0
E21	0
E22	0
E23	0
E24	0
E25	0
E26	0
E27	0
E28	0
E29	0
E30	0
E31	0
E32	0
E33	0
E34	0
E35	0
E36	0
E37	0
E38	0
E39	0
E40	0
E41	0
E42	0
E43	0
E44	0
E54	0
E46	0

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
E47	0
E48	0
E49	0
E50	0
E51	0
E52	0
E53	0
E54	0
E55	0
E56	0
E57	0
E58	0
E59	0
F1	0
F2	0
F3	0
F4	0
F5	0
F6	0
F7	0
F8	0
F9	0
F10	0
F11	0
F12	0
F13	0
F14	0
F15	0
F16	0
F17	0
F18	0
F19	0
F20	0
F21	0
F22	0
F23	0
F24	0
F25	0
F26	0
F27	0
F28	0
F29	0
F30	0
F31	0
F32	0

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
F33	0
F34	0
G1	0
G2	0
G3	0
G4	0
G5	0
G6	0
G7	0
G8	0
G9	0
G10	0
G11	0
G12	0
G13	0
G14	0
G15	0
G16	0
G17	0
G18	0
G19	0
G20	0
G21	0
G22	0
G23	0
G24	0
G25	0
G26	0
G27	0
G28	0
G29	0
G30	0
G31	0
G32	0
G33	0
G34	0
G35	0
G36	0
G37	0
G38	0
G39	0
G40	0
G41	0
G42	0
G43	0

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
G44	0
G45	0
G46	0
G47	0
G48	0
G49	0
G50	0
G51	0
G52	0
G53	0
G54	0
G55	0
G56	0
G57	0
G58	0
G59	0
G60	0
G61	0
G62	0
G63	0
G64	0
G65	0
G66	0
G67	0
G68	0
G69	0
G70	0
G71	0
G72	0
G73	0
G74	0
G75	0
G76	0
G77	0
G78	0
G79	0
G80	0
G81	0
G82	0
G83	0
G84	0
G85	0
G86	0
G87	0
G88	0
G89	0

## LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Rev.</u>
G90	0
G91	0
G92	0
G93	0
G94	0
G95	0
G96	0
G97	0
G98	0
G99	0
G100	0
G101	0
G102	0
G103	0
G104	0
G105	0
G106	0
G107	0
G108	0
G109	0
G110	0
C111	0
G112	0
G113	0
G114	0
G115	0
G116	0



## TABLE OF CONTENTS

	<u>Page</u>	
1.0	PURPOSE	1
2.0	SUMMARY OF RESULTS	1
3.0	METHOD OF ANALYSIS	2
3.1	Computer Programs	2
3.2	Equipment Voltage Criteria	2
3.3	Plant Operating Conditions	3
3.4	Development of Auxiliary System Models	4
3.4.1	Basis for Model Development	5
3.4.2	System Conditions and Cases Modeled	6
4.0	STUDY RESULTS	11
4.1	Source Voltage Limits	11
4.2	Safety Bus Voltages with Expected Source Voltage	15
4.3	Comparison of Relay Settings to Steady State and Motor Starting Transient Voltages	15
4.4	Non-Safety Auxiliary System Voltages	15
5.0	CONCLUSIONS AND RECOMMENDATIONS	17
6.0	REFERENCES	21
7.0	APPENDIX A - ACCIDENT SCENARIO CONSIDERATIONS	A1
8.0	APPENDIX B - SOURCE VOLTAGE CONSIDERATIONS	B1
9.0	APPENDIX C - VOLTAGE CRITERIA	C1
10.0	APPENDIX D - AUXILIARY SYSTEM RELAYS	D1
11.0	APPENDIX E - AUXILIARY SYSTEM MODEL ONE-LINES	E1
12.0	APPENDIX F - MOTOR ACCELERATION TIMES AND RELAY CHARACTERISTICS	F1
13.0	APPENDIX G - DETERMINATION OF SOURCE VOLTAGE LIMITS	G1
14.0	APPENDIX H - ASDOP INPUTS AND OUTPUTS (Contained in Separate Volume)	H1

## 1.0 PURPOSE

The purpose of this study is to perform all electrical distribution system analyses for BSEP Units 1 and 2 necessary to demonstrate the adequacy of the 4160V and 480VAC Systems to supply safety loads during normal and emergency conditions in accordance with NRC guidelines in reference 7. This is achieved by:

1. Identification of the voltage requirements of the auxiliary electrical distribution system and equipment under various plant operating conditions. From the voltage requirements, establish distribution system voltage criteria which will assure adequate voltage at all loads.
2. Definition of the modes (cases) of plant operation requiring analysis in order to demonstrate electrical distribution system adequacy per NRC Guidelines.
3. Modeling and completing an analysis for the above cases. For each case, a source voltage (switchyard or generator) limit was determined. The expected source voltage must be within the limits established by analysis to meet the distribution system voltage criteria.
4. Comparison of the source voltage limits with the expected values of the source voltage. Examine in greater detail those cases where the criteria are not met to determine if the voltages at the loads are adequate. If voltages are not adequate, identify the changes necessary to provide adequate voltage at the loads.

## 2.0 SUMMARY OF RESULTS

Voltage drop studies have shown that the existing BSEP Electrical Distribution System can support all 4160V and 480VAC safety loads in accordance with present NRC guidelines for determining the adequacy of station electrical distribution system voltage.

A tap change from -2.5% to -5% is recommended on Unit Substation Common C to maintain adequate voltage on the nonsafety system.

### 3.0 METHOD OF ANALYSIS

#### 3.1 Computer Programs

Voltage-drop studies for the BSEP auxiliary electrical distribution system were done using ASDOP (Auxiliary System Design Optimization Program). Aggregate load models were developed to represent the Unit Nos. 1 and 2 auxiliary systems under various postulated plant conditions. The plant conditions modeled include normal and accident plant conditions. For a detailed description of each of the models used, see Section 3.4. A CP&L procedure entitled "CP&L Benchmark Procedure for Auxiliary System Design Optimization Program (ASDOP)" dated 04/05/84 compared actual field test data with ASDOP calculated values.

The Transmission Planning Unit of the Transmission Department supplied the expected or actual 230 KV switchyard voltage values in addition to study results of how transmission grid conditions can be controlled to provide optimum switchyard voltage levels. These studies were run using the POWERFLO computer program.

#### 3.2 Equipment Voltage Criteria

The operating voltage requirements of all equipment fed from the auxiliary electrical distribution system collectively impose restrictions on the allowable voltage range of the auxiliary system source-of-feed. The auxiliary system voltage criteria, therefore, must conform to the equipment operating requirements but also be broad enough to allow for expected voltage fluctuations at the source - either the generator bus or the 230 KV switchyard bus.

A major consideration is to ensure that motors have sufficient terminal voltage to start and continue running. Since 4000-volt motors can, without stalling, ride through a transient voltage dip that is less than the minimum starting voltage, the limiting condition is to maintain sufficient voltage to start the motors. For Class 1E motors, the minimum starting voltage is 0.75 p.u. (3000 volts) for motors specified by UE&C and 0.70 p.u. (2800 volts) for motors specified by General Electric. The primary concern relative to the starting of large BOP (Balance of Plant) motors is that the voltage drop resulting from the motor start does not prevent safety loads from starting and running as designed. A secondary consideration is that the BOP motor maintain sufficient terminal voltage to start and run. The minimum terminal voltage required for starting will vary from motor to motor, depending

upon individual torque characteristics of the motor and load. For purposes of this study, the minimum starting voltage for BOP motors is assumed to be 0.85 p.u. for both 4000 and 460V motors (Reference 9). If in individual cases motor terminal voltage drops below .85 p.u., those cases are examined to determine if adequate starting voltage is applied at the motor terminals. A tabulation of all motor starting and running voltage criteria can be found in Appendix C.

In addition to the 391 volts (0.85 p.u. on 460 volt base), minimum required for 460 volt motor starting, a minimum of 408 volts (0.85 p.u. on 480-volt base) is required at the MCC in order to pick up the motor contactors. In addition to motor starting considerations, sufficient voltage must be maintained (at the 480-volt level) to ensure that 460-volt motors will continue running during a transient voltage drop caused by the starting of a large 4000-volt motor. The voltage at the MCC must not drop below 336 volts (0.70 p.u. on 480 V base), which is the voltage required to ensure the motor contactor will not drop out.

It is also important to consider motor running voltage limitations necessary to prevent overheating and the resultant reduction in motor life. To maximize motor life, the terminal voltage needs to be maintained between 0.90 p.u. and 1.10 p.u. of rated voltage. This applies to both 4000 volt and 460 volt motors. The reduction in motor life that occurs when operating at voltages outside of this range becomes significant only if the over or undervoltage is maintained for an extended period. Therefore, only for those plant operating conditions that are expected to occur for a substantial portion of the forty-year plant life, is the 0.90 p.u. to 1.10 p.u. motor terminal voltage range considered in determining source voltage limits. For accident-related conditions, the running voltage limitation at MCC buses is 0.85 p.u. to 1.10 p.u.

Another consideration is the set point of undervoltage relays. Relay settings must be examined relative to the steady state and transient voltages expected to occur on the auxiliary system. When the voltage dips below the relay set point during motor starting, voltages must recover above the relay reset point in time to prevent the relay from tripping. Thus relevant relay settings are included in the voltage criteria in Appendix C. Appendix D also lists the undervoltage relays on the auxiliary system, relay settings and relay function.

### 3.3 Plant Operating Conditions

In evaluating the ability of the electrical distribution system to support auxiliary system safety loads, the equipment

voltage criteria must be examined relative to the operating conditions expected to occur. By imposing the equipment voltage criteria to a particular operating condition, a source "voltage limit" is established. By selecting a set of operating conditions that establish the most restrictive voltage limits a "worst case" source voltage limit is defined. By comparison of the worst case minimum and maximum voltage limits with the expected values, the adequacy of the source voltage can be determined.

In this study, four operating conditions were selected for analysis. They are: Normal Power Operation, LOCA Start, LOCA Run and Light Load. Expected source voltages and source voltage limits will be different for each condition, and examination of all four is required to verify the adequacy of the distribution system's voltage regulation performance. For each of the four conditions, power may be supplied from the 230KV Switchyard, via the Startup Auxiliary Transformer (SAT). Power can be supplied from the generator bus via the Unit Auxiliary Transformer (UAT) only for the Normal Power Operation and the Light Load (during power operation) conditions.

The accident scenario used in this analysis considers NRC guidelines and actual conditions which are likely to occur at the plant. A scenario based solely on NRC guidelines would consider a LOCA on one unit with the other unit (Also Operating) proceeding to an orderly shutdown. At BSEP "worse case" voltage levels would occur if a LOCA occurred on one unit with the other unit shutdown. Thus the latter scenario is used in this analysis. The accident scenario is discussed in greater detail in Appendix A.

#### 3.4 Development Of Auxiliary System Models

Load models for the BSEP Unit Nos. 1 & 2 auxiliary electrical distribution system were developed to represent each of the plant conditions described in Section 3.3. These load models were integrated into ASDOP, and voltage-drop cases were run, which provided the information necessary to analyze the adequacy of the electrical distribution system.

With the exception of the light-load cases ("SAT Shutdown" and "UAT Light Load"), each of the models were developed to represent the auxiliary system with the tie breaker between 4160V buses Common A and Common B closed. This tie breaker is not under administrative clearance, and if closed, would increase the auxiliary system load, which would cause an increased voltage drop. Thus, using a

load model that represents the Common A-Common B tie breaker closed provides "worst-case" voltage-drop information. The tie breaker is open for the light load cases to represent the minimum load on the auxiliary system. The Common Buses are always fed from the SAT, so those buses and the loads they feed are not included in the UAT models.

### 3.4.1 Basis for Model Development

All of the motor-starting models and the accident models were derived from a basic full-load model ("SAT Full Load"). This full load model was developed by identifying all of the 4160-volt loads that would normally be running when the unit is operating at full power.

The 480-volt loads were modeled as an aggregate at each Motor Control Center except for those motors being started. For the 460-volt motors, the KVA supplied was assumed to be equal to the rated horsepower where motor full load current was not known. This assumption has proved to be accurate for motors rated at 250 horsepower or less. Since all 480-volt loads would not be running at any one time, load factors were used to approximate the running load at each 480-volt bus. The load factor applied to each load was based upon the load being classified as one of the following:

<u>Operation</u>	<u>Load Factor</u>
Back-up	0.00
Battery Charger	0.50
Continuous Loads	1.00
Fans	1.00
Heater Load	0.50
Intermittent Loads	0.50
Lighting Transformer	0.75
Power Panelboard	0.50
Rotated	Variable*
Shutdown or Startup Only	0.00
Valve Motor	0.10
Welding Feeders	0.00

- \* For 2 out of 3 rotation, the minimum load factor shall be  $2/3=0.67$ .  
If the load is large enough to significantly affect bus loading, a load factor of 1.00 was assigned.

### 3.4.2 System Conditions and Cases Modeled

One lines of the auxiliary system models described in the following sections may be found in Appendix E.

#### 3.4.2.1 Full-Load Model

Cases were developed for normal unit operation with the auxiliary system operating under normal full load conditions. The models were developed for both the Startup Auxiliary Transformer (SAT) and Unit Auxiliary Transformer (UAT) aligned to supply the Auxiliary System. Transient conditions are analyzed using the normal unit operation model by starting various distinctly modeled motors on the 4160V and 480V Systems. The steady state and motor start cases were developed to demonstrate that adequate voltages are maintained on the safety system during normal plant operation. The SAT alignment cases are used along with the voltage criteria to establish a minimum switchyard voltage limit during normal operations. The UAT cases were used along with the auxiliary system voltage criteria to establish a minimum generator voltage limit during normal operation. The SAT and UAT alignment cases are described below:

##### A. Startup Auxiliary Transformer Supplying the Load

###### CASE SAT1: SAT FULL LOAD

This case was modeled to represent auxiliary system with full auxiliary load fed from the SAT and the tie breaker between 4160V buses Common A and Common B closed.

###### CASE SAT3: SAT - 3rd CWP MOTOR START

This case was modeled to represent the auxiliary system load when starting a third 2500 hp CWP motor (2 CWP motors running) with full auxiliary load fed from the SAT and the breaker between buses Common A and Common B closed. The CWP with the longest feeder cable was started.

###### CASE SAT4: SAT - 4th CWP MOTOR START

This case was modeled to represent the auxiliary system load when starting a fourth 2500 hp Circulating Water Pump motor (3 CWP motors running) with full auxiliary load fed from the SAT and the tie breaker between buses Common A and Common B closed. The CWP with the longest feeder cable was started.

CASE SAT5: SAT - FUEL POOL COOLING PUMP MOTOR START @ 1XG (2XG)

This case was modeled to represent the auxiliary system load when starting a Fuel Pool Cooling Pump Motor on MCC 1XG for the Unit 1 analysis and on MCC 2XG for the Unit 2 analysis. Auxiliary load is fed from the SAT and the tie breaker between Common A and Common B is closed.

CASE SAT6: SAT - FUEL POOL COOLING PUMP MOTOR START @ 1XH (2XH)

This case was modeled to represent the auxiliary system load when starting a Fuel Pool Cooling Pump Motor on MCC 1XH for the Unit 1 analysis and on MCC 2XH for the Unit 2 analysis. The Auxiliary load is fed from the SAT and the tie breaker between Common A and Common B is closed.

CASE SAT7: SAT - REACTOR RECIRC PUMP MOTOR START

This case was modeled to represent the auxiliary system load when starting a Reactor Recirc Pump Motor. The auxiliary load is fed from the SAT and the tie breaker between Common A and B are closed.

CASE SAT8: SAT - RBCCW PUMP MOTOR START @ 1XE (2XE)

This case was modeled to represent the auxiliary load when starting a Reactor Building Closed Cooling Water Pump motor on MCC 1XE for Unit 1 and MCC 2XE for Unit 2. The auxiliary load is fed from the SAT and the tie breaker between Common A and B is closed.

CASE SAT18: SAT - SCREEN WASH PUMP MOTOR START @ 1SA (2SA)

This case was modeled to represent the auxiliary system load when starting a Screen Wash Pump Motor on MCC 1SA for the Unit 1 analysis and on MCC 2SA for the Unit 2 analysis. The auxiliary load is fed from the SAT and the tie breaker between Common A and B buses is closed.

CASE SAT19: SAT - TBCCW PUMP MOTOR START @ 1TM (2TM)

This case was modeled to represent the auxiliary system load when starting a Turbine Building Closed Cooling Water Pump Motor on MCC 1TM for the Unit 1



analysis and 2TM for the Unit 2 analysis. The auxiliary load is fed from the SAT and the tie breaker between Common A and B buses is closed.

#### B. UAT Supplying the Load

The UAT cases are identical to the SAT cases described above except the UAT is supplying the load. The Common A and Common B buses are not included in the UAT model since they are always supplied from the SAT. The UAT cases are:

Case UAT1: UAT - Full Load

Case UAT3: UAT - 3rd CWP Start

Case UAT4: UAT - 4th CWP Start

Case UAT5: UAT - Reactor Recirc. Pump Start

Case UAT6: UAT - Fuel Pool Cooling Pump Motor Start @ 1XG (2XG)

Case UAT7: UAT - Fuel Pool Cooling Pump Motor Start @ 1XH (2XH)

Case UAT8: UAT - RBCCW Pump Motor Start @ 1XE (2XE)

#### 3.4.2.2 LOCA Start

The "LOCA Start" cases were modeled by adding the LOCA starting load to the system at a full-load operation. Loads that are automatically shed from a LOCA signal were removed from the full-load model for the "LOCA Start" and "LOCA Run" cases.

The LOCA Start cases were developed to demonstrate the capability to start the LOCA loads when connected to the off-site source with the grid at the minimum expected voltage. The LOCA start cases are used along with the auxiliary system voltage criteria to establish a minimum switchyard voltage limit upon receipt of a LOCA. This would be the minimum transient post turbine trip switchyard voltage when the LOCA loads are starting. The LOCA start cases are:

CASE SAT9: SAT - LOCA START (BLOCKED STARTING)

This case was modeled to represent the auxiliary system immediately after a turbine trip from a LOCA with all

loads fed from the SAT. Two (2) Core Spray pumps and two (2) RHR pumps are simultaneously started.

#### CASE SAT10: LOCA START (SEQUENTIAL STARTING)

In addition to the "LOCA Start" model that represented block starting of the Core Spray and RHR pumps, a "LOCA Start" model was also developed to represent sequential starting of the Core Spray and RHR pumps. This model represents the starting of two Core Spray pump motors, five seconds after the RHR pumps have been started. The starting sequence and timing are the same as that used for starting the ECCS loads from the diesel generators. Because the starting power requirements of the ECCS load are imposed on the distribution system in smaller increments, sequential starting reduces the potential degradation of the auxiliary system voltage from a LOCA.

NOTE. LOCA logic at BSEP is presently configured for blocked starting of the ECCS loads. The sequential starting cases were run to determine the additional margin of voltage regulation performance which can be achieved by making such a modification.

#### 3.4.2.3 LOCA RUN

The "LOCA Run" cases were modeled by adding the LOCA Run loads to the system at full-load operation. Loads that are automatically shed by a LOCA signal were removed from the full load model. In addition to a steady state LOCA Run case, several LOCA Run motor start cases were developed. These cases were developed to demonstrate the capability of the auxiliary system to start large non-safety loads with minimum expected grid voltage following a LOCA without adversely impacting the operation of the safety related loads. The LOCA Run cases are used along with the auxiliary system voltage criteria to establish a steady state switchyard voltage limit following a LOCA.

The LOCA Run cases are:

##### Case SAT11: SAT-LOCA Run

This case was modeled to represent the steady state condition after a LOCA with 2 Core Spray pumps and 2 RHR pumps running.

##### Case SAT12: SAT-LOCA Run, 3rd CWP Start

This case was modeled to represent the steady state condition after a LOCA except a 3rd CWP Motor (2 CWP

motors running) is starting. The CWP with the longest feeder cable was started.

Case SAT13: SAT-LOCA Run, 4th CWP Motor Start

This case was modeled to represent the steady state condition after a LOCA except a 4th CWP motor (3 CWP running) is starting. The CWP with the longest feeder cable was started.

Case SAT14: SAT-LOCA Run Stator Coolant Pump Motor Start @ 1TD (2TD)

This case is identical to the steady state case (SAT11) except the Stator Coolant motor is starting on MCC 1TD for Unit 1 and 2TD for Unit 2.

Case SAT15: SAT-LOCA Run, Fuel Pool Cooling Motor Start @ 1XG (2XG)

This case is identical to Case SAT11, except the Fuel Pool Cooling Motor on MCC 1XG is starting for the Unit 1 analysis and the Fuel Pool Cooling Motor on MCC 2XG is started for the Unit 2 analysis.

Case SAT16: SAT-LOCA Run, Fuel Pool Cooling Motor Start @ 1XH (2XH)

This case is identical to Case SAT11, except the Fuel Pool Cooling Motor on MCC 1XH is started for the Unit 1 Analysis and the motor on MCC 2XH is started for the Unit 2 analysis.

Case SAT17: SAT-LOCA Run, TBCCW Pump Motor Start @ 1TM (2TM)

This case is identical to SAT11, except the Turbine Building Closed Cooling Water Pump Motor is starting on MCC 1TM for Unit 1 and MCC 2TM for Unit 2.

#### 3.4.2.4 Light Load Models

Case SAT2: SAT-Shutdown

This case models the auxiliary system during unit shutdown with the minimum expected auxiliary load. This case was developed to demonstrate that auxiliary system voltage would be within equipment ratings with the grid voltage at the maximum expected value. This case along with equipment voltage limits is used to establish a switchyard maximum voltage limit when the unit is shutdown.

#### Case UAT2: UAT-Light Load

This case models the auxiliary system during unit operation with the Unit Auxiliary Transformer supplying the load. The auxiliary system load is at the minimum value expected for power operation. This case was developed to demonstrate that the auxiliary system voltage would be within equipment ratings at the maximum expected generator voltage. This case along with the equipment voltage criteria is used to establish a generator maximum voltage limit for normal unit operation.

#### 4.0 STUDY RESULTS

##### 4.1 Source Voltage Limits

For each of the plant operating conditions and cases listed in section 3.4.2, ASDOP runs were made with the expected source voltage and at other selected voltages to determine a source voltage limit. The establishment of source limits and expected source voltage ranges is discussed in Appendix G. The source voltage limits, which were based on the equipment voltage criteria, were compared to the actual source voltage range expected for that plant operating condition. For Normal Operation, LOCA Start and LOCA Run Cases, if the source voltage limit is below the minimum expected voltage range, it can be concluded that the distribution system voltage regulation is adequate for that plant operating condition. For shutdown and light load cases, if the source voltage limit is above the maximum expected voltage range, it can be concluded that the distribution system voltage regulation is adequate for that operating condition. If the expected source voltage is outside the source voltage limits established by the ASDOP Analysis, then further study is required to establish auxiliary system adequacy. Table 1 summarizes the result for each case analyzed for Unit 1. Table 2 summarizes the results for Unit 2. Listed is the source voltage limit, expected source voltage and the condition which established the source limit.

The source voltage for the SAT cases is the 230KV Switchyard. The source voltage for the UAT cases is the unit's generator. Using Table 1, the Unit 1 switchyard and generator voltage limits can be compared to the expected source voltage values. The expected voltages are within the calculated limits except for cases SAT9, SAT13, SAT17, SAT18 and SAT19. For these cases, the limiting condition was established by some non-safety MCCs and loads. The nonsafety MCCs and loads were examined in greater detail for these cases and the voltage at the loads were determined to be adequate (See section 4.4,

paragraphs 1, 2, 3). In all cases (including cases SAT9, SAT13, SAT17, SAT18 and SAT19), the voltage meets the criteria on the safety buses. Thus, adequate voltage is maintained on the Unit 1 safety systems. Table 1 assumes a tap change (which has no impact on safety system voltage) is made on the transformer serving Unit Substation Common C. The purpose of the tap change is discussed in Section 4.4 Paragraph 4.

Using Table 2, the Unit 2 switchyard and generator voltage limits can be compared to the expected source voltage values. The expected voltages are within calculated limits except for cases SAT2, SAT17, SAT18 and SAT19. For case SAT2, the expected source voltage (1.017 pu) is only slightly greater (.007 pu) than the source voltage limit (1.010 pu). The voltage limit was set by non-safety MCC bus voltages and is discussed further in Section 4.4, Paragraph 5. The voltage is within limits on the safety buses and at safety loads.

For cases SAT17, SAT18 and SAT19 the limiting condition was established by some non-safety MCC and loads. The non-safety MCC and loads were examined in greater detail for these cases and determined to be adequate (See Section 4.4, paragraphs 1, 2, 3). In all cases (including SAT17, SAT18 and SAT19), the voltage meets the criteria for Unit 2 safety buses and loads. Thus adequate voltage is maintained on the Unit 2 safety system for all conditions analyzed.

TABLE 1 - SUMMARY OF RESULTS OF ASDOP ANALYSIS BSEP #1

PLANT MODE	CASE	MIN (MAX) EXPECTED SOURCE VOLTAGE (PU)	SOURCE VOLTAGE LIMIT	LIMITING CONDITIONS
Full Load	SAT1 - Full Load	1.009	1.007	460V Mtr Term. Volt.
	SAT3 - 3rd CWP Start	1.009	.984	CWP-1D Terminal Volt.
	SAT4 - 4th CWP Start	1.009	.993	CWP-1D Terminal Volt.
	SAT5 - Fuel Pool Cool Pump Start @ 1XG	1.009	.963	FPCP-1A Term. Volt.
	SAT6 - Fuel Pool Cool Pump Start @ 1XH	1.009	.968	FPCP-1B Term. Volt.
	SAT7 - Reac Recirc Pump Mtr Start @ 1B	1.009	.978	RRP-1B Terminal Volt.
	SAT8 - RBCCW Pump Mtr Start @ 1XE	1.009	.974	RBCCW Mtr Term. Volt.
	SAT18 - Screen Wash Pump Mtr Start @ 1SA	1.009*	1.046	SWP Terminal Voltage
	SAT19 - TBCCW Pump Start @ 1TM	1.009*	1.055	TBCCW Terminal Voltage
	Full Load	UAT 1 - Full Load	1.009	1.000
UAT 3 - 3rd CWP Start		1.009	.977	CWP-1D Mtr Term. Volt.
UAT 4 - 4th CWP Start		1.009	.986	CWP-1D Mtr Term. Volt.
UAT 5 - Reac Recirc Pump Mtr Start @ 1B		1.009	.981	RRP-1B Terminal Volt.
UAT 6 - Fuel Pool Cool Pump Start @ 1XG		1.009	.958	FPCP-1A Terminal Volt.
UAT 7 - Fuel Pool Cool Pump Start @ 1XH		1.009	.963	FPCP-1B Terminal Volt.
UAT 8 - RBCCW Pump Mtr Start @ 1XE		1.009	.972	RBCCW-1A Terminal Volt.
LOCA START		SAT 9 - LOCA, Blocked Starting	.965*	.966
	SAT 10 - LOCA, Sequential Starting	.965	.924	480V Contactor Drop-out
LOCA Run	SAT 11 - LOCA Run	.989	.979	480V Contactor Pickup
	SAT 12 - 3rd CWP Start	.989	.983	CWP-1D Terminal Volt.
	SAT 13 - 4th CWP Start	.989*	.993	CWP-1D Terminal Volt.
	SAT 14 - Stator Clnt Pump Mtr Start @ 1TD	.989	.952	SCP 1B Terminal Volt.
	SAT 15 - Fuel Pool Cool Pump Start @ 1XG	.989	.936	FPCP 1A Terminal Volt.
	SAT 16 - Fuel Pool Cool Pump Start @ 1XH	.989	.950	FPCP 1B Terminal Volt.
	SAT 17 - TBCCW Pump Motor Start @ 1TM	.989*	1.055	TBCCW Terminal Voltage
LIGHT LOAD	SAT 2 - SAT, Shutdown	(1.017)	1.017	460V Mtr Terminal Volt.
	UAT 2 - UAT, Light Load	(1.038)	1.095	460V Mtr Terminal Volt.

\*These cases are examined further in Section 4.4 to determine if load characteristics are such that the nonsafety loads impacted will operate satisfactorily at the expected source voltage.

TABLE 2 - SUMMARY OF RESULTS OF ASDOP ANALYSIS BSEP #2

PLANT MODE	CASE	MIN (MAX) EXPECTED SOURCE VOLTAGE (PU)	SOURCE VOLTAGE LIMIT	LIMITING CONDITIONS
Full Load	SAT1 - Full Load	1.009	1.000	460V Mtr Term. Volt.
	SAT3 - 3rd CWP Start	1.009	.987	CWP-2D Terminal Volt.
	SAT4 - 4th CWP Start	1.009	.994	CWP-2D Terminal Volt.
	SAT5 - Fuel Pool Cool Pump Start @ 2XG	1.009	.960	FPCP-2A Terminal Volt.
	SAT6 - Fuel Pool Cool Pump Start @ 2XH	1.009	.982	FPCP-2B Terminal Volt.
	SAT7 - Reac Recirc Pump Mtr Start @ 2B	1.009	.981	RRP-2B Terminal Volt.
	SAT8 - RBCCW Pump Motor Start @ 2XE	1.009	.972	RBCCW Mtr Term. Volt.
	SAT18 - Screen Wash Pump Mtr Start @ 2SA	1.009*	1.056	SWP Terminal Voltage
	SAT19 - TBCCW Pump Start @ 2TM	1.009*	1.063	TBCCW Terminal Voltage
Full Load	UAT 1 - Full Load	1.009	.997	460V Mtr Term. Volt.
	UAT 3 - 3rd CWP Start	1.009	.979	CWP-2D Terminal Volt.
	UAT 4 - 4th CWP Start	1.009	.989	CWP-2D Terminal Volt.
	UAT 5 - Reac Recirc Pump Mtr Start @ 2B	1.009	.983	RRP-2B Terminal Volt.
	UAT 6 - Fuel Pool Cool Pump Start @ 2XG	1.009	.954	FPCP-2A Terminal Volt.
	UAT 7 - Fuel Pool Cool Pump Start @ 2XH	1.009	.977	FPCP-2B Terminal Volt.
	UAT 8 - RBCCW Pump Mtr Start @ 2XE	1.009	.967	RBCCW-2A Terminal Volt.
	LOCA START	SAT9 - LOCA, Blocked Starting	.965	.926
SAT10 - LOCA, Sequential Starting		.965	.884	480V Contactor Drop-out
LOCA Run	SAT11 - LOCA Run	.991	.964	27DV Relay Setting
	SAT12 - 3rd CWP Start	.991	.978	CWP-2D Terminal Volt.
	SAT13 - 4th CWP Start	.991	.989	CWP-2D Terminal Volt.
	SAT14 - Stator Clnt Pump Mtr Start @ 2TD	.991	.944	SCP-2B Terminal Volt.
	SAT15 - Fuel Pool Cool Pump Start @ 2XH	.991	.944	FPCP-2A Terminal Volt.
	SAT16 - Fuel Pool Cool Pump Start @ 2XG	.991	.927	FPCP-2B Terminal Volt.
	SAT17 - TBCCW Pump Mtr Start @ 2TM	.991*	1.059	TBCCW Terminal Voltage
LIGHT LOAD	SAT 2 - SAT, Shutdown	(1.017)*	1.010	460V Mtr Terminal Volt.
	UAT 2 - UAT, Light Load	(1.038)	1.058	460V Mtr Terminal Volt.

\*These cases are examined further in Section 4.4 to determine if load characteristic are such that the nonsafety loads affected will operate satisfactorily at the expected source voltage.

#### 4.2 Safety Bus Voltages with Expected Source Voltage

Table 3 and 4 summarize for Units 1 and 2 respectively the Auxiliary System safety bus voltages with the expected source voltage for the Full Load, LOCA Start, LOCA Run, and Light Load Conditions. The transient values listed for each mode of operation are the minimum transient voltages on the buses for the motor start cases analyzed for the particular mode of operation. In each case, the minimum transient voltage is caused by the start of a fourth CWP motor. For each case analyzed, ASDOP outputs which give bus voltages and selected motor terminal voltages may be found in Appendix H.

#### 4.3 Comparison of Undervoltage Relay Setting with Steady State and Transient Voltage

Steady state and motor starting transient voltages were examined relative to the appropriate undervoltage relay set points. A 3rd CWP start (Cases UAT3, SAT3, SAT12), a 4th CWP start (Cases UAT4, SAT4, SAT13) and a LOCA Blocked Start (Case SAT9) result in a transient voltage dip below the safety bus undervoltage relay pickup voltage. Motor acceleration calculations were performed in these instances which verified the motors would accelerate and voltage would recover in time to prevent an undervoltage trip. The calculations, relay characteristics, and plots illustrating the results can be found in Appendix F. The calculations computed the motor acceleration time at several voltage values. The acceleration time was determined for the minimum expected motor terminal voltage. Additionally, the minimum terminal voltage at which the motor will start without tripping the undervoltage relay was determined.

#### 4.4 Non-Safety Auxiliary System Voltages

The auxiliary system voltage criteria were developed to address all operating conditions at the plant including non-safety system loads. As discussed in the previous sections, voltages are adequate for safety-related loads for any condition or case analyzed. Additionally no case was identified where non-safety loads adversely affected safety loads.

Some non-safety loads (as described in Section 4.1) set source voltage limits which were outside the range of expected source voltages. The loads were analyzed in greater detail to determine if load characteristics



would permit the loads to operate with the source voltage at the expected value. The following paragraphs summarize the results of this analysis:

1. TERMINAL VOLTAGE AT THE TBCCW PUMP AND SCREEN WASH PUMP (CASES SAT17, SAT19, SAT18): When starting the TBCCW pump during a LOCA (Case SAT17), the motor terminal voltage drops to .783 (460V base) for the Unit 1 analysis and to .7828 (460V base) for the Unit 2 analysis. During SAT-Full Load Operation (SAT19) starting the TBCCW pump drops the motor terminal voltage to .8037 (460V base) for the Unit 1 analysis and to .7957 pu for the Unit 2 analysis. During SAT-Full Load Operation (SAT18), starting the Screen Wash Pump causes the motor terminal voltage to drop to .8064 (460V base) in the Unit 1 analysis and to .7995 pu for the Unit 2 analysis. The motor terminal voltages are below the 85% starting criteria. Calculations were performed (see Appendix F) to determine if the motors would start at the ASDOP computed values. In all cases, the motors will start and accelerate at the expected terminal voltage values.
2. TERMINAL VOLTAGE AT CWP-1D WHEN STARTING A 4TH CWP DURING LOCA RUN (CASE - SAT13): When starting the fourth CWP during a LOCA on Unit 1, the CWP-1D motor terminal voltage dips to 0.8452 (4000V base). Although this voltage is below the .85 (4000V base) voltage criteria, the CWP is not a safety-related load and does not jeopardize the safety of the plant. Additionally, there is no problem with motor acceleration at the minimum expected terminal voltage.
3. VOLTAGE AT NON-SAFETY MCC CTO DURING LOCA BLOCK-START (CASE SAT9): When block starting the RHR pumps and Core Spray pumps on Unit 1 during a LOCA, MCC CTO bus voltage dips to 0.6980 (480V base). This voltage is below the 0.70 (480V base) voltage criteria for contactor drop-out. No safety-related loads are fed from CTO, therefore the possibility of contactor drop-out is not a safety concern and is not considered a problem. The MCC CTO voltage recovers to .8674 (480V base) after the motors accelerate. Therefore any loads which drop out due to low voltage can restart.
4. VOLTAGES ON LOADS FED FROM UNIT SUBSTATION COMMON C: With Unit Substation Common C transformer tapped at

the present setting (-2.5%), the Unit 1 analysis computed low voltages at the following loads fed from the unit substation:

- a. Low motor terminal voltage at loads fed from MCC RWC during SAT-Full Load (SAT1).
- b. Low bus voltage at MCC RWC during LOCA Block Start (SAT9).
- c. Low bus voltage at MCC RWC during LOCA Run (SAT11).

The low voltages can be corrected by changing the substation transformer taps from -2.5% to -5%.

5. VOLTAGE ON NON-SAFETY MCC ON UNIT 2: As discussed in Section 4.2 a slight overvoltage on some non-safety motor control centers may occur for the shutdown case (SAT2) with the 230KV system voltage at the maximum expected value. The voltage at the non-safety MCC buses only slightly exceeds (.68% max. on MCC 2TE) the maximum allowable voltage at the load terminals. There will be some additional voltage drop between the motor control center and the load. Also, the time the source voltage will be maximum with the unit shutdown should be small. Therefore, the slight overvoltage calculated in the ASDOP computer studies is not considered significant.

## 5.0

### CONCLUSIONS AND RECOMMENDATIONS

Based on our interpretation of NRC requirements and the results of voltage-drop studies, the electrical distribution system can supply power to the safety system within the equipment voltage limits. This is based on a "worst case" accident scenario of a LOCA on one unit with the other unit shutdown, as opposed to the accident scenario of a LOCA on one unit and simultaneous false LOCA on the other unit. The latter scenario was used in past voltage-drop studies, and subsequent NRC submittals were based on results of these studies; however, this scenario goes beyond the intent of any applicable regulatory requirements. A detailed discussion of the basis for the revised accident scenario can be found in Appendix A.

Specific instances were found in the analysis where non-safety loads required individual analysis. The actual voltages in these instances were demonstrated to be adequate and/or the non-safety system would operate satisfactory in all cases provided one change is made. A

tap change from -2.5% to -5% is recommended on the transformer supplying Unit Substation Common C. The tap change will assure adequate voltage is maintained for all the non-safety loads fed from the unit substation.

5.1 Addendum to Results and Conclusions

The voltage drops covered in this report were conducted with the understanding that the Screen Wash Pump Motors (fed from nonsafety MCCs 1SA and 2SA) were automatically tripped upon initiation of a LOCA signal. Since completion of this analysis, it has been discovered that this load shedding feature has been removed. This impacts the load model used for analysis in that under worst case loading, the Screen Wash Pumps could be running during a LOCA. As a result, the affected cases have been reexamined, and it was determined that the impact on the voltage regulation of the safety-related buses is insignificant and the conclusions and recommendations will not change in any way.

Relative to the nonsafety loads, two (2) additional MCCs (1SA and RWC) do not meet the minimum criteria of 0.70 pu for a LOCA Start. This condition has been evaluated as having no adverse impact on safety-related systems in Section 4.4, Item 3.

TABLE 3  
UNIT 1 SAFETY SYSTEM BUS VOLTAGES AT THE EXPECTED SOURCE VOLTAGE

Bus	FULL LOAD				LOCA START  Blocked Start (SAT9)	LOCA RUN		LIGHT LOAD		
	UAT SUPPLYING LOAD		SAT SUPPLYING LOAD			Steady State (SAT11)	Transient (SAT13)	UAT Supplying Load (UAT2)	Shutdown (SAT2)	
	Steady State (UAT1)	Transient (UAT4)	Steady State (SAT1)	Transient (SAT4)						
4KV		.9438	.8758	.9426	.8702	.7747	.9187	.8473	.9794	1.0207
480V Bus	E5	.9259	.8474	.9246	.8408	.7559	.9188	.8387	.9665	1.0266
430V Bus	E6	.9309	.8530	.9296	.8466	.7527	.9163	.8359	.9712	1.0276
480V MCC	1XC	.9235	.8448	.9222	.8382	.7527	.9162	.8358	.9642	1.0245
	2XJ	.9131	.8334	.9118	.8268	.7556	.9186	.8384	.9543	1.0208
	1XE	.9127	.8329	.9114	.8263	.7430	.9083	.8272	.9538	1.0174
	1PA	.9240	.8454	.9228	.8388	.7529	.9164	.8361	.9647	1.0250
	1XL	.9147	.8351	.9134	.8285	.7535	.9169	.8365	.9558	1.0169
	DGA	.9241	.8454	.9228	.8389	.7527	.9162	.8358	.9647	1.0256
	1CA	.9017	.8208	.9004	.8140	.7258	.8944	.8118	.9433	1.0105
	10G	.9141	.8344	.9128	.8278	.7413	.9069	.8256	.9552	1.0200
	1XG	.9104	.8304	.9091	.8238	.7509	.9148	.8342	.9517	1.0126
	1XA	.9225	.8437	.9212	.8371	.7517	.9154	.8350	.9632	1.0247
	1XD	.9298	.8519	.9285	.8454	.7513	.9152	.8347	.9702	1.0268
	2XB-2	.9275	.8494	.9263	.8429	.7486	.9129	.8322	.9680	1.0276
	DGB	.9256	.8473	.9243	.8408	.7426	.9080	.8268	.9661	1.0245
	2XK	.9144	.8350	.9131	.8284	.7524	.9160	.8356	.9554	1.0127
	1XF	.9220	.8433	.9207	.8368	.7374	.9038	.8221	.9627	1.0196
	1PB	.9293	.8514	.9280	.8449	.7508	.9148	.8342	.9697	1.0262
	1XM	.9220	.8433	.9207	.8368	.7504	.9144	.8338	.9626	1.0200
	1XH	.9137	.8343	.9125	.8277	.7429	.9083	.8271	.9548	1.0120
	1CB	.9139	.8344	.9126	.8278	.7315	.8991	.8169	.9549	1.0171
	20G	.9159	.8367	.9146	.8301	.7340	.9011	.8191	.9569	1.0189
	1XB	.9275	.8493	.9262	.8428	.7485	.9129	.8321	.9679	1.0260
	2XA-2	.9246	.8460	.9234	.8395	.7544	.9176	.8373	.9653	1.0266

NOTE: Voltages are in per unit based on bus nominal voltage.

TABLE 4  
UNIT 2 SAFETY SYSTEM BUS VOLTAGES AT THE EXPECTED SOURCE VOLTAGE LIMIT

Bus	FULL LOAD				LOCA START  Blocked Start (SAT9)	LOCA RUN		LIGHT LOAD	
	UAT SUPPLYING LOAD		SAT SUPPLYING LOAD			Steady State (SAT11)	Transient (SAT13)	UAT Supplying Load (UAT2)	Shutdown (SAT2)
	Steady State (UAT1)	Transient (UAT4)	Steady State (SAT1)	Transient (SAT4)					
4KV Bus	.9407	.8724	.9386	.8680	.7795	.9257	.8537	.9640	1.0250
480V Bus E7	.9325	.8547	.9301	.8497	.7707	.9339	.8541	.9627	1.0373
480V Bus E8	.9336	.8562	.9312	.8512	.7732	.9355	.8561	.9597	1.0395
480V MCC 2XC	.9316	.8537	.9291	.8487	.7695	.9330	.8530	.9617	1.0367
MCC 1XJ	.9198	.8409	.9174	.8358	.7672	.9311	.8510	.9504	1.0314
MCC 2XE	.9192	.8402	.9168	.8351	.7580	.9235	.8427	.9499	1.0282
MCC 2PA	.9294	.8514	.9270	.8464	.7669	.9308	.8507	.9597	1.0346
MCC 2XL	.9218	.8430	.9193	.8380	.7649	.9292	.8489	.9523	1.0281
MCC DGC	.9306	.8527	.9292	.8477	.7675	.9313	.8512	.9608	1.0363
MCC 2CA	.9149	.8355	.9125	.8304	.7492	.9164	.8348	.9509	1.0273
MCC 2XA	.9287	.8506	.9262	.8456	.7661	.9301	.8499	.9590	1.0350
MCC 2XG	.9164	.8370	.9139	.8319	.7637	.9281	.8478	.9470	1.0230
MCC 2XD	.9324	.8548	.9299	.8498	.7717	.9342	.8547	.9585	1.0385
MCC 1XB-2	.9326	.8551	.9302	.8501	.7720	.9345	.8550	.9587	1.0395
MCC DGD	.9320	.8544	.9296	.8495	.7708	.9335	.8539	.9581	1.0386
MCC 2XB	.9279	.8499	.9254	.8449	.7663	.9298	.8499	.9541	1.0366
MCC 1XK	.9220	.8434	.9195	.8384	.7726	.9350	.8555	.9484	1.0291
MCC 2XF	.9160	.8369	.9135	.8318	.7517	.9179	.8368	.9425	1.0256
MCC 2PB	.9315	.8539	.9291	.8489	.7707	.9334	.8538	.9577	1.0377
MCC 2XM	.9237	.8453	.9212	.8403	.7693	.9322	.8525	.9500	1.0297
MCC 2XH	.9042	.8239	.9017	.8187	.7600	.9246	.8442	.9311	1.0188
MCC 2CB	.9088	.8290	.9063	.8238	.7429	.9107	.8289	.9356	1.0263

NOTE: Voltages are in PU based on bus nominal voltage.

## 6.0 REFERENCES

1. BSEP Updated FSAR, Sections 8.2 and 8.3, Vol. 6.
2. Brunswick Steam Electric Plant Units 1 and 2 Electrical Distribution System Load List, Duke Power Company, September 30, 1982.
3. CP&L letter to NRC, NO-81-288, February 16, 1981.
4. Internal CP&L Memorandum BSEP/81-0204, January 26, 1981.
5. NRC Regulatory Guide 1.81, Revision 1, January 1975.
6. NRC Internal Memorandum October 27, 1978; Voltage Degradation at Class 1E 480-volt buses.
7. NRC letter to All Power Reactor Licensees, August 8, 1979.
8. UE&C Letter to CP&L Nuclear Plant Engineering Department, Ref. CU-09227, November 11, 1976.
9. UE&C Report on Voltage Drop Study, BSEP Unit 2, Revision 2, December 15, 1980.
10. UE&C 480-volt Load Study, BSEP Units 1 and 2, Revision 1, March 1, 1978.
11. Calculation NT124-E-01-F, Auxiliary Electrical Distribution System Load and Cable Impedance Calculation for BSEP Unit 2, Revision 1, May 25, 1984.
12. Calculation NT124-E-02-F, Auxiliary Electrical Distribution System Load and Cable Impedance Calculation for BSEP Unit 1, Revision 0, June 1984.
13. CP&L Benchmark Procedure for Auxiliary System Design Optimization Program (ASDOP), Revision 0, April 10, 1984.

7.0 APPENDIX A  
ACCIDENT SCENARIO CONSIDERATIONS

## 7.0 ACCIDENT SCENARIO CONSIDERATIONS

Previous BSEP Electrical Division System voltage-drop studies considered a postulated worst-case accident of a LOCA on one unit and a simultaneous false LOCA on the other unit (See "UE&C Report on Voltage-Drop Study for BSEP Unit 2", Revision 2, dated December 15, 1980.). The UE&C report indicated that the '2XLOCA' condition could cause the emergency bus voltage to degrade to unacceptable levels when the tie breaker between 4160-volt buses Common A and Common B is closed. A solution offered by UE&C to ensure sufficient emergency bus voltage for the "2XLOCA" scenario was to increase the normal 230 KV switchyard voltage from 1.000 p.u. to 1.012 p.u. when the tie breaker is closed.

The solution offered is based upon the incorrect assumption that after a turbine generator trip, the switchyard voltage would degrade a constant amount from its pre-trip voltage, regardless of whether the pre-trip voltage is at 1.000 p.u. or 1.012 p.u. This analysis does not take into consideration that the generating units supply a major portion of the VAR support that serves to hold the switchyard voltage at the required level. Upon a unit trip, this system VAR support is lost, and the drop in switchyard voltage is determined by the transmission system conditions, which dictate how much and from where the lost VAR support is made up. From Transmission System loadflow studies, it has been demonstrated that the actual drop in switchyard voltage caused by the loss of both units and the starting of the ECCS loads would be much greater than indicated in the UE&C report.

Based on an evaluation of NRC requirements relative to the adequacy of station electrical distribution system voltage, the "2XLOCA" accident scenario is more conservative than required. In the NRC's Guidelines for Voltage-Drop Calculations found in their letter to all power reactor licensees, dated August 8, 1979, Guideline No. 2 states "For multi-plant stations, a separate analysis should be performed for each unit, assuming (1) an accident in the unit being analyzed and simultaneous shutdown of all other units at that station, or; (2) an anticipated transient in the unit being analyzed (e.g., unit trip) and simultaneous shutdown of all other units at that station, whichever presents the largest load demand situation."

In the "2XLOCA" scenario, the simultaneous shutdown referred to in the above guideline is caused by simultaneous false accident signals that cause the automatic starting



of the ECCS equipment. Regulatory Guide 1.81 states that because of the low probability of a major reactor accident, a suitable basis for multi-unit nuclear power plants is the assumption that the accident occurs in only one of the units at a time, with all remaining units proceeding to an orderly shutdown. Since an "orderly shutdown of the other unit" is clearly not the loss of the unit from spurious accident signals, the Regulatory Guide supports the basis for considering a LOCA on one unit only. This scenario is further supported by IEEE 308-1971, Paragraph 8.1.4 which states in part: "A multiunit station may share preferred power supply capacity between units. In such a case, as a minimum the total preferred capacity must be sufficient to operate the engineered safety features for a design basis accident on one unit and those systems required for a concurrent safe shutdown of the remaining units."

The NRC also provides guidelines for establishing the source voltage that is to be used for the station electrical distribution system voltage-drop studies. The same August 8, 1979, NRC letter referenced above states that the voltage at the terminals of each safety load should be calculated based on the assumption that the grid voltage is at its "minimum expected value". The minimum expected value should be based on the least of the following:

- a. The minimum steady-state voltage experienced at the connection to the off-site circuit.
- b. The minimum voltage expected at the connection to the off-site circuit due to contingency plans which may result in reduced voltage from the grid.
- c. The minimum predicted grid voltage from grid stability analysis (e.g., load flow studies).

For all of the voltage-drop studies covered in this report, the minimum expected grid voltage was based on transmission system load flow studies ("c" above). For the "LOCA Start" cases, the load flow studies yielded the lowest voltage of the three methods covered in the NRC guidelines; however, for the "LOCA Run" cases the voltages from load flow studies were higher than the minimum steady-state voltage experienced at the connection to the off-site circuit ("a" above). A review of plant computer logs has revealed that the lowest steady-state voltage at the 230 KV switchyard of 222.7 KV (0.967 p.u.) occurred on August 25, 1975. This value was not used for the "LOCA Run" cases, however, for two reasons:

1. The steady-state grid voltage cannot be used to

predict the post-turbine trip grid voltage after a LOCA. As mentioned previously in this appendix, the generator serves to maintain the switchyard voltage at the required level, and, therefore, the voltage drop from an unanticipated loss of a generating unit cannot be controlled by maintaining the grid voltage with the generator.

2. Many changes have been made in the transmission system since 1975 when the lowest switchyard voltage occurred. These changes have impacted how the transmission system affects switchyard voltages.

#### Revised Accident Scenario

Based on an interpretation of NRC guidelines for degraded voltage analyses, the following accident scenario would apply to BSEP:

1. Both Brunswick units are operating with auxiliary electrical loads to support full-load operation.
2. The Common A to Common B bus tie breaker is closed.
3. There is a LOCA on BSEP Unit 2 (1); switchyard voltage degrades to the "minimum expected value".
4. The Unit 1 (2) operators simultaneously commence the process that will lead to a safe, orderly shutdown and cool-down condition.

The above accident scenario based on NRC Guidelines considers the LOCA occurring at a time when both units are operating. In the case of BSEP, an accident on a unit with the other unit shutdown results in the "worst case" voltage condition. The probability of an accident occurring on a unit with the other unit shutdown is approximately the same as when the other unit is operating. Therefore, it is reasonable the above scenario should be changed to consider the worse case condition. Therefore, the scenario used in this analysis is as follows:

1. One Brunswick Unit is operating at full load. The other is shutdown.
2. The Common A to Common B tie breaker is closed with the load supplied from the operating unit's Startup Auxiliary Transformer.

3. There is a LOCA on the operating unit; switchyard voltage degrades to the "minimum expected value".
4. Plant safety systems respond to the accident condition.

8.0 APPENDIX B  
SOURCE VOLTAGE CONSIDERATIONS

## 8.0 SOURCE VOLTAGE CONSIDERATIONS

An important consideration for maintaining adequate electrical distribution system voltages is to take the necessary steps to control the source voltage during normal plant operations and to ensure that the transmission system is operated in such a way as to minimize the loss of voltage from an uncontrolled unit trip.

Under normal operating conditions, the 230 KV switchyard voltage level is maintained in accordance with the BSEP Generation Voltage Schedule (GVS). The present GVS calls for the 230 KV switchyard voltage to be maintained between 232 KV and 234 KV. The desired switchyard voltage level is achieved through a coordinated effort between the plant operators and the System Operations Load Dispatchers at the Skaale Energy Control Center. In the voltage-drop analyses covered in this report, the GVS was used as the expected source voltage range for non-accident operating conditions. The expected voltage was compared to the calculated voltage limit to determine whether adequate source voltage could be expected for the condition modeled. It should be pointed out that the GVS is subject to change, which could change the results of the voltage-drop studies themselves. The GVS is based on a combination of interdependent plant and grid operating conditions and requirements. The considerations involved in making changes to the GVS are somewhat complex, and it is not intended in this report to cover them in detail; however, it should be pointed out that before any change in the GVS is made, the impact on plant operations would be carefully considered.

Since the desired switchyard voltage is maintained primarily by making adjustments to the power factor of the generator unit, the GVS cannot be applied for determining the expected source voltage for accident conditions resulting in a unit trip. In the case of a unit trip from a LOCA, the switchyard voltage is degraded as a result of the loss of generation, as well as the inrush current required to start the ECCS loads. The greatest difficulty in maintaining sufficient switchyard voltage comes at the instant the unit trips and the ECCS loads are required to start. After the motor inrush current has tapered off and the transmission system has had time to make the necessary adjustment, the switchyard voltage can be maintained at a higher level.

The minimum expected switchyard voltages for the accident conditions in this report were based on transmission system load flow studies that modeled transmission facilities

planned for service by the 1984 summer period. Since adequate switchyard voltage becomes more difficult to maintain as the system load increases, the desired conservatism is achieved by representing the forecasted summer peak load in the transmission system model. L. V. Sutton Steam Electric Plant Unit 3 helps support transmission voltage in the area. To develop the "worst case" transmission system conditions, all the studies except shutdown (SAT2) were run representing Sutton Unit No. 3, out of service. For the Shutdown Case (SAT2), Sutton Unit 3 was considered operating to develop the "worst case" maximum switchyard voltage.

9.0 APPENDIX C  
VOLTAGE CRITERIA

9.0 BSEP EQUIPMENT VOLTAGE CRITERIA  
VOLTAGE CONSTRAINTS

<u>Equipment</u>	<u>Name Plate Rating</u>	<u>Continuous</u>	<u>Transient</u>	<u>Remarks</u>	<u>Reference</u>
Nonclass 1E Motors	4000V	±10% (3600 to 4400 volts)	-15% starting (3400 volts)		1
Nonclass 1E GE Motors	4000V	±10% (3600 to 4400 volts)	-30% starting (2800 volts)	Applies to RHR and core spray pump motors only.	2
Class 1E UE&C Motors	4000V	±10% (3600 to 4400 volts)	-25% starting (3000 volts)		2
All Motors	460V	±10% (414 to 506 volts)	-15% starting (391 volts)	Applies to all 460 Volt motors. This criterion relaxed for accident conditions.	1
Motor Control Centers	480V	-15% (408 volts)	-30% (336 volts)	85% required for contactor pickup. 70% required for contactor hold in.	
E-Buses	4160V	89.5% (27DV relay setting) (3727.5 volts on E-bus) @ 10 sec.	82.5% (27/59E relay pick up setting)	27DV relay setting is 106.5V/10 sec. 27/59E inverse time relay setting is 105V/98V (5 secs. @ 75% V. 1.5 secs. @ 0% V)	3, 4, 5
BOP Buses	4160V	N/A	69% (27 relay setting) 2870 volts on BOP bus.	27 relay setting is 82T 1/2 L (2 secs. @ 0% V)	3, 4, 5



<u>Equipment</u>	<u>Name Plate Rating</u>	<u>Continuous</u>	<u>Transient</u>	<u>Remarks</u>	<u>Reference</u>
BOP Buses	4160V	N/A	69.8% (27/59S relay setting (2905 volts on BOP Bus)	27/59S setting is 105V/83V (5.5 sec. @ 0 v)	3, 4, 5
BOP Buses	4160V	N/A	69.8% (27/59U relay setting) (2905 volts on BOP Bus)	27/59U setting is 105/83V (5.5 sec. @ 0 V)	3, 4, 5

NOTES:

- A. Limits established for motors are voltages at the motor terminals. A 3% running drop between motor control center and motor will be assumed to account for cable voltage drop.
- B. All percentages are in 4160 Volt base, and PT ratio for all relays is 4200/120.

REFERENCES:

1. ANSI C50.41-1982.
2. UE&C voltage drop study, Rev. 2, December 15, 1980.
3. CP&L letter to NRC dated November 23, 1982 with Enclosure 1, BSEP Units 1 and 2 Adequacy of Station Electric Distribution System Voltages.
4. UC-24428 dated September 1, 1976 on "Relay Coordination Settings and Curves."
5. UC-29677 dated June 30, 1980 "Adequacy of Station Electrical Distribution System Voltages."

10.0 APPENDIX D  
AUXILIARY SYSTEM RELAYS


## 10.0 AUXILIARY SYSTEM RELAYS

The NRC guidelines for voltage drop calculations, item 8, states that "The analysis should document the voltage setpoint and any inherent or adjustable (with nominal setting) time delay for relays which initiate or execute (1) automatic transfer of loads from one source to another; (2) automatic load shedding; or (3) automatic load sequencing." The relays, settings and functions are listed below. The appropriate relays are also included in voltage criteria, Appendix C (Section 9.0).

	<u>Relay</u>	<u>Catalog No.</u>	<u>Setting</u>	<u>Function</u>
a.	27/59S (BOP-Bus)	12IAV53K1A	105V/83 (5.5 sec when volt- age drops to zero.	<ul style="list-style-type: none"> <li>a. Load sheds all breakers on its associated bus.</li> <li>b. Trips its associated Feeder to Emergency Bus.</li> <li>c. Starts Diesel Generators</li> </ul>
b.	27/59U (BOP-Bus)	12IAV53K1A	105V/83V (5.5 sec when voltage drops to zero	<ul style="list-style-type: none"> <li>a. Load sheds all breakers on its associated bus</li> <li>b. Trips its associated Feeder to Emergency Bus</li> <li>c. Starts Diesel Generators</li> </ul>
c.	27 (BOP-Bus)	12IAV54F1A	82 $\pm$ 1/2L (2 sec @ 0%)	<ul style="list-style-type: none"> <li>a. Opens master-slave breakers to associated Emergency Bus.</li> <li>b. Sheds all BOP bus loads</li> </ul>
d.	27-1 (BOP-Bus)	12HFA65D69H	Instantaneous	<ul style="list-style-type: none"> <li>a. Permits sequential loading of RHR and Core Spray Pumps during DBA</li> <li>b. Permits bypass of sequential loading circuits if off-site power is available</li> <li>c. Permits operation of Conventional Service Water Pumps if off-site power is available</li> </ul>

	<u>Relay</u>	<u>Catalog No.</u>	<u>Setting</u>	<u>Function</u>
e.	27/59E (E-bus)	12IAV53K1A	105V/98V (5 sec @ 70% V. (1.5 secs @ 0% V)	a. Permits closure of diesel generator breaker b. Load sheds all breakers on its associated bus  c. Trips tie breakers
f.	59D (E-bus)	12IAV51A1A	55V/1L (.25 sec @ 100% V.)	a. Permits closure of diesel generator breaker
g.	27-1	12HFA65D69H	Instantaneous	a. Starts sequential loading
	27-2 (E-bus)	12HFA65D69H	Instantaneous	b. Permits bypass of sequential loading circuits if off-site power is available.
	27HS (E-bus)	12HGA17C63	Instantaneous	a. Starts its associated diesel generator
	27 DV (E-bus)	ITE - 27D	106.5V/10 sec	a. Isolates its associated emergency bus from off-site distribution system when voltage is below 89.5%

11.0 APPENDIX E  
AUXILIARY SYSTEM MOD<sup>E</sup>L ONE LINES



**NOTES:**

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #

0	5/25/84	ISSUE FOR NT-124	W	H	W	H
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE
DPL <i>WIK Russell</i>			CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER		REG. NO.				
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. NO. T124-E-3002		SCALE: NONE			REV. NO. 0	
		SHEET 1 OF 36				

REV	QA	STRUC	MJC	MECH	ELECT	INSTR	

EZ

SAT

230/4.16KV

① SWYD. (230KV)

⑩②

⑩③

③

1B

Z = 0.0006018 + j0.0045289

S = 11.469  
PF = 0.89

④ 1C, 1D, E1, E2, COMMON B, COMMON A

(4160V BUS)

Z = 0.0002127 + j0.002151

S = 15.573  
PF = 0.87

4160/480V TYP.

⑤ E5

⑧ E6

⑥ 1E

⑦ 1F

⑫ COM-C

⑩ L

⑪ 3L

⑨ 15Y

④ Z = 0.03654 + j0.04456  
CMP-10

④ 2200 HP

SEE SHEET 19 & 20

SEE SHEET 23 & 24

SEE SHEET 27 & 28

SEE SHEET 30

SEE SHEET 31

SEE SHEET 35

SEE SHEET 34

SEE SHEET 33

SAT FULL LOAD WITH 4TH CIR. WAT. PUMP START


NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	WG	HTIN	
REV	DATE	DESCRIPTION	CHK	APP	
DPE	WK Ruvell		OK	WPK	
PROFESSIONAL ENGINEER			DPE	LE	
REG. NO.					
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT:	BSEP	UNIT 1			
TITLE:	ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
DWG. NO.	T124-E-3002			SCALE: NONE	REV. NO. 0
				SHEET 2 OF 36	

REV	GA	STRUC	NUC	MECH	ELECT	INQ

E3



SAT FULL LOAD  
WITH 3RD CIR. WAT. PUMP START


NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	W	H	W	H	W	H
REV	DATE	DESCRIPTION	OWN	RE	CK	DPE	DPPE	LIE
		<i>W.K. Russell</i>						
		PROFESSIONAL ENGINEER	REG. NO.					
NUCLEAR SAFETY RELATED								
CAROLINA POWER & LIGHT COMPANY								
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.								
PLANT: BSEP			UNIT 1					
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL								
DWB. NO. T124-E-3002		SCALE: NONE			REV. NO. 0			
		SHEET 3 OF 36						

REV	QA	STRUC	MECH	ELECT	I&C






SAT FULL LOAD  
WITH REACTOR RECIRC. PUMP START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/94	ISSUE FOR NT-124	WG	WKR	WJ	MTN
REV	DATE	DESCRIPTION	DMN	RE	DPE	LE
DPE	WKR		CK	DPE		
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWB. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 4 OF 36			

REV	QA	STRUC	NUC	MECH	ELECT	I&C



**NOTES:**

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5 25 84	ISSUE FOR NT-124	WG	SP	WWR	WLP	HTN
REV	DATE	DESCRIPTION	CHK	RE	DPE	DPPE	LE
DPE <i>WKR</i>							
PROFESSIONAL ENGINEER				REG. NO.			
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
Dwg. NO. T124-E-3002				SCALE: NONE		REV. NO. 0	
				SHEET 5 OF 34			

1 2 3 4 5

H H

G G

F F


E E

D D

C C

B B

A A




NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	GA	STRUC	MJC	MECH	ELECT	JAC

0	5/25/84	ISSUE FOR NT-124	W	G	W	W	W	W	W
REV	DATE	DESCRIPTION	OWN	RE	OPPE	LE			
DPE	WIK/Runell		CK	DPE	OPPE	LE			
PROFESSIONAL ENGINEER			RES. NO.						
NUCLEAR SAFETY RELATED									
CAROLINA POWER & LIGHT COMPANY									
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.									
PLANT: BSEP					UNIT 1				
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL									
DWR. NO. T124-E-3002			SCALE: NONE			REV. NO. 0			
SHEET 6 OF 36									



SAT 230/4.16KV

1 SWVD. (230KV)

102

103

3

Z = 0.0006018 + j0.0045288

S = 0.00

4 1C, 1D, E1, E2, COMMON B, COMMON A (4160V BUS)

S = 15.3570  
PF = 0.87

4160/480V TYP.

5 ES

8 E6

6 1E

7 1F

12 COM-C

10 1L

11 3L

9 15Y

45 CSP-1B

1060 HP

SEE SHEET 19 & 20

SEE SHEET 23 & 24

SEE SHEET 27 & 28

SEE SHEET 30

SEE SHEET 31

SEE SHEET 35

SEE SHEET 34

SEE SHEET 33

SAT-LOCA RUN WITH 4TH CIRC. WATER PUMP - START

41 Z = 0.03654 + j0.04456

41 CMP-1D

2200 HP

42 Z = 0.02682 + j0.02040

42 RHR-1C

1000 HP

43 Z = 0.01978 + j0.01254

43 RHR-1D

1000 HP

44 Z = 0.03941 + j0.02790

44 CSP-1A


1060 HP

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	W	G					
REV	DATE	DESCRIPTION	CHK	APP	DRN	RE	OPPE	LE	
DPE <i>W.K. Russell</i>									
PROFESSIONAL ENGINEER			REG. NO.						
NUCLEAR SAFETY RELATED									
CAROLINA POWER & LIGHT COMPANY									
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.									
PLANT: BSEP					UNIT 1				
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL									
DWG. NO. T124-E-3002							SCALE: NONE		REV. NO. 0
							SHEET 7 OF 36		

REV	QA	STRUC	MECH	ELECT	I&C



S = 13.240  
PF = 0.88

4160/480V  
TYP.

Z = 0.0006018 + j0.0045288

S = 0.00

Z = 0.0002127 + j0.002151

(4160V BUS)


SAT-LOCA RUN WITH 3RD  
CIRC. WATER PUMP - START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	WG	HTIN
REV	DATE	DESCRIPTION	CHK	RE
DPE	WK Russell		CK	DPE
PROFESSIONAL ENGINEER			REG. NO.	
NUCLEAR SAFETY RELATED				
CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.				
PLANT: BSEP		UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
DWP. NO. T124-E-3002			SCALE: NONE	
			SHEET 8 OF 36	
			REV. NO. 0	

REV	GA	STRUC	NUC	MEDH	ELECT	T&C




SAT-SHUTDOWN

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #

0	5 25 84	ISSUE FOR NT-124	WG	WKR	WJN
REV	DATE	DESCRIPTION	DMN	RE	OPPE
DPE		<i>WK Russell</i>	OK	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. NO. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 9 OF 36		

REV	GA	STRUC	NUC	MECH	ELECT	I&C




UAT FULL LOAD

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #

0	5/25/84	ISSUE FOR NT-124	WG	WTKR	WJ	HITN
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE
DPE <i>W.K. Russell</i>			CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 10 OF 36			

REV	QA	STRUC	NUC	MECH	ELECT	I&C



UAT FULL LOAD WITH 4TH CIRC. WATER PUMP START


NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP ARE IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	WG	WKR	WR	WITN
REV	DATE	DESCRIPTION	DMN	RE	DPE	LE
DPE	<i>WKR</i>		CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE:			ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL			
Dwg. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 11 OF 36			

REV	GA	STRUC	NUC	MECH	ELECT	INC






UAT FULL LOAD WITH REACTOR RECIRC. PUMP START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	MUC	MECH	ELECT	IMC

0	5/25/84	ISSUE FOR NT-124	W.G.	HTIN	HTIN	
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
DPE	<i>W.K. Russell</i>		OK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DMS. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 12 OF 36			




UAT FULL LOAD WITH 3RD CIRCULATING WATER PUMP START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS IN DESIGN BRAKE HORSEPOWER

0	5/25/84	ISSUE FOR NT-124	WG	WJ	HTTN	
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
DPE <i>WKR</i>			OK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWG. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 13 OF 36			

REV	QA	STRUC	NAJC	MECH	ELECT	I&C




UAT LIGHT LOAD

NOTES:

1. IMPEDANCES ARE IN OHMS
2. LOADS (S) ARE IN MVA
3. ○ REFERENCES COMPUTER MODEL BUS #

0	5/25/84	ISSUE FOR NT-124	W	HTIN
REV	DATE	DESCRIPTION	DMN	RE
		<i>WKR</i>	CK	DPE
PROFESSIONAL ENGINEER			REG. NO.	
NUCLEAR SAFETY RELATED				
CAROLINA POWER & LIGHT COMPANY				
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.				
PLANT: BSEP		UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
DWS. NO. T124-E-3002			SCALE: NONE	
			REV. NO. 0	

REV	QA	STRUC	NUC	MECH	ELECT	I&C



480V UNIT SUBSTATION "E5" LOADS  
RBCW-1A PUMP START


NOTES:

1. IMPEDANCES ARE IN OHMS
2. S1 = LOADS AT FULL LOAD IN KVA
3. ○ REFERENCES COMPUTER MODEL BUS #
4. HP IS DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	W	G	MTN	WKR	MTN
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE	
DPE	<i>W.R. Russell</i>		CK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			RES. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
Dwg. No. T124-E-3002				SCALE: NONE		REV. NO. 0	
				SHEET 15 OF 36			

CONTINUED FROM SHEET 15



480V UNIT SUBSTATION "E5" LOADS  
RBCW-1A PUMP START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. S1 = LOADS AT FULL LOAD IN KVA
3. ○ REFERENCES COMPUTER MODEL BUS #

REV	QA	STRUC	MJC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	WG	WJW	WKR	R	MTW
REV	DATE	DESCRIPTION	DMN	RE	CK	DPE	DPPE
DPE <i>WKR</i>			OK	DPE	DPPE	LE	
PROFESSIONAL ENGINEER		REG. NO.					
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
DWG. NO. T124-E-3002		SCALE: NONE		SHEET 16 OF 36		REV. NO. 0	


1 2 3 4 5

5

480V UNIT SUBSTATION E5

CONTINUED ON SHEET 18

75.0KVA  
PF=1.00  
(STATIC LOAD)



S1=10.80 S2=10.80 PF=0.85	S1=30.49 S2=33.45 PF=0.85	S1=100.45 S2=1.65 PF=0.85	S1=160.10 S2=126.41 PF=0.85	S1=34.49 S2=44.48 PF=0.85
---------------------------------	---------------------------------	---------------------------------	-----------------------------------	---------------------------------

480V UNIT SUBSTATION "E5" LOADS

NOTES:


1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA

REV	GA	STRUC	MUC	MECH	ELECT	IMC

0	5/25/84	ISSUE FOR NT-124	W B	W B	W B	W B
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
DPE		W K	CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWG. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
					SHEET 17 OF 36	

1 2 3 4 5

CONTINUED FROM SHEET 17



480V UNIT SUBSTATION "E5" LOADS  
FUEL POOL COOLING PUMP-1A PUMP START

NOTES:

1. IMPEDANCES OR IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER


REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	WG	SMITH	WKR	WITN
REV	DATE	DESCRIPTION	CHK	RE	OPR	LE
DPE		<i>W.K. Russell</i>				
PROFESSIONAL ENGINEER						
REG. NO.						
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWS- T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 18 OF 36			

5

480V UNIT SUBSTATION E5

CONTINUED ON SHEET 20



480V UNIT SUBSTATION "E5" LOADS

NOTES:


1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	MISC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	WG	WKA	WKA	HITN
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE
DPE	UK Russell		CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 19 OF 36			



CONTINUED FROM SHEET 19




480V UNIT SUBSTATION "E5" LOADS

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	MJC	MECH	ELECT	I&C

0	5 25 84	ISSUE FOR NT-124	W G	S. H. HITTIN	HTIN
REV	DATE	DESCRIPTION	DWN	RE	LE
DPE	WK Russell		CK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWS. NO. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 20 OF 36		




480V UNIT SUBSTATION "E6" LOADS  
FUEL POOL COOLANT PUMP - 1B START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCE'S COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	WG	ATTN	WKR	HITN
REV	DATE	DESCRIPTION	CHK	RE	DPE	LE
		<i>WK Rurall</i>				
PROFESSIONAL ENGINEER		REG. NO.				
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWG. NO. T124-E-3002			SCALE: NONE		REV. 0	
			SHEET 21 OF 36			




480V UNIT SUBSTATION "E6" LOADS  
FUEL POOL COOLANT PUMP - 1B START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	MJC	MECH	ELECT	IAC

0	5/25/84	ISSUE FOR NT-124	WJG	WJK	WJK	HITN
REV	DATE	DESCRIPTION	DNW	RE	OPPE	LE
OPR	WK Rummel		CK	OPR	OPPE	LE
PROFESSIONAL ENGINEER			RES. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWP. NO. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 22 OF 36			



CONTINUED ON SHEET 24

480V UNIT SUBSTATION "E6" LOADS

NOTES:


1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	MISC	MEDH	ELECT	INSTR

0	5/25/84	ISSUE FOR NT-124	<i>WKR</i>	<i>HITN</i>
REV	DATE	DESCRIPTION	CHK	DATE
DPE	<i>WKR</i>		OK	DPE
PROFESSIONAL ENGINEER		REG. NO.		
NUCLEAR SAFETY RELATED				
CAROLINA POWER & LIGHT COMPANY				
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.				
PLANT: BSEP		UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
DWG. NO. T124-E-3002		SCALE: NONE		REV. NO. 0
SHEET 23 OF 36				

CONTINUED FROM SHEET 23

480V UNIT SUBSTATION E6




480V UNIT SUBSTATION "E6" LOADS

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	W	G	HTN
REV	DATE	DESCRIPTION	OWN	RE	LE
DPE	WKRussell		CK	OPR	OPPE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWB. NO. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 24 OF 36		



CONTINUED ON SHEET 26


480V UNIT SUBSTATION "E6" LOADS  
RBCCW PUMP - 1B START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NAJ	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	WG	WKR	WITN
REV	DATE	DESCRIPTION	CHK	PRE	OPR
DPE	WKR		CK	PRE	LE
PROFESSIONAL ENGINEER			RES. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 25 OF 36		



480V UNIT SUBSTATION "E6" LOADS  
RBCCW PUMP - 1B START


NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5/25/84	ISSUE FOR NT-124	W	W	W	W
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
DPE	<i>W.R. Russell</i>		CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 26 OF 36			

1 2 3 4 5



480V UNIT SUBSTATION "1E" LOADS

**NOTES:**

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA


REV	QA	STRUC	M/C	M/ECH	ELECT	I/C	

0	5/25/84	ISSUE FOR NT-124	G W	SAP/TK W/K	HITN
REV	DATE	DESCRIPTION	CHK	RE	OPPE
DPE		<i>WKR</i>	OK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 27 OF 36		



1 2 3 4 5

H H



S1=237.12 S1=272.98  
 S2=237.12 S2=272.98  
 S3=226.66 S3=34.94  
 PF=0.85 PF=0.85

480V UNIT SUBSTATION "1E" LOADS

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
 S2 = LOADS AT LOCA IN KVA  
 S3 = LOADS AT SHUTDOWN IN KVA

REV	DA	STRUC	MJC	HEGH	ELECT	I&C

ISSUE FOR NT-124		W	H	H	H
REV	DATE	DESCRIPTION		CHK	DATE
DPE	<i>W.R. Russell</i>			OK	
PROFESSIONAL ENGINEER				REG. NO.	
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. No. T124-E-3002				SCALE: NONE	
				REV. NO. 0	
				SHEET 28 OF 36	

1 2 3 4 5

H H

G G

F F


E E

D D

C C

B B

A A



480V UNIT SUBSTATION "1F" LOADS  
STATOR COOLANT PUMP - 1B START

NOTES:

1. IMPEDANCES OR IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S2 = LOADS AT LOCA IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	GA	STRUC	NUC	MECH	ELECT	T&C

0	5/25/84	ISSUE FOR NT-124	WG	SPH	HTIN
REV	DATE	DESCRIPTION	OWN	RE	LE
DPE	<i>WK Russell</i>		CK	DPE	OPPE
PROFESSIONAL ENGINEER			RES. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0
SHEET 29 OF 36					

1 2 3 4 5

1 2 3 4 5

H

H

G

G

F

F

E

E

D

D


C

C

B

B

A



480V UNIT SUBSTATION "1F" LOADS

NOTES:

1. IMPEDANCES OR IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD, LIGHT LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5 25 84	ISSUE FOR NT-124	G W	D M T N	W K R	J H T N
REV	DATE	DESCRIPTION	D M N	R E	O P E	L E
DPE		<i>W.K. Russell</i>	C K	O P E	O P P E	L E
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 1			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0	
			SHEET 30 OF 36			

1 2 3 4 5

1 2 3 4 5

H H

G G

F F

E E

D D


C C

B B

A A

⑫

480V UNIT SUBSTATION COMMON-C



480V UNIT SUBSTATION "COMMON-C" LOADS

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA


REV	QA	STRUC	MJC	MEGH	ELECT	ISC	

0	5/25/94	ISSUE FOR NT-124	W G	MTM	HTM
REV	DATE	DESCRIPTION	DWN	RE	LE
DPE <i>WK Russell</i>			CK	DPE	OPPE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWG. NO. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 31 OF 36		

1 2 3 4 5

12

### 480V UNIT SUBSTATION COMMON-C



480V UNIT SUBSTATION "COMMON-C" LOADS  
SCREEN WASH PUMP MOTOR - 1A START

#### NOTES:


1. IMPEDANCES OR IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	MJC	MECH	ELECT	IAC

0	5/25/84	ISSUE FOR NT-124	W	W	W	W	W	W
REV	DATE	DESCRIPTION	CHK	RE	DPE	DPPE	LE	
DPE	<i>WKR</i>							
PROFESSIONAL ENGINEER			REG. NO.					
NUCLEAR SAFETY RELATED								
CAROLINA POWER & LIGHT COMPANY								
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.								
PLANT: BSEP			UNIT 1					
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL								
DWO. NO. T124-E-3002			SCALE: NONE			REV. NO. 0		
SHEET 32 OF 36								

1 2 3 4 5

H H



480V UNIT SUBSTATION "1SY" LOADS

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
 S2 = LOADS AT LOCA IN KVA  
 S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5 25 84	ISSUE FOR NT-124	WG	HTM	WKR	HTM
REV	DATE	DESCRIPTION	DAW	RE	DPE	LE
DPE	WK Russell		CK	DPE	DPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT:	BSEP		UNIT 1			
TITLE:	ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWG. NO.:	T124-E-3002				SCALE:	NONE
					SHEET	33 OF 36
					REV. NO.:	0

1 2 3 4 5

1 2 3 4 5

H H

G G

F F


E E

D D

C C

B B

A A



480V UNIT SUBSTATION "3L" LOADS

NOTES:

- 1. IMPEDANCES ARE IN OHMS
- 2. ○ REFERENCES COMPUTER MODEL BUS #
- 3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	NUC	MECH	ELECT	IMC

0	5/25/84	ISSUE FOR NT-124	W/B	HTTN	HTTN
REV	DATE	DESCRIPTION	DMH	RE	OPPE
DPE	W.K. Russell		OK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
Dwg. No. T124-E-3002			SCALE: NONE		REV. NO. 0
			SHEET 34 OF 36		

1 2 3 4 5

1

2

3

4

5

H

H

G

G

F

F

E

E

D

D

C

C

B

B

A

10

### 480V UNIT SUBSTATION 1L

849KVA  
PF=1.0  
(STATIC LOAD)

0.009684 + j0.007161

101

MCC-1TM

S1=220.20  
S2=220.20  
S3=4.5  
PF=0.85

### 480V UNIT SUBSTATION "1L" LOADS

#### NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
S2 = LOADS AT LOCA IN KVA  
S3 = LOADS AT SHUTDOWN IN KVA

REV	QA	STRUC	NUC	MECH	ELECT	I&C	

0	5 25 84	ISSUE FOR NT-124	W	B	HTN	
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
DPE	<i>W.R. Russell</i>		CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER		REG. NO.				
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP		UNIT 1				
TITLE:		ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
Dwg. No. T124-E-3002		SCALE: NONE		REV. NO. 0		
		SHEET 35 OF 36				



1

2

3

4

5

H

H

G

G

F

F

E

E

D

D


C

C

B

B

A




480V UNIT SUBSTATION "1L" LOADS  
 TURBINE BLDG. CLOSED COOLING  
 WATER PUMP - 1B START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. S1 = LOADS AT FULL LOAD IN KVA  
 S2 = LOADS AT LOCA IN KVA  
 S3 = LOADS AT SHUTDOWN IN KVA
4. HP IS IN DESIGN BRAKE HORSEPOWER

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	5 25 84	ISSUE FOR NT-124	WG	HTN	HTN
REV	DATE	DESCRIPTION	DMN	RE	OPPE
DPE	WKRussell		CK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 1		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DMS. NO. T124-E-3002			SCALE: NONE		REV. NO. 0
SHEET 36 OF 36					




**NOTES:**

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. HP ARE IN DESIGN BRAKE HORSEPOWER
4. RRP-2B MOTOR STARTS IN ASDOP CASE 2SAT-7
5. CWP-2B MOTOR STARTS IN ASDOP CASE 2SAT-4
6. S1 & PF1 ARE USED FOR ASDOP CASE 2SAT-4 AND S2 & PF2 ARE USED FOR ASDOP CASE 2SAT-3, 2SAT-1

REV	QA	STRUC	M&C	MECH	ELECT	I&C

0	20 94	ISSUE FOR NT-124	WG	NITM
REV	DATE	DESCRIPTION	CHK	RE
DPE		<i>W.K. Russell</i>	CK	DPE
PROFESSIONAL ENGINEER			REG. NO.	
NUCLEAR SAFETY RELATED				
CAROLINA POWER & LIGHT COMPANY				
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.				
PLANT: BSEP		UNIT 2		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL				
DWD. NO. T124-E-3001			SCALE: NONE	
			SHEET 1 OF 21	
			REV. NO. 0	




SAT LOCA START

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. HP ARE IN DESIGN BRAKE HORSEPOWER
4. X INDICATES LOAD NOT OPERATING

REV	QA	STRUC	M&C	MECH	ELECT	I&C

0	20	84	ISSUE FOR NT-124	W O	W O	W O	W O
REV	DATE	DESCRIPTION	DWN	RE	OPPE	LE	
DPE	WK Russell		OK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
DWS. NO. T124-E-3001				SCALE: NONE		REV. 0	
						SHEET 2 OF 21	




NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. HP ARE IN DESIGN BRAKE HORSEPOWER
4. X INDICATES LOAD NOT OPERATING
5. CWP-2B MOTOR STARTS IN ASDOP CASE 2SAT-13
6. S1 & PF1 ARE USED FOR ASDOP CASE 2SAT-13 AND S2 & PF2 ARE USED FOR ASDOP CASE 2SAT-12, 2SAT-11

SAT LOCA RUN

0	20	94	ISSUE FOR NT-124	W	G	W	W	W	W
REV	DATE	DESCRIPTION	CHK	RE	CHK	CHK	CHK	CHK	CHK
DPE <i>W.R. Russell</i>			CHK	RE	CHK	CHK	CHK	CHK	CHK
PROFESSIONAL ENGINEER			REG. NO.						
NUCLEAR SAFETY RELATED									
CAROLINA POWER & LIGHT COMPANY									
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.									
PLANT: BSEP					UNIT 2				
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL									
Dwg. NO. T124-E-3001			SCALE: NONE			REV. 0			
			SHEET 3 OF 21						

REV	QA	STRUC	MJC	HECH	ELECT	I&C




SAT SHUTDOWN

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. HP ARE IN DESIGN BRAKE HORSEPOWER
4. X INDICATES LOAD NOT OPERATING

REV	SA	STRUC	NUC	MECH	ELECT	JAC

0	4/20/84	ISSUE FOR NT-124	WG	WIP	ATTN	WIP	WIP	HITN
REV	DATE	DESCRIPTION	CHK	RE	OPR	OPPE	LE	
DPE <i>W.K. Russell</i>			CHK	RE	OPR	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.					
NUCLEAR SAFETY RELATED								
CAROLINA POWER & LIGHT COMPANY								
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.								
PLANT: BSEP			UNIT 2					
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL								
DPE NO. T124-E-3001			SCALE: NONE			REV. NO. 0		
			SHEET 4 OF 21					




UAT FULL LOAD

NOTES:

1. IMPEDANCES ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #
3. HP ARE IN BRAKE HORSEPOWER
4. CWP-2B MOTOR STARTS IN ASDOP CASE 2UAT-4
5. RRP-2B MOTOR STARTS IN ASDOP CASE 2UAT-5
6. S1&PF1 ARE THE LOADS AND PF AT 4160V BUS FOR ASDOP CASE 2UAT-4 AND S2&PF2 ARE FOR ASDOP CASE 2UAT-3, 2UAT-1

REV	BY	STRUC	MJC	MECH	ELECT	J&C

0	4/20/84	ISSUE FOR NT-124	M	B	W	W	HTN
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE	
DPE	<i>WK Russell</i>		CK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
<b>CAROLINA POWER &amp; LIGHT COMPANY</b>							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT:	BSEP		UNIT 2				
TITLE:	ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DMN NO.	T124-E-3001		SCALE:	NONE		REV. NO.	0
			SHEET 5 OF 21				



NOTES:

1. IMPEDANCE ARE IN OHMS
2. ○ REFERENCES COMPUTER MODEL BUS #


0	4/20/84	ISSUE FOR NT-124	W/G	CHK	RE	OPPE	LE
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE	
DPE	<i>AK Russell</i>		CHK	RE	OPPE	LE	
PROFESSIONAL ENGINEER			RES. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
Dwg. NO. T124-E-3001						SCALE: NONE	
						SHEET 6 OF 21	
						REV. NO. 0	

REV	QA	STRUC	MJC	MECH	ELECT	TAC

5

480V UNIT SUBSTATION E7

CONTINUED ON SHEET 8



480V UNIT SUBSTATION "E7" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)


REV	QA	STRUC	MJC	MECH	ELECT	I&C

0	4/20/84	ISSUE FOR NT-124	W	HITN
REV	DATE	DESCRIPTION	DMN	RE
DPE	<i>WK Russell</i>		CK	DPE
PROFESSIONAL ENGINEER		REG. NO.		
NUCLEAR SAFETY RELATED				
CAROLINA POWER & LIGHT COMPANY				
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.				
PLANT:	BSEP		UNIT 2	
TITLE:	ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL			
DMN. NO.	T124-E-3001		SCALE:	NONE
			SHEET	7 OF 21
			REV. NO.	0



CONTINUED FROM SHEET 7

480V UNIT SUBSTATION E7




480V UNIT SUBSTATION "E7" LOADS

NOTES:

- ALL S1, S2, S3 ARE IN KVA
- S1 = LOADS AT FULL LOAD, UAT-LIGHT LOAD CONDITION
- S2 = LOADS AT LOCA CONDITION
- S3 = LOADS AT SAT-SHUTDOWN CONDITION (LIGHT LOAD)

REV	QA	STRUC	NUC	MECH	ELECT	IAC

0	4 20 94	ISSUE FOR NT-124	WG -LP	HLLP -DKR	WAK -MTN	
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE
DPE	WK Russell		CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWS. NO. T124-E-3001			SCALE: NONE		REV. 0	
			SHEET 8 OF 21		NO.	



CONTINUED ON SHEET 10

480V UNIT SUBSTATION "E8" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)


REV	QA	STRUC	MJC	MECH	ELECT	IAC

0	20 84	ISSUE FOR NT-124	W/B	HTM	HTM
REV	DATE	DESCRIPTION	CHK	RE	LE
DPE	<i>W.R. Russell</i>		CK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 2		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWS NO. T124-E-3001			SCALE: NONE		REV. NO. 0
			SHEET 9 OF 21		

1 2 3 4 5

CONTINUED FROM SHEET 9

480V UNIT SUBSTATION E8




480V UNIT SUBSTATION "E8" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD, UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN CONDITION (LIGHT LOAD)

0	20	84	ISSUE FOR NT-124	W	C	W	H	H	N
REV	DATE	DESCRIPTION		DMH	RE	DPE	DPPE	LE	
DPE	WK Russell			OK					
PROFESSIONAL ENGINEER				REG. NO.					
NUCLEAR SAFETY RELATED									
CAROLINA POWER & LIGHT COMPANY									
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.									
PLANT: BSEP					UNIT 2				
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL									
DWS. NO. T124-E-3001				SCALE: NONE			REV. NO. C		
				SHEET 10 OF 21					

REV	QA	STR C	MJC	NEGH	ELECT	IAC




480V UNIT SUBSTATION "2E" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	QA	STRUC	MJC	MECH	ELECT	I&C

0	4/20/84	ISSUE FOR NT-124	WG	MTN	WKR	WKR	MTN
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE	
DPE		<i>WK Russell</i>	CK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
DWG. NO. T124-E-3001			SCALE: NONE			REV. NO. 0	
SHEET 11 OF 21							

CONTINUED FROM SHEET 11



480V UNIT SUBSTATION "2E" LOADS


NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	SA	STRAC	HJC	MEGH	ELECT	T&C

0	4/20/84	ISSUE FOR NT-124	WG	HTL	WWR	WUP	HTM
REV	DATE	DESCRIPTION	CHK	RE	OPR	OPPE	LE
OPR	WK Russell		CK	OPR	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
Dwg. No. T124-E-3001						SCALE: NONE	
						REV. 0	
						SHEET 12 OF 21	

7

480V UNIT SUBSTATION 2F




480V UNIT SUBSTATION "2F" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	SA	STRUC	NUC	MECH	ELECT	I&C

0	4/20/84	ISSUE FOR NT-124	W	W	W	W	HTTN
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE	
DPE	<i>W.R. Russell</i>		CK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
Dwg. No. T124-E-3001						SCALE: NONE	
						SHEET 13 OF 21	
						REV. NO. 0	




480V UNIT SUBSTATION "COMMON D" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	4/20/84	ISSUE FOR NT-124	WG	WTK	WJF	HTH
REV	DATE	DESCRIPTION	DRN	RE	OPR	LE
DPE		<i>WK Russell</i>	CK	OPR	OPPE	LE
PROFESSIONAL ENGINEER			RES. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWS NO. T124-E-3001			SCALE: NONE		REV. 0	
SHEET 14 OF 21						



480V UNIT SUBSTATION "COMMON D" LOADS AT SCREEN WASH PUMP START

NOTES:  
 1. S1 = LOADS AT FULL LOAD IN KVA  
 2. HP IS IN BRAKE HORSEPOWER

REV	GA	STRUC	M/C	MECH	ELECT	IAC


0	5/25/84	ISSUE FOR NT-124	WG	WKR	HTN
REV	DATE	DESCRIPTION	CHK	RE	OPPE
DPE	W.R. Russell		CK	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.		
NUCLEAR SAFETY RELATED					
CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.					
PLANT: BSEP			UNIT 2		
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL					
DWS NO. T124-E-3001			SCALE: NONE		REV. 0
			SHEET 14A OF 21		



1 2 3 4 5

H H

⑨ 480V UNIT SUBSTATION 2SY



S1=152.29	S1=105.41
S2=152.29	S2=105.41
S3=152.29	S3=105.41
PF=0.85	PF=0.85

480V UNIT SUBSTATION "2SY" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	QA	STRUC	MJC	HIGH	ELECT	IMC

0	4/20/84	ISSUE FOR NT-124	W	W	W	HTTN
REV	DATE	DESCRIPTION	DMN	RE	OPPE	LE
OPPE		<i>W Russell</i>	CK	OPPE		
PROFESSIONAL ENGINEER		REG. NO.				
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DMN NO. T124-E-3001		SCALE: NONE			REV. NO. 0	
SHEET 15 OF 21						

C C


D D

E E

F F

G G

1 2 3 4 5




480V UNIT SUBSTATION "2L" LOADS

NOTES:  
 ALL S1, S2, S3 ARE IN KVA  
 S1 = LOADS AT FULL LOAD,  
 UAT-LIGHT LOAD CONDITION  
 S2 = LOADS AT LOCA CONDITION  
 S3 = LOADS AT SAT-SHUTDOWN  
 CONDITION (LIGHT LOAD)

REV	QA	STRUC	M/C	MECH	ELECT	I&C

0	20 84	ISSUE FOR NT-124	WJ	WJ	WJ	WJ	WJ
REV	DATE	DESCRIPTION	CHK	APP	OPPE	LE	
DPE	WK Russell		OK	DPE	OPPE	LE	
PROFESSIONAL ENGINEER			REG. NO.				
NUCLEAR SAFETY RELATED							
CAROLINA POWER & LIGHT COMPANY							
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.							
PLANT: BSEP				UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL							
DWG. NO. T124-E-3001			SCALE: NONE			REV. NO. 0	
						SHEET 16 OF 21	




CONTINUED  
ON  
SHEET  
8

NOTES:  
ALL S1, S2 ARE IN KVA  
S1 = LOADS AT FULL LOAD  
S2 = LOADS AT LOCA CONDITION  
Z = IMPEDANCE (IN OHMS)

0	20 84	ISSUE FOR NT-124	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
REV	DATE	DESCRIPTION	CHK	RE	CHK	CHK	CHK	CHK
DPE		<i>WK Russell</i>						
PROFESSIONAL ENGINEER		RES. NO.						
NUCLEAR SAFETY RELATED								
PLANT:		BSEP	UNIT 2					
TITLE:		ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWS NO.		T124-E-3001				SCALE: NONE		REV. NO. 0
						SHEET 17 OF 21		

REV	SA	STRUC	MISC	MECH	ELECT	ISC

CONTINUED FROM SHEET 7




480V UNIT SUBSTATION "E7" LOADS  
 AT FUEL POOL CLEANING PUMP MOTOR 2A START

NOTES:  
 ALL S1, S2 ARE IN KVA  
 S1 = LOADS AT FULL LOAD  
 S2 = LOADS AT LOCA CONDITION  
 Z = IMPEDANCE (IN OHMS)

REV	SA	STRUC	MIC	MECH	ELECT	IMC

0	20	84	ISSUE FOR NT-124	W	M	W	W	W	W
REV	DATE	DESCRIPTION	CHK	RE	CHK	CHK	CHK	CHK	CHK
		<i>WKRussell</i>							
PROFESSIONAL ENGINEER			REG. NO.						
NUCLEAR SAFETY RELATED									
CAROLINA POWER & LIGHT COMPANY									
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.									
PLANT: BSEP					UNIT 2				
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL									
DWG. NO. T124-E-3001			SCALE: NONE			REV. 0			
			SHEET 19 OF 21						




480V UNIT SUBSTATION "2F" LOADS  
AT STATOR COOLANT PUMP 2B MOTOR START

NOTES:  
ALL S2 ARE IN KVA  
S2 = LOADS AT LOCA CONDITION  
Z = IMPEDANCE (IN OHMS)

REV	SA	STRUC	MJC	MECH	ELECT	16C

0	20 84	ISSUE FOR NT-124	WG	REVIS	WUP	HTIN
REV	DATE	DESCRIPTION	CHK	RE	DPE	LE
DPE	<i>W.K. Russell</i>		CK	DPE	DPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
Dwg. No. T124-E-3001			SCALE: NONE		REV. NO. 0	
			SHEET 19 OF 21			



480V UNIT SUBSTATION "2L" LOADS AT TBCCW-2B MOTOR START


NOTES:  
 ALL S1, S2 ARE IN KVA  
 S1 = LOADS AT FULL LOAD  
 S2 = LOADS AT LOCA CONDITION  
 Z = IMPEDANCE (IN OHMS)

REV	QA	STRUC	M/C	MECH	ELECT	I&C	

0	4/20/84	ISSUE FOR NT-124	WG	WPK	WUP	WITN
REV	DATE	DESCRIPTION	CHK	RE	OPPE	LE
DPE <i>W.K. Russell</i>			CK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWG. NO. T124-E-3001			SCALE: NONE		REV. NO. 0	
					SHEET 20 OF 21	

CONTINUED FROM SHEET 9

480V UNIT SUBSTATION E8



480V UNIT SUBSTATION "E8" LOADS AT FUEL POOL CLEANING PUMP MOTOR 2B START

NOTES:  
 ALL S1, S2 ARE IN KVA  
 S1 = LOADS AT FULL LOAD  
 S2 = LOADS AT LOCA CONDITION  
 Z = IMPEDANCE (IN OHMS)

REV	QA	STRUC	NUC	MECH	ELECT	I&C

0	20 84	ISSUE FOR NT-124	WG	HITN	W&P	HITN
REV	DATE	DESCRIPTION	DMH	RE	OPPE	LE
DPE		<i>WKRussell</i>	OK	DPE	OPPE	LE
PROFESSIONAL ENGINEER			REG. NO.			
NUCLEAR SAFETY RELATED						
CAROLINA POWER & LIGHT COMPANY						
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N.C.						
PLANT: BSEP			UNIT 2			
TITLE: ELECTRICAL DISTRIBUTION SYSTEM STUDY LOAD MODEL						
DWG. NO. T124-E-3001			SCALE: NONE		REV. NO. 0	
			SHEET 21 OF 21			

12.0 APPENDIX F  
MOTOR ACCELERATION TIMES AND RELAY CHARACTERISTICS



Computed by: J.A. KOWALCHEK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5-30-84		Pg. 1 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

A GRAPHICAL METHOD FOR PREDICTING INDUCTION MOTOR ACCELERATION TIME IS PRESENTED IN REFERENCE NO. 1. THIS METHOD WILL YIELD THE ACCELERATION TIME, IN SECONDS, IF THE FOLLOWING UNITS ARE USED:

<u>VARIABLE</u>	<u>UNIT</u>
MOTOR TORQUE (T)	NEWTON-METER
MOMENT OF INERTIA (WR <sup>2</sup> )	KILOGRAM-METER <sup>2</sup>
MOTOR SPEED	RADIANS/SECOND

REFERENCE NO. 2 APPLIES A FACTOR TO THE ABOVE METHOD FOR USE WITH THE U.S. CUSTOMARY SYSTEM AS FOLLOWS:

$$\text{EQ\#1: TIME (SEC.)} = 0.00325 \frac{\text{CHANGE IN RPM} \times \text{WR}^2}{T \text{ AVAILABLE FOR ACCELERATION}}$$

AND BASED ON THE FOLLOWING UNITS:

<u>VARIABLE</u>	<u>UNIT</u>
MOTOR TORQUE (T)	POUND- FEET (LB-FT.)
MOMENT OF INERTIA (WR <sup>2</sup> )	POUND- FEET <sup>2</sup> (LB-FT <sup>2</sup> )
MOTOR SPEED	REVOLUTIONS/MINUTE (RPM)

REFERENCE NO. 3 DEMONSTRATES A TABULAR METHOD FOR CALCULATING THE ACCELERATION TIME. THE EQUATION USED IS IDENTICAL WITH THAT USED IN REFERENCE NO. 2; WITH THE EXCEPTION THAT THE CONSTANT VALUE OF 0.00325 IS MOVED FROM THE NUMERATOR TO THE DENOMINATOR, SO THAT:

$$\text{EQ\#2: TIME (SEC.)} = \frac{\text{CHANGE IN RPM} \times \text{WR}^2}{308 \times T \text{ AVAILABLE FOR ACCELERATION}}$$

(CONTINUED)

Computed by: J.A. KOWALCHECK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 2 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

EQ#2 IS THE EQUATION USED IN THE "ELECTRONIC SPREADSHEETS" DEVELOPED FOR PREDICTING MOTOR ACCELERATION TIMES. IN ADDITION, THE SPREADSHEETS CLOSELY FOLLOW THE METHOD DESCRIBED IN REFERENCE #3.

THE VARIABLE "T" (MOTOR TORQUE) USED IN THE ABOVE EQUATIONS IS THE AVERAGE NET AVAILABLE TORQUE OVER A GIVEN SPEED RANGE. FOR THIS REASON, THE SPEED-TORQUE CURVE IS DIVIDED INTO 180 RPM (10% OF SYNCHRONOUS SPEED) SEGMENTS FROM 0 TO 1620 RPM (0-90%) AND 90 RPM SEGMENTS FROM 1620 TO 1800 RPM (90-100%). THESE AVERAGE MOTOR TORQUE AT A GIVEN SPEED, LESS THE AVERAGE LOAD TORQUE AT THE SAME SPEED IS THE AVERAGE NET TORQUE AVAILABLE.

THE VARIABLE " $WR^2$ " (MOMENT OF INERTIA) IS THE SUM OF THE MOMENTS OF INERTIA OF THE MOTOR ROTOR AND LOAD.

#### REFERENCES:

1. ELECTRIC MACHINERY; A.E. FITZGERALD, C. KINGSLEY, JR., A. KUSKO; MCGRAW-HILL; 1971; pp. 510-512.
2. ELECTRIC MOTORS AND THEIR APPLICATIONS; T.C. LLOYD; JOHN WILEY & SONS; 1969; pp. 98-100.
3. "CALCULATING TORQUE AND HEAT BUILD-UP DURING MOTOR STARTING"; W.C. BRODERICK; ELECTRICAL CONSTRUCTION AND MAINTENANCE; FEBRUARY 1979; pp. 79-81.

Computed by: J. A. Kowalchek	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 3 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

DATA REQUIREMENTS & EQUATIONS USED WITH MOTOR ACCELERATION TIME CALCULATIONS - DATA FROM FIGURES (SEE FIGURE 1).

(A) & (B) : VALUES FROM MOTOR DATA SHEETS

(C) & (D) : VALUES FROM LOAD DATA SHEETS

(E<sub>1</sub>), (E<sub>2</sub>), (E<sub>3</sub>) : PERCENT OF NOMINAL MOTOR VOLTAGE AT WHICH SPEED-TORQUE CURVES ARE SUPPLIED.

(F) : PERCENT OF MAXIMUM LOAD TORQUE; (C) (AVERAGE VALUE OVER CORRESPONDING SPEED RANGE.)

(G<sub>1</sub>), (G<sub>2</sub>), (G<sub>3</sub>) : PERCENT OF FULL-LOAD MOTOR TORQUE; (A) (AVERAGE VALUE OVER CORRESPONDING SPEED RANGE.)

(H<sub>1</sub>), (H<sub>2</sub>), (H<sub>3</sub>) : NET TORQUE AVAILABLE FOR ACCELERATION OVER CORRESPONDING SPEED RANGE AND MOTOR VOLTAGE.

e.g.: 
$$(H_1)^{0-10} = \left[ (G_1)^{0-10} \times (A) - [(F) \times (C)] \right] \div 100 \quad \text{ETC.}$$

CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY:  
 CHECKED BY:  
 PROJECT TITLE:  
 TAR NUMBER:  
 MOTOR NAME:

DATE:  
 DATE:

MOTOR FULL-LOAD TORQUE: (A) FT.-LBS.  
 MOTOR ROTOR INERTIA: (B) LBS.-FT.<sup>2</sup>  
 MAXIMUM LOAD TORQUE: (C) FT.-LBS.  
 LOAD INERTIA: (D) LBS.-FT.<sup>2</sup>

1	2	3	4	5	6	7	8	9	10	11				
MOTOR	LOAD	MOTOR	NET	ELAPSED	MOTOR	NET	ELAPSED	MOTOR	NET	ELAPSED				
SPEED	TORQUE	TORQUE	TORQUE	TIME	TORQUE	TORQUE	TIME	TORQUE	TORQUE	TIME				
(%)	(%)	(%)	(FT.-LBS.)	(SEC)	(%)	(FT.-LBS.)	(SEC)	(%)	(FT.-LBS.)	(SEC)				
0-10	(F) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>				
10-20	.	.	.	.	.	.	.	.	.	.				
20-30	.	.	.	.	.	.	.	.	.	.				
30-40	.	.	.	.	.	.	.	.	.	.				
40-50	.	.	.	.	.	.	.	.	.	.				
50-60	.	.	.	.	.	.	.	.	.	.				
60-70	.	.	.	.	.	.	.	.	.	.				
70-80	.	.	.	.	.	.	.	.	.	.				
80-90	.	.	.	.	.	.	.	.	.	.				
90-95	.	.	.	.	.	.	.	.	.	.				
95-100	.	.	.	.	.	.	.	.	.	.				
TOTAL TIME =				(K) <sub>1</sub> .00	TOTAL TIME =				(K) <sub>2</sub> .00	TOTAL TIME =				(K) <sub>3</sub> .00

↓  
 DATA  
 FROM  
 FIGURES  
 ↑

FIGURE # 1

Computed by: J.A. KOWALCZEK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 4 of 9	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY.				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

$(J_1), (J_2), (J_3)$  : ELAPSED TIME FOR ACCELERATION OVER CORRESPONDING SPEED RANGE AND MOTOR VOLTAGE.

e.g.: For 10% (180RPM) speed steps (0-10, 10-20, ... 80-90)

$$(J_1)^{0-10} = \left[ 180 \times [(B) + (D)] \right] \div \left[ 308 \times (H_1)^{0-10} \right] \text{ ETC.}$$

For 5% (90RPM) speed steps (90-95, 95-100)

$$(J_2)^{95-100} = \left[ 90 \times [(B) + (D)] \right] \div \left[ 308 \times (H_2)^{95-100} \right] \text{ ETC.}$$

$(K_1), (K_2), (K_3)$  : TOTAL TIME FOR ACCELERATION AT CORRESPONDING MOTOR VOLTAGE.

e.g.:  $(K_3) = (J_3)^{0-10} + (J_3)^{10-20} + \dots + (J_3)^{90-95} + (J_3)^{95-100} \text{ ETC.}$

NOTE: VALUES FOR (A) THROUGH (G<sub>i</sub>) ARE SUPPLIED BY THE USER. VALUES FOR (H<sub>i</sub>), (J<sub>i</sub>) & (K<sub>i</sub>) ARE CALCULATED BY THE SPREADSHEET PROGRAM.

Computed by: J.A. KOWALZHEK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 5 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

DATA REQUIREMENTS & EQUATIONS USED WITH MOTOR ACCELERATION TIME CALCULATIONS - DATA FROM CALCULATION (SEE FIGURE 2).

(A) & (B) : VALUES FROM MOTOR DATA SHEETS.

(C) & (D) : VALUES FROM LOAD DATA SHEETS.

(E<sub>1</sub>) : PERCENT OF NOMINAL MOTOR VOLTAGE AT WHICH SPEED-TORQUE INFORMATION IS AVAILABLE.

(E<sub>2</sub>) & (E<sub>3</sub>) : PERCENT OF NOMINAL MOTOR VOLTAGE FOR WHICH SPEED-TORQUE DATA IS CALCULATED.

(F) : PERCENT OF MAXIMUM LOAD TORQUE; (C) (AVERAGE VALUE OVER CORRESPONDING SPEED RANGE.)

(G<sub>1</sub>) : PERCENT OF FULL-LOAD MOTOR TORQUE; (A) (AVERAGE VALUE OVER CORRESPONDING SPEED RANGE.)

(G<sub>2</sub>) & (G<sub>3</sub>) : PERCENT OF FULL-LOAD MOTOR TORQUE; (A) (AVERAGE VALUE OVER CORRESPONDING SPEED RANGE.). CALCULATION IS BASED ON THE "INVERSE SQUARE" EFFECT ON MOTOR TORQUE.

e.g.: FOR MOTOR SPEED FROM 0 TO 9.5% OF FULL-LOAD SPEED.

$$(G_2)^{0-10} = [(E_2) \div (E_1)]^2 \times (G_1)^{0-10} \quad \text{ETC.}$$

(CONTINUED)

CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY:  
 CHECKED BY:  
 PROJECT TITLE:  
 TAR NUMBER:  
 MOTOR NAME:

DATE:  
 DATE:

MOTOR FULL-LOAD TORQUE: (A) FT.-LBS.  
 MOTOR ROTOR INERTIA: (B) LBS.-FT.<sup>2</sup>  
 MAXIMUM LOAD TORQUE: (C) FT.-LBS.  
 LOAD INERTIA: (D) LBS.-FT.<sup>2</sup>

1	2	3	4	5	6	7	8	9	10	11	
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	
0-10	(F) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>	(G) <sup>0-10</sup>	(H) <sup>0-10</sup>	(J) <sup>0-10</sup>	
10-20	.	.	.	.	.	.	.	.	.	.	
20-30	.	.	.	.	.	.	.	.	.	.	
30-40	.	.	.	.	.	.	.	.	.	.	
40-50	.	.	.	.	.	.	.	.	.	.	
50-60	.	.	.	.	.	.	.	.	.	.	
60-70	.	.	.	.	.	.	.	.	.	.	
70-80	.	.	.	.	.	.	.	.	.	.	
80-90	.	.	.	.	.	.	.	.	.	.	
90-95	.	.	.	.	.	.	.	.	.	.	
95-100	.	.	.	.	.	.	.	.	.	.	
TOTAL TIME = (K) <sub>1</sub> .00				TOTAL TIME = (K) <sub>2</sub> .00				TOTAL TIME = (K) <sub>3</sub> .00			

DATA FROM CALCULATION

FIGURE #2

Computed by: J. A. KOWALCZEK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 6 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

FOR MOTOR SPEED FROM 95 TO 100% OF FULL-LOAD SPEED, THE ABOVE EQUATION RESULTS IN AN EXCESSIVELY LOW VALUE OF MOTOR TORQUE AT MOTOR VOLTAGES BELOW NOMINAL. THIS IS BECAUSE THE MOTOR WILL REACH AN EQUILIBRIUM POINT (I.E.: STOP ACCELERATING) AT THE POINT WHERE THE AVAILABLE MOTOR TORQUE EQUALS THE REQUIRED LOAD TORQUE (SEE FIGURE #3)




FIGURE #3

FOR EXAMPLE, IN THE HYPOTHETICAL CASE SHOWN IN FIGURE #3, AN AVERAGE MOTOR TORQUE OF ABOUT 143% IS CHOSEN FOR THE RANGE OF 95 TO 100% SPEED AT FULL VOLTAGE. IF THE EQUATION ABOVE IS APPLIED IN THIS SITUATION THE CALCULATED MOTOR TORQUE AT 80% VOLTAGE WOULD BE:

(CONTINUED)



Computed by: J. A. Kowalcheck	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5-30-84		Pg. 7 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

$$\begin{aligned}
G_2^{95-100} &= \left[ \frac{E_2}{E_1} \right]^2 \times G_1^{95-100} \\
&= \left[ \frac{80}{100} \right]^2 \times 143\% \\
&= 91.5\%
\end{aligned}$$

THIS POINT IS SHOWN ON THE 80% VOLTAGE CURVE ON FIGURE #3. NOTE, HOWEVER, THAT IN THIS CASE IT COINCIDES WITH THE POINT AT WHICH THE LOAD CURVE CROSSES THE MOTOR TORQUE CURVE. IF THIS POINT IS ALSO CHOSEN FOR THE AVERAGE LOAD TORQUE, FOR THE 95 TO 100% SPEED RANGE, ZERO (0) NET TORQUE WOULD BE AVAILABLE FOR ACCELERATION. IN OTHER WORDS, IN THIS CASE WE WOULD NOT EXPECT THE MOTOR TO ACCELERATE BEYOND 95% SPEED AND WOULD NOT REACH A POINT OF STABILITY ON THE SPEED-TORQUE CURVE.

IN ORDER TO COMPENSATE FOR THE ABOVE SITUATION, AN ALTERNATE EQUATION IS USED FOR CALCULATING THE AVERAGE MOTOR TORQUE IN THE 95 TO 100% SPEED RANGE. BY TAKING THE MIDPOINT BETWEEN THE CALCULATED MOTOR TORQUE AT 90 TO 95%, AND THE LOAD TORQUE AT 95 TO 100%, AN APPROXIMATE MOTOR TORQUE FOR THE 95 TO 100% CAN BE CALCULATED. THEREFORE, IN THIS CASE:

$$\begin{aligned}
G_2^{95-100} &= \left[ G_2^{90-95} + \left[ F \times \left[ \frac{C}{A} \right] \right] \right] \div 2 \\
&= \left[ 105 + \left[ 92 \times \left[ \frac{95}{100} \right] \right] \right] \div 2 \\
&= 96.2\%
\end{aligned}$$

(CONTINUED)

Computed by: J.A. Kowalcheck	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5-30-84		Pg. 8 of 9	Rev. 0
TAR No.: NT-124			File: BNT-12A-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

THIS VALUE IS SHOWN AS POINT (X) ON FIGURE #3. BY INSPECTING FIGURE #3, IT CAN BE SEEN THAT THIS METHOD STILL PRODUCES A CONSERVATIVE VALUE FOR AVAILABLE MOTOR TORQUE AT 95 TO 100% SPEED.

(H<sub>1</sub>), (H<sub>2</sub>), (H<sub>3</sub>) : NET TORQUE AVAILABLE FOR ACCELERATION OVER CORRESPONDING SPEED RANGE AND MOTOR VOLTAGE.

e.g.:  $(H_1)^{0-10} = \left[ \left[ (G_1)^{0-10} \times (A) \right] - \left[ (F) \times (C) \right] \right] \div 100$  ETC.

(J<sub>1</sub>), (J<sub>2</sub>), (J<sub>3</sub>) : ELAPSED TIME FOR ACCELERATION OVER CORRESPONDING SPEED RANGE AND MOTOR VOLTAGE.

e.g.: FOR 10% (180RPM) SPEED STEPS (0-10, 10-20, ... 80-90)

$$(J_1)^{0-10} = \left[ 180 \times [(B) + (D)] \right] \div \left[ 308 \times (H_1)^{0-10} \right] \text{ ETC.}$$

FOR 5% (90RPM) SPEED STEPS (90-95, 95-100)

$$(J_2)^{95-100} = \left[ 90 \times [(B) + (D)] \right] \div \left[ 308 \times (H_2)^{95-100} \right] \text{ ETC.}$$

NOTE: FOR VALUES OF (H<sub>i</sub>) ≤ 0, N/A WILL BE PRINTED IN THE ELAPSED TIME COLUMN - INDICATING THAT THE MOTOR WILL NOT FULLY ACCELERATE THE LOAD.

(CONTINUED)

Computed by: J.A. KOWALCHECK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-12-F	
Checked by: Ha Nguyen	Date: 5-30-84		Pg. 9 of 9	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: PSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

$(K_1)$   $(K_2)$   $(K_3)$  : TOTAL TIME FOR ACCELERATION AT CORRESPONDING MOTOR VOLTAGE.

e.g.:  $(K_3) = (J_3)^{0-10} + (J_3)^{10-20} + \dots + (J_3)^{90-95} + (J_3)^{95-100}$  ETC.

NOTE: VALUES FOR  $(A)$  THROUGH  $(F)$ , AND  $(G_1)$  ARE SUPPLIED BY THE USER, VALUES FOR  $(G_2)$ ,  $(G_3)$ ,  $(H_i)$ ,  $(J_i)$  &  $(K_i)$  ARE CALCULATED BY THE SPREADSHEET PROGRAM.

Computed by: J. A. KOWALCHEK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-13-F	
Checked by: Ha Nguyen	Date: 5/30/84		Pg. 1 of 1	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS - SCREEN WASH PUMPS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

MINIMUM EXPECTED SWITCHYARD VOLTAGE = 1.009 p.u.  
CORRESPONDING MOTOR TERMINAL VOLTAGE

1. SCREEN WASH PUMP 2B = 0.7998 p.u. (460 V. BASE)
2. SCREEN WASH PUMP 1A = 0.7826 p.u. (460 V. BASE)

CALCULATED ACCELERATION TIMES (SEE FIGURES #1 & #2)

MOTOR VOLTAGE p.u. (%)	ACCELERATION TIME SECONDS
1.00 (100%)	0.78
.80 (80%)	1.66
.70 (70%)	4.66
.684 (68.4%)	32.60
.683 (68.3%)	FAILURE TO ACCELERATE.

CONCLUSION: SINCE THE CALCULATED ACCELERATING TIME AT 70% MOTOR TERMINAL VOLTAGE IS LESS THAN 5 SEC., NO PROBLEM IS ANTICIPATED WITH STARTING AT 78.26% MOTOR TERMINAL VOLTAGE.

REFERENCES: BYRON JACKSON DRAWING No. PC 24276-ST  
GENERAL ELECTRIC DRAWING No. 492HA165  
GENERAL ELECTRIC DRAWING No. 492HA347  
ASDOP CASE # 1SAT18.

CAROLINA POWER & LIGHT CO.  
NUCLEAR ENGINEERING & LICENSING DEPT.  
MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 05/07/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION SYSTEM  
 TAR NUMBER: NT-124  
 MOTOR NAME: SCREEN WASH PUMP(S)

MOTOR FULL-LOAD TORQUE:      740 FT.-LBS.  
 MOTOR ROTOR INERTIA:      52.66 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:      705.22 FT.-LBS.  
 LOAD INERTIA:      29.53 LBS.-FT.^2

1	2	MOTOR V = 100 %			MOTOR V = 80 %			MOTOR V = 70 %			D A T A  F R O M  I N	
		3	4	5	6	7	8	9	10	11		
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)		
0-10	5	100	704.74	.07	64.00	438.34	.11	49.00	327.34	.15	O	
10-20	2	100	725.90	.07	64.00	459.50	.10	49.00	348.50	.14	M	
20-30	6	100	697.69	.07	64.00	431.29	.11	49.00	320.29	.15		
30-40	12	102	670.17	.07	65.28	398.45	.12	49.98	285.23	.17	C	
40-50	20	104	628.56	.08	66.56	351.50	.14	50.96	236.06	.20	A	
50-60	30	106	572.83	.08	67.84	290.45	.17	51.94	172.79	.28	L	
60-70	42	110	517.81	.09	70.40	224.77	.21	53.90	102.67	.47	C	
70-80	56	126	537.48	.09	80.64	201.81	.24	61.74	61.95	.78	U	
80-90	72	160	676.24	.07	102.40	250.00	.19	78.40	72.40	.66	L	
90-95	85	194	836.16	.03	124.16	319.35	.08	95.06	104.01	.23	A	
95-100	95	142	380.84	.06	107.35	124.41	.19	92.80	16.74	1.43	T	
TOTAL TIME =				.78	TOTAL TIME =				1.66	TOTAL TIME =		4.66

FIGURE #1

CAROLINA POWER & LIGHT CO.  
NUCLEAR ENGINEERING & LICENSING DEPT.  
MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 05/07/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION SYSTEM  
 TAR NUMBER: NT-124  
 MOTOR NAME: SCREEN WASH PUMP(S)

MOTOR FULL-LOAD TORQUE:      740 FT.-LBS.  
 MOTOR ROTOR INERTIA:        52.66 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:       705.22 FT.-LBS.  
 LOAD INERTIA:                29.53 LBS.-FT.^2

		MOTOR V = 100 %			MOTOR V = 68.4 %			MOTOR V = 68.3 %				
1	2	3	4	5	6	7	8	9	10	11		
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)		
0-10	5	100	704.74	.07	46.79	310.95	.15	46.65	309.94	.15	D	
10-20	2	100	725.90	.07	46.79	332.11	.14	46.65	331.10	.15	A	
20-30	6	100	697.69	.07	46.79	303.90	.16	46.65	302.89	.16	T	
30-40	12	102	670.17	.07	47.72	268.51	.18	47.58	267.48	.18	A	
40-50	20	104	628.56	.08	48.66	219.02	.22	48.51	217.97	.22	F	
50-60	30	106	572.83	.08	49.59	155.42	.31	49.45	154.35	.31	R	
60-70	42	110	517.81	.09	51.46	84.64	.57	51.31	83.53	.58	O	
70-80	56	126	537.48	.09	58.95	41.31	1.16	58.78	40.03	1.20	M	
80-90	72	160	676.24	.07	74.86	46.18	1.04	74.64	44.56	1.08	C	
90-95	85	194	836.16	.03	90.76	72.22	.33	90.50	70.25	.34	A	
95-100	95	142	380.84	.06	90.65	.85	28.34	90.52	-.13N/A		L	
TOTAL TIME =				.78	TOTAL TIME =				32.60	TOTAL TIME = N/A		I
											O	
											N	

FIGURE #2

Computed by: J.A. KOWALCHECK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-14-F	
Checked by: He Nguyen	Date: 5/21/84		Pg. 1 of 1	Rev. 0
TAR NO.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS - RHR PUMPS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

MINIMUM EXPECTED SWITCHYARD VOLTAGE = 0.965 p.u.

MINIMUM EXPECTED MOTOR VOLTAGE:

$\frac{4160 \text{ V. BASE}}{0.7675 \text{ p.u.}}$

$\frac{4000 \text{ V. BASE}}{0.7982 \text{ p.u.}}$

CALCULATED ACCELERATION TIMES (SEE FIGURES #1, #2 & #3)

MOTOR VOLTAGE p.u. (%)	ACCELERATION TIME SECONDS		
1.00 (100%)	2.14		
.80 (80%)	4.74		
USE THESE VALUES TO BE CONSERVATIVE	.748 (74.8%)	8.45 } CALCULATIONS BASED ON MOTOR TORQUE VALUES GIVEN AT 70% VOLTAGE.	
	.747 (74.7%)		8.56
	.739 (73.9%)	6.39 } CALCULATIONS BASED ON MOTOR TORQUE VALUES GIVEN AT 80% VOLTAGE	
	.738 (73.8%)		8.51
	.70 (70%)		89.41

CONCLUSION: EXPECTED ACCELERATING TIME AT MOTOR TERMINAL VOLTAGE OF 0.7982 (4000 V. BASE) IS APPROXIMATELY 4.9 SECONDS (INTERPOLATED BETWEEN 0.80 p.u. AND 0.748 p.u.). MINIMUM VOLTAGE AT WHICH THE MOTOR WILL ACCELERATE IN LESS THAN 8.5 SECONDS IS 0.748 p.u. (8.5 SECONDS IS BASED ON THE MINIMUM TIME FOR DEGRADED VOLTAGE TRIP AT POST TURBINE-TRIP CONDITIONS)

REFERENCES: BYRON JACKSON DRAWING No. PC 29800-2 (F.P. 9527-50785)  
GENERAL ELECTRIC DRAWING No. 388HA329, REV. 1 (F.P. 9527-50766)  
ASDOP CASE ISAT 9

CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 04/24/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY  
 TAR NUMBER: NT-124  
 MOTOR NAME: RESIDUAL HEAT REMOVAL

MOTOR FULL-LOAD TORQUE:      2954 FT.-LBS.  
 MOTOR ROTOR INERTIA:        820 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:       2950 FT.-LBS.  
 LOAD INERTIA:                95 LBS.-FT.^2

1 MOTOR SPEED (%)	2 LOAD TORQUE (%)	MOTOR V = 100 %			MOTOR V = 80 %			MOTOR V = 70 %			D A T A			
		3 MOTOR TORQUE (%)	4 NET TORQUE (FT.-LBS.)	5 ELAPSED TIME (SEC)	6 MOTOR TORQUE (%)	7 NET TORQUE (FT.-LBS.)	8 ELAPSED TIME (SEC)	9 MOTOR TORQUE (%)	10 NET TORQUE (FT.-LBS.)	11 ELAPSED TIME (SEC)				
0-10	4	100	2836.00	.19	64	1772.56	.30	49	1329.46	.40	F			
10-20	2	100	2895.00	.18	64	1831.56	.29	49	1388.46	.39	R			
20-30	6	100	2777.00	.19	64	1713.56	.31	49	1270.46	.42	O			
30-40	12	102	2659.08	.20	64	1536.56	.35	49	1093.46	.49	M			
40-50	20	105	2511.70	.21	65	1330.10	.40	50	887.00	.60				
50-60	30	110	2364.40	.23	67	1094.18	.49	50	592.00	.90	F			
60-70	42	118	2246.72	.24	75	976.50	.55	54	356.16	1.50	I			
70-80	56	132	2247.28	.24	85	858.90	.62	60	120.40	4.44	G			
80-90	72	157	2513.78	.21	100	830.00	.64	74	61.96	8.63	U			
90-95	86	192	3134.68	.09	122	1066.88	.25	93	210.22	1.27	R			
95-100	95	150	1628.50	.16	112	505.98	.53	95	3.80	70.36	E S			
				TOTAL TIME =	2.14					TOTAL TIME =	4.74			
											TOTAL TIME =	89.41		

FIGURE #1



CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 05/07/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION STUDY  
 TAR NUMBER: NT-124  
 MOTOR NAME: RESIDUAL HEAT REMOVAL

MOTOR FULL-LOAD TORQUE:      2954 FT.-LBS.  
 MOTOR ROTOR INERTIA:        820 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:       2950 FT.-LBS.  
 LOAD INERTIA:                95 LBS.-FT.^2

1	2	MOTOR V = 70 %			MOTOR V = 74.8 %			MOTOR V = 74.7 %			D A T A  F R O M  I N	
		3	4	5	6	7	8	9	10	11		
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)		
0-10	4	49	1329.46	.40	55.95	1534.77	.35	55.80	1530.36	.35	O	
10-20	2	49	1388.46	.39	55.95	1593.77	.34	55.80	1589.36	.34	N	
20-30	6	49	1270.46	.42	55.95	1475.77	.36	55.80	1471.36	.36		
30-40	12	49	1093.46	.49	55.95	1298.77	.41	55.80	1294.36	.41	C	
40-50	20	50	887.00	.60	57.09	1096.50	.49	56.94	1092.00	.49	A	
50-60	30	50	592.00	.90	57.09	801.50	.67	56.94	797.00	.67	L	
60-70	42	54	356.16	1.50	61.66	582.43	.92	61.49	577.56	.93	C	
70-80	56	60	120.40	4.44	68.51	371.81	1.44	68.33	366.40	1.46	U	
80-90	72	74	61.96	8.63	84.50	372.03	1.44	84.27	365.36	1.46	L	
90-95	86	93	210.22	1.27	106.19	599.90	.45	105.91	591.52	.45	A	
95-100	95	95	3.80	70.36	100.53	167.20	1.60	100.39	163.01	1.64	T	
TOTAL TIME =				89.41	TOTAL TIME =				8.45	TOTAL TIME =		8.56

FIGURE #2

CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 05/07/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION STUDY  
 TAR NUMBER: NT-124  
 MOTOR NAME: RESIDUAL HEAT REMOVAL

MOTOR FULL-LOAD TORQUE:    2954 FT.-LBS.  
 MOTOR ROTOR INERTIA:        820 LBS.-FT.<sup>2</sup>  
 MAXIMUM LOAD TORQUE:       2950 FT.-LBS.  
 LOAD INERTIA:                 95 LBS.-FT.<sup>2</sup>

1	2	MOTOR V = 80 %			MOTOR V = 73.9 %			MOTOR V = 73.8 %			D A T A  F R O M  I O N		
		3	4	5	6	7	8	9	10	11			
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)			
0-10	4	64	1772.56	.30	54.61	1495.24	.36	54.46	1490.88	.36	O		
10-20	2	64	1831.56	.29	54.61	1554.24	.34	54.46	1549.88	.35	M		
20-30	6	64	1713.56	.31	54.61	1436.24	.37	54.46	1431.88	.37			
30-40	12	64	1536.56	.35	54.61	1259.24	.42	54.46	1254.88	.43	C		
40-50	20	65	1330.10	.40	55.47	1048.45	.51	55.32	1044.02	.51	A		
50-60	30	67	1094.18	.49	57.17	803.86	.67	57.02	799.29	.67	L		
60-70	42	75	976.50	.55	64.00	651.52	.82	63.83	646.40	.83	C		
70-80	56	85	858.90	.62	72.53	490.59	1.09	72.34	484.79	1.10	U		
80-90	72	100	830.00	.64	85.33	396.69	1.35	85.10	389.87	1.37	L		
90-95	86	122	1066.88	.25	104.10	538.24	.50	103.82	529.92	.50	A		
95-100	95	112	505.98	.53	99.49	136.37	1.96	99.35	132.21	2.02	T		
				TOTAL TIME =	4.74					TOTAL TIME =	8.39		
							TOTAL TIME =				8.51	O	
											N		

FIGURE #3

Computed by: J.A. KOWALCHECK	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-15-F	
Checked by: Ha Nguyen	Date: 5/21/84		Pg. 1 of 1	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: MOTOR ACCELERATION TIME CALCULATIONS - CORE SPRAY PUMPS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

MINIMUM EXPECTED SWITCHYARD VOLTAGE = 0.965 p.u.

MINIMUM EXPECTED MOTOR VOLTAGE:

<u>4160V. BASE</u>	<u>4000V. BASE</u>
0.7624 p.u.	0.7929 p.u.

CALCULATED ACCELERATION TIMES (SEE FIGURES #1 & #2)

MOTOR VOLTAGE p.u. (%)	ACCELERATION TIME SECONDS
1.00 (100%)	1.52
.80 (80%)	2.92
.70 (70%)	5.45
.667 (66.7%)	8.44
.666 (66.6%)	8.58

CONCLUSION: EXPECTED ACCELERATING TIME AT MOTOR TERMINAL VOLTAGE OF 0.7929 pu (4000V. BASE) IS APPROXIMATELY 3.1 SECONDS. MINIMUM VOLTAGE AT WHICH MOTOR WILL ACCELERATE IN LESS THAN 8.5 SECONDS IS 0.667 p.u. (8.5 SECONDS IS BASED ON THE MINIMUM TIME FOR FOR DEGRADED VOLTAGE TRIP AT POST TURBINE-TRIP CONDITIONS.)

REFERENCES: BYRON JACKSON DRAWING No. PC29797-2 (F.P. 9527-50786)  
GENERAL ELECTRIC DRAWING No. 338HA304 (F.P. 9527-5419)  
ASDOP CASE No. 1SAT9

CAROLINA POWER & LIGHT CO.  
 NUCLEAR ENGINEERING & LICENSING DEPT.  
 MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 04/24/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION STUDY  
 TAR NUMBER: NT-124  
 MOTOR NAME: CORE SPRAY

MOTOR FULL-LOAD TORQUE:      3678 FT.-LBS.  
 MOTOR ROTOR INERTIA:        750 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:       2950 FT.-LBS.  
 LOAD INERTIA:                120 LBS.-FT.^2

1 MOTOR SPEED (%)	2 LOAD TORQUE (%)	MOTOR V = 100 %			MOTOR V = 80 %			MOTOR V = 70 %			D A T A		
		3 MOTOR TORQUE (%)	4 NET TORQUE (FT.-LBS.)	5 ELAPSED TIME (SEC)	6 MOTOR TORQUE (%)	7 NET TORQUE (FT.-LBS.)	8 ELAPSED TIME (SEC)	9 MOTOR TORQUE (%)	10 NET TORQUE (FT.-LBS.)	11 ELAPSED TIME (SEC)			
0-10	5	100	3530.50	.14	64	2206.42	.23	49	1654.72	.31	F		
10-20	2	100	3619.00	.14	64	2294.92	.22	49	1743.22	.29	R		
20-30	6	100	3501.00	.15	64	2176.92	.23	49	1625.22	.31	O		
30-40	12	101	3360.78	.15	64	1999.92	.25	49	1448.22	.35	M		
40-50	20	105	3271.90	.16	65	1800.70	.28	50	1249.00	.41			
50-60	30	110	3160.80	.16	68	1616.04	.31	50	954.00	.53	F		
60-70	43	118	3071.54	.17	75	1490.00	.34	53	680.84	.75	I		
70-80	55	132	3232.46	.16	84	1467.02	.35	60	584.30	.87	G		
80-90	72	157	3650.46	.14	100	1554.00	.33	74	597.72	.85	U		
90-95	85	190	4480.70	.06	123	2016.44	.13	93	913.04	.28	R		
95-100	95	140	2346.70	.11	105	1059.40	.24	90	507.70	.50	E		
TOTAL TIME =				1.52	TOTAL TIME =				2.92	TOTAL TIME =			5.45

FIGURE #1

CAROLINA POWER & LIGHT CO.  
NUCLEAR ENGINEERING & LICENSING DEPT.  
MOTOR ACCELERATION TIME CALCULATIONS

INPUT BY: JOHN A. KOWALCHECK      DATE: 05/07/84  
 CHECKED BY:                              DATE:  
 PROJECT TITLE: BSEP ELECTRICAL DISTRIBUTION STUDY  
 TAR NUMBER: NT-124  
 MOTOR NAME: CORE SPRAY

MOTOR FULL-LOAD TORQUE:      3678 FT.-LBS.  
 MOTOR ROTOR INERTIA:        750 LBS.-FT.^2  
 MAXIMUM LOAD TORQUE:       2950 FT.-LBS.  
 LOAD INERTIA:                120 LBS.-FT.^2

1	2	MOTOR V = 70      X			MOTOR V = 66.7      X			MOTOR V = 66.6      X			D A T A  F R O M  I O N	
		3	4	5	6	7	8	9	10	11		
MOTOR SPEED (%)	LOAD TORQUE (%)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)	MOTOR TORQUE (%)	NET TORQUE (FT.-LBS.)	ELAPSED TIME (SEC)		
0-10	5	49	1654.72	.31	44.49	1488.80	.34	44.36	1483.90	.34	O	
10-20	2	49	1743.22	.29	44.49	1577.30	.32	44.36	1572.40	.32	M	
20-30	6	49	1625.22	.31	44.49	1459.30	.35	44.36	1454.40	.35		
30-40	12	49	1448.22	.35	44.49	1282.30	.40	44.36	1277.40	.40	C	
40-50	20	50	1249.00	.41	45.40	1079.70	.47	45.26	1074.69	.47	A	
50-60	30	50	954.00	.53	45.40	784.70	.65	45.26	779.69	.65	L	
60-70	43	53	680.84	.75	48.12	501.38	1.01	47.98	496.07	1.02	C	
70-80	55	60	584.30	.87	54.48	381.13	1.33	54.31	375.13	1.36	U	
80-90	72	74	597.72	.85	67.19	347.15	1.46	66.99	339.75	1.50	L	
90-95	85	93	913.04	.28	84.44	598.13	.43	84.19	588.83	.43	A	
95-100	95	90	507.70	.50	80.32	151.57	1.68	80.19	146.91	1.73	T	
				TOTAL TIME =	5.45					TOTAL TIME =	8.44	
										TOTAL TIME =	8.58	O

FIGURE # 2

Computed by: <i>H. K. Russell</i>	Date: <i>5/25/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-73-F</i>	
Checked by: <i>H. Nguyen</i>	Date: <i>5-29-84</i>		Pg. 1 of 2	Rev. 0
TAR No.: <i>NT-124</i>			File: <i>BNT-124-AN-5543</i>	
Project Title: <i>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</i>				
Calculation Title: <i>CIRCULATING WATER PUMP MOTOR ACCELERATION TIME</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

### PURPOSE

THE PURPOSE OF THIS CALCULATION IS TO DETERMINE THE APPROXIMATE ACCELERATION TIME OF THE BSEP CIRCULATING WATER PUMP MOTORS AT THEIR MINIMUM EXPECTED TERMINAL VOLTAGE

### LIST OF REFERENCES

1. - MCGRAW EDISON COMPANY, LOCKED & ACCELERATION TIME VS CURRENT CURVE FOR 2500 HP CWP MOTORS

2. ASDOP CASES:

1 SAT 4	2 SAT 4
1 SAT 13	2 SAT 13
1 UAT 4	2 UAT 4

### BODY OF CALCULATION

FROM THE ABOVE REFERENCED ASDOP CASES, THE MINIMUM MOTOR TERMINAL VOLTAGE AT STARTING IS 0.8451 p.u. (ASDOP CASE 1 SAT 13)

FROM REFERENCE NO. 1 ACCELERATING TIMES ARE AVAILABLE FOR 80% AND 100% NOMINAL VOLTAGE. THEREFORE TO BE CONSERVATIVE THE 80% CURVE WILL BE USED TO DETERMINE THE MAXIMUM ACCELERATING TIME.

ACCELERATING TIME @ 80% TERMINAL VOLTAGE  $\approx$  5 SECONDS

Computed by: <i>W.K. Russell</i>	Date: <i>5/25/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-73-F	
Checked by: <i>H. Nguyen</i>	Date: <i>5/29/84</i>		Pg. 2 of 2	Rev. 0
TAR No.: <i>NT-124</i>			File: <i>BNT-124-AN-5543</i>	
Project Title: <i>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</i>				
Calculation Title: <i>CIRCULATING WATER PUMP MOTOR ACCELERATION TIME</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

### CONCLUSIONS

FOR THE PLANT CONDITIONS ANALYZED IT CAN BE REASONABLY ASSUMED THAT THE ACCELERATION TIME OF THE CIRCULATING WATER PUMP MOTORS WILL BE LESS THAN 5 SECONDS.


FROM THE ABOVE REFERENCED ASDOP CASES THE MINIMUM 4160 VOLT BUS VOLTAGE FOR A CWP MOTOR START IS 0.7910 P.U. (CASE ISAT13). FROM CALCULATION ID NT124-E-08-F REV. 0, THE ALLOWABLE ACCELERATION TIME BASED ON THE 27/59E VOLTAGE RELAY SETTING IS APPROXIMATELY 11 SECONDS.

THEREFORE THE STARTING OF A CWP MOTOR DOES NOT DEGRADE THE ELECTRICAL DISTRIBUTION SYSTEM VOLTAGE TO A LEVEL THAT WILL ADVERSELY IMPACT THE OPERATION OF 4160 VOLT SAFETY RELATED LOADS.

**SPEED-TORQUE-CURRENT  
 CURVES**

2500 HP. PF. 0.85 RPM. } PH. 60 Cycles 4000 Volts  
 SIZE: TYPE IC 7836-UE FRAME  
 SERIAL NO. PROD. NO.

LOAD TORQUE = 36820 lb-ft.  
 LOAD CURRENT = 349 Amperes




*Handwritten signature and date: 12/6/74*

Recd: JULY 6 1981  
 DHT



LOCKED AND ACCELERATION TIME VS CURRENT  
 2500 Vp 20 POLE STRAIGHT INDUCTION MOTOR

1 PH CURRENT = 300 AMPERE  
 LOAD W.M. = 12000 WATT  
 LOAD TORQUE = PER S/P CURVE SHOW PAGE 5016



Computed by: <i>W.K. Russell</i>	Date: <i>5/18/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-08-F</i>	
Checked by: <i>P.S. Reddy</i>	Date: <i>5/18/84</i>		Pg. <i>1</i> of <i>4</i>	Rev. <i>0</i>
TAR No.: <i>NT-124</i>			File: <i>BNT-124-AN-5543</i>	
Project Title: <i>BSEP ELECT DIST SYS STUDY</i>				
Calculation Title: <i>27/59E RELAY CHARACTERISTICS UNIT NO. 1</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

### PURPOSE

THE PURPOSE OF THIS CALCULATION IS TO ESTABLISH EMERGENCY BUS VOLTAGE RELAY CHARACTERISTICS WHICH WILL BE USED TO EVALUATE TRANSIENT VOLTAGE CONDITIONS ON THE 4160 V EMERGENCY BUSES.

### LIST OF REFERENCES

- GENERAL ELECTRIC INSTRUCTION BOOK GEH-181AE (IAV RELAYS)
- EEC LETTER UC 29677, JUNE 30, 1980
- DESIGN BASIS DOCUMENT DBD-9527-041-1 REV. 1, 2/14/78,  
"DEGRADED VOLTAGE ON EMERGENCY BUS"

### BODY OF CALCULATION

FROM LOCA START ANALYSIS (ASDOP CASE 1SAT9):

$$\begin{aligned} \text{MINIMUM VOLTAGE AT E-BUS} &= 0.7746 \text{ pu. (4160 V BASE)} \\ &= 3222 \text{ V} \end{aligned}$$

SETTING OF 27/59E RELAY:

RIGHT CONTACT 98 VOLTS  
LEFT CONTACT 105 VOLTS

$$\text{PT RATIO} = 4200/120 = 35/1$$

$$\begin{aligned} \text{RIGHT CONTACT CLOSURE / LEFT CONTACT PICKUP RATIO} \\ &= 98 \times 35 / 105 \times 35 = 3430 / 3675 \\ &= 0.825 \text{ pu} / 0.883 \text{ p.u.} \\ &= 0.93 \end{aligned}$$

Computed by: <i>WKRussell</i>	Date: <i>5/18/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-08-F</i>	
Checked by: <i>D.S.Reddy</i>	Date: <i>5/11/84</i>		Pg. <i>2</i> of <i>4</i>	Rev. <i>0</i>
TAR No.: <i>NT-124</i>		File: <i>BNT-124-AN-5543</i>		
Project Title: <i>BSEP ELECT DIST SYS STUDY</i>				
Calculation Title: <i>27/59E RELAY CHARACTERISTICS UNIT NO.1</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

PER UNIT E-BUS VOLTAGE AS MULTIPLE OF LEFT CONTACT  
PICKUP:

$$\frac{0.7749}{0.883} = 0.88$$

THUS, FROM TIME-VOLTAGE CURVE FOR IAV 53 RELAY (93% CURVE)  
TRIP TIME AT 0.7749 p.u.  $\cong$  10 SECONDS

TO ESTABLISH TRIP ZONE OF 27/59E RELAY, THE FOLLOWING POINTS  
ARE TAKEN FROM THE IAV 53 TIME-VOLTAGE CURVE

P.U. E-BUS VOLTAGE	P.U. E-BUS VOLTAGE AS MULTIPLE OF LEFT CONTACT PICKUP VOLTAGE	TRIP TIME (SEC)
0.50	0.57	2.7
0.60	0.68	3.4
0.70	0.79	5.2
0.75	0.86	7.5
0.7749	0.88	10
0.80	0.91	12.5

### CONCLUSION

ASSUMING CONSERVATIVELY THAT THE VOLTAGE ON THE E-BUS REMAINS  
AT 0.7749 DURING ACCELERATION OF THE "LOCA START" LOADS, 27/59E  
RELAY WILL ALLOW TEN (10) SECONDS FOR ACCELERATION.

Computed by: *W.R. Russell* Date: *5/3/84*  
 Checked by: *P.S. Rubin* Date: *5/11/84*  
 TAR No.: *NT-124*

CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: *NT124-E-08-F*  
 Pg. 3 of 4 Rev. 0  
 File: *BNT-124-AN-55A3*

Project Title: **BSEP ELECTRICAL DIST SYS STUDY**

Calculation Title: **27/59E RELAY CHARACTERISTICS UNIT NO.1**

STATUS: **FINAL**





Fig. 13 (X-630603-3) TIME-VOLTAGE CURVES FOR TYPES 1A, 2A, 3A, 4A, 5A, 6A, 7A, 8A, 9A, 10A, 11A, 12A, 13A, 14A, 15A, 16A, 17A, 18A, 19A, 20A, 21A, 22A, 23A, 24A, 25A, 26A, 27A, 28A, 29A, 30A, 31A, 32A, 33A, 34A, 35A, 36A, 37A, 38A, 39A, 40A, 41A, 42A, 43A, 44A, 45A, 46A, 47A, 48A, 49A, 50A, 51A, 52A, 53A, 54A, 55A, 56A, 57A, 58A, 59A, 60A, 61A, 62A, 63A, 64A, 65A, 66A, 67A, 68A, 69A, 70A, 71A, 72A, 73A, 74A, 75A, 76A, 77A, 78A, 79A, 80A, 81A, 82A, 83A, 84A, 85A, 86A, 87A, 88A, 89A, 90A, 91A, 92A, 93A, 94A, 95A, 96A, 97A, 98A, 99A, 100A, 101A, 102A, 103A, 104A, 105A, 106A, 107A, 108A, 109A, 110A, 111A, 112A, 113A, 114A, 115A, 116A, 117A, 118A, 119A, 120A, 121A, 122A, 123A, 124A, 125A, 126A, 127A, 128A, 129A, 130A, 131A, 132A, 133A, 134A, 135A, 136A, 137A, 138A, 139A, 140A, 141A, 142A, 143A, 144A, 145A, 146A, 147A, 148A, 149A, 150A, 151A, 152A, 153A, 154A, 155A, 156A, 157A, 158A, 159A, 160A, 161A, 162A, 163A, 164A, 165A, 166A, 167A, 168A, 169A, 170A, 171A, 172A, 173A, 174A, 175A, 176A, 177A, 178A, 179A, 180A, 181A, 182A, 183A, 184A, 185A, 186A, 187A, 188A, 189A, 190A, 191A, 192A, 193A, 194A, 195A, 196A, 197A, 198A, 199A, 200A

Computed by: <i>W.K. Russell</i>	Date: <i>5/18/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-08-F</i>	
Checked by: <i>P.S. Reddy</i>	Date: <i>5/18/84</i>		Pg. 4 of 4	Rev. 0
TAR No.: <i>NT-124</i>			File: <i>BNT-124-AN-55A3</i>	
Project Title: <i>BSEP ELECT. DIST. SYS STUDY</i>				
Calculation Title: <i>27/59E RELAY CHARACTERISTICS UNIT NO.1</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>WKRussell</u> Date: <u>5/18/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-03-F</u>	
Checked by: <u>D.S. Reddy</u> Date: <u>5/18/84</u>		Pg. 1 of 4	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECT DIST SYS STUDY</u>			
Calculation Title: <u>27/59E RELAY CHARACTERISTICS UNIT NO. 2</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

PURPOSE:

THE PURPOSE OF THIS CALCULATION IS TO ESTABLISH EMERGENCY BUS VOLTAGE RELAY CHARACTERISTICS WHICH WILL BE USED TO EVALUATE TRANSIENT VOLTAGE CONDITIONS ON THE 4160 V EMERGENCY BUSES.

LIST OF REFERENCES:

- GENERAL ELECTRIC INSTRUCTION BOOK GEH-1814E (IAV RELAYS)
- UE EC LETTER UC 29677, JUNE 30, 1980
- DESIGN BASIS DOCUMENT DBD-9527-041-1, REV 1, 2/14/78, "DEGRADED VOLTAGE ON EMERGENCY BUS"

BODY OF CALCULATION

FROM LOCA START ANALYSIS (ASDOP CASE 2SAT9):

$$\begin{aligned} \text{MINIMUM VOLTAGE AT E BUS} &= 0.7795 \text{ p.u. (4160V BASE)} \\ &= 3243 \text{ V} \end{aligned}$$

SETTING OF 27/59E RELAY:

RIGHT CONTACT 98 VOLTS  
LEFT CONTACT 105 VOLTS

$$\text{PTRATIO} = 4200/120 = 35/1$$

$$\begin{aligned} \text{RIGHT CONTACT CLOSURE / LEFT CONTACT PICK UP RATIO} \\ = 98 \times 35 / 105 \times 35 &= 3430/3675 \\ &= 0.825 \text{ pu} / 0.883 \text{ pu} \\ &= 0.93 \end{aligned}$$

Computed by: <i>WKRumell</i>	Date: <i>5/18/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-03-F	
Checked by: <i>P. J. Reddy</i>	Date: <i>5/18/84</i>		Pg. 2 of 4	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECT. DIST. SYS. STUDY				
Calculation Title: 27/59E RELAY CHARACTERISTICS UNIT NO. 2				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

PER UNIT E-BUS VOLTAGE AS MULTIPLE OF LEFT CONTACT  
PICKUP:

$$\frac{0.7795}{0.883} = 0.88$$

THUS, FROM TIME-VOLTAGE CURVE FOR IAV53 RELAY (93% CURVE)

TRIP TIME @ 0.7795 pu.  $\cong$  10 SECONDS

TO ESTABLISH TRIP ZONE OF 27/59 RELAY, THE FOLLOWING POINTS  
ARE TAKEN FROM THE IAV53 TIME-VOLTAGE CURVE

P.U. E-BUS VOLTAGE	P.U. E-BUS VOLTAGE AS MULTIPLE OF LEFT CONTACT PICKUP VOLTAGE	TRIP TIME (SEC.)
0.50	0.57	2.7
0.60	0.68	3.4
0.70	0.79	5.2
0.75	0.85	7.5
0.7795	0.88	10
0.80	0.91	12.5

### CONCLUSION

ASSUMING CONSERVATIVELY THAT THE VOLTAGE ON THE E-BUS REMAINS  
AT 0.7795 DURING ACCELERATION OF THE "LOCA START" LOADS, 27/59E  
RELAY WILL ALLOW 10 SECONDS FOR ACCELERATION.

Computed by: *W.R. Russell* Date: *4/13/84*  
 Checked by: *P.S. Reed* Date: *5/18/84*  
 TAR No.: *NT-124*

CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: *NT124-E-03-F*  
 Pg. 3 of 4 Rev. 0  
 File: *BNT-124-AN-5543*

Project Title: **BSEP ELECTRICAL DIST SYS STUDY**  
 Calculation Title: **27/59E RELAY CHARACTERISTICS UNIT 2**





FIG. 13 (K-6306833-3) TIME-VOLTAGE CURVES FOR TYPE 1AV53A VOLTAGE RELAY UNIT 2

F33



Computed by: <i>W.K. Russell</i>	Date: <i>5/18/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-03-F</i>	
Checked by: <i>P.S. Reddy</i>	Date: <i>5/18/84</i>		Pg. 4 of 4	Rev. 0
TAR No.: <i>NT-124</i>			File: <i>BNT-124-AN-5643</i>	
Project Title: <i>BSEP ELECT DIST SYS STUDY</i>				
Calculation Title: <i>27/59E RELAY CHARACTERISTICS UNIT NO. 2</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



13.0 APPENDIX G  
DETERMINATION OF SOURCE VOLTAGE LIMITS

## 13.0 DETERMINATION OF SOURCE VOLTAGE LIMITS

The source voltage limits were determined by defining the mathematical relationship between the source voltage and the auxiliary system bus voltage in question. Once the voltage limit was determined, a computer run was made at that source voltage limit to verify the calculated results.

For an explanation of the method of establishing source voltage limits, Case 2SAT4, (Fourth 2500 hp CWP Motor Start), is used as an example. To establish a relationship between the motor terminal voltage and the switchyard voltage, computer runs were made at two switchyard voltages: .986 p.u., 1.009 p.u.. As can be seen from the graph on Page G-65, a plot of the motor terminal voltages to each corresponding switchyard voltage defines a straight line. Once defined, this linear relationship provides the capability of determining the source voltage corresponding to any selected motor terminal voltage and vice versa. It can be seen from the graph that the minimum motor starting voltage of 3400V corresponds to a switchyard voltage of 228.62 KV (0.994 p.u.). The 228.62 KV is the minimum required switchyard voltage (i.e., voltage limit) for a CWP motor start under the operating conditions specified.

Plots for each of the cases covered in the report follow.

Computed by: JA Veane	Date: 5/8/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT24-E-16-F	
Checked by: J.A. Kawachek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISATI - FULL LOAD OPERATION				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN 460V MOTOR TERMINAL VOLTAGE ABOVE 90% ON A 460 V BASE\* (USE WORST CASE MCC:CTO)

SWYD VOLTAGE	4160 V BUS COEF VOLTAGE		MCC CTO VOLTAGE 460 V BASE		460 V MOTOR TERMINAL VOLTAGE 460 V BASE	
	COEF	VOLTAGE	460 V BASE	460 V BASE	460 V BASE	460 V BASE
0.97	0.8966		0.8757	0.8392	0.8494	0.8140
1.009	0.9426		0.9298	0.8911	0.9019	0.8643

\* ASSUME A 3% VOLTAGE DROP ON A 460 V BASE FROM THE MCC TO THE MOTOR TERMINALS

90% MOTOR TERMINAL VOLTAGE ON A 460V BASE = 0.8625

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.97} = m (X_{1.009} - X_{0.97})$$

$$1.009 - 0.97 = m (0.8643 - 0.8140) \quad m = \frac{0.039}{0.0503} = 0.775$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.775 (0.8643) + b \quad b = 0.339$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.775 (0.8625) + 0.339 = \underline{1.007}$$

$$\text{4160 V BUS COEF VOLTAGE: } Y_{0.9426} - Y_{0.8966} = m (X_{0.9426} - X_{0.8966})$$


$$0.9426 - 0.8966 = m (0.8643 - 0.8140) \quad m = \frac{0.046}{0.0503} = 0.915$$

$Y = mx + b$  @ 0.9426 COEF VOLTAGE (1.009 SWITCHYARD VOLTAGE)

$$0.9426 = 0.915 (0.8643) + b \quad b = 0.152$$

$$\text{COEF BUS VOLTAGE LIMIT} = 0.915 (0.8625) + 0.152 = \underline{0.941}$$

Computed by: <u>J. Kean</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-16-F</u>	
Checked by: <u>J.A. KWALCHEK</u>	Date: <u>5/24/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATI- FULL LOAD CONDITION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J.A. Koore</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-17-F</u>	
Checked by: <u>J.A. Kowalick</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATZ - SHUTDOWN CONDITION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: LIMIT THE 460 V MOTOR TERMINAL VOLTAGE TO 110% (460 V BASE)\*

SWVD. VOLTAGE	4160V BUS COEA VOLTAGE	480V MCC ITE VOLTAGE
0.990	0.9923	1.0241
1.017	1.0207	1.0546

\* ASSUME NO VOLTAGE DROP FROM MCC TO MOTOR TERMINALS  
110% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 1.054

SWITCHYARD VOLTAGE:  $Y_{1.017} - Y_{0.99} = M(X_{1.017} - X_{0.99})$

$$1.017 - 0.99 = M(1.0546 - 1.0241) \quad M = \frac{0.027}{0.0305} = 0.885$$

$Y = MX + b$  @ 1.017 SWITCHYARD VOLTAGE:

$$1.017 = 0.885(1.0546) + b \quad b = 0.084$$

SWITCHYARD VOLTAGE LIMIT =  $0.885(1.054) + 0.084 = \underline{\underline{1.0168}}$

4160 V BUS COEA VOLTAGE:  $Y_{1.0207} - Y_{0.9923} = M(X_{1.0207} - X_{0.9923})$


$$1.0207 - 0.9923 = M(1.0546 - 1.0241) \quad M = \frac{0.0284}{0.0305} = 0.931$$

$Y = MX + b$  @ 1.0207 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$1.0207 = 0.931(1.0546) + b \quad b = 0.039$$

COEA BUS VOLTAGE LIMIT =  $0.931(1.054) + 0.039 = \underline{\underline{1.020}}$

Computed by: <u>J.A. Koone</u>	Date: <u>5/14/64</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-17-F</u>
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/24/64</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>1SATZ - SHUTDOWN CONDITION</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: J.A. Keane	Date: 5/9/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT24-E-18-F	
Checked by: J.A. Keane	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 1SAT3 - 3RD CWP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN CWP-ID MOTOR TERMINAL ABOVE 85% STARTING VOLTAGE (4600 V BASE)

SWYD.	4160 V BUS COEA VOLTAGE	CWP-ID MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8369	0.8348	0.8027
1.009	0.8801	0.8779	0.8441

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$$

$$1.009 - 0.97 = m(0.8441 - 0.8027) \quad m = \frac{0.039}{0.0414} = 0.942$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.942(0.8441) + b \quad b = 0.214$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.942(0.817) + 0.214 = \underline{0.984}$$

$$\text{4160 V BUS COEA VOLTAGE: } Y_{0.8801} - Y_{0.8369} = m(X_{0.8801} - X_{0.8369})$$

$$0.8801 - 0.8369 = m(0.8441 - 0.8027) \quad m = \frac{0.0432}{0.0414} = 1.043$$


$Y = mx + b$  @ 0.8801 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.8801 = 1.043(0.8441) + b \quad b = -0.0003$$

$$\text{COEA BUS VOLTAGE LIMIT} = 1.043(0.817) + (-0.0003) = \underline{0.852}$$



Computed by: <u>JA (Care)</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-18-F</u>	
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT3-320 CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Kane	Date: 5/9/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-19-F	
Checked by: J.A. KOWALCHEK	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 12A4 4TH CWP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN CWP-10 MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000V BASE)

SWYD. VOLTAGE	4160V BUS COEA VOLTAGE	CWP-10 MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8261	0.8240	0.7923
1.009	0.8702	0.8680	0.8346

85% MOTOR TERMINAL VOLTAGE ON 4160V BASE = 0.817

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8346 - 0.7923) \quad m = \frac{0.039}{0.0423} = 0.922$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.922(0.8346) + b \quad b = 0.240$$

SWITCHYARD VOLTAGE LIMIT =  $0.922(0.817) + 0.240 = \underline{0.993}$

4160 V BUS COEA VOLTAGE:  $Y_{0.8702} - Y_{0.8261} = m(X_{0.8346} - X_{0.7923})$


$$0.8702 - 0.8261 = m(0.8346 - 0.7923) \quad m = \frac{0.0441}{0.0423} = 1.043$$

$Y = mX + b$  @ 0.8702 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE)

$$0.8702 = 1.043(0.8346) + b \quad b = -0.0003$$

COEA BUS VOLTAGE LIMIT =  $1.043(0.817) + (-0.0003) = \underline{0.852}$

Computed by: <u>JA Kane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-19-F</u>	
Checked by: <u>J.A. Kowalick</u>	Date: <u>5/24/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-9543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1SAT4 - 4TH CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Keane	Date: 5/9/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-20-F	
Checked by: J.A. Kowalchuk	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 1SAT5 - FUEL POOL CLEANING PUMP 1A MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCD-1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	4160V BUS VOLTAGE	CDEA VOLTAGE	FUEL POOL CLEANING PUMP 1A MOTOR TERMINAL VOLTAGE 460 V BASE	480 V BASE
	0.97	0.8946	0.8606	0.8247
	1.009	0.9405	0.9145	0.8764

85% MOTOR TERMINAL VOLTAGE ON 480V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m (X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m (0.8764 - 0.8247) \quad m = \frac{0.039}{0.0517} = 0.754$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.754 (0.8764) + b \quad b = 0.348$$

SWITCHYARD VOLTAGE LIMIT =  $0.754 (0.815) + 0.348 = \underline{0.963}$

4160 V BUS CDEA VOLTAGE:  $Y_{0.9405} - Y_{0.8946} = m (X_{0.9405} - X_{0.8946})$


$$0.9405 - 0.8946 = m (0.8764 - 0.8247) \quad m = \frac{0.0459}{0.0517} = 0.888$$

$Y = mX + b$  @ 0.9405 CDEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9405 = 0.888 (0.8764) + b \quad b = 0.162$$

CDEA BUS VOLTAGE LIMIT =  $0.888 (0.815) + 0.162 = \underline{0.886}$

Computed by: <u>JA Keane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-20-F</u>	
Checked by: <u>J.A. Kowalczak</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATS-FUEL POOL CLEANING PUMP 1A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Leane	Date: 5/9/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-21-F	
Checked by: J.A. Kowalchek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISAT6 FUEL POOL CLEANING PUMP 1B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCP-1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	460 V BUS	FUEL POOL CLEANING PUMP 1B MOTOR TERMINAL VOLTAGE	
VOLTAGE	CDEA VOLTAGE	460 V BASE	480 V BASE
0.97	0.8947	0.8535	0.8179
1.009	0.9407	0.9065	0.8687

85% MOTOR TERMINAL VOLTAGE ON A 480 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8687 - 0.8179) \quad m = \frac{0.039}{0.0508} = 0.768$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.768(0.8687) + b \quad b = 0.342$$

SWITCHYARD VOLTAGE LIMIT =  $0.768(0.815) + 0.342 = \underline{\underline{0.968}}$

460 V BUS CDEA VOLTAGE:  $Y_{0.9407} - Y_{0.8947} = m(X_{0.9407} - X_{0.8947})$


$$0.9407 - 0.8947 = m(0.8687 - 0.8179) \quad m = \frac{0.046}{0.0508} = 0.906$$

$Y = mX + b$  @ 0.9407 CDEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9407 = 0.906(0.8687) + b \quad b = 0.154$$

CDEA BUS VOLTAGE LIMIT =  $0.906(0.815) + 0.154 = \underline{\underline{0.892}}$

Computed by: <b>JA Yoon</b>	Date: <b>5/15/84</b>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <b>NT124-E-21-F</b>	
Checked by: <b>J.A. KAWALCHECK</b>	Date: <b>5/24/84</b>		Pg. 2 of 2	Rev. <b>0</b>
TAK No.: <b>NT-124</b>			File: <b>BNT-124-AN-5543</b>	
Project Title: <b>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</b>				
Calculation Title: <b>ISAT6 FUEL POOL CLEANING PUMP 1B MOTOR START</b>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Yeane	Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-22-F	
Checked by: J.A. Kowalchuk	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISAT7- REACTOR RECIRC PUMP 1B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN REACTOR RECIRC PUMP 1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000 V BASE)

SWYD.	4160 V BUS VOLTAGE	IB VOLTAGE	REACTOR RECIRC PUMP 1B MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8162		0.8420	0.8096
1.009	0.8510		0.8779	0.8441

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8441 - 0.8096) \quad m = \frac{0.039}{0.0345} = 1.130$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 1.130(0.8441) + b \quad b = 0.055$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.130(0.817) + 0.055 = \underline{0.978}$$

4160 V BUS IB VOLTAGE:  $Y_{0.8510} - Y_{0.8162} = m(X_{0.8510} - X_{0.8162})$

$$0.8510 - 0.8162 = m(0.8441 - 0.8096) \quad m = \frac{0.0348}{0.0345} = 1.009$$


$Y = mX + b$  @ 0.8510 IB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.8510 = 1.009(0.8441) + b \quad b = -0.0007$$

$$\text{IB BUS VOLTAGE LIMIT} = 1.009(0.817) + (-0.0007) = \underline{0.824}$$



Computed by: <u>JA Kead</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-22-F</u>	
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT7- REACTOR RECIRC PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Leane	Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-23-F	
Checked by: J.A. Kowalchuk	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISATB - REACTOR BLDG. CLOSED COOLING WTR. PUMP 1A MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN RDCW PUMP 1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	460 V BUS VOLTAGE	COEA VOLTAGE	REACTOR BLDG. CCW PUMP 1A MOTOR TERMINAL VOLTAGE 460 V BASE	480 V BASE
0.97	0.8944		0.8449	0.8097
1.009	0.9404		0.8971	0.8597

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$$

$$1.009 - 0.97 = m(0.8597 - 0.8097) \quad m = \frac{0.039}{0.050} = 0.780$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.780(0.8597) + b \quad b = 0.338$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.780(0.815) + 0.338 = \underline{0.974}$$

$$\text{460 V BUS COEA VOLTAGE: } Y_{0.9404} - Y_{0.8944} = m(X_{0.8597} - X_{0.8097})$$


$$0.9404 - 0.8944 = m(0.8597 - 0.8097) \quad m = \frac{0.046}{0.050} = 0.920$$

$Y = mx + b$  @ 0.9404 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9404 = 0.920(0.8597) + b \quad b = 0.150$$

$$\text{COEA BUS VOLTAGE LIMIT} = 0.920(0.815) + 0.150 = \underline{0.900}$$

Computed by: <u>JA Vorne</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-23-F</u>
Checked by: <u>J.A. Kawalchuk</u>	Date: <u>5/24/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ISAB- REACTOR BLOG. CLOSED COOLING WTR. PUMP 1A MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: <u>JAYCOLE</u> Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-24-F</u>	
Checked by: <u>J.A. KAWALCHECK</u> Date: <u>5/24/84</u>		Pg. 1 of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ISAT9 - LOCA, BLOCK START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: MAINTAIN 480 V MCC CTO VOLTAGE ABOVE 70% CONTACTOR DROP-OUT VOLTAGE (480 V BASE)

<u>SWYD VOLTAGE</u>	<u>4160 V BUS COEA VOLTAGE</u>	<u>480 V MCC CTO VOLTAGE</u>
0.930	0.7372	0.6529
0.965	0.7747	0.6980

$$\text{SWITCHYARD VOLTAGE: } Y_{0.965} - Y_{0.930} = m(X_{0.965} - X_{0.930})$$

$$0.965 - 0.930 = m(0.6980 - 0.6529)$$

$$m = \frac{0.035}{0.0451} = 0.776$$

$$Y = mx + b \text{ @ } 0.965 \text{ SWITCHYARD VOLTAGE:}$$

$$0.965 = 0.776(0.698) + b$$

$$b = 0.423$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.776(0.70) + 0.423 = \underline{\underline{0.966}}$$

$$\text{4160 V BUS COEA VOLTAGE: } Y_{0.7747} - Y_{0.7372} = m(X_{0.7747} - X_{0.7372})$$

$$0.7747 - 0.7372 = m(0.6980 - 0.6529)$$

$$m = \frac{0.0375}{0.0451} = 0.832$$

$$Y = mx + b \text{ @ } 0.7747 \text{ COEA VOLTAGE (0.965 SWITCHYARD VOLTAGE):}$$

$$0.7747 = 0.832(0.6980) + b$$

$$b = 0.194$$

$$\text{COEA BUS VOLTAGE LIMIT} = 0.832(0.70) + 0.194 = \underline{\underline{0.776}}$$

Computed by: JA (copy) Date: 5/15/84  
 Checked by: J.A. KOWALCHEK Date: 5/24/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-24-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ISAT9-LOCA, BLOCK STARTING

Status: Prelim.  Final  Void



Computed by: <u>J.A. Kama</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-25-F</u>	
Checked by: <u>J.A. Kama</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-R4-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATICA-LOCA, SEQ. START: START 2 RHR PUMPS, 2 CSP'S OFF</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 480 V MCC CTO VOLTAGE ABOVE 70% CONTACTOR DROP-OUT VOLTAGE (480 V BASE)

SWYD VOLTAGE	4160 V BUS COEA VOLTAGE	480 V MCC CTO VOLTAGE
0.93	0.8042	0.7328
0.965	0.8434	0.7783

SWITCHYARD VOLTAGE:  $Y_{0.965} - Y_{0.930} = M(X_{0.965} - X_{0.930})$

$$0.965 - 0.930 = M(0.7783 - 0.7328) \quad M = \frac{0.035}{0.0455} = 0.769$$

$Y = MX + b$  @ 0.965 SWITCHYARD VOLTAGE:

$$0.965 = 0.769(0.7783) + b \quad b = 0.367$$

SWITCHYARD VOLTAGE LIMIT =  $0.769(0.70) + 0.367 = \underline{0.905}$

4160 V BUS COEA VOLTAGE:  $Y_{0.8434} - Y_{0.8042} = M(X_{0.8434} - X_{0.8042})$


$$0.8434 - 0.8042 = M(0.7783 - 0.7328) \quad M = \frac{0.0392}{0.0455} = 0.862$$

$Y = MX + b$  @ 0.8434 COEA VOLTAGE (0.965 SWITCHYARD VOLTAGE):

$$0.8434 = 0.862(0.7783) + b \quad b = 0.173$$

COEA BUS VOLTAGE LIMIT =  $0.862(0.70) + 0.173 = \underline{0.776}$

Computed by: <u>JA Keane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-25-F</u>
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ISATKA-LOCA, SEQ. START: START 2 RHR PUMPS, 2 CSP'S OFF</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: <u>JA Keane</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-26-F</u>	
Checked by: <u>J.A. Kowalcheck</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
JAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1SAT10B-LOCA, SEQ. START-START 2 CSP'S, 2 RHR PUMPS RUNNING</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 480 V MCC CTO VOLTAGE ABOVE 70%  
CONTACTOR DROP-OUT VOLTAGE (480 V BASE)

SWVD. VOLTAGE	4160 V BUS COFA VOLTAGE	480 V MCC CTO VOLTAGE
0.930.	0.7830.	0.7078.
0.965.	0.8225.	0.7541.

SWITCHYARD VOLTAGE:  $Y_{0.965} - Y_{0.930} = m(X_{0.965} - X_{0.930})$

$$0.965 - 0.930 = m(0.7541 - 0.7078) \quad m = \frac{0.035}{0.0463} = 0.756.$$

$Y = mX + b$  @ 0.965 SWITCHYARD VOLTAGE:

$$0.965 = 0.756(0.7541) + b \quad b = 0.395.$$

SWITCHYARD VOLTAGE LIMIT =  $0.756(0.70) + 0.395 = \underline{0.924}$ .

4160 V BUS COFA VOLTAGE:  $Y_{0.8225} - Y_{0.7830} = m(X_{0.8225} - X_{0.7830})$

$$0.8225 - 0.7830 = m(0.7541 - 0.7078) \quad m = \frac{0.0395}{0.0463} = 0.853.$$


$Y = mX + b$  @ 0.8225 COFA VOLTAGE (0.965 SWITCHYARD VOLTAGE):

$$0.8225 = 0.853(0.7541) + b \quad b = 0.179.$$

COFA BUS VOLTAGE LIMIT =  $0.853(0.700) + 0.179 = \underline{0.776}$ .



Computed by: <u>JA Keane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-26-F</u>	
Checked by: <u>J.A. KOWALCHECK</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATIOB-LOCA, SEQ. START - START 2 CSP'S, 2 RHR PUMPS RUNNING</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J.A. Lease</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-27-F</u>	
Checked by: <u>J.A. Kowalczuk</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-S543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT11 - LOCA RUN</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 480 V MCC CTO VOLTAGE ABOVE 85% CONTACTOR PICK-UP VOLTAGE (480 V BASE)

<u>SWYO VOLTAGE</u>	<u>4160 V BUS COEA VOLTAGE</u>	<u>480 v MCC CTO VOLTAGE</u>
0.940	0.8602	0.7977
0.989	0.9187	0.8642

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$0.989 - 0.940 = m(0.8642 - 0.7977)$        $m = \frac{0.049}{0.0665} = 0.737$

$Y = mX + b$  @ 0.989 SWITCHYARD VOLTAGE:

$0.989 = 0.737(0.8642) + b$        $b = 0.352$

SWITCHYARD VOLTAGE LIMIT =  $0.737(0.85) + 0.352 = \underline{\underline{0.979}}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9187} - Y_{0.8602} = m(X_{0.9187} - X_{0.8602})$


$0.9187 - 0.8602 = m(0.8642 - 0.7977)$        $m = \frac{0.0585}{0.0665} = 0.880$

$Y = mX + b$  @ 0.9187 COEA VOLTAGE (0.989 SWITCHYARD VOLT.):

$0.9187 = 0.880(0.8642) + b$        $b = 0.158$

COEA BUS VOLTAGE LIMIT =  $0.880(0.85) + 0.158 = \underline{\underline{0.906}}$

Computed by: <b>JA Keane</b>	Date: <b>5/15/64</b>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <b>NT124-E-27-F</b>
Checked by: <b>J.A. KOWALCHECK</b>	Date: <b>5/24/64</b>		Pg. <b>2</b> of <b>2</b>
TAR No.: <b>NT-124</b>			File: <b>BNT-124-AN-5543</b>
Project Title: <b>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</b>			
Calculation Title: <b>ISATII - LOCA RUN</b>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: DA Lane	Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-28-F	
Checked by: J.A. Kowalchek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISAT12 - LOCA RUN: 3RD CWP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION; MAINTAIN CWP-10 MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000 V BASE)

SWTD.	4160 V BUS COEF VOLTAGE	CWP-10 MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.940	0.8028	0.8008	0.7700
0.989	0.8577	0.8555	0.8226

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m(0.8226 - 0.7700) \quad m = \frac{0.049}{0.0526} = 0.932$$

$Y = mx + b$  @ 0.989 SWITCHYARD VOLTAGE:

$$0.989 = 0.932(0.8226) + b \quad b = 0.222$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.932(0.817) + 0.222 = \underline{\underline{0.983}}$$

4160 V BUS COEF VOLTAGE:  $Y_{0.8577} - Y_{0.8028} = m(X_{0.8577} - X_{0.8028})$

$$0.8577 - 0.8028 = m(0.8226 - 0.7700) \quad m = \frac{0.0549}{0.0526} = 1.044$$

$Y = mx + b$  @ 0.8577 COEF VOLTAGE (0.989 SWITCHYARD VOLTAGE):

$$0.8577 = 1.044(0.8226) + b \quad b = -0.001$$

$$\text{COEF BUS VOLTAGE LIMIT} = 1.044(0.817) + (-0.001) = \underline{\underline{0.852}}$$

Computed by: JA Kane Date: 5/15/84  
 Checked by: J.A. Kowalchek Date: 5/24/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT24-E-28-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ISAT12- LOCA RUN: 3RD CWP MOTOR START

Status: Prelim.  Final  Void



Computed by: JA Yeane	Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-29-F	
Checked by: J.A. Kowalchek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISAT13-LOCA RUN: 4TH CWP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN CWP-ID MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000 V BASE)

SWYD.	4160 V BUS COEA VOLTAGE	CIRCULATING WATER PUMP ID MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.940	0.7911	0.7892	0.7588
0.989	0.8473	0.8452	0.8127

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m (X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m (0.8127 - 0.7588) \quad m = \frac{0.049}{0.0539} = 0.909$$

$Y = mx + b$  @ 0.989 SWITCHYARD VOLTAGE:

$$0.989 = 0.909(0.8127) + b \quad b = 0.250$$

SWITCHYARD VOLTAGE LIMIT =  $0.909(0.817) + 0.250 = \underline{\underline{0.993}}$

4160 V BUS COEA VOLTAGE:  $Y_{0.8473} - Y_{0.7911} = m (X_{0.8473} - X_{0.7911})$


$$0.8473 - 0.7911 = m (0.8127 - 0.7588) \quad m = \frac{0.0562}{0.0539} = 1.043$$

$Y = mX + b$  @ 0.8473 COEA VOLTAGE (0.989 SWITCHYARD VOLTAGE):

$$0.8473 = 1.043(0.8127) + b \quad b = -0.0003$$

COEA BUS VOLTAGE LIMITS =  $1.043(0.817) + (-0.0003) = \underline{\underline{0.852}}$

Computed by: <u>J. A. Yeane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-29-F</u>	
Checked by: <u>J. A. Kowalchek</u>	Date: <u>5/24/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-S543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT13-LOCA RUN; 4TH CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Keay</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-30-F</u>	
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AH-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT 14 - LOCA RUN: STATOR COOLANT PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN SCP-1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	4160 V BUS	STATOR COOLANT PUMP 1B MOTOR TERMINAL VOLTAGE	
VOLTAGE	COEA VOLTAGE	460 V BASE	480 V BASE
0.940	0.8581	0.8349	0.8001
0.989	0.9165	0.9002	0.8627

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m(0.8627 - 0.8001) \quad m = \frac{0.049}{0.0626} = 0.783$$

$Y = mX + b$  @ 0.989 SWITCHYARD VOLTAGE:

$$0.989 = 0.783(0.8627) + b \quad b = 0.314$$

SWITCHYARD VOLTAGE LIMIT =  $0.783(0.815) + 0.314 = \underline{0.952}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9165} + Y_{0.8581} = m(X_{0.9165} - X_{0.8581})$

$$0.9165 - 0.8581 = m(0.8627 - 0.8001) \quad m = \frac{0.0584}{0.0626} = 0.933$$


$Y = mX + b$  @ 0.9165 COEA VOLTAGE (0.989 SWITCHYARD VOLTAGE)

$$0.9165 = 0.933(0.8627) + b \quad b = 0.112$$

SWITCHYARD VOLTAGE LIMIT =  $0.933(0.815) + 0.112 = \underline{0.872}$



Computed by: <u>JA Keane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124 - E-30 - F</u>	
Checked by: <u>J.A. Kowalczuk</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT14-LOCA RUN; STATOR COOLANT PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: J.A. Keane	Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-71-F	
Checked by: J.A. Kowalchek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISATIS-LOCA RUN: FUEL POOL CLEANING PUMP 1A MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCP-1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD. VOLTAGE	4160V BUS COEA VOLTAGE	FUEL POOL CLEANING PUMP 1A 460 V BASE	MOTOR TERMINAL VOLTAGE 460 V BASE
0.940	0.8582	0.8551	0.8195
0.989	0.9166	0.9210	0.8826

85% MOTOR TERMINAL VOLTAGE ON 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m(0.8826 - 0.8195) \quad m = \frac{0.049}{0.0631} = 0.777$$

$Y = mx + b$  @ 0.989 SWITCHYARD VOLTAGE:

$$0.989 = 0.777(0.8826) + b \quad b = 0.303$$

SWITCHYARD VOLTAGE LIMIT =  $0.777(0.815) + 0.303 = \underline{0.936}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9166} - Y_{0.8582} = m(X_{0.9166} - X_{0.8582})$


$$0.9166 - 0.8582 = m(0.8826 - 0.8195) \quad m = \frac{0.0584}{0.0631} = 0.926$$

$Y = mx + b$  @ 0.9166 COEA VOLTAGE (0.989 SWITCHYARD VOLTAGE):

$$0.9166 = 0.926(0.8826) + b \quad b = 0.099$$

COEA BUS VOLTAGE LIMIT =  $0.926(0.815) + 0.099 = \underline{0.854}$

Computed by: <u>JA Klean</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-31-F</u>	
Checked by: <u>J.A. Kowalcheck</u>	Date: <u>5/24/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>(SATIS-LOCA RUN; FUEL POOL CLEANING PUMP 1A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Lease</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation Jn: <u>NT124-E-32-F</u>	
Checked by: <u>J.A. KRALCHECK</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. D
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AM-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT 16-LOCA RUN; FUEL POOL CLEANING PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCP-1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SNYD.	4160V BUS COEA VOLTAGE	FUEL POOL CLEANING PUMP 1B MOTOR TERMINAL VOLTAGE	460 V BASE	460 V BASE
0.940	0.8584	0.8374	0.8025	
0.989	0.9168	0.9029	0.8653	

85% MOTOR TERMINAL VOLTAGE ON 460V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m(0.8653 - 0.8025) \quad m = \frac{0.049}{0.0628} = 0.780$$

$Y = mX + b$  @ 0.989 SWITCHYARD VOLTAGE:

$$0.989 = 0.780(0.8653) + b \quad b = 0.314$$

SWITCHYARD VOLTAGE LIMIT =  $0.780(0.815) + 0.314 = \underline{0.950}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9168} - Y_{0.8584} = m(X_{0.9168} - X_{0.8584})$


$$0.9168 - 0.8584 = m(0.8653 - 0.8025) \quad m = \frac{0.0584}{0.0628} = 0.930$$

$Y = mX + b$  @ 0.9168 COEA VOLTAGE (0.989 SWITCHYARD VOLTAGE)

$$0.9168 = 0.930(0.8653) + b \quad b = 0.112$$

COEA BUS VOLTAGE LIMIT =  $0.930(0.815) + 0.112 = \underline{0.870}$

Computed by: <u>JA Keane</u>	Date: <u>5/15/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation In: <u>NT124-E-32-F</u>	
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/24/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATIG-LOCA RUN; FUEL POOL CLEANING PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>DA Leane</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-33-F</u>	
Checked by: <u>J.A. Kowalcheck</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT17-LOCA RUN; TBCCW PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN TBCCW PUMP 1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	4160 V BUS	TURBINE BLDG. CLOSED COOL. WTR. PUMP MOTOR TERMINAL VOLTAGE	460 V BASE	480 V BASE
VOLTAGE	COEA VOLTAGE			
0.940	0.8559		0.7325	0.7020
0.989	0.9141		0.7830	0.7504

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.989} - Y_{0.940} = m(X_{0.989} - X_{0.940})$

$$0.989 - 0.940 = m(0.7504 - 0.7020) \quad m = \frac{0.049}{0.0484} = 1.012$$

$Y = mX + b$  @ 0.989 SWITCHYARD VOLTAGE;

$$0.989 = 1.012(0.7504) + b \quad b = 0.230$$

SWITCHYARD VOLTAGE LIMIT =  $1.012(0.815) + 0.230 = \underline{1.055}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9141} - Y_{0.940} = m(X_{0.9141} - X_{0.940})$


$$0.9141 - 0.8559 = m(0.7504 - 0.7020) \quad m = \frac{0.0582}{0.0484} = 1.203$$

$Y = mX + b$  @ 0.9141 COEA VOLTAGE (0.989 SWITCHYARD VOLTAGE):

$$0.9141 = 1.203(0.7504) + b \quad b = 0.011$$

COEA BUS VOLTAGE LIMIT =  $1.203(0.815) + 0.011 = \underline{0.991}$

Computed by: <u>JA Kane</u>	Date: <u>5/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-33-F</u>	
Checked by: <u>J.A. KOWALCZEK</u>	Date: <u>5/24/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISAT17-LOCA RUN; TBCCW PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: J.A. Yeane	Date: 5/14/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-34-F	
Checked by: J.A. Kowalchek	Date: 5/24/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ISAT18-SCREEN WASH PUMP 1A MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN SWP- 1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	4160 V BUS	SCREEN WASH PUMP 1A	MOTOR TERMINAL VOLTAGE
VOLTAGE	COEA VOLTAGE	460 V BASE	460 V BASE
0.970	0.8896	0.7603	0.7286
1.009	0.9353	0.8064	0.7728

85% MOTOR TERMINAL VOLTAGE ON 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.970} = m(X_{1.009} - X_{0.970})$

$1.009 - 0.970 = m(0.7728 - 0.7286)$        $m = \frac{0.039}{0.0442} = 0.882$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$1.009 = 0.882(0.7728) + b$        $b = 0.327$

SWITCHYARD VOLTAGE LIMIT =  $0.882(0.815) + 0.327 = \underline{1.046}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9353} - Y_{0.8896} = m(X_{0.9353} - X_{0.8896})$

$0.9353 - 0.8896 = m(0.7728 - 0.7286)$        $m = \frac{0.0457}{0.0442} = 1.034$

$Y = mX + b$  @ 0.9353 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$0.9353 = 1.034(0.7728) + b$        $b = 0.136$

COEA BUS VOLTAGE LIMIT =  $1.034(0.815) + 0.136 = \underline{0.979}$



Computed by: J.A. Kowalchek Date: 5/16/84  
 Checked by: J.A. Kowalchek Date: 5/24/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-34-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ISAT18 - SCREEN WASH PUMP 1A MOTOR START

Status: Prelim.  Final  Void



Computed by: <u>J.A. Kwan</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-35F</u>	
Checked by: <u>J.A. Kwan</u>	Date: <u>5/24/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSXP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ISATA - TBCCW PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN TBCCW PUMP 1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE

SWYD. VOLTAGE	4160 V BUS COEA VOLTAGE	TURBINE BLDG. CLOSED COOL. WTR. PUMP MOTOR TERMINAL VOLT. 460 V BASE	480 V BASE
0.970	0.8921	0.7639	0.7321
1.009	0.9379	0.8037	0.7702

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

$$\text{SWITCHYARD VOLTAGE} = Y_{1.009} - Y_{0.970} = m(X_{1.009} - X_{0.970})$$

$$1.009 - 0.970 = m(0.7702 - 0.7321) \quad m = \frac{0.039}{0.0381} = 1.024$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 1.024(0.7702) + b \quad b = 0.220$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.024(0.815) + 0.220 = \underline{1.055}$$

$$4160 \text{ V BUS COEA VOLTAGE: } Y_{0.9379} - Y_{0.8921} = m(X_{0.9379} - X_{0.8921})$$

$$0.9379 - 0.8921 = m(0.7702 - 0.7321) \quad m = \frac{0.0458}{0.0381} = 1.202$$

$Y = mX + b$  @ 0.9379 COEA VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9379 = 1.202(0.7702) + b \quad b = 0.012$$

$$\text{COEA BUS VOLTAGE LIMIT} = 1.202(0.815) + 0.012 = \underline{0.997}$$

Computed by: J.A. Kowal Date: 5/16/84  
 Checked by: J.A. Kowal Date: 5/24/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-35-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ISAT19 - TBCCW PUMP 1B MOTOR START

Status: Prelim.  Final  Void



Computed by: J. A. Yeare Date: 5/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT24-E-36-F	
Checked by: J. A. Kowalchuk Date: 5/25/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AH-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: 1UATI - FULL LOAD CONDITION			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION; MAINTAIN 460V MOTOR TERMINAL VOLTAGE ABOVE 90% ON A 460 V BASE\* (USE WORST CASE MCC: 1CA)

GEN. VOLTAGE	460 V BUS COEA VOLTAGE	MCC 1CA VOLTAGE 460V BASE	460 V MOTOR TERMINAL VOLTAGE 460V BASE	480 V BASE
0.97	0.9008	0.8879	0.8509	0.8254
1.009	0.9438	0.9409	0.9017	0.8745

.8746

\* ASSUME A 3% VOLTAGE DROP ON A 460 V BASE FROM THE MCC TO THE MOTOR TERMINALS

90% MOTOR TERMINAL VOLTAGE ON A 480 V BASE = 0.863

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8745 - 0.8254) \quad m = \frac{0.039}{0.0491} = 0.794$$

.793

$Y = mx + b$  @ 1.009 GENERATOR VOLTAGE:

$$1.009 = 0.794(0.8745) + b \quad b = 0.315$$

GENERATOR VOLTAGE LIMIT =  $0.794(0.863) + 0.315 = \underline{1.000}$  .999

460 V BUS COEA VOLTAGE:  $Y_{0.9438} - Y_{0.9008} = m(X_{0.9438} - X_{0.9008})$

$$0.9438 - 0.9008 = m(0.8745 - 0.8254) \quad m = \frac{0.043}{0.0491} = 0.876$$


.876

$Y = mx + b$  @ 0.9438 COEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$$0.9438 = 0.876(0.8745) + b \quad b = 0.178$$

COEA BUS VOLTAGE LIMIT =  $0.876(0.863) + 0.178 = \underline{0.934}$

Computed by: <u>J.A. Keane</u>	Date: <u>5/11/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-36-F</u>	
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/25/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1UAT1 - FULL LOAD OPERATION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J. F. Keane</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-37-F</u>	
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/25/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AH-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1VAT2- LIGHT LOAD CONDITION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: LIMIT THE 460V MOTOR TERMINAL VOLTAGE TO 110% \* (460 V BASE)

GEN. VOLTAGE	4160 V BUS COEA VOLTAGE	480 V MCC ITN VOLTAGE
1.000	0.9383	0.9393
1.038	0.9794	0.9850

\* ASSUME NO VOLTAGE DROP FROM MCC TO MOTOR TERMINALS  
110% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 1.054

GENERATOR VOLTAGE:  $Y_{1.038} - Y_{1.000} = m(X_{1.038} - X_{1.000})$

$$1.038 - 1.000 = m(0.9850 - 0.9393) \quad m = \frac{1.038}{0.0457} = 0.832$$

$Y = mX + b$  @ 1.038 GENERATOR VOLTAGE:

$$1.038 = 0.832(0.985) + b \quad b = 0.218$$

GENERATOR VOLTAGE LIMIT =  $0.832(1.054) + 0.218 = \underline{1.095}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9794} - Y_{0.9383} = m(X_{0.9794} - X_{0.9383})$


$$0.9794 - 0.9383 = m(0.9850 - 0.9393) \quad m = \frac{0.0411}{0.0457} = 0.899$$

$Y = mX + b$  @ 0.9794 COEA VOLTAGE (1.038 GENERATOR VOLTAGE)

$$0.9794 = 0.899(0.985) + b \quad b = 0.094$$

COEA BUS VOLTAGE LIMIT =  $0.899(1.054) + 0.094 = \underline{1.042}$

Computed by: <i>J.A. Keane</i>	Date: <i>5/14/64</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT24-E-37-F</i>	
Checked by: <i>J.A. Kowalchuk</i>	Date: <i>5/25/64</i>		Pg. <i>2</i> of <i>2</i>	Rev. <i>0</i>
TAR No.: <i>NT-124</i>		File: <i>BNT-124-AN-5543</i>		
Project Title: <i>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</i>				
Calculation Title: <i>IVAT2- LIGHT LOAD CONDITION</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Coare</u>	Date: <u>5/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculator ID: <u>NT124-E-38-F</u>	
Checked by: <u>J.A. Kovalchek</u>	Date: <u>5/25/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1UAT3 - 3RD CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN CWP-10 MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000 V BASE)

GEN. VOLTAGE	4160 V BUS COEA VOLTAGE	CIRCULATING WATER PUMP 10 MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8446	0.8425	0.8101
1.009	0.8847	0.8824	0.8485

85% MOTOR TERMINAL VOLTAGE ON 4160V BASE = 0.817

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.970 = m(0.8485 - 0.8101) \quad m = \frac{0.039}{0.0384} = 1.016$$

$Y = mX + b$  @ 1.009 GENERATOR VOLTAGE:

$$1.009 = 1.016(0.8485) + b \quad b = 0.147$$

GENERATOR VOLTAGE LIMIT =  $1.016(0.817) + 0.147 = \underline{0.977}$

4160 V BUS COEA VOLTAGE:  $Y_{0.8847} - Y_{0.8446} = m(X_{0.8847} - X_{0.8446})$

$$0.8847 - 0.8446 = m(0.8485 - 0.8101) \quad m = \frac{0.0401}{0.0384} = 1.044$$


$Y = mX + b$  @ 0.8847 COEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$$0.8847 = 1.044(0.8485) + b \quad b = -0.001$$

COEA BUS VOLTAGE LIMIT =  $1.044(0.817) + (-0.001) = \underline{0.852}$



Computed by: <u>JA Vease</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-38-F</u>	
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/25/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AH-SS43</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1UAT3-3RD CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Keane</u>	Date: <u>5/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT/24-E-39-F</u>	
Checked by: <u>J.A. Kowalcheck</u>	Date: <u>5/25/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AH-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>WAT4- 4TH CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN CWP-10 MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000 V BASE)

GEN. VOLTAGE	4160 V BUS COEA VOLTAGE	CIRCULATING WATER PUMP 10 MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.970	0.8350	0.8329	0.8009
1.009	0.8758	0.8736	0.8400

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$1.009 - 0.97 = m(0.8400 - 0.8009)$        $m = \frac{0.039}{0.0391} = 0.997$

$Y = mX + b$  @ 1.009 GENERATOR VOLTAGE:

$1.009 = 0.997(0.8400) + b$        $b = 0.171_{.172}$

GENERATOR VOLTAGE LIMIT =  $0.997(0.817) + 0.171 = \underline{0.986}$  .937

4160 V BUS COEA VOLTAGE:  $Y_{0.8758} - Y_{0.835} = m(X_{0.8758} - X_{0.835})$

$0.8758 - 0.8350 = m(0.8400 - 0.8009)$        $m = \frac{0.0408}{0.0391} = 1.044$  1.044

$Y = mX + b$  @ 0.8758 COEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$0.8758 = 1.044(0.8400) + b$        $b = -0.001_{-.0005}$

COEA BUS VOLTAGE LIMIT =  $1.044(0.817) + (-0.001) = \underline{0.852}$  .852

Computed by: JA Kane Date: 5/14/84  
 Checked by: J.A. Kowalchek Date: 5/25/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-39-F  
 Pg. 2 of 2 Rev. D  
 File: BNT-124-AN-9543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: IVAT4- 4TH CWP MOTOR START

Status: Prelim.  Final  Void



Computed by: <u>JA Keane</u> Date: <u>5/11/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-40-F</u>	
Checked by: <u>J.A. Kowalcheck</u> Date: <u>5/25/84</u>		Pg. <u>1 of 2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>528 ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>1UATS - REACTOR RECIRC PUMP 1B MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: MAINTAIN RRP-1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (4000V BASE)

GEN VOLTAGE	4160V BUS 1B VOLTAGE	REACTOR RECIRC PUMP 1B MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.970	0.8145	0.8402	0.8079
1.009	0.8477	0.8745	0.8409

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.970} = m (X_{1.009} - X_{0.970})$

$1.009 - 0.970 = m (0.8409 - 0.8079)$        $m = \frac{0.039}{0.033} = 1.182$

$Y = mX + b$  @ 1.009 GENERATOR VOLTAGE:

$1.009 = 1.182(0.8409) + b$        $b = 0.015$

GENERATOR VOLTAGE LIMIT =  $1.182(0.817) + 0.015 = \underline{0.981}$

4160 V BUS 1B VOLTAGE:  $Y_{0.8477} - Y_{0.8145} = m (X_{0.8477} - X_{0.8145})$


$0.8477 - 0.8145 = m (0.8409 - 0.8079)$        $m = \frac{0.0332}{0.033} = 1.006$

$Y = mX + b$  @ 0.8477 1B VOLTAGE (1.009 GENERATOR VOLTAGE):

$0.8477 = 1.006(0.8409) + b$        $b = 0.002$

1B BUS VOLTAGE LIMIT =  $1.006(0.817) + 0.002 = \underline{0.824}$

Computed by: <u>JA Keane</u>	Date: <u>5/14/64</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-40-F</u>	
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/25/64</u>		Pg. <u>2 of 2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>IVATS- REACTOR RECIRC PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Keane</u>	Date: <u>5/11/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-41-F</u>	
Checked by: <u>J.A. Kowalczek</u>	Date: <u>5/25/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEY ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>1UAT6-FUEL POOL CLEANING PUMP 1A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCP-1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

GEN. VOLTAGE	4160V BUS COEA VOLTAGE	FUEL POOL CLEANING PUMP 1A MOTOR TERMINAL VOLTAGE 460 V BASE	480 V BASE
0.970	0.8990	0.8657	0.8296
1.009	0.9418	0.9160	0.8778

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

$$\text{GENERATOR VOLTAGE: } Y_{1.009} - Y_{0.970} = m(X_{1.009} - X_{0.970})$$

$$1.009 - 0.970 = m(0.8778 - 0.8296) \quad m = \frac{0.039}{0.0482} = 0.809$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.809(0.8778) + b \quad b = 0.299$$

$$\text{GENERATOR VOLTAGE LIMIT} = 0.809(0.815) + 0.299 = \underline{\underline{0.958}}$$

$$\text{4160 V BUS COEA VOLTAGE: } Y_{0.9418} - Y_{0.8990} = m(X_{0.9418} - X_{0.8990})$$


$$0.9418 - 0.8990 = m(0.8778 - 0.8296) \quad m = \frac{0.0428}{0.0482} = 0.888$$

$Y = mX + b$  @ 0.9418 COEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$$0.9418 = 0.888(0.8778) + b \quad b = 0.162$$

$$\text{COEA BUS VOLTAGE LIMIT} = 0.888(0.815) + 0.162 = \underline{\underline{0.886}}$$

Computed by: <u>J. A. Keane</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-41-F</u>	
Checked by: <u>J. A. Kowalchuk</u>	Date: <u>5/25/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-R4-AH-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>IUAT6- FUEL POOL CLEANING PUMP 1A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JA Keane</u>	Date: <u>5/11/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-12-F</u>	
Checked by: <u>J.A. KOWALCHECK</u>	Date: <u>5/25/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>IUAT7-FUEL POOL CLEANING PUMP 1B MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN FPCP-1B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

GEN. VOLTAGE	4160 V BUS COEA VOLTAGE	FUEL POOL CLEANING PUMP 1B MOTOR TERMINAL VOLTAGE 460 V BASE	480 V BASE
0.970	0.8991	0.8586	0.8228
1.009	0.9419	0.9078	0.8700

85% MOTOR TERMINAL VOLTAGE ON 460 V BASE = 0.815

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.970} = m(X_{1.009} - X_{0.970})$

$1.009 - 0.970 = m(0.8700 - 0.8228)$        $m = \frac{0.039}{0.0472} = 0.826$

$Y = mX + b$  @ 1.009 GENERATOR VOLTAGE:

$1.009 = 0.826(0.8700) + b$        $b = 0.290$

GENERATOR VOLTAGE LIMIT =  $0.826(0.815) + 0.290 = \underline{0.963}$

4160 V BUS COEA VOLTAGE:  $Y_{0.9419} - Y_{0.8991} = m(X_{0.9419} - X_{0.8991})$

$0.9419 - 0.8991 = m(0.8700 - 0.8228)$        $m = \frac{0.0428}{0.0472} = 0.907$

$Y = mX + b$  @ 0.9419 COEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$0.9419 = 0.907(0.8700) + b$        $b = 0.153$

COEA BUS VOLTAGE LIMIT =  $0.907(0.815) + 0.153 = \underline{0.892}$



Computed by: J. A. Keare Date: 5/14/84  
 Checked by: J. A. Kowalcheck Date: 5/25/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-42-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: 1UAT7- FUEL POOL CLEANING PUMP 1B MOTOR START

Status: Prelim.  Final  Void



Computed by: JA Keane	Date: 5/11/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-43-F	
Checked by: JA KOWALCHECK	Date: 5/25/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNF-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: WATB - RBCCW PUMP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN RBCCW PUMP 1A MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

GEN.	4160V BUS	REACTOR BLDG. CLOSED CLG. WTR. PUMP MOTOR TERMINAL VOLT.
VOLTAGE	CDEA VOLTAGE	460V BASE
0.970	0.8988	0.8479
1.009	0.9416	0.8965
		480 V BASE
		0.8126
		0.8591

85% MOTOR TERMINAL VOLTAGE @ 480 V BASE = 0.815

GENERATOR VOLTAGE:  $Y_{1.009} - Y_{0.970} = m(X_{1.009} - X_{0.970})$

$$1.009 - 0.970 = m(0.8591 - 0.8126) \quad m = \frac{0.039}{0.0465} = 0.839$$

$Y = mx + b$  @ 1.009 GENERATOR VOLTAGE:

$$1.009 = 0.839(0.8591) + b \quad b = 0.288$$

GENERATOR VOLTAGE LIMIT =  $0.839(0.815) + 0.288 = \underline{0.972}$

4160 V BUS CDEA VOLTAGE:  $Y_{0.9416} - Y_{0.8988} = m(X_{0.9416} - X_{0.8988})$


$$0.9416 - 0.8988 = m(0.8591 - 0.8126) \quad m = \frac{0.0428}{0.0465} = 0.920$$

$Y = mx + b$  @ 0.9416 CDEA VOLTAGE (1.009 GENERATOR VOLTAGE):

$$0.9416 = 0.920(0.8591) + b \quad b = 0.151$$

CDEA BUS VOLTAGE LIMIT =  $0.920(0.815) + 0.151 = \underline{0.901}$

Computed by: <u>JA Veane</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-43-F</u>
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/25/84</u>		Pg. <u>2</u> of <u>2</u>
TAR No.: <u>NT-124</u>			Rev. <u>0</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			File: <u>BNT-124-AN-S543</u>
Calculation Title: <u>UAT8- RBCCW PUMP 1A MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-44-F	
Checked by: J.A. Kowalchuk	Date: 4/30/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AU-5543		
Project Title: BSEP-ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT1-FULL LOAD CONDITION				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN 460V MOTOR TERMINAL VOLTAGES ABOVE 90% ON 460V BASE (USE WORST CASE MCC: 2XH)

SWYD.	4160 V BUS VOLTAGE	MCC 2XH VOLTAGE		* 460V MOTOR TERMINAL VOLTAGE	
		480 V BASE CDEB VOLTAGE	460 V BASE	480 V BASE	460 V BASE
0.95	0.8684	0.8192	0.8548	0.7946	0.8292
1.009	0.9386	0.9017	0.9409	0.8747	0.9127

\* ASSUMED A 3% VOLTAGE DROP ON A 460 V BASE FROM THE MCC TO THE MOTOR TERMINALS

90% MOTOR TERMINAL VOLTAGE ON A 460 V BASE = 0.863

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.95} = m (X_{1.009} - X_{0.95})$

$$1.009 - 0.95 = m (0.8747 - 0.7946) \quad m = \frac{0.059}{0.0801} = 0.737$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.737(0.8747) + b \quad b = 0.364$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.737(0.863) + 0.364 = \underline{\underline{1.000}}$$

4160 V BUS CDEB VOLTAGE:  $Y_{0.9386} - Y_{0.8684} = m (X_{0.9386} - X_{0.8684})$


$$0.9386 - 0.8684 = m (0.8747 - 0.7946) \quad m = \frac{0.0702}{0.0801} = 0.8764$$

$Y = mx + b$  @ 0.9386 CDEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9386 = 0.8764(0.8747) + b \quad b = 0.172$$

$$\text{CDEB BUS VOLTAGE LIMIT} = 0.8764(0.863) + 0.172 = \underline{\underline{0.928}}$$

Computed by: J.A. Keane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-44 - F
Checked by: J.A. Kowalchek	Date: 4/3/84		Pg. 2 of 2 Rev. 0
TAR No.: NT-124			File: BNT-124-AU-5543
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: 2SAT1 - FULL LOAD CONOITION			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Gore	Date: 4/4/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-45-F	
Checked by: J.A. Kowaluk	Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SATZ - SHUTDOWN CONDITIONS				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE REQUIRED TO LIMIT THE 460 V MOTOR TERMINAL VOLTAGE TO 110% (460 V BASE)

SWYD VOLTAGE	4160 V BUS COEB VOLTAGE	480 V MCC ZTE VOLTAGE
0.95	0.9548	0.9860
1.017	1.0250	1.0614

110% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 1.0542\*

\* ASSUME NO VOLTAGE DROP FROM MCC TO MOTOR TERMINALS

SWITCHYARD VOLTAGE:  $Y_{1.017} - Y_{0.95} = m(X_{1.017} - X_{0.95})$

$$1.017 - 0.95 = m(1.0614 - 0.9860) \quad m = \frac{0.067}{0.0754} = 0.889$$

$Y = mx + b$  @ 1.017 SWITCHYARD VOLTAGE:

$$1.017 = 0.889(1.0614) + b \quad b = 0.073$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.889(1.0542) + 0.073 = \underline{1.010}$$

4160 V BUS COEB VOLTAGE:  $Y_{1.025} - Y_{0.9548} = m(X_{1.025} - X_{0.9548})$


$$1.025 - 0.9548 = m(1.0614 - 0.9860) \quad m = \frac{0.0702}{0.0754} = 0.931$$

$Y = mx + b$  @ 1.025 COEB VOLTAGE (0.996 SWITCHYARD VOLTAGE)

$$1.025 = 0.931(1.0614) + b \quad b = 0.037$$

$$4160 \text{ V BUS COEB VOLTAGE LIMIT} = 0.931(1.0542) + 0.037 = \underline{1.018}$$

Computed by: <u>J.A. Keane</u>	Date: <u>4/4/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-45-F</u>
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/1/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ZSATZ - SHUT DOWN CONDITION</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-46-F	
Checked by: J.A. Kowalchek	Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEY ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT3 - 3RD CWP MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITIONS: VOLTAGE NEEDED TO MAINTAIN THE 4000 V MOTOR TERMINAL VOLTAGE AT 85% (ON 4000 V BASE)

SWYD. VOLTAGE	4000 V CIRCULATING WATER PUMP MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.95	0.8095	0.7784
1.009	0.8751	0.8414

85% MOTOR TERMINAL VOLTAGE ON A 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.95} = m(X_{1.009} - X_{0.95})$$

$$1.009 - 0.95 = m(0.8414 - 0.7784)$$

$$m = \frac{0.059}{0.063} = 0.937$$

$$Y = mx + b \text{ @ } 1.009 \text{ SWITCHYARD VOLTAGE:}$$


$$1.009 = 0.937(0.8414) + b$$

$$b = 0.221$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.937(0.817) + 0.221 = \underline{\underline{0.987}}$$



Computed by: <u>JA Keane</u> Date: <u>4/5/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-46-F</u>
Checked by: <u>J.A. KOWALCHECK</u> Date: <u>5/1/84</u>		Pg. <u>2</u> of <u>2</u> Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>		
Calculation Title: <u>ZSAT3 - 3RD CWP MOTOR START</u>		
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>		



Computed by: JA Keane Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-47-F	
Checked by: J.A. Kowalchek Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AW-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: 2SAT4- 4TH CWP MOTOR START			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN THE 4000 V MOTOR TERMINAL VOLTAGE AT 85% (4000 V BASE)

SWYD VOLTAGE	4000 V CIRCULATING WATER PUMP MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.986	0.8408	0.8085
1.009	0.8666	0.8333

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.95} = M(X_{1.009} - X_{0.95})$$

$$1.009 - 0.986 = M(0.8333 - 0.8085)$$

$$M = \frac{0.023}{0.0248} = 0.927$$


$$Y = MX + b \text{ @ } 1.009 \text{ SWITCHYARD VOLTAGE}$$

$$1.009 = 0.927(0.8333) + b$$

$$b = 0.237$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = (0.927)(0.817) + 0.237 = \underline{\underline{0.994}}$$

Computed by: <u>J.A. Year</u>	Date: <u>4/5/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-47-F</u>
Checked by: <u>J.A. Kucalcheck</u>	Date: <u>5/1/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AU-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2SAT4- 4TH CWP MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-48-F	
Checked by: J.A. Kowalchek	Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZSAT5- FUEL POOL CLEANING PUMP 2A MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN 460 V MOTOR  
TERMINAL VOLTAGE AT 85% ON 460 V BASE

SWVD VOLTAGE	460 V BUS CDEB VOLTAGE	460 V FUEL POOL CLEANING PUMP 2A MOTOR 460 V BASE	460 V FUEL POOL CLEANING PUMP 2A MOTOR 460 V BASE
0.95	0.8665	0.8365	0.8016
1.009	0.9365	0.9177	0.8795

85% MOTOR TERMINAL VOLTAGE ON 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.95} = m(X_{1.009} - X_{0.95})$

$$1.009 - 0.95 = m(0.8795 - 0.8016) \quad m = \frac{0.059}{0.0779} = 0.757$$

$Y = MX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.757(0.8795) + b \quad b = 0.343$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = (0.757)(0.815) + 0.343 = \underline{0.960}$$

460 V BUS CDEB VOLTAGE:  $Y_{0.9365} - Y_{0.8665} = m(X_{0.9365} - X_{0.8665})$


$$0.9365 - 0.8665 = m(0.8795 - 0.8016) \quad m = \frac{0.0700}{0.0779} = 0.899$$

$Y = MX + b$  @ 0.9365 CDEB VOLTAGE (1.009 SWITCHYARD VOLTAGE)

$$0.9365 = 0.899(0.8795) + b \quad b = 0.146$$

$$460 \text{ V BUS CDEB VOLTAGE LIMIT} = 0.899(0.815) + 0.146 = \underline{0.879}$$

Computed by: JA Keane	Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-48-F
Checked by: J.A. Kowalchuk	Date: 5/1/84		Pg. 2 of 2 Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: 2SAT5-FUEL POOL CLEANING PUMP 2A MOTOR START			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Yoane	Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT 124-E-49-F	
Checked by: J.A. Kowalchek	Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AU-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT6- FUEL POOL CLEANING PUMP 2B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN THE 460V MOTOR TERMINAL VOLTAGE AT 85% ON 460 V BASE

SWVD.	4160 V BUS	460 V FUEL POOL CLEANING PUMP 2B MOTOR TERMINAL VOLTAGE	460 V BASE	480 V BASE
0.95	0.8666	0.8066	0.8066	0.7730
1.009	0.9366	0.8870	0.8870	0.8500

85% MOTOR TERMINAL VOLTAGE ON 480 V BASE = 0.815

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.95} = m(X_{1.009} - X_{0.95})$$

$$1.009 - 0.95 = m(0.8500 - 0.7730)$$

$$m = \frac{0.059}{0.0770} = 0.766$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.766(0.8500) + b$$

$$b = 0.358$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = (0.766) 0.815 + 0.358 = \underline{0.982}$$

$$\text{4160 V BUS COEB VOLTAGE: } Y_{0.9366} - Y_{0.8666} = m(X_{0.9366} - X_{0.8666})$$

$$0.9366 - 0.8666 = m(0.8500 - 0.7730)$$

$$m = \frac{0.070}{0.0770} = 0.909$$


$Y = mX + b$  @ 0.9366 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE)

$$0.9366 = 0.909(0.8500) + b$$

$$b = 0.164$$

$$\text{4160 V BUS COEB VOLTAGE LIMIT} = 0.909(0.815) + 0.164 = \underline{0.905}$$

Computed by: <u>JA Keane</u> Date: <u>4/5/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-49-F</u>
Checked by: <u>J.A. Kowalcheck</u> Date: <u>5/1/84</u>		Pg. <u>2</u> of <u>2</u> Rev. <u>1</u>
TAR No.: <u>NT-124</u>		File: <u>NT-124-A-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>		
Calculation Title: <u>2SAT6- FUEL POOL CLEANING PUMP <del>2B</del> MOTOR START</u>		
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>		



Computed by: JAKane	Date: 4/5/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-50-F	
Checked by: J.A. Kowalchek	Date: 5/1/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AU-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZSAT7- REACTOR RECIRC PUMP ZB MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN 4000 V MOTOR TERMINAL VOLTAGE AT 85% ON 4000 V BASE

SWYD	4000 V REACTOR RECIRC PUMP ZB MOTOR TERMINAL VOLTAGE		
VOLTAGE	4000 V BASE	4160 V BASE	
0.95	0.821	0.789	
1.009	0.875	0.8412	

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{1.009} - Y_{0.95} = m(X_{1.009} - X_{0.95})$$

$$1.009 - 0.95 = m(0.8412 - 0.789)$$

$$m = \frac{0.059}{0.0522} = 1.13$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 1.13(0.8412) + b$$

$$b = 0.058$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.13(0.817) + 0.058 = \underline{\underline{0.981}}$$



Computed by: J.A. Keane Date: 4/5/84  
 Checked by: J.A. Kowalchek Date: 5/1/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-50-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ZSAT7 REACTOR RECIRC PUMP 2B MOTOR START

Status: Prelim.  Final  Void



Computed by: <u>J.A. Keane</u> Date: <u>4/5/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-51-F</u>	
Checked by: <u>J.A. Kowalchuk</u> Date: <u>5/1/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ZSAT8- REACTOR BLDG. CLOSED COOLING WATER PUMP ZA MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE AT 85% ON 460V BASE

SWVD	4160 V BUS COEB	REACTOR BLDG. CCW PUMP ZA MOTOR TERMINAL VOLTAGE	460 V BASE	460 V BASE
0.95	0.8663		0.8211	0.7869
1.009	0.9363		0.8995	0.8620

85% TERMINAL VOLTAGE ON 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.95} = m(X_{1.009} - X_{0.95})$

$$1.009 - 0.95 = m(0.8620 - 0.7869) \quad m = \frac{0.059}{0.0751} = 0.786$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.786(0.862) + b \quad b = 0.331$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.786(0.815) + 0.331 = \underline{0.972}$$

4160V BUS COEB VOLTAGE:  $Y_{0.9363} - Y_{0.8663} = m(0.8620 - 0.7869)$

$$0.9363 - 0.8663 = m(0.862 - 0.7869) \quad m = \frac{0.070}{0.0751} = 0.932$$

$Y = mX + b$  @ 0.9363 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9363 = 0.932(0.862) + b \quad b = 0.133$$

$$\text{COEB BUS VOLTAGE LIMIT} = 0.932(0.815) + 0.133 = \underline{0.893}$$

Computed by: J.A. Keane Date: 4/10/64  
 Checked by: J.A. Kowalchek Date: 5/1/64  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT 124-E-51-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: 2SAT8- REACTOR BLDG. CLOSED COOLING WATER PUMP 2A MOTOR START

Status: Prelim.  Final  Void



Computed by: JA Korne Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY	Calculation ID: NT124-E-52-F	
Checked by: J.A. Korne Date: 5/1/84	NUCLEAR PLANT ENGINEERING DEPARTMENT	Pg. 1 of 2	Rev. 0
TAR No.: NT-124	CALCULATION SHEET	File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: ZSAT9 - LOCA, BLOCK STARTING			
Status: Prelim. <input type="checkbox"/> Final <input type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: VOLTAGE NEEDED TO PREVENT 480 V CONTACTOR  
DRCP-OUT AT MCC 2TM (0.70 ON 480 V BASE)

SWYD VOLTAGE	4160 V BUS CDEB VOLTAGE	480V MCC 2TM VOLTAGE
0.965	0.7795	0.7409
1.00	0.8155	0.7773

$$\text{SWITCHYARD VOLTAGE: } Y_{1.00} - Y_{0.965} = m (X_{1.00} - X_{0.965})$$

$$1.00 - 0.965 = m (0.7773 - 0.7409) \quad m = \frac{0.035}{0.0364} = 0.961$$

$$Y = MX + b \text{ @ 1.00 SWITCHYARD VOLTAGE:}$$

$$1.00 = 0.961 (0.7773) + b \quad b = 0.253$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.961 (0.70) + 0.253 = \underline{0.926}$$

$$\text{4160V BUS CDEB VOLTAGE: } Y_{0.8155} - Y_{0.7795} = m (X_{0.8155} - X_{0.7795})$$

$$0.8155 - 0.7795 = m (0.7773 - 0.7409) \quad m = \frac{0.036}{0.0364} = 0.989$$

$$Y = MX + b \text{ @ 0.8155 CDEB VOLTAGE (1.00 SWITCHYARD VOLTAGE)}$$

$$0.8155 = 0.989 (0.7773) + b \quad b = 0.047$$

$$\text{CDEB VOLTAGE LIMIT} = 0.989 (0.70) + 0.047 = \underline{0.739}$$

Computed by: J.A. Keane Date: 4/10/84  
 Checked by: J.A. Kowalchek Date: 5/1/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-52-F  
 Pg. 2 of 2 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: 2SAT9- LXA, BLOCK STARTING

Status: Prelim.  Final  Void



.739 - 480 V CONTACTOR DROP-OUT  
 VOLTAGE AT MCC 2TM

BUS CDEB P.U. VOLTAGE (4160 V BASE)

Computed by: JA Keane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-53-F	
Checked by: JA. Kowalchek	Date: 5/2/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT10A-LOCA, SEQ. START-START 2 RHR PUMPS; 2 CSP'S OFF				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE TO PREVENT 480 V CONTACTOR DROP-OUT AT MCC 2TM (0.70 ON 480 V BASE)

SWYO. VOLTAGE	4160 V BUS COEB	480 V MCC 2TM
0.965.	0.8469.	0.8090.
1.00.	0.8849.	0.8472.

SWITCHYARD VOLTAGE:  $Y_{1.00} - Y_{0.965} = m(X_{1.00} - X_{0.965})$

$$1.00 - 0.965 = m(0.8472 - 0.8090) \quad m = \frac{0.035}{0.0382} = 0.916$$

$Y = mX + b$  @ 1.00 SWITCHYARD VOLTAGE:

$$1.00 = 0.916(0.8472) + b \quad b = 0.224$$

SWITCHYARD VOLTAGE LIMIT =  $0.916(0.70) + 0.224 = \underline{0.865}$

4160 V BUS COEB VOLTAGE:  $Y_{0.8849} - Y_{0.8469} = m(X_{0.8849} - X_{0.8469})$


$$0.8849 - 0.8469 = m(0.8472 - 0.8090) \quad m = \frac{0.038}{0.0382} = 0.995$$

$Y = mX + b$  @ 0.8849 COEB VOLTAGE (1.00 SWITCHYARD VOLTAGE)

$$0.8849 = 0.995(0.8472) + b \quad b = 0.042$$

COEB VOLTAGE LIMIT =  $0.995(0.70) + 0.042 = \underline{0.739}$

Computed by: <u>J. A. Kovalchek</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-53-F</u>
Checked by: <u>J. A. Kovalchek</u>	Date: <u>5/2/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2SATOA - LOCA, SEQ. START - START 2 RHR PUMPS; 2 CSI'S OFF</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/16/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-54-F	
Checked by: J.A. KAWALCZYK	Date: 5/2/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZSATIO B-LOCA, SEQ. START-START Z CSP'S; 2 QHRS RUNNING				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO PREVENT 480 V CONTACTOR DROP-OUT AT MCC ZTM (0.70 ON 480 V BASE)

SWYD. VOLTAGE	4160 V BUS COEB VOLTAGE	480 V MCC ZTM VOLTAGE
0.965	0.8266	0.7885
1.00	0.8646	0.8268

SWITCHYARD VOLTAGE:  $Y_{1.00} - Y_{0.965} = m(X_{1.0} - X_{0.965})$

$$1.00 - 0.965 = m(0.8268 - 0.7885) \quad m = \frac{0.035}{0.0383} = 0.914$$

$Y = mx + b$  @ 1.00 SWITCHYARD VOLTAGE:

$$1.00 = 0.914(0.8268) + b \quad b = 0.244$$

SWITCHYARD VOLTAGE LIMIT =  $0.914(0.70) + 0.244 = \underline{\underline{0.884}}$

4160 V BUS COEB VOLTAGE:  $Y_{0.8646} - Y_{0.8266} = m(X_{0.8646} - X_{0.8266})$

$$0.8646 - 0.8266 = m(0.8268 - 0.7885) \quad m = \frac{0.038}{0.0383} = 0.992$$


$Y = mx + b$  @ 0.8646 COEB VOLTAGE (1.00 SWITCHYARD VOLTAGE):

$$0.8646 = 0.992(0.8268) + b \quad b = 0.044$$

COEB VOLTAGE LIMIT =  $0.992(0.70) + 0.044 = \underline{\underline{0.738}}$



Computed by: <u>DA Keane</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-54-F</u>
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>5/2/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			Rev. <u>0</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			File: <u>BNT-124-AN-5543</u>
Calculation Title: <u>2SAT10B-LOCA, SEQ. START- START 2 CSP'S; 2 RHR PUMPS RUNNING</u>			
Status: Preim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-55-F	
Checked by: J.A. Kowalchek	Date: 5/2/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-ANS-543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZSAT11-LOCA RUN				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 4160 V BUS VOLTAGE ABOVE 89.5%  
27.0V RELAY SETTING

<u>SWYD. VOLTAGE</u>	<u>4160 V BUS COEB VOLTAGE</u>
0.97.	0.9011.
0.991.	0.9257.

$$\text{SWITCHYARD VOLTAGE: } Y_{0.991} - Y_{0.97} = m (X_{0.991} - X_{0.97})$$

$$0.991 - 0.97 = m (0.9257 - 0.9011)$$

$$m = \frac{0.021}{0.0246} = 0.854.$$


$$Y = mX + b \text{ @ } 0.991 \text{ SWITCHYARD VOLTAGE:}$$

$$0.991 = 0.854(0.9257) + b$$

$$b = 0.200.$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.854(0.895) + 0.200 = \underline{\underline{0.964}}$$

Computed by: <u>J.A. Keane</u>	Date: <u>4/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-55-F</u>
Checked by: <u>J.A. Kawalchuk</u>	Date: <u>5/2/84</u>		Pg. <u>2</u> of <u>2</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2SAT11 - LOCA RUN</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Vane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-56-F	
Checked by: J.A. Kowalcheck	Date: 5/2/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZSAT:2 - LOCA RUN; START 3RD CWP MOTOR				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 4000 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON 4000 V BASE

VOLTAGE	4000 V BASE	4160 V BASE
0.97	0.8407	0.8084
0.991	0.8636	0.8304

85% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{0.991} - Y_{0.97} = m(X_{0.991} - X_{0.97})$$

$$0.991 - 0.97 = m(0.8304 - 0.8084)$$

$$m = \frac{0.021}{0.022} = 0.954$$


$Y = mX + b$  @ 0.991 SWITCHYARD VOLTAGE:

$$0.991 = 0.954(0.8304) + b$$

$$b = 0.199$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.954(0.817) + 0.199 = \underline{\underline{0.976}}$$

Computed by: <u>J. Keane</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-56-F</u>	
Checked by: <u>J.A. Kowalczyk</u>	Date: <u>5/2/84</u>		Pg. <u>2</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>2SAT12-LOCA RUN; START 3RD. CWP MOTOR</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J.A. Veare</u> Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-57-F</u>	
Checked by: <u>J.A. KOWALCHEK</u> Date: <u>5/2/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>①</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ZSAT13 - LOCA RUN; START 4TH CWP MOTOR</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: MAINTAIN 4000 V MOTOR TERMINAL VOLTAGE AT 85% ON 4000 V BASE

SWYD. VOLTAGE	4000 V CIRCULATING WATER PUMP 2B MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.978	0.8378	0.8056
0.991	0.8523	0.8195

85% TERMINAL VOLTAGE ON A 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE: } Y_{0.991} - Y_{0.978} = m(X_{0.991} - X_{0.978})$$

$$0.991 - 0.978 = m(0.8195 - 0.8056)$$

$$m = \frac{0.013}{0.0139} = 0.935$$


$$Y = mX + b \text{ @ } 0.991 \text{ SWITCHYARD VOLTAGE:}$$

$$0.991 = 0.935(0.8195) + b$$

$$b = 0.225$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.935(0.817) + 0.225 = \underline{\underline{0.989}}$$

Computed by: <u>JH Keane</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-57-F</u>
Checked by: <u>J.A. Kowalchek</u>	Date: <u>5/2/84</u>		Pg. <u>2</u> of <u>2</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2SAT13 · LOCA RUN; START 4TH CWP MOTOR</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Keane	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-58-F	
Checked by: J.A. Kowalcheck	Date: 5/2/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT14- LOCA RUN; STATOR COOLANT PUMP 2B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON 460 V BASE

SWYD	4160 V BUS	460 V STATOR COOLANT PUMP 2B MOTOR TERMINAL VOLTAGE	
VOLTAGE	COEB VOLTAGE	460 V BASE	480 V BASE
0.97	0.8988	0.8843	0.8475
0.991	0.9232	0.9114	0.8734

85% TERMINAL VOLTAGE ON 480V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.991} - Y_{0.97} = m(X_{0.991} - X_{0.97})$

$$0.991 - 0.97 = m(0.8734 - 0.8475) \quad m = \frac{0.021}{0.0259} = 0.811$$

$Y = mX + b$  @ 0.991 SWITCHYARD VOLTAGE:

$$0.991 = 0.811(0.8734) + b \quad b = 0.283$$

SWITCHYARD VOLTAGE LIMIT =  $0.811(0.815) + 0.283 = \underline{0.944}$

4160 V BUS COEB VOLTAGE:  $Y_{0.9232} - Y_{0.8988} = m(X_{0.9232} - X_{0.8988})$

$$0.9232 - 0.8988 = m(0.8734 - 0.8475) \quad m = \frac{0.0244}{0.0259} = 0.942$$


$Y = mX + b$  @ 0.9232 COEB VOLTAGE (0.991 SWITCHYARD VOLTAGE):

$$0.9232 = 0.942(0.8734) + b \quad b = 0.100$$

COEB BUS VOLTAGE LIMIT =  $0.942(0.815) + 0.100 = \underline{0.868}$



Computed by: JA Keene	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-58-F	
Checked by: J.A. Kowalchek	Date: 5/2/84		Pg. 2 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SAT14-LOCA RUN; STATOR COOLANT PUMP 2B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: JA Keene	Date: 4/10/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-59-F	
Checked by: J.A. Kowalchek	Date: 5/2/84		Pg. 1 of 2	Rev. ①
TAR No.: NT-124			File: BNT-124-AN-5543	
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: 2SATIS-LOCA RUN; FPCP-2B MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON 460 V BASE

SWYD.	4160 V BUS COEB VOLTAGE	460 V FUEL POOL CLEANING PUMP 2B MOTOR TERMINAL VOLTAGE	460 V BASE	460 V BASE
0.97	0.8992		0.8837	0.8469
0.991	0.9237		0.9103	0.8724

85% MOTOR TERMINAL VOLTAGE ON A 460V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.991} - Y_{0.97} = m(X_{0.991} - X_{0.97})$

$$0.991 - 0.97 = m(0.8724 - 0.8469) \quad m = \frac{0.021}{0.0255} = 0.823$$

$Y = mX + b$  @ 0.991 SWITCHYARD VOLTAGE:

$$0.991 = 0.823(0.8724) + b \quad b = 0.273$$

SWITCHYARD VOLTAGE LIMIT =  $0.823(0.815) + 0.273 = \underline{0.944}$

4160 V BUS COEB VOLTAGE:  $Y_{0.9237} - Y_{0.8992} = m(X_{0.9237} - X_{0.8992})$


$$0.9237 - 0.8992 = m(0.8724 - 0.8469) \quad m = \frac{0.0245}{0.0255} = 0.961$$

$Y = mX + b$  @ 0.9237 COEB VOLTAGE (0.991 SWITCHYARD VOLTAGE)

$$0.9237 = 0.961(0.8724) + b \quad b = 0.085$$

COEB BUS VOLTAGE LIMIT =  $0.961(0.815) + 0.085 = \underline{0.868}$

Computed by: <u>JA Keane</u> Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-59-F</u>
Checked by: <u>J.A. Kowal</u> Date: <u>5/2/84</u>		Pg. <u>2</u> of <u>2</u> Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>		
Calculation Title: <u>2SATIS-LOCA RUN; FPCP-2B MOTOR START</u>		
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>		



Computed by: <u>J.A. Kasse</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-60-E</u>	
Checked by: <u>J.A. KAJALCHECK</u>	Date: <u>5/2/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>NT-124-AU-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ZSAT16- LOCA RUN; FPCP ZA MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 460 V BASE

SWYD.	4160 V BUS	460 V FUEL POOL CLEANING PUMP ZA MOTOR TERMINAL VOLTAGE
VOLTAGE	COEB VOLTAGE	460 V BASE
0.97	0.8991	0.9054
0.991	0.9236	0.9327

85% TERMINAL VOLTAGE ON A 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.991} - Y_{0.97} = m(X_{0.991} - X_{0.97})$

$$0.991 - 0.97 = m(0.8938 - 0.8677) \quad m = \frac{0.021}{0.0261} = 0.805$$

$Y = mx + b$  @ 0.991 SWITCHYARD VOLTAGE:

$$0.991 = 0.805(0.8938) + b \quad b = 0.271$$

SWITCHYARD VOLTAGE LIMIT =  $0.805(0.815) + 0.271 = \underline{\underline{0.927}}$

4160 V BUS COEB VOLTAGE:  $Y_{0.9236} - Y_{0.8991} = m(X_{0.9236} - X_{0.8991})$


$$0.9236 - 0.8991 = m(0.8938 - 0.8677) \quad m = \frac{0.0245}{0.0261} = 0.939$$

$Y = mx + b$  @ 0.9236 COEB VOLTAGE (0.791 SWITCHYARD VOLTAGE)

$$0.9236 = 0.939(0.8938) + b \quad b = 0.084$$

COEB BUS VOLTAGE LIMIT =  $0.939(0.815) + 0.084 = \underline{\underline{0.849}}$

Computed by: <u>JA Keane</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-60-F</u>	
Checked by: <u>J.A. KOWALCHEK</u>	Date: <u>5/2/84</u>		Pg. <u>2 of 2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>ENT-124-AM-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ZSAT16- LOCA RUN; FPCP 2A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>JAYCANE</u>	Date: <u>5/14/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT24-E-61-F</u>	
Checked by: <u>J.A. KOWALCHECK</u>	Date: <u>5/25/84</u>		Pg. <u>1</u> of <u>4</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>2 SAT17 - LOCA RUN; START TBCCW PUMP 2B MOTOR</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN TBCCW PUMP 2B MOTOR TERMINAL VOLTAGE ABOVE 85% STARTING VOLTAGE (460 V BASE)

SWYD.	4160 V BUS VOLTAGE	460 V BASE CDEA VOLTAGE	TURBINE BUS, CLOSED COOL. WTR. PUMP MOTOR TERMINAL VOLT.	460 V BASE CDEA VOLTAGE
0.97	0.8962	0.7616	0.7299	
0.991	0.9206	0.7828	0.7502	

85% MOTOR TERMINAL VOLTAGE ON 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{0.991} - Y_{0.97} = m(X_{0.991} - X_{0.97})$

$$0.991 - 0.97 = m(0.7502 - 0.7299) \quad m = \frac{0.021}{0.0203} = 1.035$$

$Y = mX + b$  @ 0.991 SWITCHYARD VOLTAGE:

$$0.991 = 1.035(0.7502) + b \quad b = 0.215$$

SWITCHYARD VOLTAGE LIMIT =  $1.035(0.815) + 0.215 = \underline{1.059}$

4160 V BUS CDEA VOLTAGE:  $Y_{0.9206} - Y_{0.8962} = m(X_{0.9206} - X_{0.8962})$

$$0.9206 - 0.8962 = m(0.7502 - 0.7299) \quad m = \frac{0.0244}{0.0203} = 1.202$$

$Y = mX + b$  @ 0.9206 CDEA VOLTAGE (0.991 SWITCHYARD VOLTAGE):

$$0.9206 = 1.202(0.7502) + b \quad b = 0.019$$

CDEA BUS VOLTAGE LIMIT =  $1.202(0.815) + 0.019 = \underline{0.999}$

Computed by: JA Veore Date: 5/16/84  
 Checked by: J.A. Kowalczyk Date: 5/25/84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NT124-E-61-F  
 Pg. 2 of 4 Rev. 0  
 File: BNT-124-AN-5543

Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY

Calculation Title: ZSAT17- LXA RUN; TBCCW PUMP ZB MOTOR START

Status: Prelim.  Final  Void



Computed by: <u>WK Russell</u> Date: <u>4/6/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-61-F</u>	
Checked by: <u>J.A. Kowalcheck</u> Date: <u>5/2/84</u>		Pg. <u>3</u> of <u>4</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AM-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2SAT17 TBCCW-2B PUMP MOTOR START @ LOCA RUN</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION

VOLTAGE TO PREVENT CONTACTOR DROP OUT AT MCL ZTM (0.70 ON 480V BASE)

<u>SWYD VOLTAGE</u>	<u>4160V BUS VOLTAGE</u>	<u>MCL ZTM VOLTAGE</u>
0.970	0.8962	0.7593
0.991	0.9206	0.7804

SWYD VOLTAGE  $Y_{0.991} - Y_{0.970} = m (X_{0.991} - X_{0.970})$

$0.991 - 0.970 = m (0.7804 - 0.7593)$

$m = 0.995$

$y = mx + b$  @ 0.991 SWYD VOLTAGE

$0.991 = (0.995)(0.7804) + b$

$b = 0.215$

SWYD VOLTAGE LIMIT  $(0.995)(0.70) + 0.215 = \underline{\underline{0.912}}$

4160V BUS VOLTAGE  $Y_{0.9206} - Y_{0.8962} = m (X_{0.9206} - X_{0.8962})$

$0.9206 - 0.8962 = m (0.7804 - 0.7593)$


$m = 1.156$   $y = mx + b \Rightarrow 0.9206 = (1.156)(0.7804) + b$

$b = 0.0185$

4160V BUS VOLTAGE LIMIT  $(1.156)(0.70) + 0.0185 = \underline{\underline{0.828}}$



Computed by: <u>JAL</u>	Date: <u>4/10/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-61-F</u>	
Checked by: <u>J.A. KOWALCHECK</u>	Date: <u>5/2/84</u>		Pg. <u>4</u> of <u>4</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>2SAT17-LOCA RUN; START TBCCW PUMP 2A</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>H. Nauffen</u> 0-1-84	Date: <u>0-1-84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-62-F</u>	
Checked by: <u>J.A. Kowalcheck</u> 6-1-84	Date: <u>6-1-84</u>		Pg. 1 of 2	Rev. 1
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP - Elec. Dist. Syst. study</u>				
Calculation Title: <u>2SAT18 - Screen wash pump 2B Motor start</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

limiting condition: Maintain SWP-2B motor terminal voltage above 85% starting voltage (460V base)

SWYD	4160V BUS	SCREEN WASH PUMP 2B MOTOR	TERMINAL VOLTAGE
VOLTAGE	CDEB VOLTAGE	460V BASE	480V BASE
0.970	0.8875	0.7573	0.7257
1.009	0.9332	0.7995	0.7662

85% MOTOR TERMINAL VOLTAGE ON 480V BASE = 0.815

$$\text{SWYD VOLTAGE: } Y_{1.009} - Y_{0.970} = M(X_{1.009} - X_{0.970})$$

$$1.009 - 0.970 = M(0.7662 - 0.7257) \Rightarrow M = 0.963$$

$$Y = MX + b \text{ @ } 1.009 \text{ SWYD voltage}$$

$$1.009 = 0.963(0.7662) + b \Rightarrow b = 0.271$$

$$\text{SWYD voltage limit} = 0.963(0.815) + 0.271 = \underline{1.056}$$

$$\text{4160V BUS CDEB voltage: } Y_{0.9332} - Y_{0.8875} = M(X_{0.9332} - X_{0.8875})$$

$$0.9332 - 0.8875 = M(0.7662 - 0.7257) \Rightarrow M = 1.128$$

$$Y = MX + b \text{ @ } 0.9332 \text{ CDEB voltage (1.009 SWYD voltage)}$$

$$0.9332 = 1.128(0.7662) + b \Rightarrow b = 0.069$$

$$\text{CDEB voltage limit} = 1.128(0.815) + 0.069 = \underline{0.988}$$

Computed by: *Ha Nguyen* Date: *6-1-84*  
 Checked by: *J.A. Kowalchek* Date: *6-1-84*  
 TAR No.: *NT-124*


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: *NT124-E-62-F*  
 Pg. *2* of *2* Rev. *1*  
 File: *BNT-124-AN-5543*

Project Title: *BSEP Elec. Dist. Syst. Study*

Calculation Title: *2SAT19-SCREEN WASH PUMP 2B MOTOR START*

Status: Prelim.  Final  Void



Computed by: H. Nguyen	Date: 6-1-84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-63-F	
Checked by: J.A. Kovalchek	Date: 6-1-84		Pg. 1 of 2	Rev. 1
TAR No.: NT-124			File: BN7-124-AN-5243	
Project Title: BSEP-Elec. Dist. syst. Study				
Calculation Title: 2SAT19 - TBCCW - 2B pump motor start				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

limiting condition: Maintain TBCCW pump 2B motor terminal voltage above 85% starting voltage (460V base)

SWYD	460V BUS	TURB. BLD. CLOSED COOL. PMP 2B MOTOR TERM. VOLTAGE
VOLTAGE	CDEB VOLTAGE	460V BASE
0.970	0.8896	0.7560
1.009	0.9354	0.7957
		480V BASE
		0.7245
		0.7625

85% motor terminal voltage on 480V base = 0.815

$$\text{SWYD VOLTAGE } Y_{1.009} - Y_{0.970} = M (X_{1.009} - X_{0.970})$$

$$1.009 - 0.970 = M(0.7625 - 0.7245) \Rightarrow M = 1.026$$

$$Y = MX + b @ 1.009 \text{ SWYD VOLTAGE}$$

$$1.009 = 1.026(0.7625) + b \Rightarrow b = 0.227$$

$$\text{SWYD voltage limit} = 1.026(0.815) + 0.227 = \underline{1.063}$$

$$\text{460V BUS CDEB VOLTAGE: } Y_{0.9354} - Y_{0.8896} = M(X_{0.9354} - X_{0.8896})$$

$$0.9354 - 0.8896 = M(0.7625 - 0.7245) \Rightarrow M = 1.205$$

$$Y = MX + b @ 0.9354 \text{ CDEB voltage (1.009 SWYD voltage):}$$

$$0.9354 = 1.205(0.7625) + b \Rightarrow b = 0.017$$

$$\text{CDEB BUS voltage limit} = 1.205(0.815) + 0.017 = 0.999$$

Computed by: Ha Nguyen Date: 6-1-84  
 Checked by: J.A. Kowalchek Date: 6-1-84  
 TAR No.: NT-124


CAROLINA POWER & LIGHT COMPANY  
 NUCLEAR PLANT ENGINEERING DEPARTMENT  
 CALCULATION SHEET

Calculation ID: NTR4-E-63-F  
 Pg. 2 of 2 Rev. 1  
 File: BNT-124-AN-5543

Project Title: BSEP Elec. Dist. Syst. Study

Calculation Title: 2SAT19 - TBCCW - 2B pump motor start

Status: Prelim.  Final  Void



Computed by: J.A. Keane	Date: 4/6/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-64-F	
Checked by: J.A. Kowalchuk	Date: 4/27/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124			File: ANT-124-AN-5543	
Project title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZUAT1 - FULL LOAD CONDITION				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO MAINTAIN 460V MOTOR TERMINAL VOLTAGE ABOVE 90% ON A 460V BASE \* (USE WORST CASE MCC: 2XM)

FCCP-22?

SWYD VOLTAGE	4160V BUS COEB VOLTAGE	MCC 2XM VOLTAGE		460V MOTOR TERMINAL VOLTAGE	
		460V BASE	460V BASE	460V BASE	460V BASE
0.97	0.8977	0.8910	0.8539	0.8643	0.8283
1.009	0.9407	0.9435	0.9042	0.9152	0.8771

\* ASSUME A 3% VOLTAGE DROP ON A 460V BASE FROM THE MCC TO THE MOTOR TERMINALS

90% MOTOR TERMINAL VOLTAGE ON A 460V BASE = 0.862

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8771 - 0.8283) \quad m = \frac{0.039}{0.0488} = 0.799$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.799(0.8771) + b \quad b = 0.308$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.799(0.862) + 0.308 = \underline{\underline{0.997}}$$

4160V BUS COEB VOLTAGE:  $Y_{0.9407} - Y_{0.8977} = m(X_{0.9407} - X_{0.8977})$


$$0.9407 - 0.8977 = m(0.8771 - 0.8283) \quad m = \frac{0.043}{0.0488} = 0.881$$

$Y = mx + b$  @ 0.9407 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9407 = 0.881(0.8771) + b \quad b = 0.168$$

$$\text{COEB BUS VOLTAGE LIMIT} = 0.881(0.862) + 0.168 = \underline{\underline{0.927}}$$

Computed by: <u>J. A. Yeare</u> Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-64-F</u>
Checked by: <u>J. A. Kowalcheck</u> Date: <u>4/27/84</u>		Pg. 2 of 2 Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AW-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>		
Calculation Title: <u>ZWATI- FULL LOAD CONDITION</u>		
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>		



Computed by: <u>J. A. Kowalchek</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-55-F</u>	
Checked by: <u>J. A. Kowalchek</u>	Date: <u>4/27/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ZUATZ- LIGHT LOAD CONDITION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: VOLTAGE NEEDED TO LIMIT THE 4000 V MOTOR  
TERMINAL VOLTAGE TO 110% ON A 4000 V BASE

SWYD. VOLTAGE

0.99 ·

1.017 ·

4160 V BUS ZB VOLTAGE

0.9912 ·

1.0181 ·

110% MOTOR TERMINAL VOLTAGE ON 4160 V BASE = 1.058 \*

\* ASSUME NO VOLTAGE DROP FROM 4160 V BUS TO MOTOR TERMINALS

SWITCHYARD VOLTAGE:  $Y_{1.017} - Y_{0.99} = m (X_{1.017} - X_{0.99})$

$$1.017 - 0.99 = m (1.0181 - 0.9912) \quad m = \frac{0.027}{0.0269} = 1.004$$


$Y = mX + b$  @ 1.017 SWITCHYARD VOLTAGE:

$$1.017 = 1.004 (1.0181) + b \quad b = -0.005$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.004 (1.058) - 0.005 = \underline{\underline{1.057}}$$



Computed by: <u>JAL case</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-65-F</u>	
Checked by: <u>J.A. KONTALCHER</u>	Date: <u>4/27/84</u>		Pg. 2 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>NT-124-AH-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>ZUATZ - LIGHT LOAD CONDITION</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J.A. Kane</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-66-F</u>	
Checked by: <u>J.A. Kane</u>	Date: <u>4/30/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>NT-124-AW-5543</u>		
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>2UAT3-3RD CWP MOTOR SALT</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 4000V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 4000V BASE

SWYD. VOLTAGE	4000 V CIRCULATING WATER PUMP MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8053	0.8080
1.009	0.8801	0.8465

85% MOTOR TERMINAL VOLTAGE ON A 4160 V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE} = Y_{1.009} - X_{0.97} = m (X_{1.009} - X_{0.97})$$


$$1.009 - 0.97 = m(0.8465 - 0.808) \quad m = \frac{0.039}{0.0385} = 1.013$$

$$Y = mX + b \quad @ \quad 1.009 \text{ SWITCHYARD VOLTAGE:}$$

$$1.009 = 1.013(0.8465) + b \quad b = 0.151$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.013(0.817) + 0.151 = \underline{0.979}$$

Computed by: <i>S. V. ...</i>	Date: <i>4/16/84</i>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <i>NT124-E-66-F</i>	
Checked by: <i>J. A. Kowalchek</i>	Date: <i>4/30/84</i>		Pg. 2 of 2	Rev. 0
TAR No.: <i>NT-124</i>		File: <i>ANT-124-AN-5543</i>		
Project Title: <i>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</i>				
Calculation Title: <i>ZUAT3 - 3RD CWP MOTOR START</i>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				



Computed by: <u>J.A. Keane</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation In: <u>NT124-E-67-F</u>	
Checked by: <u>J.A. Kowalchek</u>	Date: <u>4/30/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM</u>				
Calculation Title: <u>ZUAT4 - 4TH CWP MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 4000 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 4000 V BASE

SWYD. VOLTAGE	4000 V CIRCULATING WATER PUMP 2B MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.979	0.8396	0.8073
1.009	0.8709	0.8374

85% MOTOR TERMINAL VOLTAGE ON A 4160 V BASE = 0.817

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.979} = m(X_{1.009} - X_{0.979})$

$$1.009 \cdot 0.979 = m(0.8374 - 0.8073)$$

$$m = \frac{0.030}{0.0301} = 0.997$$


$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.997(0.8374) + b$$

$$b = 0.174$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 0.997(0.817) + 0.174 = \underline{\underline{0.989}}$$

Computed by: <u>J.A. Keane</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation In: <u>NT124-E-67-F</u>
Checked by: <u>J.A. Kowalchek</u>	Date: <u>4/3/84</u>		Pg. <u>2</u> of <u>2</u>
TAR No.: <u>NT-124</u>			File: <u>NT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ZVAT4 - 4TH CWP MORR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: <u>JA Cane</u> Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-68-F</u>	
Checked by: <u>JA Kowalchek</u> Date: <u>4/30/84</u>		Pg. 1 of 2	Rev. 0
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>ZUATS- REACTOR RECIRC PUMP ZB MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITION: MAINTAIN 4000 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 4000 V BASE

SWYD, VOLTAGE	4000 V REACTOR RECIRC PUMP ZB MOTOR TERMINAL VOLTAGE 4000 V BASE	4160 V BASE
0.97	0.8383	0.8061
1.009	0.8725	0.8389

85% MOTOR TERMINAL VOLTAGE ON A 4160V BASE = 0.817

$$\text{SWITCHYARD VOLTAGE} = Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$$

$$1.009 - 0.97 = m(0.8389 - 0.8061) \quad m = \frac{0.039}{0.0328} = 1.189$$


$$Y = mX + b \text{ @ } 1.009 \text{ SWITCHYARD VOLTAGE LIMIT:}$$

$$1.009 = 1.189(0.8389) + b \quad b = 0.012$$

$$\text{SWITCHYARD VOLTAGE LIMIT} = 1.189(0.817) + 0.012 = \underline{\underline{0.983}}$$

G109

Computed by: JA [Signature]	Date: 4/16/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT124-E-68-F
Checked by: J.A. Kowalcheck	Date: 4/30/84		Pg. 2 of 2
TAR No.: NT-124			Rev. 0
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			File: BNT-124-AU-5543
Calculation Title: 2UATS- REACTOR RECIRC PUMP 2B MOTOR START			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: <u>J.A. Kane</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-8-F</u>	
Checked by: <u>J.A. Kowalchuk</u>	Date: <u>4/30/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>				
Calculation Title: <u>2UAT6-FUEL POOL CLEANING, PUMP 2A MOTOR START</u>				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITIONS MAINTAIN 460V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 460V BASE

SWYD	4160 V BUS	FUEL POOL CLEANING PUMP 2A MOTOR TERMINAL VOLTAGE	
VOLTAGE	COEB VOLTAGE	460 V BASE	480 V BASE
0.97	0.8958	0.8712	0.8349
1.009	0.9387	0.9208	0.8824

85% MOTOR TERMINAL VOLTAGE ON A 480 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8824 - 0.8349) \quad m = \frac{0.039}{0.0475} = 0.821$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.821(0.8824) + b \quad b = 0.285$$

SWITCHYARD VOLTAGE LIMIT =  $0.821(0.815) + 0.285 = \underline{0.954}$

4160 V BUS COEB VOLTAGE:  $Y_{0.9387} - Y_{0.8958} = m(X_{0.9387} - X_{0.8958})$

$$0.9387 - 0.8958 = m(0.8824 - 0.8349) \quad m = \frac{0.0429}{0.0475} = 0.9032$$


$Y = mX + b$  @ 0.9387 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9387 = 0.9032(0.8824) + b \quad b = 0.1417$$

COEB BUS VOLTAGE LIMIT =  $0.9032(0.815) + 0.1417 = \underline{0.878}$



Computed by: JA Keane	Date: 4/16/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation In: NT124-E-69-F
Checked by: J.A. KUALCHEK	Date: 4/30/84		Pg. 2 of 2
TAR No.: NT-124			Rev. 0
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			File: ANI-124-AN-5543
Calculation Title: 2UAT6 - FUEL POOL CLEANING PUMP 2A MOTOR START			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: JA Vane	Date: 4/16/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-70-F	
Checked by: JA Kowalcheck	Date: 4/30/84		Pg. 1 of 2	Rev. 0
TAR No.: NT-124		File: BNT-124-AN-5543		
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY				
Calculation Title: ZUAT 7 - FUEL POOL CLEANING PUMP ZB MOTOR START				
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>				

LIMITING CONDITION: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 480 V BASE

SWYO.	460V BUS	460 V FUEL POOL CLEANING PUMP ZB MOTOR TERMINAL VOLTAGE	
VOLTAGE	COEB VOLTAGE	460 V BASE	480 V BASE
0.97	0.8959	0.8416	0.8065
1.009	0.9388	0.8907	0.8536

85% MOTOR TERMINAL VOLTAGE ON A 480 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8536 - 0.8065) \quad m = \frac{0.039}{0.0471} = 0.828$$

$Y = mX + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.828(0.8536) + b \quad b = 0.302$$

SWITCHYARD VOLTAGE LIMIT =  $0.828(0.815) + 0.302 = \underline{0.977}$

460 V BUS COEB VOLTAGE:  $Y_{0.9388} - Y_{0.8959} = m(X_{0.9388} - X_{0.8959})$


$$0.9388 - 0.8959 = m(0.8536 - 0.8065) \quad m = \frac{0.0429}{0.0471} = 0.911$$

$Y = mX + b$  @ 0.9388 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9388 = 0.911(0.8536) + b \quad b = 0.161$$

COEB BUS VOLTAGE LIMIT =  $0.911(0.815) + 0.161 = \underline{0.903}$

Computed by: <u>JA Keene</u>	Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT124-E-70-F</u>
Checked by: <u>JA. Kowalchek</u>	Date: <u>4/30/84</u>		Pg. 2 of 2
TAR No.: <u>NT-124</u>			File: <u>BNT-124-AN-5543</u>
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2UAT 7 - FUEL POOL CLEANING; PUMP 2B MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



Computed by: <u>J.A. Ware</u> Date: <u>4/16/84</u>	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: <u>NT-124-E-71-F</u>	
Checked by: <u>J.A. Kowalcheck</u> Date: <u>4/30/84</u>		Pg. <u>1</u> of <u>2</u>	Rev. <u>0</u>
TAR No.: <u>NT-124</u>		File: <u>BNT-124-AN-5543</u>	
Project Title: <u>BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY</u>			
Calculation Title: <u>2UAT8 - REACTOR BLDG. CLOSED COOLING WATER PUMP 2A MOTOR START</u>			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			

LIMITING CONDITIONS: MAINTAIN 460 V MOTOR TERMINAL VOLTAGE ABOVE 85% ON A 460 V BASE

SWYD	4160 V BUS	460 V REACTOR BLDG. CLOSED COOL. WTR. PUMP 2A MOTOR TERM. VOLTAGE	460 V BASE	480 V BASE
VOLTAGE	COEB VOLTAGE			
0.97	0.8957		0.8541	0.8185
1.009	0.9386		0.9020	0.8644

85% MOTOR TERMINAL VOLTAGE ON A 460 V BASE = 0.815

SWITCHYARD VOLTAGE:  $Y_{1.009} - Y_{0.97} = m(X_{1.009} - X_{0.97})$

$$1.009 - 0.97 = m(0.8644 - 0.8185) \quad m = \frac{0.039}{0.0459} = 0.850$$

$Y = mx + b$  @ 1.009 SWITCHYARD VOLTAGE:

$$1.009 = 0.850(0.8644) + b \quad b = 0.274$$

SWITCHYARD VOLTAGE LIMIT =  $0.850(0.815) + 0.274 = \underline{\underline{0.967}}$

4160 V BUS COEB VOLTAGE:  $Y_{0.9386} - Y_{0.8957} = m(X_{0.9386} - X_{0.8957})$


$$0.9386 - 0.8957 = m(0.8644 - 0.8185) \quad m = \frac{0.0429}{0.0459} = 0.935$$

$Y = mx + b$  @ 0.9386 COEB VOLTAGE (1.009 SWITCHYARD VOLTAGE):

$$0.9386 = 0.935(0.8644) + b \quad b = 0.130$$

COEB BUS VOLTAGE LIMIT =  $0.935(0.815) + 0.130 = \underline{\underline{0.892}}$

Computed by: JA Keane	Date: 4/16/84	CAROLINA POWER & LIGHT COMPANY NUCLEAR PLANT ENGINEERING DEPARTMENT CALCULATION SHEET	Calculation ID: NT-124-E-71-F
Checked by: J.A. Kowalcheck	Date: 4/30/84		Pg. 2 of 2    Rev. 0
TAR No.: NT-124			File: BNT-124-AN-5543
Project Title: BSEP ELECTRICAL DISTRIBUTION SYSTEM STUDY			
Calculation Title: 2UATB- REACTOR BLDG. CLOSED COOLING WATER PUMP 2A MOTOR START			
Status: Prelim. <input type="checkbox"/> Final <input checked="" type="checkbox"/> Void <input type="checkbox"/>			



**CAROLINA POWER & LIGHT COMPANY  
BRUNSWICK STEAM ELECTRIC PLANT  
UNITS 1 & 2**

**LOW VOLTAGE (208/120 VOLT)  
ELECTRICAL DISTRIBUTION SYSTEM  
STUDY**

**DUKE | MANAGEMENT AND  
POWER | TECHNICAL SERVICES**